

July 17, 2014

Paul Franzia  
Bronco Wine Company  
P O Box 789  
Ceres, CA 95307

**RE: Final – Authority to Construct/Certificate of Conformity (Minor Mod)**  
**Facility Number: N-1665**  
**Project Number: N-1141841**

Dear Mr. Franzia:

The Air Pollution Control Officer has issued the Authority to Construct permit to Bronco Wine Company for the installation of a diesel-fired emergency engine powering an electrical generator, at 6342 Bystrum Road, Ceres, CA.

Enclosed is the Authority to Construct permit and invoice for the engineering evaluation fees pursuant to District Rule 3010. The District's analysis of the proposal was sent to US EPA Region IX on June 2, 2014. No comments were received following the District's preliminary decision on this project.

Prior to operating with modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Rupi Gill at (209) 557-6400.

Sincerely,



Arnaud Marjollet  
Director of Permit Services

AM:fjc

Enclosures

cc: Gerardo C. Rios, EPA (w/enclosure) via email

**Seyed Sadredin**

Executive Director/Air Pollution Control Officer

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



**San Joaquin Valley**  
AIR POLLUTION CONTROL DISTRICT

Due Date
9/15/2014

Amount Due
\$ 565.00

Amount Enclosed

ATCFEE N1141841  
1665 N105066 7/17/2014

**RETURN THIS TOP PORTION ONLY, WITH REMITTANCE TO:**

BRONCO WINE COMPANY  
P O BOX 789  
CERES, CA 95307

SJVAPCD  
4800 Enterprise Way  
Modesto, CA 95356-8718

*Thank You!*



**San Joaquin Valley**  
AIR POLLUTION CONTROL DISTRICT

SJVAPCD Tax ID: 77-0262563

BRONCO WINE COMPANY  
6342 BYSTRUM RD  
CERES, CA 95307

Facility ID
N1665

Invoice Date
7/17/2014

Invoice Number
N105066

Invoice Type
Project: N1141841

**PROJECT NUMBER: 1141841**

APPLICATION FILING FEES	\$ 71.00
ENGINEERING TIME FEES	\$ 565.00
TOTAL FEES	\$ 636.00
LESS PREVIOUSLY PAID PROJECT FEES APPLIED TO THIS INVOICE	(\$ 71.00)
<b>PROJECT FEES DUE (Enclosed is a detailed statement outlining the fees for each item.)</b>	<b>\$ 565.00</b>

Late Payment (see Rule 3010, Section 11.0 Late Fees)	
Postmarked	Total Due
After 9/15/2014 through 9/25/2014	\$ 621.50
After 9/25/2014	\$ 847.50
After 10/15/2014	Permits To Operate MAY BE SUSPENDED

San Joaquin Valley Air Pollution Control District  
4800 Enterprise Way, Modesto, CA 95356-8718, (209) 557-6400, Fax (209) 557-6475

**Invoice Detail**

Facility ID: N1665

BRONCO WINE COMPANY  
 6342 BYSTRUM RD  
 CERES, CA 95307

Invoice Nbr: N105066  
 Invoice Date: 7/17/2014  
 Page: 1

**Application Filing Fees**

Project Nbr	Permit Number	Description	Application Fee
N1141841	N-1665-516-0	389 BHP IVECO MODEL F2CE9685A-E DIESEL-FIRED EMERGENCY ENGINE (TIER 3 CERTIFIED) POWERING AN ELECTRICAL GENERATOR.	\$ 71.00
<b>Total Application Filing Fees:</b>			<b>\$ 71.00</b>

**Engineering Time Fees**

Project Nbr	Quantity	Rate	Description	Fee
N1141841	6 hours	\$ 106.00 /h	Standard Engineering Time	\$ 636.00
			Less Credit For Application Filing Fees	(\$ 71.00)
			Standard Engineering Time SubTotal	\$ 565.00
<b>Total Engineering Time Fees:</b>				<b>\$ 565.00</b>



# AUTHORITY TO CONSTRUCT

**PERMIT NO:** N-1665-516-0

**ISSUANCE DATE:** 07/17/2014

**LEGAL OWNER OR OPERATOR:** BRONCO WINE COMPANY

**MAILING ADDRESS:** P O BOX 789  
CERES, CA 95307

**LOCATION:** 6342 BYSTRUM RD  
CERES, CA 95307

**EQUIPMENT DESCRIPTION:**

389 BHP IVECO MODEL F2CE9685A-E DIESEL-FIRED EMERGENCY ENGINE (TIER 3 CERTIFIED) POWERING AN ELECTRICAL GENERATOR.

## CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
7. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, and 17 CCR 93115] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

Arnaud Marjollet, Director of Permit Services

N-1665-516-0 Jul 17 2014 9:11AM - CRUZF Joint Inspection NOT Required

9. Emissions from this IC engine shall not exceed any of the following limits: 2.43 g-NO<sub>x</sub>/bhp-hr, 0.50 g-CO/bhp-hr, or 0.17 g-VOC/bhp-hr. [District Rule 2201 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed 0.13 g-PM<sub>10</sub>/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
13. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
14. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
15. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
16. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
17. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
18. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
19. U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII and 40 CFR Part 63 Subpart ZZZZ. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in these subparts. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rules 4001 and 4002] Federally Enforceable Through Title V Permit