



FACILITY PERMIT TO OPERATE CHEVRON PRODUCTS COMPANY

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type	Emission* And Requirements	Conditions
Process 16: STORAGE TANKS Process 21: MISCELLANEOUS PETROLEUM					P13.1
System 5: PORTABLE STORAGE TANKS System 10: FUEL STORAGE AND DISPENSING					S13.3- S13.6
STORAGE TANK, FIXED ROOF, PORTABLE, -T-101, ABOVEGROUND, GASOLINE, NO DISPENSING NOZZLE, HARD PIPED TO FIRE SCHOOL PROPS., 1000 GALS; WIDTH: 4 FT 10 IN; HEIGHT: 4 FT 8 IN; LENGTH: 11 FT A/N: 405783 Permit to Construct Issued: 08/10/04	D1875				C1.51, D90.35, E118.1, H23.x, J109.1, J119.1, J123.1, J373.x, K67.47

CONDITIONS:

PROCESS CONDITIONS

P13.1 All devices under this process are subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
HAPs	40CFR61, SUBPART	FF

[40CFR 61 Subpart FF, 12-4-2003]

[Processes subject to this condition: 16]

SYSTEM CONDITIONS

S13.3 All devices under this system are subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	1149
VOC	District Rule	463
VOC	District Rule	1178

[RULE 1149, 5-2-2008; RULE 1178, 4-7-2006; RULE 463, 5-6-2005]

[Systems subject to this condition : Process 16, System 1 , 2 , 3 , 5]

S13.6 All devices under this system are subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	461



FACILITY PERMIT TO OPERATE CHEVRON PRODUCTS COMPANY

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[RULE 461, 3-7-2008]

[Systems subject to this condition : Process 21, System 10]

C. Throughput or Operating Parameter Limits

C1.51 The operator shall limit the throughput to no more than ~~381 barrels~~ **1333.5 gallons** in any one calendar ~~year~~ **month**.

[RULE 1304(c)-Offset Exemption, 6-14-1996]

[Devices subject to this condition : D1875]

D. Monitoring/Testing Requirements

D90.35 The operator shall monitor the throughput of this device according to the following specifications:

The throughput shall be derived by using engineering calculations using parameters obtained from process records, purchase records, shipping invoices, manual tank level gauging, etc.

Records of throughput shall be retained for a period of five years and made available to the Executive Officer upon request.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : D1875, D2186, D3777]

E. Equipment Operation/Construction Requirements

E118.1 The operator shall ensure that all openings to the atmosphere on the tank and on the tank truck shall be closed during a gasoline transfer to the storage tank.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D1875]

H. Applicable Rules

H23.x This equipment is subject to the applicable requirements of the following rules or regulations:

<u>Contaminant</u>	<u>Rule</u>	<u>Rule/Subpart</u>
VOC	<u>District Rule</u>	<u>1149</u>
VOC	<u>District Rule</u>	<u>463</u>

[RULE 1149, 5-2-2008; RULE 463, 5-6-2005-11-4-2011]

[Devices subject to this condition : D1875]



FACILITY PERMIT TO OPERATE CHEVRON PRODUCTS COMPANY

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

J. Rule 461

J109.1 The operator shall use, except for diesel transfer, the phase I vapor recovery system in full operation whenever this equipment is in use. This system shall be installed, operated and maintained to meet all CARB certification requirements.

[RULE 461, ~~3-7-2008~~ **4-6-2012**]

[Devices subject to this condition : D1871, **D1875**]

J119.1 A CARB certified pressure/vacuum relief valve shall be installed on the tank vent stack and shall be set as specified in its CARB certification.

[RULE 461, ~~3-7-2008~~ **4-6-2012**]

[Devices subject to this condition : D1875]

J123.1 The operator shall not dispense fuel from this equipment into motor vehicles.

[RULE 461, ~~3-7-2008~~ **4-6-2012**]

[Devices subject to this condition : D1875]

J373.x The operator shall comply with the following gasoline transfer requirements:

Except for diesel transfers, Phase I vapor recovery systems shall be in full operation whenever fuel is being transferred into storage tanks.

A static pressure leak decay test shall be conducted within sixty (60) days from the issue date of the permit and annually thereafter to demonstrate that the storage tanks and associated vapor return piping and fittings are free from vapor leaks. The test shall be conducted in accordance with CARB's most recent version of test procedure TP-201.3B as a performance test and as a reverification test. Results shall be submitted to the AQMD, Office of Engineering and Compliance, within seventy-two (72) hours of test.

A leak rate and cracking pressure test of pressure/vacuum relief vent valves shall be conducted within ten days (10) after the Standing Loss Control vapor recovery systems is installed and at least once every three (3) years thereafter to determine the pressure and vacuum at which the pressure/vacuum vent valve actuates, and to determine the volumetric leak rate at a given pressure. The test shall be conducted in accordance with the most recent version of test procedure TP-201.1E.

The AQMD shall be notified by e-mail at r461testing@aqmd.gov or by facsimile at telephone number (909) 396-3606 at least seventy-two (72) hours prior to any of the above mentioned testing requirements. Such notification shall include the name of the owner or operator; the name of the contractor; the location of the facility; and the scheduled start and completion dates of the tests to be performed.



FACILITY PERMIT TO OPERATE CHEVRON PRODUCTS COMPANY

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The testing for the above mentioned tests shall be conducted in accordance with the most recent Rule 461 amendment or CARB executive order requirements, whichever is more stringent.

[RULE 461, 4-6-2012]

[Devices subject to this condition : D1875]

K. Record Keeping/Reporting

K67.47 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

All records and test results required to be maintained by Rule 461.

Such records shall be maintained and kept on file for at least five years, and shall be made available to the Executive Officer or his authorized representative upon request.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997; RULE 461, 3-7-2008 4-6-2012]

[Devices subject to this condition : D1871, D1875, D4270]