

South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

March 9, 2010

Mr. Paul Lacroix
Reliant Energy Etiwanda, LLC
8996 Etiwanda Ave
Rancho Cucamonga, CA 91739

SUBJECT: Reliant Energy, Etiwanda, LLC (Facility ID# 115315)

Dear Mr. Lacroix:

The revised RECLAIM/Title V Facility Permit dated March 9, 2010 for equipment located at 8996 Etiwanda Ave., Rancho Cucamonga, CA 91739, reflects the approval of the Permit to Operate for the emergency fire pump engine (D95). The equipment is included in Section D of the permit. The corresponding application numbers are summarized in the table below:

Application	Description	Device ID#
503709	Emergency IC Engine	D95
503707	Title V De Minimis Significant Revision	//////////

The proposed permit was forwarded to EPA on December 29, 2009 for the 45 day review. No comments were received.

Please review the attached Section D carefully. Insert the enclosed section into your Facility Permit and discard the earlier version. Questions concerning your permit should be directed to Mr. Chris Perri at (909) 396-2696 or cperri@aqmd.gov.

Sincerely,

Michael D. Mills, P.E.
Senior Manager
General Commercial & Energy Team
Engineering & Compliance

Cc: Gerardo Rios (electronically to R9AirPermits_sc@epa.gov)
Melesio Hernandez, SCAQMD compliance
Records
Energy Unit Files



FACILITY PERMIT TO OPERATE

**RRI ENERGY ETIWANDA, INC.
8996 ETIWANDA AVE
ETIWANDA, CA 91739**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By Mike Mills for
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance



**FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.**

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	11	04/10/2009
B	RECLAIM Annual Emission Allocation	18	01/01/2010
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	19	03/09/2010
E	Administrative Conditions	17	04/10/2009
F	RECLAIM Monitoring and Source Testing Requirements	12	04/10/2009
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	13	04/10/2009
H	Permit To Construct and Temporary Permit to Operate	20	04/10/2009
I	Compliance Plans & Schedules	9	04/10/2009
J	Air Toxics	7	04/10/2009
K	Title V Administration	8	04/10/2009
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	9	04/10/2009
B	Rule Emission Limits	7	04/10/2009



**FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: INTERNAL COMBUSTION ENGINES					
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, LIQUIFIED PETROLEUM GAS, HERCULES, MODEL HXLE, 4 CYCLE, 6 CYLINDERS, NATURALLY ASPIRATED, 79 HP A/N: 409111	D3		NOX: PROCESS UNIT**	NOX: 3.9 GRAM/BHP-HR LPG (5) [RULE 2009, 5-11-2001]; NOX: 139 LBS/1000 GAL. LPG (1) [RULE 2012, 5-11-2001; RULE 2012, 12-5-2003]; PM: (9) [RULE 404, 2-7-1986]	D12.1
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DIESEL FUEL, CUMMINS, MODEL CFP9E-F60, WITH AFTERCOOLER, TURBOCHARGER, 359 BHP A/N: 503709	D95			CO: 1.42 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; NOX: 2.39 GRAM/BHP-HR DIESEL (4) [RULE 2005, 5-6-2005]; PM10: 0.12 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; VOC: 0.12 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.4, D12.9, I296.2, K67.5
Process 4: POWER GENERATION-BOILERS					

* (1) (1A) (1B) Denotes RECLAIM emission factor
 (3) Denotes RECLAIM concentration limit
 (5) (5A) (5B) Denotes command and control emission limit
 (7) Denotes NSR applicability limit
 (9) See App B for Emission Limits
 (2) (2A) (2B) Denotes RECLAIM emission rate
 (4) Denotes BACT emission limit
 (6) Denotes air toxic control rule limit
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 4: POWER GENERATION-BOILERS					
BOILER, NO. 3, NATURAL GAS, COMBUSTION ENGINEERING, TANGENTIALLY FIRED, WITH STAGED COMBUSTION, FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 2900 MMBTU/HR WITH A/N: 431106 BURNER, TWENTY FOUR, NATURAL GAS, COMBUSTION ENGINEERING, WITH STAGED COMBUSTION, 2900 MMBTU/HR GENERATOR, 320 MW	D22	C55 C57	NOX: MAJOR SOURCE**	CO: 500 PPMV (5) [RULE 1303(b)(2)-Offset, 5-10-1996]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 7 PPMV (5) [RULE 2009, 5-11-2001]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]; SO2: (9) [40CFR 72 - Acid Rain Provisions, 11-24-1997]	A195.1, A195.6, D28.1, E193.4
SELECTIVE CATALYTIC REDUCTION, SYSTEM A, SERVING BOILER NO. 3, IN-DUCT TYPE, HALDOR TOPSOE, VANADIUM/TUNGSTEN TITANIUM, 1151 CU.FT.; WIDTH: 33 FT ; HEIGHT: 16 FT ; LENGTH: 23 FT WITH A/N: 431108 AMMONIA INJECTION, GRID A	C55	D22		NH3: 10 PPMV (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	A195.5, D12.3, D12.4, D12.5, D28.4, E179.2, E179.3, E193.4

* (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 4: POWER GENERATION-BOILERS					
SELECTIVE CATALYTIC REDUCTION, SYSTEM B, SERVING BOILER NO. 3, IN-DUCT TYPE, HALDOR TOPSOE, VANADIUM/TUNGSTEN TITANIUM, 1151 CU.FT.; WIDTH: 33 FT.; HEIGHT: 16 FT.; LENGTH: 23 FT WITH A/N: 431108 AMMONIA INJECTION, GRID B	C57	D22		NH3: 10 PPMV (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	A195.5, D12.3, D12.4, D12.5, D28.4, E179.2, E179.3, E193.4
BOILER, NO. 4, NATURAL GAS, COMBUSTION ENGINEERING, TANGENTIALY FIRED, WITH STAGED COMBUSTION, FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 2900 MMBTU/HR WITH A/N: 431107 BURNER, TWENTY FOUR, NATURAL GAS, COMBUSTION ENGINEERING, WITH STAGED COMBUSTION, 2900 MMBTU/HR GENERATOR, 320 MW	D24	C59 C61	NOX: MAJOR SOURCE**	CO: 500 PPMV (5) [RULE 1303(b)(2)-Offset, 5-10-1996]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 7 PPMV (5) [RULE 2009, 5-11-2001]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]; SO2: (9) [40CFR 72 - Acid Rain Provisions, 11-24-1997]	A195.1, A195.6, D28.1, E193.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(3) Denotes RECLAIM concentration limit
(5) (5A) (5B) Denotes command and control emission limit
(7) Denotes NSR applicability limit
(9) See App B for Emission Limits
(2) (2A) (2B) Denotes RECLAIM emission rate
(4) Denotes BACT emission limit
(6) Denotes air toxic control rule limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 4: POWER GENERATION-BOILERS					
SELECTIVE CATALYTIC REDUCTION, SYSTEM C, SERVING BOILER NO. 4, IN-DUCT TYPE, HALDOR TOPSOE, VANADIUM/TUNGSTEN TITANIUM, 1151 CU.FT.; WIDTH: 33 FT; HEIGHT: 16 FT; LENGTH: 23 FT WITH A/N: 431124 AMMONIA INJECTION, GRID C	C59	D24		NI13: 10 PPMV (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	A195.5, D12.3, D12.4, D12.5, D28.4, E179.2, E179.3, E193.4
SELECTIVE CATALYTIC REDUCTION, SYSTEM D, SERVING BOILER NO. 4, IN-DUCT TYPE, HALDOR TOPSOE, VANADIUM/TUNGSTEN TITANIUM, 1151 CU.FT.; WIDTH: 33 FT; HEIGHT: 16 FT; LENGTH: 23 FT WITH A/N: 431124 AMMONIA INJECTION, GRID D	C61	D24		NI13: 10 PPMV (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	A195.5, D12.3, D12.4, D12.5, D28.4, E179.2, E179.3, E193.4
Process 5: AMMONIA STORAGE					
STORAGE TANK, PRESSURIZED, NO. 1, WITH A VAPOR RETURN LINE, AQUEOUS AMMONIA 19%, 10000 GALS A/N: 375852	D63				C157.1, E144.1, E193.4
STORAGE TANK, PRESSURIZED, NO. 2, WITH A VAPOR RETURN LINE, AQUEOUS AMMONIA 19%, 10000 GALS A/N: 376914	D64				C157.1, E144.1, E193.4

* (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 6: R219 EXEMPT EQUIPMENT SUBJECT TO SOURCE-SPECIFIC RULE					
RULE 219 EXEMPT EQUIPMENT, ABRASIVE BLASTING EQUIPMENT, GLOVE-BOX, <= 53 FT ³ , WITH DUST FILTER	E50			PM: (9) [RULE 1140, 8-2-1985; RULE 404, 2-7-1986; RULE 405, 2-7-1986]	D322.1, D381.1, K67.1
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS	E52			ROG: (9) [RULE 1113, 11-8-1996; RULE 1113, 12-5-2003; RULE 1171, 8-2-2002; RULE 1171, 11-7-2003]	K67.2
RULE 219 EXEMPT EQUIPMENT, COOLING TOWERS	E54				I123.4
Process 7: WASTE WATER TREATMENT					
SUMP, WASTE WATER, OPEN TOP, CATCH BASIN, WIDTH: 24 FT ; DEPTH: 11 FT ; LENGTH: 20 FT A/N: 340465	D53				E179.1, E202.1, K67.3

* (1) (1A) (1B) Denotes RECLAIM emission factor
 (2) (2A) (2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit
 (4) Denotes BACT emission limit
 (5) (5A) (5B) Denotes command and control emission limit
 (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits
 (10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.**

SECTION D: DEVICE ID INDEX

**The following sub-section provides an index
to the devices that make up the facility
description sorted by device ID.**



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.
SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D3	1	2	0
D22	2	4	0
D24	3	4	0
E50	5	6	0
E52	5	6	0
D53	5	7	0
E54	5	6	0
C55	2	4	0
C57	3	4	0
C59	4	4	0
C61	4	4	0
D63	4	5	0
D64	4	5	0
D95	1	2	0



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 9-11-1998]

F18.1 Acid Rain SO₂ Allowance Allocation for affected units are as follows:

Device ID	Boiler ID	Contaminant	Tons in any year
18	Boiler No. 1	SO ₂	115
20	Boiler No. 2	SO ₂	29
22	Boiler No. 3	SO ₂	1362
24	Boiler No. 4	SO ₂	261

a). The allowance allocation(s) shall apply to calendar years 2000 through 2009.

b). The number of allowances allocated to Phase II affected units by U.S. EPA may change in a 1998 revision to 40CFR73 Tables 2,3, and 4. In addition, the number of allowances actually held by an affected source in a unit account may differ from the number allocated by U.S. EPA. Neither of the aforementioned conditions necessitate a revision to the unit SO₂ allowance allocations identified in this permit (see 40 CFR 72.84)



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[40CFR 73 Subpart B, 1-11-1993]

F24.1 Accidental release prevention requirements of Section 112(r)(7):

a). The operator shall comply with the accidental release prevention requirements pursuant to 40 CFR Part 68 and shall submit to the Executive Officer, as a part of an annual compliance certification, a statement that certifies compliance with all of the requirements of 40 CFR Part 68, including the registration and submission of a risk management plan (RMP).

b). The operator shall submit any additional relevant information requested by the Executive Officer or designated agency.

[40CFR 68 - Accidental Release Prevention, 5-24-1996]

DEVICE CONDITIONS

A. Emission Limits

A195.1 The 500 PPM CO emission limit(s) is averaged over 60 minutes.

[RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D22, D24]

A195.5 The 10 PPMV NH₃ emission limit(s) is averaged over 60 minutes at 3 percent oxygen, dry. The operator shall calculate and continuously record the ammonia slip concentration using the following:.



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

NH_3 (ppmv) = $[a - (b * c / 1000000)] * 1000000 / b$, where:

a = ammonia injection rate (lbs/hr)/17 (lbs/lb-mole).

b = dry exhaust gas flow rate (lbs/hr)/29 (lbs/lb-mole).

c = change in measured NO_x across the SCR (ppmv, dry basis).

The operator shall install and maintain a NO_x analyzer to measure the SCR inlet NO_x ppmv accurate to plus or minus 5 percent calibrated at least once every 12 months.

The ammonia slip calculation procedures described above shall not be used for compliance determination or emission information determination without corroborative data using District Method 207.1 and 5.3 or EPA Method 17 for the determination of ammonia.

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : C55, C57, C59, C61]

A195.6 The 7.0 PPMV NO_x emission limit(s) is averaged over 720 operating hours, heat input weighted average, at 3 percent oxygen, dry.



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

A data acquisition system shall be installed and maintained to continuously calculate and record the NOx ppmv based on the 720 operating hour average..

The average shall be calculated based on emissions during all boiler operating hours except start ups defined as whenever the unit is being brought up to normal operating temperature from an inactive status, and the exhaust temperature entering the SCR catalyst is less than 450 F, and shutdowns defined as whenever the unit is allowed to cool from a normal operating temperature to inactive status, and the exhaust temperature entering the SCR catalyst is less than 450 F.

The average shall be calculated based on emissions during all boiler operating hours except calibration and maintenance periods, Part 75 linearity testing, RATA testing, equipment breakdown periods as defined in Rule 2004, and periods of zero fuel flow.

The heat input weighted average NOx concentration shall be calculated using the following equation, or other equivalent equation:

1. PPMV at 3 percent oxygen = $E_t/Q_t \times K$
2. where:
3. PPMV at 3 percent oxygen = Concentration of NOx in PPMv at 3 percent oxygen
4. E_t = Total reported NOx emissions during the averaging period including emissions reported as a result of missing data procedures pursuant to Rule 2012
5. Q_t = Total heat input during the averaging period
6. K = A conversion factor from lbs/MMBtu to PPM, which can be determined using EPA 40 CFR60 Method 19. The default K value is 819.

[RULE 2009, 5-11-2001]

[Devices subject to this condition : D22, D24]

C. Throughput or Operating Parameter Limits

C1.4 The operator shall limit the operating time to no more than 200 hour(s) in any one year.



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The 200 hours per year shall include no more than 50 hours in any one year for maintenance and testing purposes.

[RULE 1110.2, 2-1-2008; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;**
RULE 1470, 6-1-2007]

[Devices subject to this condition : D95]

C157.1 The operator shall install and maintain a pressure relief valve set at 25 psig.

[**RULE 1303(a)(1)-BACT, 5-10-1996**]

[Devices subject to this condition : D63, D64]

D. Monitoring/Testing Requirements

D12.1 The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[RULE 1110.2, 11-14-1997; **RULE 2012, 5-11-2001; RULE 2012, 12-5-2003**]

[Devices subject to this condition : D3]

D12.3 The operator shall install and maintain a(n) flow meter to accurately indicate the flow rate of the total hourly throughput of injected ammonia (NH₃).



FACILITY PERMIT TO OPERATE RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. The accuracy of the device shall be verified once every 12 months.

The operator shall maintain the ammonia injection rate between 0 and 2 gpm on a 1 hour average basis

[RULE 2012, 5-11-2001; RULE 2012, 12-5-2003]

[Devices subject to this condition : C55, C57, C59, C61]

D12.4 The operator shall install and maintain a(n) pressure gauge to accurately indicate the differential pressure across the SCR catalyst bed in inches of water column.

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

The operator shall maintain the differential pressure between 0 and 7.5 inches of water column on a 1 hour average basis

[RULE 2012, 5-11-2001; RULE 2012, 12-5-2003]

[Devices subject to this condition : C55, C57, C59, C61]

D12.5 The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature of the boiler exhaust at the inlet of the SCR reactor.



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

The operator shall maintain the temperature between 450 and 700 degrees F except during start ups and shutdowns

[RULE 2012, 5-11-2001; RULE 2012, 12-5-2003]

[Devices subject to this condition : C55, C57, C59, C61]

D12.9 The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[RULE 1110.2, 2-1-2008; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 1470, 6-1-2007]

[Devices subject to this condition : D95]

D28.1 The operator shall conduct source test(s) in accordance with the following specifications:



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The test shall be conducted to demonstrate compliance with the Rule 1303 emission limit for CO.

The test shall be conducted to determine the CO emissions at the outlet when the equipment is operating under normal conditions.

The test shall be conducted to determine compliance with the CO emissions by either: (a) conducting a source test using District method 100.1 measured over a 30 minute averaging time, or (b) using a portable analyzer and District-approved test method.

The test shall be conducted at least annually. No test shall be required in any one calendar year during which the equipment does not operate on any day that year.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : D22, D24]

D28.4 The operator shall conduct source test(s) in accordance with the following specifications:



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The test shall be conducted to determine the NH₃ emissions using District Methods 207.1 and 5.3, or EPA Method 17 measured over a 60 minute averaging time period. The NO_x concentration, as determined by reading the CEMS, shall be simultaneously recorded during the test. If the CEMS is inoperable, a test shall be conducted to determine the NO_x emissions using District Method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted during ammonia injection periods, at least quarterly during the first twelve months of operation of the SCR after the initial performance test, and at least annually (calendar) thereafter. No test shall be required in any one calendar year during which the equipment does not operate on any day that year.

The District shall be notified of the date and time of the test at least 7 days prior to the test.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit.

The test shall be conducted and the results submitted to the District within 45 days after the test date.

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : C55, C57, C59, C61]

D322.1 The operator shall perform annual inspection of the equipment and filter media for leaks, broken or torn filter media, and improperly installed filter media.

[RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995]

[Devices subject to this condition : E50]



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D381.1 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on an annual basis, at least, unless the equipment did not operate during the entire annual period. The routine annual inspection shall be conducted while the equipment is in operation and during daylight hours. If any visible emissions (not including condensed water vapor) are detected, the operator shall take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

- 1). Stack or emission point identification;
- 2). Description of any corrective actions taken to abate visible emissions; and
- 3). Date and time visible emission was abated.

[RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995]


[Devices subject to this condition : E50]

E. Equipment Operation/Construction Requirements

E144.1 The operator shall vent this equipment, during filling, only to the vessel from which it is being filled.

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D63, D64]



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E179.1 For the purpose of the following condition number(s), clean and maintain shall be defined as draining and vacuuming.

Condition Number 202-1

[RULE 402, 5-7-1976]

[Devices subject to this condition : D53]

E179.2 For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every month and shall be calculated based upon the average of the continuous monitoring for that month.

Condition Number 12-4

[RULE 2012, 5-11-2001; RULE 2012, 12-5-2003]

[Devices subject to this condition : C55, C57, C59, C61]

E179.3 For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour.

Condition Number D 12- 5

Condition Number D 12- 3

Condition Number A 195- 5

[RULE 2012, 5-11-2001; RULE 2012, 12-5-2003]

[Devices subject to this condition : C55, C57, C59, C61]



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E193.4 The operator shall construct, operate, and maintain this equipment according to the following specifications:

In accordance with all the mitigation measures stipulated in the CEQA document that was prepared for this project by the South Coast AQMD (SCH No. 2001021027)

[CA PRC CEQA, 11-23-1970]

[Devices subject to this condition : D22, D24, C55, C57, C59, C61, D63, D64]

E202.1 The operator shall clean and maintain this equipment according to the following specifications:

whenever the catch basin is full, and at least once per year

[RULE 402, 5-7-1976]

[Devices subject to this condition : D53]

H. Applicable Rules

H23.4 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Chromium, Hexavalent	District Rule	1404

The operator has submitted 2 consecutive tests showing hexavalent chrome levels below 0.15 mg/l of circulating water, therefore, as of July 2005, periodic water testing under 1404(b)(5) is no longer required



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[RULE 1404, 4-6-1990]

[Devices subject to this condition : E54]

I. Administrative

1296.2 This equipment shall not be operated unless the operator demonstrates to the Executive Officer that the facility holds sufficient RTCs to offset the prorated annual emissions increase for the first compliance year of operation. In addition, this equipment shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the first compliance year of operation, the facility holds sufficient RTCs in an amount equal to the annual emissions increase.

To comply with this condition, the operator shall hold, prior to the 1st compliance year, and at the beginning of each subsequent compliance year, a minimum of 378 lbs/yr NOx RTC

[RULE 2005, 5-6-2005]

[Devices subject to this condition : D95]

K. Record Keeping/Reporting

K67.1 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the dust collector

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995]

[Devices subject to this condition : E50]

K67.2 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

For architectural applications where no thinners, reducers, or other VOC containing materials are added, maintain semi-annual records for all coating consisting of (a) coating type, (b) VOC content as supplied in grams per liter (g/l) of materials for low-solids coatings, (c) VOC content as supplied in g/l of coating, less water and exempt solvent, for other coatings.

For architectural applications where thinners, reducers, or other VOC containing materials are added, maintain daily records for each coating consisting of (a) coating type, (b) VOC content as applied in grams per liter (g/l) of materials used for low-solids coatings, (c) VOC content as applied in g/l of coating, less water and exempt solvent, for other coatings.

[RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995]

[Devices subject to this condition : E52]

K67.3 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

a log listing the date and time the catch basin is drained or vacuumed

[RULE 402, 5-7-1976]

[Devices subject to this condition : D53]



FACILITY PERMIT TO OPERATE
RRI ENERGY ETIWANDA, INC.

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.5 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

An engine operating log listing on a monthly basis the emergency use hours of operation, maintenance and testing hours of operation, and any other hours of use with a description of the reason for operation. Additionally, each time the engine is started manually, the log shall include the date of operation and the timer reading in hours at the beginning and end of operation

The log shall be kept for a minimum of three calendar years prior to the current year and be made available to District personnel upon request. The total hours of operation for the previous calendar year shall be recorded sometime during the first 15 days of January of each year

[RULE 1110.2, 2-1-2008; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;
RULE 1470, 6-1-2007]

[Devices subject to this condition : D95]