



FACILITY PERMIT TO OPERATE


**ORANGE COUNTY SANITATION DISTRICT
10844 ELLIS AVE
FOUNTAIN VALLEY, CA 92708**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By 
for Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	0	01/12/2009
B	RECLAIM Annual Emission Allocation	0	01/12/2009
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	1	05/28/2009
E	Administrative Conditions	0	01/12/2009
F	RECLAIM Monitoring and Source Testing Requirements	0	01/12/2009
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	0	01/12/2009
H	Permit To Construct and Temporary Permit to Operate	2	05/05/2010
I	Compliance Plans & Schedules	0	01/12/2009
J	Air Toxics	0	01/12/2009
K	Title V Administration	0	01/12/2009
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	0	01/12/2009
B	Rule Emission Limits	0	01/12/2009



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

This section consists of a table listing all equipment with Permits to Construct and copies of all individual Permits to Construct issued to various equipment at the facility. Each permit will list operating conditions including periodic monitoring requirements and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application Number	Permit to Construct Granted On	Equipment Description	Page Number
R-299283	6-22-2004	SCRUBBER, ODOR	3
394229	4-19-2002	ODOR CONTROL UNIT	6
432418	11-18-2004	SEWAGE TREATMENT (>5 MG/D) ANAEROBIC	7
453210	10-17-2006	SEWAGE TREATMENT (>5 MG/D) ANAEROBIC	10
494460	02-09-2010	BOILER (>10 MMBTU/HR) NAT GAS & DIGESTER GAS	15
504150	05-05-2010	ODOR CONTROL UNIT	19

NOTE: EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N R-299283
Granted as of 6/22/2004

Equipment Description:

MODIFICATION OF THE EXISTING AIR POLLUTION CONTROL SYSTEM (PRIMARY BASINS), COVERED BY APPLICATION NO. 222813, CONSISTING OF:

1. FOUR SCRUBBERS, NOS. 5 THROUGH 8, EACH VERTICAL TYPE, PACKED TOWER, 10'-0" DIA. X 33'-0" H., WITH ASSOCIATED PUMPS.
2. CHEMICAL FEED SYSTEM WHICH MAY CONTAIN CAUSTIC SODA, HYDROGEN PEROXIDE AND BLEACH.
3. AUTOMATIC CHEMICAL FEED AND HYDROGEN SULFIDE (H₂S) MONITORING SYSTEM.
4. EXHAUST SYSTEM WITH ASSOCIATED BLOWERS VENTING PRIMARY SEDIMENTATION BASINS NUMBERS ONE THROUGH 15.

BY THE ADDITION OF:

1. SCRUBBER NO.11, VERTICAL TYPE, PACKED TOWER, 10'-0" DIA. X 33'-0" H., WITH ASSOCIATED PUMPS.
2. EXHAUST SYSTEM WITH ASSOCIATED BLOWER VENTING PRIMARY SEDIMENTATION BASINS 16 THROUGH 31.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

4. WITHIN 180 DAYS FROM THE DATE OF THE INITIAL START-UP OF THE NEW CLARIFIERS, OCSO SHALL CONDUCT EMISSION VERIFICATION TEST IN ACCORDANCE WITH AQMD SAMPLING TEST PROCEDURES AND METHODS OF ANALYSIS. WRITTEN NOTICE OF THE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A FINAL REPORT ON THE TEST RESULTS SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. THE VERIFICATION TEST SHALL INCLUDE SAMPLING OF INFLUENT WATER TO THE HEADWORKS AND THE NEW PRIMARY CLARIFIERS AND THE BELT PRESS FILTRATE FOR THE FOLLOWING:

- A. AMMONIA
- B. BENZENE
- C. CARBON DISULFIDE
- D. CARBON TETRACHLORIDE
- E. CHLOROBENZENE
- F. CHLOROFORM
- G. 1,4 (P)-DICHLOROBENZENE
- H. ETHYL BENZENE
- I. ETHYLENE DICHLORIDE (1,2-DICHLOROETHANE)
- J. HYDROGEN SULFIDE
- K. METHYL CHLOROFORM (1,1,1-TRICHLOROETHANE)
- L. METHYLENE CHLORIDE (DICHLOROMETHANE)
- M. METHYL-TERT-BUTYL ETHER (MTBE)
- N. STYRENE
- O. TETRACHLOROETHYLENE (PERCHLOROETHYLENE)
- P. TOLUENE
- Q. TRICHLOROETHYLENE
- R. VINYL CHLORIDE
- S. VINYLIDENE CHLORIDE
- T. XYLENES (MIXTURE AND ISOMERS)

THE RESULTS FROM THE LIQUID SAMPLING SHALL BE USED WITH EMISSION FACTORS DEVELOPED DURING THE COMPLIANCE TESTING OF P1-33 PRIMARY CLARIFIERS AND AB 2588 TESTING PROGRAM TO ESTIMATE EMISSIONS FROM THE NEW PRIMARY CLARIFIERS AND THE RELATED FACILITIES.

[RULE 1303(b)(2)- OFFSET], [RULE 1401]

5. A SUFFICIENT NUMBER OF SCRUBBERS, FROM 5 THROUGH 8 AND 11, SHALL BE IN OPERATION WHEN THE BASIC EQUIPMENT ARE IN OPERATION TO MAINTAIN THE SCRUBBER OUTLET H₂S CONCENTRATIONS, AS MEASURED BY THE AUTOMATIC CHEMICAL FEED AND H₂S MONITORING SYSTEM, LESS THAN THE MAXIMUM OUTLET H₂S LIMITS AS SPECIFIED IN CONDITION NO. 8, EXCEPT DURING UNFORESEEN AND ROUTINE MAINTENANCE WORK OR POWER OUTAGE IN THE PLANT THAT REQUIRES THE SCRUBBERS TO BE SHUTDOWN FOR A PERIOD NOT TO EXCEED 10 HOURS PER INCIDENT PER EQUIPMENT AND 50 HOURS PER YEAR PER EQUIPMENT.

[RULE 402]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

6. WHEN THE SCRUBBERS ARE IN OPERATION, AUTOMATIC CHEMICAL FEED AND H₂S MONITORING SYSTEM SHALL BE IN OPERATION AND MAINTAINED TO RECORD THE SCRUBBER OUTLET H₂S CONCENTRATION, IN PPMV, EXCEPT DURING SHUTDOWN FOR MAINTENANCE. THE H₂S MONITORING SYSTEM SHALL BE CALIBRATED PURSUANT TO MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS.
[RULE 402]
7. WHEN THE AUTOMATIC CHEMICAL FEED AND H₂S MONITORING SYSTEM IS NOT OPERATING, PH OF THE SCRUBBING LIQUID AND THE SCRUBBER OUTLET H₂S CONCENTRATION SHALL BE MEASURED AND RECORDED AT LEAST ONCE PER SHIFT.
[RULE 402]
8. WHEN THE SCRUBBERS ARE IN OPERATION, THE DAILY AVERAGE CONCENTRATION OF SULFUR COMPOUNDS, CALCULATED AS H₂S MEASURED AT THE OUTLET OF EACH SCRUBBER SHALL NOT EXCEED 2 PPMV AND 3 PPMV WHEN THE EXHAUST BLOWER IS OPERATING AT LOW AND HIGH SPEED, RESPECTIVELY.
[RULE 402]
9. RECORDS SHALL BE KEPT AND MAINTAINED FOR THE DAILY AVERAGE H₂S CONCENTRATION, IN PPMV, AT THE OUTLET OF EACH SCRUBBER WHILE IN OPERATION. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

**THIS PERMIT TO CONSTRUCT R-299283 SUPERSEDES PERMIT TO CONSTRUCT 299283
ISSUED 08/10/1999.**



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 394229
Granted as of 4/19/2002

Equipment Description:

ODOR CONTROL SYSTEM CONSISTING OF (LOCATED AT PLANT NO. 1, WASTEHAULER STATION):

1. BIOFILTER, BIOREM, SINGLE MODULE, WITH INCOMING FOUL AIR HUMIDIFICATION CHAMBER, BIOFILTER MEDIA, IRRIGATION SYSTEM AND ASSOCIATED PUMPS.
2. TWO EXHAUST BLOWERS (ONE STAND-BY), 300 CFM CAPACITY.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL PROVIDE TO SCAQMD FINAL DESIGN DRAWINGS, PROCESS AND FLOW DIAGRAM, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, SIZE AND MAXIMUM CAPACITY) PRIOR TO INSTALLATION OF THE EQUIPMENT. DEVIATIONS FROM THE ABOVE DESCRIPTION AND PROPOSED DESIGN AFFECTING EQUIPMENT PERFORMANCE OR EMISSIONS SHALL BE APPROVED IN WRITING BY THE AQMD.
[RULE 204]
5. THE CONCENTRATION OF H₂S FOR THE INLET AND OUTLET OF THE BIOFILTER SHALL BE MEASURED AT LEAST ONCE PER WEEK. THE H₂S CONCENTRATION IN BIOFILTER EXHAUST SHALL NOT EXCEED 2 PPMV AVERAGED OVER THE NUMBER OF MEASUREMENTS TAKEN OVER ANY GIVEN WEEK.
[RULE 402]
6. THE BED DEPTH AND BED PACKING SHALL BE DESIGNED TO ACHIEVE A MINIMUM EBRT OF 40 SECONDS.
[RULE 402]
7. RECORDS TO DEMONSTRATE COMPLIANCE WITH THE CONDITIONS OF THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO THE SCAQMD PERSONNEL UPON REQUEST.
[RULE 204]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 432418
Granted as of 11/18/2004

Equipment Description:

ALTERATION OF THE EXISTING SEWAGE TREATMENT PLANT, COVERED BY PERMIT TO CONSTRUCT APPLICATION NO. 407071 (AND EXISTING P/O F66565), CONSISTING OF:

1. HEADWORKS STATION NO. 1 WITH TWO GRIT CHAMBERS, 28'-0" L. X 20'-0" W. X 14'-0" D., TWO SPLITTER BOXES, 15'-0" L. X 4'-0" W. X 7'-6" D., TWO GRIT CLASSIFIERS, AND ASSOCIATED PUMPS AND BLOWER.
2. HEADWORKS STATION NO. 2 WITH FIVE GRIT CHAMBERS, 38'-0" L. X 20'-0" W. X 14'-0" D., THREE SPLITTER BOXES, 15'-0" L. X 8'-0" W. X 15'-0" D., FOUR BAR SCREENS WITH A RAKE ASSEMBLY, EIGHT GATE OPERATORS, FIVE SPLITTER BOX WEIR GATE OPERATORS, AND ASSOCIATED PUMPS, BLOWERS AND COMPRESSOR.
3. FIFTEEN PRIMARY BASINS CONSISTING OF TWO 188'-0" L. X 40'-0" W. X 9'-0" D. RECTANGULAR BASINS WITH CONCRETE AND ALUMINUM COVERS, THREE 140'-0" DIA. X 9'-0" D. CIRCULAR BASINS WITH ALUMINUM GEODESIC DOME COVERS, TEN 10'-0" L. X 195'-0" W. X 10'-0" D. RECTANGULAR BASINS WITH CONCRETE AND ALUMINUM COVERS AND ASSOCIATED PUMPS AND BLOWERS.
4. FOUR TRICKLING FILTERS, EACH 180' DIA. X 6'-0" D., WITH TWO GATE OPERATORS AND ASSOCIATED PUMPS.
5. SECONDARY CLARIFIERS CONSISTING OF ONE 140'-0" DIA. X 9'-0" D., AND TWENTY-FOUR 150'-0" L. X 40'-0" W. X 10'-0" D. WITH ASSOCIATED PUMPS.
6. ACTIVATED SLUDGE PLANT PRIMARY EFFLUENT PUMP STATION WITH ASSOCIATED PUMPS.
7. TEN AERATION BASINS, EACH 275'-0" L. X 45'-0" W. X 15'-0" D. WITH ASSOCIATED BLOWERS.
8. SIX SLUDGE THICKENERS, EACH 40'-0" DIA. X 8'-0" D., WITH ASSOCIATED SWEEP DRIVER AND CONVEYORS.
9. TWELVE DIGESTER TANK CONSISTING OF FOUR 90'-0" DIA. X 30'-0" D, EACH 208,780 CUBIC FEET CAPACITY, EIGHT 110'-0" DIA. X 30'-0" D, EACH APPROXIMATELY 330,430 CUBIC FEET CAPACITY WITH ASSOCIATED PUMPS AND COMMINUTERS.
10. THIRTY-TWO DIGESTER CLEANING BEDS, 58'-0" L. X 56'-0" W. X 3'-2" D.
11. DIGESTER GAS STORAGE TANKS, 25,000 CUBIC FEET CAPACITY, 42'-0" DIA. X 33'-6" H. WITH THREE COMPRESSORS.



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

12. SLUDGE PROCESSING STATION WITH TWO GRINDERS, EIGHT DEWATERING FILTER PRESSES, TRANSFER PUMP HOPPERS, AUGERS, STORAGE HOPPERS AND A TRUCK LOAD-OUT HOPPER.

BY THE ADDITION OF:

1. SIXTEEN PRIMARY BASINS, 195'-0" L. X 40'-0" W. X 10'-0" D., EACH WITH CONCRETE COVERS AND 6 MGD AVERAGE CAPACITY AND ASSOCIATED PUMPS AND BLOWERS.
2. FOUR EXISTING TRICKLING FILTERS (ITEM NO. 4 ABOVE) REPLACED WITH TWO NEW TRICKLING FILTERS, EACH 166' DIA. X 20' - 0" MEDIA DEPTH, AND ASSOCIATED PUMPS. EACH NEW TRICKLING FILTER WITH TWO EXHAUST STACKS, EACH STACK 40' HIGH, AND WITH A TOTAL AIR FLOW RATE OF 25,000 CFM PER TRICKLING FILTER.
3. ONE EXISTING SECONDARY CLARIFIER (ITEM NO. 5 ABOVE) REPLACED WITH TWO NEW SECONDARY CLARIFIERS CONSISTING OF 175' - 0" DIA. X 15' - 0" D. WITH ASSOCIATED PUMPS.
4. TWO NEW SECONDARY CLARIFIERS, EACH 150'-0" L. X 40'-0" W. X 10'-0" D., WITH ASSOCIATED PUMPS (ITEM NO 5).

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. THE HEADWORKS FACILITIES, PRIMARY TREATMENT BASINS, AND SLUDGE PROCESS STATION SHALL NOT BE OPERATED UNLESS THEY ARE FULLY ENCLOSED AND THEIR EXHAUST AIR VENTED TO AIR POLLUTION CONTROL SYSTEMS, WHICH ARE IN FULL OPERATION AND HAVE VALID PERMITS TO CONSTRUCT OR OPERATE ISSUED BY THE SCAQMD.
[RULE 402]
5. THE DAILY TOTAL INFLUENT FLOW, IN MILLION GALLONS PER DAY (MGD), TO THE HEADWORKS, PRIMARY TREATMENT PROCESS, AND SECONDARY TREATMENT PROCESS SHALL BE RECORDED.
[RULE 204]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

6. THE TOTAL INFLUENT FLOW OF WASTEWATER TO THE PRIMARY WASTEWATER TREATMENT PROCESS SHALL NOT EXCEED 216 MILLION GALLONS PER DAY (MGD), AVERAGED ON A CALENDAR MONTH, EXCEPT DURING WET WEATHER PERIODS AND EMERGENCY PERIODS INVOLVING PUBLIC HEALTH AND SAFETY.
[RULE 1304(a) (4)-MODELING & OFFSETS EXEMPTION]
7. THE TOTAL INFLUENT FLOW OF WASTEWATER TO THE SECONDARY WASTEWATER TREATMENT PROCESS SHALL NOT EXCEED 92 MILLION GALLONS PER DAY (MGD), AVERAGED ON A CALENDAR MONTH, EXCEPT DURING WET WEATHER PERIODS AND EMERGENCY PERIODS INVOLVING PUBLIC HEALTH AND SAFETY.
[RULE 1304(a) (4)-MODELING & OFFSETS EXEMPTION]
8. THE HYDROGEN SULFIDE (H₂S) CONCENTRATION (PPMV) IN THE EXHAUST STACKS OF EACH TRICKLING FILTER SHALL BE MEASURED AND RECORDED ON A DAILY BASIS.
[RULE 402]
9. RAW DIGESTER GAS PRODUCED AT THIS FACILITY SHALL NOT BE RELEASED INTO THE ATMOSPHERE. ALL COLLECTED DIGESTER GAS SHALL BE EITHER BE COMBUSTED IN DIGESTER GAS FLARES, INTERNAL COMBUSTION ENGINES, OR BOILERS, WHICH HAVE VALID PERMITS TO CONSTRUCT OR OPERATE ISSUED BY THE SCAQMD, EXCEPT DURING MAINTENANCE WORK OR CLEANING OF THE DIGESTERS AND RELATED DIGESTER GAS SYSTEM WHICH REQUIRES ISOLATION OF THE DIGESTER GAS LINE, IN WHICH CASE COLLECTED DIGESTER GAS SHALL BE TREATED BY ACTIVATED CARBON.
[RULE 402]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 453210
Granted as of 10/17/2006

Equipment Description:

ALTERATION OF THE EXISTING SEWAGE TREATMENT PLANT (216 MGD), COVERED BY PERMIT TO CONSTRUCT APPLICATION NO.432418 (AND EXISTING P/O F66565), CONSISTING OF:

1. HEADWORKS STATION NO. 1 WITH TWO GRIT CHAMBERS, 28'-0" L. X 20'-0" W. X 14'-0" D., TWO SPLITTER BOXES, 15'-0" L. X 4'-0" W. X 7'-6" D., TWO GRIT CLASSIFIERS, AND ASSOCIATED PUMPS AND BLOWER.
2. HEADWORKS STATION NO. 2 WITH FIVE GRIT CHAMBERS, 38'-0" L. X 20'-0" W. X 14'-0" D., THREE SPLITTER BOXES, 15'-0" L. X 8'-0" W. X 15'-0" D., FOUR BAR SCREENS WITH A RAKE ASSEMBLY, EIGHT GATE OPERATORS, FIVE SPLITTER BOX WEIR GATE OPERATORS, AND ASSOCIATED PUMPS, BLOWERS AND COMPRESSOR.
3. FIFTEEN PRIMARY BASINS CONSISTING OF TWO 188'-0" L. X 40'-0" W. X 9'-0" D. RECTANGULAR BASINS WITH CONCRETE AND ALUMINUM COVERS, THREE 140'-0" DIA. X 9'-0" D. CIRCULAR BASINS WITH ALUMINUM GEODESIC DOME COVERS, TEN 10'-0" L. X 195'-0" W. X 10'-0" D. RECTANGULAR BASINS WITH CONCRETE AND ALUMINUM COVERS AND ASSOCIATED PUMPS AND BLOWERS.
4. FOUR TRICKLING FILTERS, EACH 180' DIA. X 6'-0" D., WITH TWO GATE OPERATORS AND ASSOCIATED PUMPS.
5. SECONDARY CLARIFIERS CONSISTING OF ONE 140'-0" DIA. X 9'-0" D. AND TWENTY-FOUR 150'-0" L. X 40'-0" W. X 10'-0" D. WITH ASSOCIATED PUMPS.
6. ACTIVATED SLUDGE PLANT PRIMARY EFFLUENT PUMP STATION WITH ASSOCIATED PUMPS.
7. TEN AERATION BASINS, EACH 275'-0" L. X 45'-0" W. X 15'-0" D. WITH ASSOCIATED BLOWERS.
8. SIX SLUDGE THICKENERS, EACH 40'-0" DIA. X 8'-0" D., WITH ASSOCIATED SWEEP DRIVER AND CONVEYORS.
9. TWELVE DIGESTER TANK CONSISTING OF FOUR 90'-0" DIA. X 30'-0" D. EACH 208,780 CUBIC FEET CAPACITY, EIGHT 110'-0" DIA. X 30'-0" D, EACH APPROXIMATELY 330,430 CUBIC FEET CAPACITY WITH ASSOCIATED PUMPS AND COMMUNUTERS.
10. THIRTY-TWO DIGESTER CLEANING BEDS, 58'-0" L. X 56'-0" W. X 3'-2" D.
11. DIGESTER GAS STORAGE TANKS, 25,000 CUBIC FEET CAPACITY, 42'-0" DIA. X 33'-6" H. WITH THREE COMPRESSORS.



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

12. SLUDGE PROCESSING STATION WITH TWO GRINDERS, EIGHT DEWATERING FILTER PRESSES, TRANSFER PUMP HOPPERS, AUGERS, STORAGE HOPPERS AND A TRUCK LOAD-OUT HOPPER.
- 13.* SIXTEEN PRIMARY BASINS, 195'-0" L. X 40'-0" W. X 10'-0" D., EACH WITH CONCRETE COVERS AND 6 MGD AVERAGE CAPACITY AND ASSOCIATED PUMPS AND BLOWERS.
- 14.* FOUR EXISTING TRICKLING FILTERS (ITEM NO. 4 ABOVE) REPLACED WITH TWO NEW TRICKLING FILTERS, EACH 166' DIA. X 20' - 0" MEDIA DEPTH, AND ASSOCIATED PUMPS. EACH NEW TRICKLING FILTER WITH TWO EXHAUST STACKS, EACH STACK 40' HIGH, AND WITH A TOTAL AIR FLOW RATE OF 25,000 CFM PER TRICKLING FILTER.
- 15.* ONE EXISTING SECONDARY CLARIFIER (ITEM NO. 5 ABOVE) REPLACED WITH TWO NEW SECONDARY CLARIFIERS CONSISTING OF 175' - 0" DIA. X 15' - 0" D. WITH ASSOCIATED PUMPS.

* Construction for the above items 13, 14, and 15 has been completed (under A/N 407071).

BY THE ADDITION OF: (OCSD JOB NO. P1-82 ACTIVATED SLUDGE PLANT REHABILITATION) UNDER A/N 432418.

16. TWO NEW SECONDARY CLARIFIERS, EACH 150'-0" L. X 40'-0" W. X 10'-0" D.

BY THE REMOVAL OF:

10. THIRTY-TWO DIGESTER CLEANING BEDS, 58'-0" L. X 56'-0" W. X 3'-2" D.

AND BY THE ADDITION OF:

17. NEW SECONDARY ACTIVATED SLUDGE FACILITY 2 (OCSD JOB NO. P1-102), AND NEW SLUDGE DEWATERING BEDS (OCSD JOB NO. P1-106) UNDER A/N 453210,
 - I. SIX AERATION BASINS (NOS. 11 THROUGH 16), COVERED, EACH 227' - 2" L. X 45' - 0" W. X 26' - 0" D., WITH ASSOCIATED AERATION BLOWERS, DIFFUSERS, MIXERS, AND PUMPS, AND VENTING THROUGH SIX STACKS, EACH 7' - 11" H., AND 10,000 SCFM.
 - II. SIX SECONDARY CLARIFIERS (NOS. 27, 29, 31, 32, 33, AND 34), UNCOVERED, EACH 155' DIA. X 16' SIDE WATER D., WITH ASSOCIATED RETURN ACTIVATED SLUDGE (RAS), WASTE ACTIVATED SLUDGE (WAS), AND SECONDARY SCUM PUMPS.
 - III. SODIUM HYPOCHLORITE (NaOCl) SOLUTION SYSTEM ADDITION (TO THE EXISTING BLEACH SYSTEM) FOR CHLORINATION OF THE TREATED EFFLUENT, RETURN ACTIVATED SLUDGE (RAS), WASTE ACTIVATED SLUDGE (WAS), AND SURFACE WASTE.
18. SLUDGE MANAGEMENT SYSTEM CONSISTING OF:
 - I. TRUCK WASH STATION
 - II. SAWDUST STORAGE
 - III. TWO (2) DEWATERING BEDS FOR PLANT CLEANING OPERATIONS, EACH 110' - 0" L. X 56' - 0" W., AND WITH APPROXIMATELY 580 CUBIC YARDS CAPACITY.
 - IV. ONE DEWATERING BED FOR PLANT CLEANING OPERATIONS, 100' - 0" L. X 24' - 0" W., WITH APPROXIMATELY 44 CUBIC YARDS CAPACITY.



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT


Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. ORANGE COUNTY SANITATION DISTRICT (OCSD) SHALL MAKE A WRITTEN REQUEST FOR AND OBTAIN AN EXTENSION OF TIME TO CONSTRUCT THIS EQUIPMENT ON AN ANNUAL BASIS UNTIL SUCH TIME CONSTRUCTION IS COMPLETED AND THE EQUIPMENT IS PUT INTO OPERATION. AT LEAST 30 DAYS PRIOR TO THE EXPIRATION DATE OF THE PERMIT TO CONSTRUCT, OCSD SHALL PROVIDE IN THE WRITTEN REQUEST, VERIFIABLE DATA TO AQMD IN ORDER TO SHOW COMPLIANCE WITH THE CONSTRUCTION SCHEDULE AS PROVIDED IN THE APPLICATION UNDER WHICH THIS PERMIT TO CONSTRUCT IS GRANTED. IF THERE ARE CHANGES TO THE INCREMENTS OF PROGRESS AND/OR CONSTRUCTION SCHEDULE, THEY WILL NOT BECOME EFFECTIVE UNTIL OCSD RECEIVES WRITTEN CONFIRMATION OF SUCH CHANGES FROM AQMD.
[RULE 204]
5. THE HEADWORKS FACILITIES, PRIMARY TREATMENT BASINS, AND SLUDGE PROCESS STATION SHALL NOT BE OPERATED UNLESS THEY ARE FULLY ENCLOSED AND THEIR EXHAUST AIR VENTED TO AIR POLLUTION CONTROL SYSTEMS, WHICH ARE IN FULL OPERATION AND HAVE VALID PERMITS TO CONSTRUCT OR OPERATE ISSUED BY THE SCAQMD. IN THE EVENT AIR POLLUTION CONTROL SYSTEM(S) ARE SHUTDOWN FOR CONSTRUCTION OR MAINTENANCE WORK, THE H₂S EMISSIONS SHALL NOT EXCEED THE CONCENTRATION LIMITS AS SPECIFIED IN THE SHUT DOWN OF AIR POLLUTION CONTROL EQUIPMENT PERMIT.
[RULE 402]
6. THE DAILY TOTAL INFLUENT FLOW, IN MILLION GALLONS PER DAY (MGD), TO THE HEADWORKS, PRIMARY TREATMENT PROCESS, AND SECONDARY TREATMENT PROCESS SHALL BE RECORDED.
[RULE 204]
7. THE TOTAL INFLUENT FLOW OF WASTEWATER TO THE PRIMARY WASTEWATER TREATMENT PROCESS SHALL NOT EXCEED 216 MILLION GALLONS PER DAY (MGD), AVERAGED ON A CALENDAR MONTH, EXCEPT DURING WET WEATHER PERIODS AND EMERGENCY PERIODS INVOLVING PUBLIC HEALTH AND SAFETY.
[RULE 1304 (a) (4) - MODELING & OFFSETS EXEMPTION]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

8. THE TOTAL INFLUENT FLOW OF WASTEWATER TO THE SECONDARY WASTEWATER TREATMENT PROCESS SHALL NOT EXCEED 92 MILLION GALLONS PER DAY (MGD), AVERAGED ON A CALENDAR MONTH, EXCEPT DURING WET WEATHER PERIODS AND EMERGENCY PERIODS INVOLVING PUBLIC HEALTH AND SAFETY.
[RULE 1304 (a) (4) – MODELING & OFFSETS EXEMPTION]
9. THE AVERAGE DAILY PRIMARY EFFLUENT FLOW RATE, TREATED BY THE NEW ACTIVATED SLUDGE FACILITY 2 (JOB NO. P1-102 CONSISTING OF SIX AERATION BASINS AND SIX SECONDARY CLARIFIERS), SHALL NOT EXCEED 60 MILLION GALLONS PER DAY (MGD), AVERAGED ON A CALENDAR MONTH, EXCEPT DURING WET WEATHER PERIODS AND EMERGENCY PERIODS INVOLVING PUBLIC HEALTH AND SAFETY.
[RULE 204]
10. WITHIN 60 DAYS AFTER ACHIEVING THE MAXIMUM INFLUENT FLOW RATE FOR THE ACTIVATED SLUDGE FACILITY 2 (JOB NO. P1-102), BUT NOT LATER THAN 180 DAYS AFTER INITIAL START-UP, ORANGE COUNTY SANITATION DISTRICT (OCS D) SHALL CONDUCT SOURCE TESTS TO DETERMINE EMISSIONS FROM AT LEAST TWO OF THE SIX NEW AERATION BASINS' EXHAUST STACKS, AND AT LEAST TWO OF THE SIX NEW SECONDARY CLARIFIERS' SURFACE EMISSIONS, IN ACCORDANCE WITH THE AQMD OR OTHER APPROVED TEST PROCEDURES. A TEST PROTOCOL INCLUDING ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED TO THE AQMD, REFINERY AND WASTE MANAGEMENT TEAM, FOR APPROVAL AT LEAST 30 DAYS PRIOR TO START OF THE TESTS. NOTICE SHALL BE PROVIDED TO THE AQMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. WRITTEN RESULTS OF SUCH PERFORMANCE TESTS SHALL BE SUBMITTED WITHIN 60 DAYS AFTER TESTING. THE TESTS SHALL DETERMINE THE EMISSIONS TO ATMOSPHERE FROM TWO OF THE AERATION BASINS AND TWO OF THE SECONDARY CLARIFIERS FOR:
 - A. TOTAL NON-METHANE HYDROCARBONS (TNMHC) AND TOXIC AIR CONTAMINANTS (TAC) PRESENT, (LBS/HR AND PPMV).
 - B. AMMONIA AND HYDROGEN SULFIDE (H₂S), (LBS/HR AND PPMV).
 - C. CARBON DIOXIDE, OXYGEN AND NITROGEN
 - D. MOISTURE CONTENT, TEMPERATURE AND EXHAUST FLOW RATE.
11. ADEQUATE NUMBER OF SAMPLING PORTS WITH ITS SAFE ACCESS, SHALL BE INSTALLED AND MAINTAINED IN THE AERATION BASINS' EXHAUST STACK (JOB NO. P1-102) IN ACCORDANCE WITH SCAQMD'S RULE 217.
[RULE 217]
12. ORANGE COUNTY SANITATION DISTRICT (OCS D) SHALL CALCULATE THE MAXIMUM INDIVIDUAL CANCER RISK (MICR), ACUTE HAZARD INDEX (HIA) AND CHRONIC HAZARD INDEX (HIC), BASED ON THE SOURCE TESTS RESULTS, USING AQMD PUBLISHED "RISK ASSESSMENT PROCEDURES FOR RULES 1401 AND 212" (VERSION 7.0, JULY 1, 2005), TO DETERMINE THE COMPLIANCE WITH RULE 1401. RESULTS SHALL BE SUBMITTED TO AQMD.
[RULE 1401]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

13. IF SOURCE TESTS RESULTS INDICATE THAT THE TOTAL VOLATILE ORGANIC COMPOUNDS (VOC) EMISSIONS FROM THE AERATION BASINS EXCEED 13 LBS PER DAY OR AS DETERMINED BY AQMD, THEN OCSD SHALL CONDUCT IN DETAIL THE TECHNOLOGICAL FEASIBLE STUDY AND COST-EFFECTIVENESS ANALYSIS FOR A SUITABLE AIR POLLUTION CONTROL EQUIPMENT TO DETERMINE LOWEST ACHIEVABLE EMISSION RATE (LAER) FROM SUCH PROCESS.
[RULE 1303 (a) (1) - BACT]
14. THE HYDROGEN SULFIDE (H₂S) CONCENTRATION (PPMV) IN THE EXHAUST STACKS OF EACH TRICKLING FILTER SHALL BE MEASURED AND RECORDED ON A DAILY BASIS.
[RULE 402]
15. RAW DIGESTER GAS PRODUCED AT THIS FACILITY SHALL NOT BE RELEASED INTO THE ATMOSPHERE. ALL COLLECTED DIGESTER GAS SHALL BE EITHER COMBUSTED IN DIGESTER GAS FLARES, INTERNAL COMBUSTION ENGINES, OR BOILERS WITH VALID AQMD PERMIT, OR SHALL BE TREATED THROUGH A PERMITTED AIR POLLUTION CONTROL DEVICE(S).
[RULE 402]
16. THE SAWDUST USED IN THE SLUDGE MANAGEMENT SYSTEM SHALL BE STORED AND KEPT SUFFICIENTLY MOIST TO PREVENT ANY AIR BORNE PARTICULATE MATTER EMISSIONS.
[RULE 402]
17. OCSD SHALL KEEP THE FOLLOWING DAILY RECORDS WITH REGARDS TO THE SLUDGE MANAGEMENT SYSTEM,
 - I. THE AMOUNT OF SLUDGE DEWATERED IN EACH DRYING BED.
 - II. NUMBER OF TRUCKS WASHED.
 - III. NUMBER OF LEAKY OR OVERFILLED TRUCKS.[RULE 204]
18. RECORDS TO DEMONSTRATE COMPLIANCE WITH THE CONDITIONS OF THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO THE SCAQMD PERSONNEL UPON REQUEST.
[RULE 204]



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

PERMIT TO CONSTRUCT

A/N 494460
Granted as of 02/09/2010

Equipment Description:

BOILER, HURST BOILER AND WELDING COMPANY, MODEL S5-250-125W OR EQUIVALENT, FIRE-TUBE TYPE, WITH POWER FLAME INC., MODEL NVC8-G-30 LOW NO_x BURNER OR EQUIVALENT, 10,500,000 BTU PER HOUR, WITH DIGESTER GAS AS PRIMARY FUEL AND NATURAL GAS AS STAND-BY FUEL.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED, UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL PROVIDE TO SCAQMD FINAL BOILER DESIGN DRAWINGS, P & I DIAGRAMS, CONTROLS, EQUIPMENT SPECIFICATIONS (MAKE, MODEL, DIMENSIONS, SIZE AND MAXIMUM CAPACITY) PRIOR TO INSTALLATION OF THE EQUIPMENT.
[RULE 204]
4. THIS EQUIPMENT SHALL BE PRIMARILY FIRED WITH DIGESTER GAS. NATURAL GAS MAY BE USED AS A STANDBY FUEL, IN THE EVENT DIGESTER GAS IS NOT AVAILABLE.
[RULE 204, 1146]
5. A FUEL METER SHALL BE INSTALLED AND MAINTAINED IN THE FUEL SUPPLY LINE(S) TO MEASURE, INDICATE AND RECORD THE AMOUNT OF FUEL(S) (SCFM) BURNED IN THIS EQUIPMENT.
[RULE 1303 (b) (1) & 1303 (b) (2) – MODELING & OFFSET]
6. WHEN IN OPERATION, TOTAL HEAT INPUT FOR THIS EQUIPMENT SHALL NOT EXCEED 10.5 MMBTU/HR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE (BTU/SCF) OF FUEL GAS BURNED IN THIS EQUIPMENT BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
[RULE 1303 (b) (1) & 1303 (b) (2) – MODELING & OFFSET]



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

7. THIS EQUIPMENT SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE THE COMBUSTION AIR AND FUEL RATE AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED PERIODICALLY, ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME BURNER FIRING RATE.
[RULE 1146]

8. EMISSIONS FOR OXIDES OF NITROGEN (NO_x) AND CARBON MONOXIDE (CO) SHALL NOT EXCEED THE FOLLOWING LIMITS AND SHALL BE MEASURED BY VOLUME, ON A DRY BASIS, AT 3% O₂.

<u>FUEL USED</u>	<u>NO_x AS NO₂</u>	<u>CO</u>
DIGESTER GAS	30 PPMV	≤100 PPMV
NATURAL GAS	12 PPMV	≤50 PPMV

[RULE 1146, RULE 1303 (a) (1) – BACT/LAER]

9. ON AND AFTER JANUARY 1, 2015, EMISSIONS OF NO_x SHALL NOT EXCEED 15 PPMV (CORRECTED TO 3% O₂, DRY) WHILE FIRING ON DIGESTER GAS
[RULE 1146]

10. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT AN INITIAL SOURCE TEST, AND SUBSEQUENT SOURCE TESTS ONCE EVERY THREE YEARS THEREAFTER, UNDER THE FOLLOWING CONDITIONS:

- A. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THIS TEST.
- B. A SOURCE TEST PROTOCOL SHALL BE SUBMITTED TO AQMD WITHIN 30 DAYS OF INITIAL START UP AND SHALL BE APPROVED BY AQMD BEFORE THE TEST COMMENCES. THE PROTOCOL SHALL INCLUDE PROPOSED OPERATING CONDITIONS OF THE EQUIPMENT DURING THE TEST, AND A DESCRIPTION OF ALL SAMPLING AND ANALYTICAL PROCEDURES TO BE USED.
- C. SOURCE TESTING SHALL BE CONDUCTED WITHIN 60 CALENDAR DAYS AFTER NORMAL OPERATION OF THE EQUIPMENT HAS BEEN ESTABLISHED, BUT NO LATER THAN 180 DAYS AFTER INITIAL START UP.
- D. THE SOURCE TESTS SHALL BE PERFORMED WHEN THE BOILER IS OPERATING AT MAXIMUM, MINIMUM AND AVERAGE LOAD FOR EACH FUEL (DIGESTER GAS AND NATURAL GAS) TO BE BURNED. THE SAMPLING TIME AT EACH LOAD SHALL BE FOR A MINIMUM OF 15 CONSECUTIVE MINUTES.
- E. TWO COPIES OF THE SOURCE TEST RESULTS SHALL BE SUBMITTED TO AQMD, ATTN. GAURANG RAWAL, WITHIN 60 DAYS OF THE TESTS COMPLETION. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING:

FUEL FLOW RATE (EACH FUEL)
FLUE GAS FLOW RATE (EACH FUEL)
METHANE (INLET DIGESTER GAS)



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

TOTAL NON-METHANE ORGANICS (EXHAUST & INLET DIGESTER GAS)
SPECIATED TRACE ORGANICS (EXHAUST, DIGESTER GAS)
TOTAL PARTICULATES (EXHAUST)
OXIDES OF NITROGEN (EXHAUST)
CARBON MONOXIDE (EXHAUST)
OXYGEN
DIGESTER GAS BTU (HHV), AND TOTAL SULFUR CONTENT (AS H₂S, PPMV)

THE REPORT SHALL PRESENT THE EMISSIONS DATA IN PARTS PER MILLION (PPMV) ON A DRY BASIS, POUNDS PER HOUR, AND LBS/MMBTU.
[RULE 217, RULE 404, RULE 1146, RULE 1303(A) (1), 1303 (B) (1), 1303(B) (2) - BACT, MODELING AND OFFSET, 1401]

10. MONITORING AND TESTING OF THE BOILER SHALL BE PERFORMED ACCORDING TO RULE 1146.
[RULE 1146]

11. EMISSIONS RESULTING FROM THIS EQUIPMENT SHALL NOT EXCEED THE FOLLOWING:

<u>POLLUTANT</u>	<u>POUNDS PER HOUR</u>
CO	0.90 (0.43 WITH NATURAL GAS)
NO _x	0.44 (0.17 WITH NATURAL GAS)
PM ₁₀	0.056
ROG	0.083
SO _x	0.13

[RULE 404, 431.1, 1303(a) (1)-BACT, 1303(b) (2) - OFFSET]

12. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH APPLICABLE REQUIREMENTS OF 40 CFR 63 SUBPART DDDDD.
[40 CFR 63 SUBPART DDDDD]

13. ALL RECORDS REQUIRED BY THIS PERMIT SHALL BE KEPT AND MAINTAINED FOR A MINIMUM OF FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 3004 (a) (1)]

Periodic Monitoring:

14. THE OPERATOR SHALL DETERMINE COMPLIANCE WITH THE EMISSION LIMIT(S) IN CONDITION NO. 11, AT LEAST ONCE EVERY FIVE YEARS USING AQMD-APPROVED TEST METHOD. THE TEST SHALL BE CONDUCTED WHEN THE EQUIPMENT IS OPERATING UNDER NORMAL CONDITIONS. THE OPERATOR SHALL COMPLY WITH ALL GENERAL TESTING, REPORTING, AND RECORDKEEPING REQUIREMENTS IN SECTIONS E AND K OF THIS PERMIT.
[RULE 1303 - OFFSET, 3004 (a) (4)]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

Emissions And Requirements:

15. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407
CO: 400 PPMV, @ 3% O₂, DRY BASIS, RULE 1146
PM: 0.1 GR/SCF, RULE 409



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO CONSTRUCT

A/N 504150
Granted as of

Equipment Description:

MODIFICATION OF THE EXISTING ODOR CONTROL SYSTEM, F94280, CONSISTING OF:

1. FOUL AIR DUCTING FROM WET WELL AND ASSOCIATED TRUNK LINES (ELLIS PUMP STATION, OCSD PLANT NO. 1).
2. TWO BLOWERS, IN PARALLEL, EACH 7500 SCFM FLOW RATE
3. TWO ADSORBERS, IN PARALLEL, CONTAINING US FILTER/WESTATES MIDAS OCM OR CALGON CARBON MINOTAUR, EACH WITH A MINIMUM OF 8000 LBS OF HIGH H₂S CAPACITY ACTIVATED CARBON.
4. TWO EXHAUST STACKS, EACH 2' - 6" DIA. X 6.5' H. WITH RAIN CAP.

BY REPLACEMENT WITH NEW ADSORBENT MEDIA BLEND, EXHAUST STACK, AND REMOVAL OF A RAIN CAP, AS FOLLOWS,

1. FOUL AIR DUCTING FROM WET WELL AND ASSOCIATED TRUNK LINES (STEVE ANDERSON LIFT STATION, OCSD PLANT NO. 1).
2. TWO BLOWERS, IN PARALLEL, EACH 7500 SCFM FLOW RATE
3. TWO ADSORBERS, IN PARALLEL, CONTAINING PUREAIR FILTRATION OR EQUAL ADSORBENT MEDIA, A BLEND OF POTASSIUM PERMANGANATE BASED AND GRANULAR ACTIVATED CARBON MEDIA, EACH ADSORBER WITH A MINIMUM OF 382 CUBIC FEET OF HIGH H₂S CAPACITY MEDIA BLEND.
4. HYDROGEN SULFIDE CONTINUOUS EMISSION MONITORING AND INTEGRATED SAMPLING SYSTEM.
5. TWO EXHAUST STACKS, EACH 2' - 0" DIA. X 25' - 6" H.

PERMIT CONDITIONS:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATIONS UNDER WHICH THIS PERMIT IS ISSUED.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
[RULE 204]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

3. THIS PERMIT SHALL EXPIRE IF CONSTRUCTION OF THE EQUIPMENT IS NOT COMPLETED WITHIN ONE YEAR FROM THE DATE OF ISSUANCE OF THIS PERMIT UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER.
[RULE 205]
4. IDENTIFICATION TAG (S) OR NAMEPLATE (S) SHALL BE DISPLAYED ON THE EQUIPMENT TO SHOW MANUFACTURER MODEL NO. AND SERIAL NO. THE TAG (S) OR PLATE (S) SHALL BE ISSUED BY THE MANUFACTURER AND SHALL BE AFFIXED TO THE EQUIPMENT IN A PERMANENT AND CONSPICUOUS POSITION.
[RULE 204]
5. A FLOW METER SHALL BE INSTALLED AND MAINTAINED AT THE INLET STREAM TO EACH CARBON ADSORBER TO INDICATE THE FOUL AIR TREATED, IN CUBIC FEET PER MINUTE (CFM). IN CASE A PRESSURE SENSOR DEVICE IS USED IN PLACE OF THE FLOW METER, A CONVERSION CHART SHALL BE MAINTAINED TO INDICATE THE CORRESPONDING FLOW RATE, IN CFM, TO THE PRESSURE READING.
[RULE 204]
6. MAXIMUM FOUL AIR FLOW TO BE TREATED BY EACH OF THE CARBON ADSORBER SHALL NOT EXCEED 7500 CFM.
[RULE 402]
7. FOR EACH CARBON ADSORBER, TOTAL ORGANIC COMPOUNDS (TOCs) CONCENTRATION (PPMV) SHALL BE MONITORED AT EACH EXHAUST STACK, AT LEAST ONCE EVERY 7 DAYS OF OPERATION, FOR THE FIRST SIX-MONTH AND THEN ON A MONTHLY BASIS, USING A PHOTO IONIZATION DETECTOR OR AN ORGANIC VAPOR ANALYZER. RECORDS SHALL BE MAINTAINED AND KEPT ON FILE.
[RULE 204]
8. THE TOC CONCENTRATION MEASURED AT THE EXHAUST FROM EACH CARBON ADSORBER SHALL NOT EXCEED 2.2 PPMV, AS CARBON.
[RULE 204]
9. WHEN IN OPERATION, H₂S CONCENTRATION (PPMV) IN EACH EXHAUST STACK SHALL BE MONITORED AND RECORDED USING A HYDROGEN SULFIDE CONTINUOUS EMISSION MONITORING AND INTEGRATED SAMPLING SYSTEM (CEMS). WHEN THE H₂S MONITORING SYSTEM IS SHUTDOWN FOR REPAIR OR MAINTENANCE, PORTABLE DEVICES SUCH AS JEROME OR COLORIMETRIC TUBES SHALL BE USED TO MEASURE AND RECORD OUTLET H₂S AT LEAST ONCE PER SHIFT.
10. THE HYDROGEN SULFIDE (H₂S) CONCENTRATION MEASURED AT EACH EXHAUST STACK, USING CEMS SHALL NOT EXCEED 2.45PPMV, AVERAGED OVER ONE HOUR
[RULE 402, 1401]
11. IF THE HYDROGEN SULFIDE (H₂S) CONCENTRATION MEASURED AT THE EXHAUST STACK IS DETECTED ABOVE 2.2 PPMV, THEN IMMEDIATE CORRECTIVE MEASURES SHALL BE TAKEN INCLUDING ACTIVATED CARBON REPLACEMENT, WITH FRESH CARBON, BEFORE RESUMING OPERATION.
[RULE 402, 1401]



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

12. SPENT CARBON REMOVED FROM THIS SYSTEM SHALL BE MAINTAINED OR STORED IN CLOSED CONTAINERS PRIOR TO REMOVAL FROM SITE.
[RULE 204]
13. IF THE OPERATION OF THIS EQUIPMENT RESULTS IN CONSIDERABLE NUMBER OF ODOR COMPLAINTS, THE WORK SHALL CEASE AND MITIGATION MEASURES SHALL BE IMPLEMENTED IMMEDIATELY. WORK SHALL NOT RESUME UNTIL EMISSIONS CAUSING THE COMPLAINTS IS MITIGATED.
[RULE 402]
14. RECORDS SHALL BE MAINTAINED AS REQUIRED BY THIS PERMIT INCLUDING CARBON CHANGE OVER DATE(S) FOR COMPLIANCE. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

10/10/10



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765

