



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

August 22, 2012

Mr. James D. Ruth
General Manager
Orange County Sanitation District
PO Box 8127
Fountain Valley, CA 92728-8127

Subject: De Minimis Significant Revision to Title V Permit for Orange County Sanitation District (OCSD), Sewage Treatment Plant, Fountain Valley (ID# 017301)

Dear Mr. Ruth,

Enclosed please find the revised Title Page, Table of Contents, Section D and section H of the Title V Permit for OCSD, sewage treatment plant located at 10844 Ellis Avenue, Fountain Valley, CA, in Orange County. On June 19, 2012, the South Coast Air Quality Management District (AQMD) issued draft permit for Environmental Protection Agency's (EPA) review, and no comments were received from EPA. No public notice was required for this revision.

The revised Section D and Section H reflect the approval of the permits as shown below.

SECTION D, REVISION 3, PERMIT TO OPERATE

| Appl. No. | Equipment | Description |
|-----------|---------------------------------|--|
| 512830 | Storage Tank, Hydrochloric Acid | Existing storage tank, fixed roof, for hydrochloric acid, 8,000 –gallon, venting to a passive activated carbon drum. |
| 512831 | Storage Tank, Hydrochloric Acid | Existing storage tank, fixed roof, for hydrochloric acid, 2,000 –gallon, venting to a passive activated carbon drum. |

SECTION H, REVISION 4, PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

| Appl. No. | Equipment | Description |
|-----------|--|--|
| 520793 | Odor Control equipment, 40, 000 cfm capacity | Odor control equipment consisting of multi-stage chemical scrubbers and GAC system treating 40,000 cfm exhaust from Sludge Thickening and Dewatering Building. |
| 520794 | Sewage Treatment Plant > 5 MGD, anaerobic | Modifications to sewage treatment plant > 5 MGD, anaerobic, (PC 453210) by installations of New Sludge Thickening and Dewatering Facility. |

Mr. James D. Ruth
General Manager
Title V Permit Revision
OCSD, Facility ID. 17301

-2-

August 22, 2012

Please review the attached pages carefully. Insert the enclosed section in your Title V Facility Permit and discard the earlier versions. Questions concerning this revised permit should be directed to Mr. Gaurang Rawal at (909) 396-2543.

The operation of your facility is bound by the conditions and/or requirements stated in your Facility Permit to Operate. If you determine any administrative errors, please contact Mr. Gaurang Rawal at the above number within 30 days of receipt of your permit.

Sincerely,



Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery and Waste Management Permitting

JC: CDT: GCR

cc: w/ enclosure
Geraldo Rios, EPA Region IX
Compliance
Title V Central File
Title V Revision A/N 520795