



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

March 8, 2011
Via electronic submittal

Mr. Gerardo Rios
USEPA – Region IX
Mail Stop A-5-2
75 Hawthorne Blvd.
San Francisco, CA 94105

Dear Mr. Rios,

Proposed De Minimis Significant Revision to Title V Permit for Eastern Municipal Water District (EMWD), San Jacinto Regional Water Reclamation Plant (ID# 019159)

Enclosed for your 45-day review is the proposed revision to the Title V Permit for EMWD, municipal waste water treatment plant located at 770 North Sanderson Avenue, San Jacinto, CA in Riverside County. This revision is considered to be de minimis significant. We are enclosing the appropriate pages of the proposed Section H, which includes the permit as shown below, and the engineering evaluation.

SECTION H, PERMIT TO CONSTRUCT

Appl. No.	Equipment	Description
503050	BOILER (5-20MMBTU/HR), DIGESTER GAS	Alteration of Condition No. 12: to correct the PM10 emission limit due to error in original calculation.
504377	BOILER (5-20MMBTU/HR), OTHER FUEL	Construction and installation of a natural gas and digester gas fired 5.4mmBtu/hr fire tube boiler.
509759	ICE (50-500 HP) NON- EMERGENCY STATIONARY NAT GAS ONLY, WITH NSCR	Alteration of a natural gas fired 330 HP ICE used to drive a water pump to replace the catalytic converter to meet the requirements of Rule 1110.2.
509760	ICE (50-500 HP) NON- EMERGENCY STATIONARY NAT GAS ONLY, WITH NSCR	Alteration of a natural gas fired 330 HP ICE used to drive a water pump to replace the catalytic converter to meet the requirements of Rule 1110.2.

The initial Title V permit for this facility was issued on February 1, 2007.

This request is being made via electronic submittal in order to facilitate your review. If you have any questions or need additional information, please contact Ms. Angela Shibata at (909) 396-2737 or by email at ashibata@aqmd.gov.

Sincerely,

Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery and Waste Management Permitting

JC: CDT: AIS

Enclosures

cc: Felipe Gregorio, EMWD, with proposed permit
A/N 509761, Title V Permit Revision (No. 06)