

Date TBD

Ms. June M Christman
Environmental Manager
Tesoro Refining and Marketing Company
2101 East Pacific Coast Hwy
Wilmington, CA 90744

Subject: Rule 1176 Compliance Plan Application Number 476368

Dear Ms. Christman:

The District has reviewed above application, which Tesoro submitted in pursuant to paragraph (d)(2) of District Rule 1176. Based on the information provided, your compliance plan dated December 6, 2007 is approved and is subject to the conditions as shown below.

1. AS THE RESULT OF SELECTING THE COMPLIANCE OPTION SPECIFIED IN RULE 1176(e)(7)(A) FOR REPEAT EMITTING DRAIN SYSTEM COMPONENTS (DSCs), YOUR FACILITY SHALL COMPLY WITH THE FOLLOWING SCHEDULE:

Within 60 days or longer, as approved by the Executive Officer, after a DSC becomes a repeat emitting DSC, effectively control the DSC by installing a DSC control, if previously uncontrolled, or a more efficient DSC control to eliminate excess emissions from the DSC.

Repeat-emitting DSC is a DSC that has emitted VOC, measured pursuant to paragraph (h)(1) of Rule 1176, greater than 500 ppm above background levels at least three times during any consecutive 12 months.

2. AS THE RESULT OF SELECTING THE COMPLIANCE OPTION SPECIFIED IN RULE 1176(e)(7)(A) FOR REPEAT EMITTING DSCs THE OPERATOR SHALL INSPECT AND MONITOR WASTEWATER SEPARATORS, CLOSED VENT SYSTEMS, AND ALL DSCs IN ACCORDANCE TO THE REQUIREMENTS OF RULE 1176(f)(1)(A).
3. ALL NEW PROCESS DRAINS INSTALLED AFTER SEPTEMBER 13, 1996 SHALL BE EQUIPPED WITH WATER SEAL CONTROLS, OR ALTERNATIVE CONTROLS AS APPROVED BY THE EXECUTIVE OFFICER.

Please contact Ms. Sawsan Andrawis at 909-396-2607/ sandrawis@aqmd.gov if you have any questions.

Sincerely,

Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery/Waste Management/Terminals Permitting
Engineering & Compliance

JC: TV: BC: SAA
cc: Chhai Chorn
file