



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

December 14, 2010

Mr. Anthony Pack
General Manager
Eastern Municipal Water District
PO Box 8300
Perris, CA 92572-8300

Subject: San Jacinto Valley Regional Water Reclamation Plant (Facility ID 019159)
Title V Facility Permit, Revision No. 4

Dear Mr. Pack,

Enclosed please find the revised Title page, Table of Contents, Section D and Section H of your Title V Facility Permit. The revised sections reflect the approval of a De Minimis Significant Permit Revision of the Title V permit. The South Coast Air Quality Management District (AQMD) issued a draft permit for Environmental Protection Agency (EPA) review on October 22, 2010, and no comments were received from the EPA. No Public Notice was requirement for the Revision.

The revision to Section H includes the revised permit as shown below:

SECTION H, PERMIT TO CONSTRUCT

Appl. No.	Equipment	Description
512190	SEWAGE TREATMENT PLANT (>5 MGD), ANAEROBIC	Alteration of the sewage treatment plant includes updating the equipment description and to allow the alteration of the secondary digester into a cold sludge storage tank.

Applications 485853, 485855, 485856, 486679, and 486680 in Section D and 446534 and 475845 in Section H have been re-issued to correct typographical errors under Administrative Permit Revision. Application 475846 has been cancelled and removed from Section H under Administrative Permit Revision. Please see the attached table for the summary of the administrative changes.

Please review the attached pages and then insert the enclosed sections in you Title V Facility Permit, and discard the earlier versions. If you have any questions concerning changes to your permit, or if you determine any administrative error, please contact Angela Shibata (909) 396-2737, within 30 days of the receipt of your permit.

Sincerely,

Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery and Waste Management Permitting

JC: CDT: AIS
Attachments

cc: w/ enclosure
Geraldo Rio, EPA Region IX
Compliance
Title V Central File
Title V Application 508839 File

SECTION D. PERMIT TO OPERATE

Appl. No.	Equipment	Description
485853 (Permit G4345)	ICE (50-500 HP) NON- EMERGENCY STATIONARY NAT GAS ONLY, WITH NSCR	Alteration of Condition No. 16: to change the Rule 1110.2 NOx limit from 36 ppmv to 45 ppmv. The engine is less than 500 HP, see Rule 1110.2.
485855 (Permit G4346)	ICE (50-500 HP) NON- EMERGENCY STATIONARY NAT GAS ONLY, WITH NSCR	Alteration of Condition No. 4: to correct the misspelling of the word operate and Condition No. 19: to change the Rule 1110.2 NOx limit from 36 ppmv to 45 ppmv. The engine is less than 500 HP, see Rule 1110.2.
485856 (Permit G4347)	ICE (50-500 HP) DIGESTER GAS	Alteration of Condition No. 13: to change the Rule 1110.2 NOx limit from 36 ppmv to 45 ppmv. The engine is less than 500 HP, see Rule 1110.2.
486679 (Permit G4348)	ICE (50-500 HP) NON- EMERGENCY STATIONARY NAT GAS ONLY, WITH NSCR	Alteration of Condition No. 18: to change the Rule 1110.2 NOx limit from 36 ppmv to 45 ppmv. The engine is less than 500 HP, see Rule 1110.2.
486680 (Permit G4344)	ICE (50-500 HP) NON- EMERGENCY STATIONARY NAT GAS ONLY, WITH NSCR	Alteration of Condition No. 18: to change the Rule 1110.2 NOx limit from 36 ppmv to 45 ppmv. The engine is less than 500 HP, see Rule 1110.2.

SECTION H. PERMIT TO CONSTRUCT

Appl. No.	Equipment	Description
446534	DIGESTER GAS FLARING SYSTEM	Alteration of Condition No. 26 to read: "PM: 0.1 GR/SCF, RULE 409," instead of "PM: 0.1 GR/SF, RULE 409."
475845	BIOFILTER	Removal of Condition No. 7: THE CONCENTRATION OF H2S SHALL BE MEASURED AT LEAST ONCE PER WEEK, AT THE INLET TO THE BIOFILTER, THE H2S CONCENTRATION SHALL NOT EXCEED 40 PPM. [RULE 402] This condition was inadvertently included in this permit by our error. The facility is Rule 431.1 exempt, see Facility Wide Conditions No. 3 in Section D. Correcting Condition No. 8 rule tag from [RULE 3003] to [RULE 204].
475846	SEWAGE TREATMENT PLANT (>5 MDG), ANAEROBIC	Cancelled and removed from Title V Permit. All modifications have been merged into approved Permit to Construct under A/N 512190.