



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

January 20, 2012  
via Electronic Submittal

Mr. Gerardo Rios  
USEPA – Region IX  
Mail Stop A-5-2  
75 Hawthorne Blvd.  
San Francisco, CA 94105

Dear Mr. Rios:

Proposed Minor Revision to Title V Permit for NM Milliken Genco LLC (ID#129661)

Enclosed for your 45-day review is the proposed revision to the Title V Permit for NM Milliken Genco LLC located at 2050 South Milliken, Ontario, CA. This revision is considered to be a Minor permit revision; a public notice is not required. We are enclosing the proposed revisions to Sections D and I, including the revised permits as shown below, and the engineering evaluations.

**SECTION D: PERMIT TO OPERATE**

<b>Appl. No.</b>	<b>Description</b>
515470	<p>Change of Conditions :</p> <ul style="list-style-type: none"><li>• Clarify calculation methods, maximum limit and recordkeeping for the hourly heating value of landfill gas burned in this IC engine.</li><li>• Add non-resettable elapsed time meter.</li><li>• Remove air/fuel ratio controller requirement; engine is equipped with a NOx CEMS.</li><li>• Update VOC &amp; NOx concentration limits based on current Rule 1110.2 requirements.</li><li>• Add Methane concentration limit based on the current Rule 1150.1 requirement.</li><li>• Convert RHC, NOx &amp; CO BACT emission limits from gram/bhp-hr to ppmv with no O<sub>2</sub> correction.</li></ul>
515471	<p>Change of Conditions :</p> <ul style="list-style-type: none"><li>• Clarify calculation methods, maximum limit and recordkeeping for the hourly heating value of landfill gas burned in this IC engine.</li><li>• Add non-resettable elapsed time meter.</li><li>• Remove air/fuel ratio controller requirement; engine is equipped with a NOx CEMS.</li><li>• Update VOC &amp; NOx concentration limits based on current Rule 1110.2 requirements.</li><li>• Add Methane concentration limit based on the current Rule 1150.1 requirement.</li><li>• Convert RHC, NOx &amp; CO BACT emission limits from gram/bhp-hr to ppmv with no O<sub>2</sub> correction.</li></ul>

## SECTION I: PLANS AND SCHEDULES

Appl. No.	Description
486800	• New Rule 1110.2 Inspection and Monitoring Plan

The Title V permit renewal for this facility was issued on December 21, 2007. The proposed changes will result in no emission increases.

This request is being made via electronic submittal in order to facilitate your review. If you have any questions or need additional information, please contact Mr. Ken Matsuda at (909) 396-2656 or by email at kmatsuda@aqmd.gov.

Sincerely,



Jay Chen, P.E.

Senior AQ Engineering Manager  
Refinery and Waste Management Permitting

Enclosures

JC:CDT:KKM:jtu

cc: Suparna Chakladar, FORTISTAR Methane Group, w/o enclosure  
Appl.No. 515617, w/ enclosures