



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

February 26, 2013

Mr. Paul D. Jones II  
General Manager  
Eastern Municipal Water District  
PO Box 8300  
Perris, CA 92572-8300

**Subject:** Eastern Municipal Water District (EMWD), Temecula Valley Regional Water Reclamation Facility (TVRWRF) (Facility ID 001703) Title V Facility Permit Revision No. 8

Dear Mr. Jones,

Enclosed please find the revised Title page, Table of Contents, Section D, and Section H of your Title V Facility Permit. The revised sections reflect the approval of a Minor Permit Revision and a De Minimis Significant Permit Revision of the Title V permit that have been combined into one final Title V Permit Revision. The South Coast Air Quality Management District (AQMD) issued a draft permit for Environmental Protection Agency (EPA) review on October 5, 2012 (Minor Permit Revision) and November 3, 2012 (De Minimis Significant Permit Revision), and no comments were received from the EPA. No Public Notice was required for the Revisions. The revision to Section D and Section H includes the revised permit as shown below:

Section D, Permit To Operate

Appl. No.	Equipment	Description
526292	ICE, > 500 HP, Non-Emergency Stationary, Other Fuel	Replacement of an air to fuel ratio controller and change condition no. 3 to limit the BTU value for the natural gas/air fuel blend used to fire the engine. [Minor Revision] This application was originally submitted to EPA for review as a Permit to Construct. Final Permit to this equipment will be issued as Permit to Construct/Operate under Administrative Revision. This application supersedes and replaces Permit G5391, A/N 485850 and A/N 518819.
526293	ICE, > 500 HP, Non-Emergency Stationary, Other Fuel	Replacement of an air to fuel ratio controller and change condition no. 3 to limit the BTU value for the natural gas/air fuel blend used to fire the engine. [Minor Revision] This application was originally submitted to EPA for review as a Permit to Construct. Final Permit to this equipment will be issued as Permit to Construct/Operate under Administrative Revision. This application supersedes and replaces Permit G5390, A/N 485849 and A/N 518818.
541131	ICE, > 500 HP, Emergency Elec. Generator, Diesel	Increase monthly maintenance and testing hours and removing a condition that is no longer applicable. [De Minimis Revision]

Section H, Permit To Construct

<b>Appl. No.</b>	<b>Equipment</b>	<b>Description</b>
534092	ICE, > 500 HP, Non-Emergency Stationary, Natural Gas Only	Replacement of the catalytic converter on the engine. [De Minimis Revision] Also, corrected the catalyst model due to typographical error under Administrative Revision.

The Facility Permit reflects the inclusion of the following additional administrative changes:

Section D, Permit To Operate – Administrative Revision

<b>Appl No.</b>	<b>Equipment</b>	<b>Description</b>
485849	ICE, > 500 HP, Non-Emergency Stationary, Other Fuel	Permit was inactivated, since it was replaced and superseded by A/N 526293.
485850	ICE, > 500 HP, Non-Emergency Stationary, Other Fuel	Permit was inactivated, since it was replaced and superseded by A/N 526292.

Section H, Permit To Construct – Administrative Revision

<b>Appl No.</b>	<b>Equipment</b>	<b>Description</b>
513153	Sewage Treatment (>5 MG/D) Anaerobic	Permit was re-issued to remove a Rule 219 boiler from the Equipment Description.
518818	ICE, > 500 HP, Non-Emergency Stationary, Other Fuel	Permit was cancelled, since it was replaced and superseded by A/N 526293.
518819	ICE, > 500 HP, Non-Emergency Stationary, Other Fuel	Permit was cancelled, since it was replaced and superseded by A/N 526292.
522637	ICE, > 500 HP, Emergency Elec. Generator, Diesel	Permit was cancelled, since it was replaced and superseded by A/N 541131.

Please review the attached pages and then insert the enclosed sections in your Title V Facility Permit, and discard the earlier versions. If you have any questions concerning changes to your permit, or if you determine any administrative error, please contact Angela Shibata (909) 396-2737, within 30 days of the receipt of your permit.

Sincerely,



Danny Luong, P.E.  
Senior Enforcement Engineering Manager  
Refinery and Waste Management Permitting

DL: CDT: AIS

Attachments

cc: w/ enclosure  
Geraldo Rio, EPA Region IX  
Compliance  
Title V Central File  
Title V Application 522636 & 534089 File