

South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

April 16, 2009

Gerardo Rios
Chief, Permits Office
USEPA – Region IX
75 Hawthorne Blvd.
San Francisco, CA 94105

Dear Mr. Rios,

Enclosed are the proposed revised pages of the Title V permit [Section D-revised permits for Central Generation system (CGS) engines] for the facility listed below.

Facility ID #	Facility Name	Address
029110	Orange County Sanitation District (OCSD)	22212 Brookhurst St, Huntington Beach, CA 92646

The proposed revised Title V permit under A/N 496824 includes changes to Permits to Operate for five (5) identical internal combustion engine applications (A/N 480908, 480909, 480911, 480912 and 480916).

- Incorporating Rule 1110.2 emission concentration limits using Emission Correction Factor (ECF), based on source tests results, with no impact on mass emissions.
- The engines' source testing and reporting requirements were clarified.

The change of conditions for ECF is considered a minor permit revision to the Title V permit issued January 12, 2009. A public notice is not required. We respectfully request for your expedited review instead of normal 45-day review and commenting period.

If there are specific questions on the proposed revised permit, please contact Gaurang Rawal, AQ Engineer, at (909) 396-2543.

Sincerely,



Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery and Waste Management Permitting

JC: CDT: GCR

Enclosures

cc: James D. Ruth, General Manager, OCSD.

A/N 496824- TV permit revision (01)