



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 17, 2008

Mr. Gerardo Rios
U.S. EPA, Region IX
75 Hawthorne Street
San Francisco, CA 94105

Re: LADWP Harbor Generation Station, facility ID 800170

Dear Mr. Rios:

The South Coast Air Quality Management District (AQMD) has received and reviewed an application from Los Angeles Department of Water and Power (LADWP) for a minor permit revision to the Title V permit of its Harbor Generation Station (HGS). The proposed permit revision would increase the gas turbine diesel readiness test from 30 minutes per month to 60 minutes per month for the five simple cycle gas turbine generators. The following is a summary of the applications.

Application #	Device #	Section #	Proposed Actions
477853	D101	D	Condition A99.9, A99.10, A99.11, B75.1, D59.3, I296.1
477854	D107	D	Condition A99.9, A99.10, A99.11, B75.1, D59.3, I296.1
477855	D113	D	Condition A99.9, A99.10, A99.11, B75.1, D59.3, I296.1
477856	D119	D	Condition A99.9, A99.10, A99.11, B75.1, D59.3, I296.1
477857	D125	D	Condition A99.9, A99.10, A99.11, B75.1, D59.3, I296.1
477858			Title V facility permit revision

A copy of our engineering analysis and the proposed revision to the existing Title V permit are enclosed for the 45-day EPA review. If you have any questions or wish to provide comments regarding this project, please call Mr. Li Chen (909) 396-2426 or Mr. John Yee (909) 396-2531.

Very truly yours,

Michael D. Mills, P.E.
Senior Manager
General Commercial and Energy Team
Engineering and Compliance

Attachments

cc: Bruce Moore, LADWP
Energy Unit Files

Cleaning the air that we breathe.