South Coast
Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 · www.aqmd.gov

September 9, 2010

Mr. Anthony Pack
General Manager
Eastern Municipal Water District
PO Box 8300
Perris, CA 92572-8300

Subject: Perris Valley Regional Water Reclamation Plant (Facility ID 007417)
Title V Facility Permit, Revision No. 3

Dear Mr. Pack,

Enclosed please fine the revised Title page, Table of Contents, Section D, Section H, Section K, and Appendix B of your Title V Facility Permit. The revised sections reflect the approval of a De Minimis Significant Permit Revision of the Title V permit. The South Coast Air Quality Management District (AQMD) issued a draft permit for Environmental Protection Agency (EPA) review on July 23, 2010, and no comments were received from the EPA. No Public Notice was requirement for the Revision.

The revision to Section D and H includes the revised permits as shown below:

SECTION D, PERMIT TO OPERATE

Appl. No.	Equipment
499897	Installation of a digester gas treatment system and fuel cell power plant 600 kW.
503372	Converting a stationary 1970 HP Natural Gas/LPG fired ICE for electric generation from prime-use to emergency use.

SECTION H, PERMIT TO OPERATE

Appl. No.	Equipment
505538	Installation of a digester gas and natural gas boiler used to provide hot water.

Please review the attached pages and then insert the enclosed sections in you Title V Facility Permit, and discard the earlier versions. If you have any questions concerning changes to your permit, or if you determine any administrative error, please contact Angela Shibata (909) 396-2737, within 30 days of the receipt of your permit.

Sincerely,

Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery and Waste Management Permitting

JC: CDT: AIS
Attachments
cc: w/ enclosure
Geraldo Rio, EPA Region IX
Compliance
Title V Central File
Title V Application 499898 File