



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

March 6, 2012

Mr. Anthony Falbo
Senior Vice President - Operations
FORTISTAR Methane Group
NM Milliken Genco LLC
5087 Junction Road
Lockport, NY 14094

SUBJECT: Title V Facility Permit Revision – NM Milliken Genco LLC

REFERENCE: SCAQMD Facility ID: 129661
Title V Permit Revision A/N 515617

Dear Mr. Falbo:

Attached is a Permit Revision to your Title V Facility Permit. This revision includes the following sections:

- Title Page and Table of Contents – Revision # 2, March 6, 2012
- Section A – Revision #2, March 6, 2012
- Section D – Revision #2, March 6, 2012
- Section I – Revision #2, March 6, 2012

The three permit applications included in this permit revision are:

SECTION D: PERMIT TO OPERATE

Appl. No.	Description
515470 & 515471	Landfill gas-fired IC engines #1 & #2 - Change of Conditions : <ul style="list-style-type: none"> • Clarify calculation methods, maximum limit and recordkeeping for the hourly heating value of landfill gas burned in this IC engine. • Add non-resettable elapsed time meter. • Remove air/fuel ratio controller requirement; engine is equipped with a NOx CEMS. • Update VOC & NOx concentration limits based on current Rule 1110.2 requirements. • Add Methane concentration limit based on the current Rule 1150.1 requirement. • Convert RHC, NOx & CO BACT emission limits from gram/bhp-hr to ppmv with no O₂ correction.

SECTION I: PLANS AND SCHEDULES

Appl. No.	Description
486800	<ul style="list-style-type: none"> • New Rule 1110.2 Inspection and Monitoring Plan

SECTION A: FACILITY INFORMATION

Administrative changes to Section A included in this permit revision:

Permit Action	
1	Change the Mailing Address from: 2225 E. 28 th St., Suite 508, Signal Hill, CA 90755 to: 5087 Junction Road, Lockport, NY 14094
2	Change the Responsible Official from: Dean Comand, Division Manager, tel (905) 465-4500 to: Anthony Falbo, Senior Vice President - Operations, tel (716) 439-1004
3	Change the Contact Person from: Paul Ervin, West Coast Operations Manager, tel (562) 424-5830 to: Suparna Chakladar, Vice President, tel (951) 833-4153

The proposed minor permit revision was submitted to EPA Region IX for review on January 20, 2012. No comment was received.

Please review the attached sections carefully. Insert the enclosed sections into your Facility Permit and discard the earlier versions. The operation of your facility is bound by the conditions and/or requirements stated in the facility Permit to Operate. If you determine that there are administrative errors in your Facility Permit, please notify Mr. Jonathan Uhl at (909) 396-2725, or juhl@aqmd.gov, within 30 days of the receipt of your permit.

Sincerely,



Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery and Waste Management Permitting

JC:CT:KM:JU

Attachment: Revised Title V Facility Permit, Sections A, D & I

cc: w/enclosure
Geraldo Rios, EPA Region IX
Compliance
Title V Central File
Title V Application File (515617)