



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 4, 2009

Mr. Gerardo Rios
Chief, Permits Office
US EPA, Region IX- Air 3.
75 Hawthorne Blvd.
San Francisco, CA 94105

Dear Mr. Rios:

Please find the attached revised version of the Disneyland (800189, SIC 7900) Facility Permit. This revision was previously sent to EPA for your review on July 21, 2009. The revised Facility Permit reflects the inclusion of the following equipment approved for Permit to Operate:

Application No.	Equipment	Device no.	Process/System
498054	Space Heater	D266	2
498055	Space Heater	D267	2
498056	Space Heater	D268	2
498057	Space Heater	D269	2
498058	Space Heater	D270	2
498059	Space Heater	D271	2
498060	Space Heater	D272	2
498061	Space Heater	D273	2
498062	Space Heater	D274	2
499580	Pressure Washer	D275	2
499582	Emergency ICE	D276	1

The following equipment will be modified as a Rule 441 Research Permit and added to Section H:

Application No.	Equipment	Device no.	Process/System
500099	Gasoline Storage	D277	4
500099	Gasoline Storage	D278	4
500099	Gasoline Dispensing	D279	4
500099	Gasoline Dispensing	D280	4
500099	Gasoline Dispensing	D281	4
500099	Bulk Loading Arm	D282	4
500099	Bulk Loading Arm	D283	4

Cleaning the air that we breathe...


Mr. Gerardo Rios, U.S. EPA

-2-

September 4, 2009

Insert the enclosed Sections D and H into the Facility Permit and discard the earlier versions. Questions concerning changes to your permit should be directed to Mr. Roy Olivares at (909) 396-2208.

Very truly yours,



Michael D. Mills
Senior Manager
General Commercial & Energy Team
Engineering and Compliance

Attachments
CERTIFIED MAIL



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 4, 2009

Mr. Hao Jiang
Environmental Engineer
Disneyland Resort
P.O. Box 3232
Anaheim, CA 92802

Attention: Mr. Jiang
Facility ID: 800189

Please find attached the revised version of your Facility Permit. The revised Facility Permit reflects the inclusion of the following equipment approved for Permit to Operate:

Application No.	Equipment	Device no.	Process/System
498054	Space Heater	D266	2
498055	Space Heater	D267	2
498056	Space Heater	D268	2
498057	Space Heater	D269	2
498058	Space Heater	D270	2
498059	Space Heater	D271	2
498060	Space Heater	D272	2
498061	Space Heater	D273	2
498062	Space Heater	D274	2
499580	Pressure Washer	D275	2
499582	Emergency ICE	D276	1

The following equipment will be modified as a Rule 441 Research Permit and added to Section H:

Application No.	Equipment	Device no.	Process/System
500099	Gasoline Storage	D277	4
500099	Gasoline Storage	D278	4
500099	Gasoline Dispensing	D279	4
500099	Gasoline Dispensing	D280	4
500099	Gasoline Dispensing	D281	4
500099	Bulk Loading Arm	D282	4
500099	Bulk Loading Arm	D283	4

Cleaning the air that we breathe...

Insert the enclosed Sections D and H into the Facility Permit and discard the earlier versions. Questions concerning changes to your permit should be directed to Mr. Roy Olivares at (909) 396-2208.

Very truly yours,

Michael D. Mills

Michael D. Mills
Senior Manager
General Commercial & Energy Team
Engineering and Compliance

Enclosure
Certified Mail
Return Receipt Requested



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	0	08/03/2007
B	RECLAIM Annual Emission Allocation	2	01/01/2009
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	4	09/04/2009
E	Administrative Conditions	0	08/03/2007
F	RECLAIM Monitoring and Source Testing Requirements	0	08/03/2007
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	0	08/03/2007
H	Permit To Construct and Temporary Permit to Operate	3	09/04/2009
I	Compliance Plans & Schedules	0	08/03/2007
J	Air Toxics	0	08/03/2007
K	Title V Administration	1	06/06/2008
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	0	08/03/2007
B	Rule Emission Limits	1	06/06/2008



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
System 1 : EMERGENCY					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 133DN, WITH TURBOCHARGER, 210 HP A/N: 478422	D1		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.11, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 64DT, WITH TURBOCHARGER, 137 HP A/N: 478423	D2		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.11, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 133DN, 210 HP A/N: 180124	D3		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, D12.1, E71.7, H23.6
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 133DT, WITH TURBOCHARGER, 290 HP A/N: 478424	D4		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.11, D12.1, E71.4, E71.7, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, FORD, MODEL 4DEF4XR1601B, 52 HP A/N: 180129	D5		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, D12.1, E71.7, H23.6
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 64DT, WITH TURBOCHARGER, 137 HP A/N: 478425	D7		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.11, C177.1, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 64DTA, WITH AFTERCOOLER, TURBOCHARGER, 163 HP A/N: 478426	D8		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.11, C177.1, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 133DTA, WITH AFTERCOOLER, TURBOCHARGER, 368 HP A/N: 195818	D10		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.2, C177.1, D12.1, E71.7, H23.6
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 6.4DTA, WITH AFTERCOOLER, TURBOCHARGER, 160 HP A/N: 478430	D12		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.11, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL 3208TA, WITH AFTERCOOLER, TURBOCHARGER, 299 HP A/N: 478431	D15		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.20, C177.1, D12.1, E71.6, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, DETROIT DIESEL, MODEL 40-8.7LT, WITH TURBOCHARGER, 205 BHP A/N: 478432	D95		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.11, C177.1, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL 3508 DITA, WITH AFTERCOOLER, TURBOCHARGER, 1337 BHP A/N: 303611	D98		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.3, C177.1, D12.1, E71.6, H23.6
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, JOHN DEERE, MODEL 6059T, WITH A TURBOCHARGER, 166 BHP A/N: 478433	D99		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.20, C177.1, D12.1, E71.6, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, GENERAC 7.4GN, MODEL CG070, WITH CATALYTIC REDUCTION, 116 HP A/N: 334912	D101		NOX: PROCESS UNIT**	NOX: 37.9 LBS/MMSCF NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-5-2003] ; PM: (9) [RULE 404,2-7-1986]	C1.1, D12.1, H23.12
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP A/N: 344925	D115		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995]	C1.1, D12.1, H23.12, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				<p><i>RULE 2012,4-9-1999</i> ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999] ; PM: (9) [RULE 404,2- 7-1986]</p> <p>ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]</p>	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP A/N: 344926	D116		NOX: PROCESS UNIT**	<p>CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995</p> <p><i>RULE 2012,4-9-1999</i> ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999] ; PM: (9) [RULE 404,2- 7-1986]</p> <p>ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999]</p>	C1.1, D12.1, H23.12, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP A/N: 344927	D117		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 <i>RULE 2012,4-9-1999</i>] ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9-1999] ; PM: (9) [RULE 404,2-7-1986] ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	C1.1, D12.1, H23.12
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP A/N: 344928	D118		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 <i>RULE 2012,4-9-1999</i>] ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, D12.1, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP A/N: 344929	D119		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 RULE 2012,4-9-1999] ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999] ; PM: (9) [RULE 404,2- 7-1986] ROG: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999]	C1.1, D12.1, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3306SITA, NATURAL GAS, RICH BURN, WITH TURBOCHARGER AND AFTERCOOLER, WITH CATALYTIC REDUCTION, 194 BHP A/N: 344913	D120		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995	C1.1, D12.1, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				<i>RULE 2012,4-9-1999</i> ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999] ; PM: (9) [RULE 404,2- 7-1986] ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3304SINA, NATURAL GAS, WITH CATALYTIC REDUCTION, 95 BHP A/N: 344914	D121		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 <i>RULE 2012,4-9-1999</i> ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999] ; PM: (9) [RULE 404,2- 7-1986] ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	C1.1, D12.1, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor
(2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3516SITA, NATURAL GAS, LEAN BURN, WITH TURBOCHARGER AND AFTERCOOLER, 1482 BHP A/N: 344899	D122		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 RULE 2012,4-9-1999] ; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9-1999] ; PM: (9) [RULE 404,2-7-1986] ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	C1.1, D12.1, H23.12
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344933	D123		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 RULE 2012,4-9-1999] ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	C1.1, D12.1, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344934	D124		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 RULE 2012,4-9-1999] ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999] ; PM: (9) [RULE 404,2- 7-1986] ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	C1.1, D12.1, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344935	D125		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995	C1.1, D12.1, H23.12, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				<p><i>RULE 2012,4-9-1999</i> ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999] ; PM: (9) [RULE 404,2- 7-1986]</p> <p>ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]</p>	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344936	D126		NOX: PROCESS UNIT**	<p>CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995</p> <p><i>RULE 2012,4-9-1999</i> ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999] ; PM: (9) [RULE 404,2- 7-1986]</p> <p>ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]</p>	C1.1, D12.1, H23.12, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344937	D127		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 RULE 2012,4-9-1999] ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9-1999] ; PM: (9) [RULE 405,2-7-1986] ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	CI.1, D12.1, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344938	D128		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 RULE 2012,4-9-1999] ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9-1999] ; PM: (9) [RULE 404,2-7-1986]	CI.1, D12.1, H23.12, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344939	D129		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 RULE 2012,4-9-1999] ; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9- 1999] ; PM: (9) [RULE 404,2- 7-1986] ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	C1.1, D12.1, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, GASOLINE, FORD, MODEL LSG-875R-6003-C, WITH CATALYTIC REDUCTION, 193 HP A/N: 359091	D131		NOX: PROCESS UNIT**	CO: 0.6 GRAM/BHP-HR GASOLINE (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 102 LBS/1000 GAL GASOLINE (1) [RULE 2012,12- 7-1995;RULE 2012,4-9-1999]	C1.1, D12.1, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor
(2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				NOX: 0.15 GRAM/BHP-HR GASOLINE (4) [RULE 2005,10-15-1993;RULE 2005,4-9-1999] ; PM: (9) [RULE 404,2-7-1986] ; ROG: 0.15 GRAM/BHP-HR GASOLINE (4) [RULE 1303(a)(1)-BACT,5-10-1996]	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 7.5 DTA, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 184 BHP A/N: 362182	D133		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 264 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 2005,10-15-1993;RULE 2005,4-9-1999] ; PM: (9) [RULE 404,2-7-1986] ; PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996] ROG: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996]	CI.1, D12.1, E71.6, E202.2, H23.6, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CUMMINS, MODEL 800 GTA 500 G3, NATURAL GAS, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 1334 BHP A/N: 360419	D134		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 RULE 2012,4-9-1999] ; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,10-15-1993;RULE 2005,4-9-1999] ; PM: (9) [RULE 404,2-7-1986] ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	C1.1, D12.1, E202.3, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 7.5 DTA, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 184 BHP A/N: 367064	D146		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 264 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,4-9-1999] NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 2005,10-15-1993;RULE 2005,4-9-1999] ; PM: (9) [RULE 404,2-7-1986] ; PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996]	C1.1, D12.1, E71.6, E202.2, H23.6, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				ROG: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996]	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL 3303 ATACC, WITH AFTERCOOLER, TURBOCHARGER, 377 BHP A/N: 378803	D149		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000] ; NOX: 302 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995 RULE 2012,4-9-1999] ; NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000] ; PM: (9) [RULE 404,2-7-1986] PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000] ; ROG: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996 RULE 1303(a)(1)-BACT,10-20-2000]	C1.1, C1.11, D12.1, E71.1, E71.4, H23.6, K67.4

- * (1)(1A)(1B) Denotes RECLAIM emission factor
- (3) Denotes RECLAIM concentration limit
- (5)(5A)(5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits
- (2)(2A)(2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, PARADISE PIER HOTEL, DIESEL FUEL, CUMMINS, MODEL N-855-F, 6 CYLINDERS, FOUR CYCLE, NATURALLY ASPIRATED, SERIAL NO. 1815303, 240 HP A/N: 311603	D152		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,3-16-2001] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.22, D12.1, H23.6
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, PARADISE PIER HOTEL, DIESEL FUEL, CATERPILLAR, MODEL 3508DI, 8 CYLINDERS, INTERCOOLED, SERIAL NO. 28Z00641, WITH TURBOCHARGER, 712 HP A/N: 478427	D153		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,3-16-2001] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.20, C177.1, D12.1, E71.6, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, CUMMINS, MODEL 4BT3.9-G4, 4 CYLINDERS, SERIAL NO. 45901859, WITH TURBOCHARGER, 102 HP A/N: 363159	D159		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,3-16-2001] NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; PM: (9) [RULE 404,2-7-1986] ; PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996]	C1.8, D12.1, E71.6, H23.6, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				ROG: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)- BACT,5-10-1996]	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, CUMMINS, MODEL 6CT8.3G, 6 CYLINDERS, FOUR CYCLE, WITH TURBOCHARGER, 207 HP A/N: 478428	D160		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7- 1995;RULE 2012,3-16-2001] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.11, C177.1, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, CUMMINS, MODEL 6CT8.3G, 6 CYLINDERS, FOUR CYCLE, WITH TURBOCHARGER, 207 HP A/N: 241137	D162		NOX: PROCESS UNIT**	NOX: 2.9 LBS/HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10- 1996] ; NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,3-16- 2001] PM: (9) [RULE 404,2-7-1986] ; ROG: 0.11 LBS/HR DIESEL (4) [RULE 1303(a)(1)-BACT,5- 10-1996]	C177.1, D12.1, E71.6, H23.6, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, CUMMINS, MODEL 6CT8.3G, 6 CYLINDERS, FOUR CYCLE, WITH TURBOCHARGER, 207 HP A/N: 241138	D163		NOX: PROCESS UNIT**	NOX: 2.9 LBS/HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10- 1996] ; NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,3-16- 2001]	C177.1, D12.1, E71.6, H23.6, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				PM: (9) [RULE 404,2-7-1986] ; ROG: 0.11 LBS/HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996]	
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DISNEYLAND HOTEL, DIESEL FUEL, CLARKE GM DIESEL INC, MODEL MD-4-1226, 4 CYLINDERS, SERIAL NO. 47463, 73 HP A/N: 241139	D164		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,3-16-2001] ; PM: (9) [RULE 404,2-7-1986]	C1.8, C1.22, D12.1, H23.6, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, ALLIS-CHALMERS, MODEL 649, 6 CYLINDERS, FOUR CYCLE, SERIAL NO. K820640605, 73 HP A/N: 478429	D168		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,3-16-2001] ; PM: (9) [RULE 404,2-7-1986]	C1.1, C1.20, D12.1, E71.6, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, JOHN DEERE, MODEL 6081A, WITH AFTERCOOLER, TURBOCHARGER, 250 BHP A/N: 397419	D169		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 304 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,3-16-2001]	C1.1, C1.11, D12.1, E71.1, E71.4, H23.6, K67.4

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 2005,4-9-1999;RULE 2005,4-20-2001] ; PM: (9) [RULE 404,2-7-1986] ; PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996] ROG: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996]	
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DIESEL FUEL, CUMMINS, MODEL 6BTA5.9F1, PARADISE PIER HOTEL, WITH AFTERCOOLER, TURBOCHARGER, 182 BHP A/N: 408907	D172		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995;RULE 2012,3-16-2001] NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 2005,4-9-1999;RULE 2005,4-20-2001] ; PM: (9) [RULE 404,2-7-1986] ; PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996] ROG: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; SOX: 15 PPMM DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996]	C1.1, C1.22, D12.1, H23.6, K67.4, K67.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
 (5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, CATERPILLAR, MODEL G3412STIA/450KW, SERIAL NO. 7DM, JOHNSON MATTHEY-MODEL QXC-30-08-NSCR, MODEL EPC-100-CONTROLLER, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 622 BHP A/N: 412302	D173		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995] RULE 2012,3-16-2001] ; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996] ; PM: (9) [RULE 404,2-7-1986] ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996]	C1.1, C1.11, D12.1, E71.1, E202.3, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, CUMMINS, MODEL GTA14 GS/GC 280 KW, WITH NSCR-MIRATECH, MODEL MCS-22Y1515-08-C2, CONTROLLER-MODEL MEC-2001-1LP, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 431 BHP A/N: 419597	D174		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995]	C1.1, C1.11, D12.1, E71.3, E202.3, H23.12, K67.13

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				<p><i>RULE 2012,3-16-2001</i> ; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,4-9-1999;RULE 2005,4-20- 2001] ; PM: (9) [RULE 404,2- 7-1986]</p> <p>ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002]</p>	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, PERKINS, MODEL 1004-40T, WITH TURBOCHARGER, 95.2 BHP A/N: 425385	D175		NOX: PROCESS UNIT**	<p>CO: 3.7 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)- BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002] ; NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7- 1995</p> <p><i>RULE 2012,3-16-2001</i> ; NOX + ROG: 5.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)- BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002;RULE 2005,4-20-2001]</p> <p>PM: 0.3 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)- BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002] ; PM: (9) [RULE 404,2-7-1986]</p>	C1.1, C1.11, D12.1, E71.4, H23.6, K67.14

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, CATERPILLAR, MODEL G3406SITA (250 KW), WITH NSCR, JOHNSON MATTHEY, QXC20, A/F, WOODWARD, MODEL GECO, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 367 BHP A/N: 431660	D176		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-5-2003 RULE 2012,5-6-2005] ; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,4-9-1999] ; PM: (9) [RULE 404,2-7-1986] ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996]	C1.1, C1.11, D12.1, E71.5, E202.3, H23.12, K67.14
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, FORD, MODEL WSG-1068, WITH NSCR, MINE-X, MODEL DC47, NEUTRONIC, MARK V, A/F CONTROLLER, WITH CATALYTIC REDUCTION, TURBOCHARGER, 176 BHP A/N: 436095	D178		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996] ; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995]	C1.1, D12.1, E202.3, H23.12, K67.14

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,4-20-2001] ; PM: (9) [RULE 404,2-7-1986] ; ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996]	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL G3456 DITA AA, WITH AFTERCOOLER, TURBOCHARGER, 685 BHP A/N: 445773	D179		NOX: PROCESS UNIT**	CO: 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002] ; NOX: 221 LBS/1000 GAL DIESEL (1) [RULE 2012,12-5-2003] ; NOX + ROG: 4.8 GRAM/BHP-HR DIESEL (4) [RULE 2005,4-20-2001] ; PM: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470,6-1-2007] ; PM: (9) [RULE 404,2-7-1986] ; PM10: 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002]	C1.1, D12.1, E71.4, E116.1, H23.6, K67.16

- * (1)(1A)(1B) Denotes RECLAIM emission factor
- (3) Denotes RECLAIM concentration limit
- (5)(5A)(5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits
- (2)(2A)(2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL G3456 DITA AA, WITH AFTERCOOLER, TURBOCHARGER, 685 BHP A/N: 445774	D180		NOX: PROCESS UNIT**	CO: 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] ; NOX: 221 LBS/1000 GAL DIESEL (1) [RULE 2012,12-5-2003] ; NOX + ROG: 4.8 GRAM/BHP-HR DIESEL (4) [RULE 2005,4-20-2001] ; PM: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470,6-1-2007] ; PM: (9) [RULE 404,2-7-1986] ; PM10: 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002]	C1.1, D12.1, E71.4, E116.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL G3456 DITA AA, WITH AFTERCOOLER, TURBOCHARGER, 685 BHP A/N: 445775	D181		NOX: PROCESS UNIT**	CO: 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002] ; NOX: 221 LBS/1000 GAL DIESEL (1) [RULE 2012,12-5-2003] ; NOX + ROG: 4.8 GRAM/BHP-HR DIESEL (4) [RULE 2005,4-20-2001] ; PM: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470,6-1-2007].	C1.1, D12.1, E71.4, E116.1, H23.6, K67.16

- * (1)(1A)(1B) Denotes RECLAIM emission factor
- (3) Denotes RECLAIM concentration limit
- (5)(5A)(5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits
- (2)(2A)(2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				PM: (9) [RULE 404,2-7-1986] ; PM10: 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)- BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002]	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, FORD, MODEL ESG-642, WITH NSCR, MODEL L102, WITH AIR FUEL RATIO CONTROLLER, WITH CATALYTIC REDUCTION, 67 BHP A/N: 444735	D182		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] ; NOX: 437 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995 RULE 2012,3-16-2001] ; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] ; PM: (9) [RULE 404,2-7-1986] ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002]	C1.1, D12.1, E71.4, E71.5, H23.12, K67.14
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL 3306ATACC, WITH AFTERCOOLER, TURBOCHARGER, 377 BHP A/N: 445546	D183		NOX: PROCESS UNIT**	CO: 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)- BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002] ; NOX: 209 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7- 1995	C1.1, D12.1, E71.4, E116.1, H23.6, K67.16

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
 (5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				<p><i>RULE 2012,3-16-2001</i>] ; NOX + ROG: 4.8 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002;RULE 2005,4-20-2001</p> <p>RULE 2005,5-6-2005] ; PM: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470,6-1-2007] ; PM: (9) [RULE 404,2-7-1986]</p> <p>PM10: 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002]</p>	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL C-9 DITA, LOCATED AT NEMO SITE, WITH AFTERCOOLER, TURBOCHARGER, 398 BHP A/N: 459428	D223		NOX: PROCESS UNIT**	<p>CO: 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] ; NOX: 136 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005]</p> <p>NOX + ROG: 3 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002;RULE 2005,5-6-2005] ; PM: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470,6-1-2007]</p>	C1.1, C1.11, D12.1, E71.4, E116.1, H23.6, K67.16

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				PM: (9) [RULE 404,2-7-1986] ; PM10: 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)- BACT,5-10-1996;RULE <i>1303(a),12-6-2002]</i>	
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, CATERPILLAR, MODEL G3046 SITA, WITH NSCR,JOHNSON MATTHEY, MODEL QXE 10-8, A/F, GILL MODEL 120, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 367 BHP A/N: 478405	D259		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE <i>1303(a),12-6-2002]</i> ; NOX: 413 LBS/MMSCF NATURAL GAS (1) [RULE 2012,5-6-2005] NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,5-6-2005] ; PM: (9) [RULE 404,2-7-1986] ; ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)- BACT,5-10-1996 <i>RULE 1303(a),12-6-2002]</i>	C1.1, C1.11, D12.1, E71.5, E116.1, E202.3, H23.12, K67.14

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
 (5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, GENERAL MOTORS, MODEL VORTEC 8.1 L POWERTRAIN, WITH NSCR, CLEAN AIR, MODEL CQD0950BCCN40 WITH AIR/FUEL RATIO CONTROLLER, WITH CATALYTIC REDUCTION, TURBOCHARGER, 195 BHP A/N: 499582	D276		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] ; NOX: 390 LBS/MMSCF NATURAL GAS (1) [RULE 2012,5-6-2005] NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005,5-6-2005] ; PM: (9) [RULE 404,2-7-1986] ; ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996 RULE 1303(a),12-6-2002]	C1.1, C1.11, D12.1, E71.5, E202.3, K67.14
System 2 : NON - EMERGENCY					
INTERNAL COMBUSTION ENGINE, NON-EMERGENCY, DIESEL FUEL, JOHN DEERE, MODEL 4045TF275, ON-SITE PORTABLE DRIVING A WOOD CHIPPER, WITH TURBOCHARGER, 115 BHP A/N: 432411	D177		NOX: PROCESS UNIT**	CO: 3.7 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)-BACT,5-10-1996] ; NOX: 188 LBS/1000 GAL DIESEL (1) [RULE 2012,12-7-1995]	C1.12, D12.1, D323.1, K67.15

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION, INDUSTRIAL					
				NOX + ROG: 4.9 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 2005,4-20-2001] ; PM: 0.22 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)- BACT,5-10-1996] PM: (9) [RULE 404,2-7-1986]	
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, EAST UNIT # 2, NATURAL GAS, SUPERIOR, MODEL LND145P, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 12.57 MMBTU/HR WITH A/N: 370698 BURNER, INDUSTRIAL COMBUSTION, MODEL LNDG105, WITH LOW NOX BURNER	D16		NOX: LARGE SOURCE**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 400 PPMV (5) [RULE 1146,11-17-2000] ; NOX: 30 PPMV NATURAL GAS (3) [RULE 2012,12-7-1995 RULE 2012,4-9-1999] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	D12.3, D12.4, H23.4, H23.12
BOILER, WEST UNIT # 2, NATURAL GAS, SUPERIOR, MODEL LND145S, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 9.95 MMBTU/HR WITH A/N: 405301	D17		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 400 PPMV (5) [RULE 1146,11-17-2000] ; NOX: 47.75 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995	D12.4, H23.4, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
 (5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BURNER, INDUSTRIAL COMBUSTION, MODEL LNDG105, WITH LOW NOX BURNER				RULE 2012, 4-9-1999] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	
BOILER, EAST UNIT # 1, NATURAL GAS, SUPERIOR, MODEL LND145P, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 12.57 MMBTU/HR WITH A/N: 370699	D18		NOX: LARGE SOURCE**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 400 PPMV (5) [RULE 1146,11-17-2000] ; NOX: 30 PPMV NATURAL GAS (3) [RULE 2012,12-7-1995] RULE 2012, 4-9-1999] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	D12.3, D12.4, H23.4, H23.12
BURNER, INDUSTRIAL COMBUSTION, MODEL LNDG105, WITH LOW NOX BURNER					
BOILER, WEST UNIT # 1, NATURAL GAS, SUPERIOR, MODEL LND145S, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 9.95 MMBTU/HR WITH A/N: 405302	D19		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 400 PPMV (5) [RULE 1146,11-17-2000] ; NOX: 47.75 LBS/MMSCF NATURAL GAS (1) [RULE 2012,12-7-1995] RULE 2012, 4-9-1999] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	D12.4, H23.4, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BURNER, INDUSTRIAL COMBUSTION, MODEL LNDG105, WITH LOW NOX BURNER					
BOILER, B1, NATURAL GAS, CLEAVER BROOKS, MODEL FLX, WITH LOW NOX BURNER, 8.5 MMBTU/HR WITH A/N: 360389	D135		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000] CO: 400 PPMV (5) [RULE 1146,11-17-2000] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,12-7-1995;RULE 2012,3-16-2001] NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,4-9-1999] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	E202.4, H23.4, H23.12
BURNER, NATURAL GAS, ALZETA, MODEL CSB84					
BOILER, B2, NATURAL GAS, CLEAVER BROOKS, MODEL FLX, WITH LOW NOX BURNER, 8.5 MMBTU/HR WITH A/N: 360386	D137		NOX: PROCESS UNIT**	CO: 400 PPMV NATURAL GAS (5A) [RULE 1146,11-17-2000] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002]	E202.4, H23.4, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BURNER, NATURAL GAS, ALZETA, MODEL CSB84				CO: 2000 PPMV NATURAL GAS (5) [RULE 407,4-2-1982] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,12-7-1995;RULE 2012,3-16-2001] NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,4-9-1999] ; PM: 0.1 GRAINS/SCF NATURAL GAS (5) [RULE 409,8-7-1981]	
BOILER, B3, NATURAL GAS, CLEAVER BROOKS, MODEL FLX, WITH LOW NOX BURNER, 8.5 MMBTU/HR WITH A/N: 360387	D138		NOX: PROCESS UNIT**	CO: 400 PPMV NATURAL GAS (5A) [RULE 1146,11-17-2000] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000] CO: 2000 PPMV NATURAL GAS (5) [RULE 407,4-2-1982] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,12-7-1995;RULE 2012,3-16-2001]	E202.4, H23.4, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BURNER, NATURAL GAS, ALZETA, MODEL CSB84				NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,4-9-1999] ; PM: 0.1 GRAINS/SCF NATURAL GAS (5) [RULE 409,8-7-1981]	
BOILER, B4, NATURAL GAS, CLEAVER BROOKS, MODEL FLX, WITH LOW NOX BURNER, 8.5 MMBTU/HR WITH A/N: 360388	D139		NOX: PROCESS UNIT**	CO: 400 PPMV NATURAL GAS (5A) [RULE 1146,11-17-2000] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000] CO: 2000 PPMV NATURAL GAS (5) [RULE 407,4-2-1982] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,12-7-1995;RULE 2012,3-16-2001] NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,4-9-1999] ; PM: 0.1 GRAINS/SCF NATURAL GAS (5) [RULE 409,8-7-1981]	E202.4, H23.4, H23.12
BURNER, NATURAL GAS, ALZETA, MODEL CSB84					

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
HEATER, CPI, NO. 1, NATURAL GAS, INTERNATIONAL BOILER WORKS, MODEL TH-3, WITH LOW NOX BURNER, 3.8 MMBTU/HR A/N: 457328	D200		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 400 PPMV (5) [RULE 1146.1,5-13-1994] ; NOX: 49.18 LBS/MMSCF NATURAL GAS (1) [RULE 2012,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981] ; PM: (9) [RULE 404,2-7-1986]	D332.1, E17.1, H23.8, H23.12
HEATER, CPI, NO. 2, NATURAL GAS, INTERNATIONAL BOILER WORKS, MODEL TH-3, WITH LOW NOX BURNER, FLUE GAS RECIRCULATION, 3.4 MMBTU/HR WITH A/N: 457329 BURNER, NATURAL GAS, GORDON-PAITT, MODEL LNR10-C20, WITH LOW NOX BURNER, 3.4 MMBTU/HR	D202		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 400 PPMV (5) [RULE 1146,11-17-2000;RULE 1146.1,5-13-1994] ; NOX: 30 PPMV NATURAL GAS (4) [RULE 2005,2-14-1997] NOX: 49.18 LBS/MMSCF NATURAL GAS (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981] ; PM: (9) [RULE 404,2-7-1986]	D332.1, E17.1, H23.8, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PARADISE PIER HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 1, 5 MMBTU/HR WITH A/N: 459430 BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D206		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] CO: 400 PPMV NATURAL GAS (5) [RULE 1146,11-17-2000] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,5-6-2005] ; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	D12.4, H23.4, H23.12
BOILER, PARADISE PIER HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 2, 5 MMBTU/HR WITH A/N: 459431	D207		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002]	D12.4, H23.4, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000				CO: 400 PPMV NATURAL GAS (5) [RULE 1146,11-17-2000] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,5-6-2005] ; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	
BOILER, PARADISE PIER HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 3, 5 MMBTU/HR WITH A/N: 459432	D209		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] CO: 400 PPMV NATURAL GAS (5) [RULE 1146,11-17-2000] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,5-6-2005] ; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	D12.4, H23.4, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000					
BOILER, PARADISE PIER HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 4, 5 MMBTU/HR WITH A/N: 459433	D211		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] CO: 400 PPMV NATURAL GAS (5) [RULE 1146,11-17-2000] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,5-6-2005] ; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	D12.4, H23.4, H23.12
BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000					
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 1, 5 MMBTU/HR WITH A/N: 473755	D214		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002]	C1.13, D12.4, H23.4, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000				CO: 400 PPMV NATURAL GAS (5) [RULE 1146,11-17-2000] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,5-6-2005] ; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 2, 5 MMBTU/HR WITH A/N: 473757	D215		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] CO: 400 PPMV NATURAL GAS (5) [RULE 1146,11-17-2000] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,5-6-2005] ; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	C1.13, D12.4, H23.4, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000					
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 3, 5 MMBTU/HR WITH A/N: 473758	D217		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] CO: 400 PPMV NATURAL GAS (5) [RULE 1146,11-17-2000] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,5-6-2005] ; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	C1.13, D12.4, H23.4, H23.12
BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000					
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 4, 5 MMBTU/HR WITH A/N: 473761	D219		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002]	C1.13, D12.4, H23.4, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000				CO: 400 PPMV NATURAL GAS (5) [RULE 1146,11-17-2000] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,5-6-2005] ; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 5, 5 MMBTU/HR WITH A/N: 473762	D221		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)-BACT,5-10-1996;RULE 1303(a),12-6-2002] CO: 400 PPMV NATURAL GAS (5) [RULE 1146,11-17-2000] ; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012,5-6-2005] ; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	C1.13, D12.4, H23.4, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, LANDA, MODEL VHW 3-700, 0.21 MMBTU/HR A/N: 471806	D224		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, STEAM X, MODEL DELCO, 0.28 MMBTU/HR A/N: 471807	D225		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, STEAM X, MODEL VANGUARD, 0.28 MMBTU/HR A/N: 471808	D226		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 407,4-2-1982]	B59.2, C1.14, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, A&M EQUIPMENT SERVICE, MODEL AMHGD-2003, NO. 1, 0.21 MMBTU/HR A/N: 471809	D227		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, D12.8, K67.18

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, A&M EQUIPMENT SERVICE, MODEL AMHGD-2003, NO. 2, 0.21 MMBTU/HR A/N: 471810	D228		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 1, 0.3 MMBTU/HR A/N: 471811	D229		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 2, 0.3 MMBTU/HR A/N: 471812	D230		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 1, 0.3 MMBTU/HR A/N: 471813	D231		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
 (5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 2, 0.3 MMBTU/HR A/N: 471814	D232		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 3, 0.3 MMBTU/HR A/N: 471816	D233		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 4, 0.3 MMBTU/HR A/N: 471817	D234		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 5, 0.3 MMBTU/HR A/N: 471818	D235		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 6, 0.3 MMBTU/HR A/N: 471820	D236		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 7, 0.3 MMBTU/HR A/N: 471821	D237		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 8, 0.3 MMBTU/HR A/N: 471822	D238		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 9, 0.3 MMBTU/HR A/N: 471823	D239		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 10, 0.3 MMBTU/HR A/N: 471824	D240		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 281, NO. 1, 0.56 MMBTU/HR A/N: 471825	D241		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 281, NO. 2, 0.56 MMBTU/HR A/N: 471826	D242		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 281, NO. 3, 0.56 MMBTU/HR A/N: 471827	D243		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.17, D12.8, K67.18

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 281, NO. 4, 0.56 MMBTU/HR A/N: 471829	D244		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.17, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 281, NO. 6, 0.56 MMBTU/HR A/N: 471831	D246		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 281, NO. 8, 0.56 MMBTU/HR A/N: 471834	D248		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.17, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 281, NO. 9, 0.56 MMBTU/HR A/N: 471835	D249		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, D12.8, K67.18

- * (1)(1A)(1B) Denotes RECLAIM emission factor
- (3) Denotes RECLAIM concentration limit
- (5)(5A)(5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits
- (2)(2A)(2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 247, NO. 1, 0.56 MMBTU/HR A/N: 471836	D250		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 247, NO. 3, 0.56 MMBTU/HR A/N: 471839	D252		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.17, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 247, NO. 4, 0.56 MMBTU/HR A/N: 471840	D253		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 11, 0.3 MMBTU/HR A/N: 478418	D255		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.16, C1.18, D12.8, K67.18

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 12, 0.3 MMBTU/HR A/N: 478419	D256		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.16, C1.18, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 13, 0.3 MMBTU/HR A/N: 478420	D257		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.16, C1.18, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 14, 0.3 MMBTU/HR A/N: 478421	D258		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.16, C1.18, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 3, 0.3 MMBTU/HR A/N: 487371	D262		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 4, 0.3 MMBTU/HR A/N: 487373	D263		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 5, 0.3 MMBTU/HR A/N: 487374	D264		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 6, 0.3 MMBTU/HR A/N: 487375	D265		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.18
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO.1, 0.16 MMBTU/HR A/N: 498054	D266		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.23, D12.8, K67.22

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO. 2, 0.16 MMBTU/HR A/N: 498055	D267		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO.3, 0.16 MMBTU/HR A/N: 498056	D268		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO. 4, 0.16 MMBTU/HR A/N: 498057	D269		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE51, NO. 1, 0.175 MMBTU/HR A/N: 498058	D270		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 409,8-7-1981] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.23, D12.8, K67.22

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE51, NO. 2, 0.175 MMBTU/HR A/N: 498059	D271		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE52, NO. 1, 0.219 MMBTU/HR A/N: 498060	D272		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE52, NO. 2, 0.219 MMBTU/HR A/N: 498061	D273		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE52, NO. 2, 0.219 MMBTU/HR A/N: 498061	D274		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 409,8-7-1981] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	B59.2, C1.23, D12.8, K67.22

* (1)(1A)(1B) Denotes RECLAIM emission factor
 (2)(2A)(2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit
 (4) Denotes BACT emission limit
 (5)(5A)(5B) Denotes command and control emission limit
 (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit
 (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits
 (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL HOT2-1100, NO. 1, 0.16 MMBTU/HR A/N: 499580	D275		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005,5-6-2005] ; PM: 0.1 GRAINS/SCF (5) [RULE 407,4-2-1982]	B59.2, C1.24, D12.8, K67.22
Process 3 : ORGANIC SOLVENT SURFACE COATING					
SPRAY COATING OPERATION, WATER WASH TYPE, WITH SPRAY BOOTH A/N: 12162X	D20			PM: (9) [RULE 404,2-7-1986] ; ROG: (9) [RULE 1107,11-9-2001;RULE 1107,1-6-2006;RULE 1136,6-14-1996;RULE 1171,11-7-2003 RULE 1171,2-1-2008]	D322.2, H23.2, K67.3
SPRAY COATING OPERATION, FLOOR TYPE, WITH 24 EXHAUST FILTERS, EACH 20" X 25" X 2", WITH SPRAY BOOTH A/N: 214087	D21			PM: (9) [RULE 404,2-7-1986] ; ROG: (9) [RULE 1107,11-9-2001;RULE 1107,1-6-2006;RULE 1136,6-14-1996;RULE 1171,11-7-2003 RULE 1171,2-1-2008]	A63.1, B27.4, C6.1, D12.2, D322.1, E175.1, H23.2, K67.2
SPRAY COATING OPERATION, FLOOR TYPE, WITH 21 EXHAUST FILTERS, EACH 20" X 25" X 2", WITH SPRAY BOOTH A/N: 214086	D22			PM: (9) [RULE 404,2-7-1986] ; ROG: (9) [RULE 1107,11-9-2001;RULE 1107,1-6-2006;RULE 1136,6-14-1996;RULE 1171,11-7-2003 RULE 1171,2-1-2008]	A63.1, B27.4, C6.1, D12.2, D322.1, E175.1, H23.2, K67.2

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 3 : ORGANIC SOLVENT SURFACE COATING					
SPRAY COATING OPERATION, AUTOMOTIVE TYPE, WITH 22 EXHAUST FILTERS, EACH 20" X 25" X 2", WITH SPRAY BOOTH A/N: 19482X	D24			PM: (9) [RULE 404,2-7-1986] ; ROG: (9) [RULE 1107,11-9-2001;RULE 1107,1-6-2006;RULE 1136,6-14-1996;RULE 1171,11-7-2003 RULE 1171,2-1-2008]	C6.1, D12.2, D322.1, E175.1, H23.2, K67.2
SPRAY COATING OPERATION, SOLVENT, DISNEYLAND HOTEL, AUTOMOTIVE TYPE, WITH 44 EXHAUST FILTERS, EACH 20" X 25" X 1.5", WITH SPRAY BOOTH A/N: 241140	D165			PM: (9) [RULE 404,2-7-1986] ; ROG: (9) [RULE 1107,11-9-2001;RULE 1107,1-6-2006;RULE 1136,6-14-1996;RULE 1145,2-14-1997 RULE 1145,12-3-2004;RULE 1171,11-7-2003;RULE 1171,2-1-2008]	B27.4, C1.9, C1.10, C6.1, D12.2, D322.1, E175.2, H23.2, K67.2, K67.8
Process 4 : PETROLEUM MARKETING, CONSUMER FLEET FUELING					
System 1 : FUEL STORAGE AND DISPENSING SYSTEMS					
STORAGE TANK, UNDERGROUND, GASOLINE, NOT METHANOL COMPATIBLE, WITH OPW (VR-102-E), 10000 GALS A/N:	D36				D330.1, E193.1, J373.1, K67.20
STORAGE TANK, UNDERGROUND, GASOLINE, NOT METHANOL COMPATIBLE, WITH OPW (VR-102-E), 10000 GALS A/N:	D40				D330.1, E193.1, J373.1, K67.20

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 4 : PETROLEUM MARKETING, CONSUMER FLEET FUELING					
FUEL DISPENSING NOZZLE, BALANCE TYPE PHASE II CONTROL, GASOLINE, WITH BALANCE RETRACTOR (G-70-52-AM), WITH PHASE II VAPOR RECOVERY SYSTEM A/N:	D88				D330.1, E193.2, J110.1, J373.1, K67.20
FUEL DISPENSING NOZZLE, BALANCE TYPE PHASE II CONTROL, GASOLINE, WITH BALANCE RETRACTOR (G-70-52-AM), WITH PHASE II VAPOR RECOVERY SYSTEM A/N:	D89				D330.1, E193.1, E193.2, J110.1, J373.1
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR0201-G), WITH PHASE II VAPOR RECOVERY SYSTEM A/N:	D90				D330.1, E193.1, E193.2, J110.1, J373.1, K67.19
DISPENSE MOBILE FUELER, GASOLINE, FRANZEN-HILL (G-70-193), WITH TWO HEALY 100 JET PUMPS, 400 GALS; WIDTH: 3 FT 8 IN; HEIGHT: 3 FT 10 IN; LENGTH: 7 FT 1 IN A/N: 367066	D147				C1.6, C1.7, E71.2, J110.1, J397.1, K67.6
FUEL DISPENSING NOZZLE, GASOLINE, EQUIPPED WITH PHASE II VAPOR RECOVERY, HEALY, MODEL 400 ORVR A/N: 367066	D148				

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 5 : FABRICATED METALS					
System 1 :					
ABRASIVE BLASTING, OPEN, SAND WITH A/N: 193050 ABRASIVE BLASTING NOZZLE, DIAMETER: 0.375 IN	D44			PM: (9) [RULE 1140,2-1-1980;RULE 1140,8-2-1985;RULE 405,2-7-1986]	D323.1, K67.5
ABRASIVE BLASTING, ROOM, SAND, BAGHOUSE SERVICES, WITH 3000 LB POT, WIDTH: 15 FT 8 IN; HEIGHT: 15 FT 11 IN; LENGTH: 28 FT WITH A/N: 385807 ABRASIVE BLASTING NOZZLE, 2, MAXIMUM WORKING PRESSURE OF 120 PSI, DIAMETER: 0.625 IN	D156	C158		PM: (9) [RULE 404,2-7-1986]	B27.2, K67.11
BAGHOUSE, UNITED AIR SPECIALIST, MODEL SBD24-3, PULSE JET CLEANING, SERIAL NO. 60042645, 7440 SQ.FT.; 24 CARTRIDGE A/N: 385808	C158	D156		PM: (9) [RULE 404,2-7-1986]	C6.2, D12.2, D322.3, D381.1, E102.1, K67.10
ABRASIVE BLASTING, CARBON DIOXIDE (DRY ICE), COLDJET, MODEL 2000, WITH 40 POUND CAPACITY HOPPER WITH A/N: 404957 ABRASIVE BLASTING NOZZLE, 1, WITH A MAX. THROAT AREA OF 0.068 IN2, 140 PSIA	D170			PM: (9) [RULE 1140,2-1-1980;RULE 1140,8-2-1985;RULE 405,2-7-1986]	B59.1, D381.1, H23.5, K67.11

- * (1)(1A)(1B) Denotes RECLAIM emission factor
- (3) Denotes RECLAIM concentration limit
- (5)(5A)(5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits
- (2)(2A)(2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 7 : FABRICATED METALS, MACHINING OPERATIONS					
System 1 :					
PLASMA ARC CUTTER, DUAL CARRIAGE TYPE, WITH A FOUR TORCH CAPACITY A/N: 243063	D48	C49		PM: (9) [RULE 405,2-7-1986]	D323.1
ELECTROSTATIC PRECIPITATOR, TEPCO TRION, MODEL T5200, WITH A 3 H.P. BLOWER A/N: 249015	C49	D48		PM: (9) [RULE 404,2-7-1986]	D323.1, E202.1
Process 8 : SMOKE EFFECTS					
System 1 :					
FILTER, HEPA, FARR A/N: 288923	C96			PM: (9) [RULE 404,2-7-1986]	D322.1, D323.1, K67.2
Process 9 : R-219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECIFIC RULES					
System 1 :					
RULE 219 EXEMPT EQUIPMENT, AIR CONDITIONING UNITS, COMFORT A/C	E102				H23.3
RULE 219 EXEMPT EQUIPMENT, PRINTING EQUIPMENT, WITH RELATED COATING, LAMINATING AND DRYING EQUIPMENT	E104			ROG: (9) [RULE 1130.1,12-13-1996;RULE 1171,11-7-2003;RULE 1171,2-1-2008]	

- * (1)(1A)(1B) Denotes RECLAIM emission factor
- (3) Denotes RECLAIM concentration limit
- (5)(5A)(5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits
- (2)(2A)(2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 9 : R-219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECIFIC RULES					
RULE 219 EXEMPT EQUIPMENT, CLEANING EQUIPMENT, SMALL, UNHEATED, NON-CONVEYORIZED	E105			ROG: (9) [RULE 1171,11-7-2003;RULE 1171,2-1-2008]	H23.1
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS	E107			ROG: (9) [RULE 1113,11-8-1996;RULE 1113,7-13-2007;RULE 1171,11-7-2003;RULE 1171,2-1-2008]	K67.1
RULE 219 EXEMPT EQUIPMENT, HAND LAY, BRUSH AND ROLL UP RESIN OPERATIONS	E108			ROG: (9) [RULE 1162,11-17-2000;RULE 1162,7-8-2005;RULE 1171,11-7-2003;RULE 1171,2-1-2008]	
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, LOW USE OR EMISSIONS	E111			ROG: (9) [RULE 1106.1,2-12-1999;RULE 1171,11-7-2003;RULE 1171,2-1-2008]	
RULE 219 EXEMPT EQUIPMENT, LAMINATING EQUIPMENT, LOW USE OR EMISSIONS	E112			ROG: (9) [RULE 1168,10-3-2003;RULE 1168,1-7-2005;RULE 1171,11-7-2003;RULE 1171,2-1-2008]	
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, LOW USE OR EMISSIONS	E113			ROG: (5) [RULE 1128,3-8-1996;RULE 1171,11-7-2003;RULE 1171,2-1-2008]	

* (1)(1A)(1B) Denotes RECLAIM emission factor
 (2)(2A)(2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit
 (4) Denotes BACT emission limit
 (5)(5A)(5B) Denotes command and control emission limit
 (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit
 (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits
 (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: DEVICE ID INDEX

**The following sub-section provides an index
to the devices that make up the facility
description sorted by device ID.**



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D1	1	1	1
D2	1	1	1
D3	1	1	1
D4	1	1	1
D5	1	1	1
D7	1	1	1
D8	2	1	1
D10	2	1	1
D12	2	1	1
D15	2	1	1
D16	29	2	0
D17	29	2	0
D18	30	2	0
D19	30	2	0
D20	52	3	0
D21	52	3	0
D22	52	3	0
D24	53	3	0
D36	53	4	1
D40	53	4	1
D44	55	5	1
D48	56	7	1
C49	56	7	1
D88	54	4	1
D89	54	4	1
D90	54	4	1
D95	2	1	1
C96	56	8	1
D98	3	1	1
D99	3	1	1
D101	3	1	1
E102	56	9	1
E104	56	9	1
E105	57	9	1
E107	57	9	1
E108	57	9	1



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	Section D Page No.	Process	System
E111	57	9	1
E112	57	9	1
E113	57	9	1
D115	3	1	1
D116	4	1	1
D117	5	1	1
D118	5	1	1
D119	6	1	1
D120	6	1	1
D121	7	1	1
D122	8	1	1
D123	8	1	1
D124	9	1	1
D125	9	1	1
D126	10	1	1
D127	11	1	1
D128	11	1	1
D129	12	1	1
D131	12	1	1
D133	13	1	1
D134	14	1	1
D135	31	2	0
D137	31	2	0
D138	32	2	0
D139	33	2	0
D146	14	1	1
D147	54	4	1
D148	54	4	1
D149	15	1	1
D152	16	1	1
D153	16	1	1
D156	55	5	1
C158	55	5	1
D159	16	1	1
D160	17	1	1
D162	17	1	1



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D163	17	1	1
D164	18	1	1
D165	53	3	0
D168	18	1	1
D169	18	1	1
D170	55	5	1
D172	19	1	1
D173	20	1	1
D174	20	1	1
D175	21	1	1
D176	22	1	1
D177	28	1	2
D178	22	1	1
D179	23	1	1
D180	24	1	1
D181	24	1	1
D182	25	1	1
D183	25	1	1
D200	34	2	0
D202	34	2	0
D206	35	2	0
D207	35	2	0
D209	36	2	0
D211	37	2	0
D214	37	2	0
D215	38	2	0
D217	39	2	0
D219	39	2	0
D221	40	2	0
D223	26	1	1
D224	41	2	0
D225	41	2	0
D226	41	2	0
D227	41	2	0
D228	42	2	0
D229	42	2	0



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D230	42	2	0
D231	42	2	0
D232	43	2	0
D233	43	2	0
D234	43	2	0
D235	43	2	0
D236	44	2	0
D237	44	2	0
D238	44	2	0
D239	44	2	0
D240	45	2	0
D241	45	2	0
D242	45	2	0
D243	45	2	0
D244	46	2	0
D246	46	2	0
D248	46	2	0
D249	46	2	0
D250	47	2	0
D252	47	2	0
D253	47	2	0
D255	47	2	0
D256	48	2	0
D257	48	2	0
D258	48	2	0
D259	27	1	1
D262	48	2	0
D263	49	2	0
D264	49	2	0
D265	49	2	0
D266	49	2	0
D267	50	2	0
D268	50	2	0
D269	50	2	0
D270	50	2	0
D271	51	2	0



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D272	51	2	0
D273	51	2	0
D274	51	2	0
D275	52	2	0
D276	28	1	1



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

F1.1 The operator shall limit the material processed to no more than 2000 lb(s) in any one year.

For the purpose of this condition, material processed shall be defined as 1,1,1 trichloroethane.

[H&S 44300, 7-1-1988]

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 9-11-1998]

F14.2 The operator shall not purchase diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

[RULE 431.2, 5-4-1990; RULE 431.2, 9-15-2000]

F48.1 The operator shall not operate at this facility non chain driven, uncontrolled charbroiler exceeding the opacity limits specified in Rule 401.

[RULE 401, 3-2-1984; RULE 401, 9-11-1998]

DEVICE CONDITIONS

A. Emission Limits



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

A63.1 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
VOC	Less than or equal to 10 LBS IN ANY ONE DAY

[RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D21, D22]

B. Material/Fuel Type Limits

B27.2 The operator shall not use abrasive material (except for abrasive containing nickel) containing any carcinogenic compounds identified in the SCAQMD Rule 1401, as amended 18-aug-2000.

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D156]

B27.4 The operator shall not use materials containing any compounds identified in the SCAQMD Rule 1401, as amended 12/07/1990.

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D21, D22, D165]

B59.1 The operator shall only use the following material(s) in this device :

Diesel fuel

[RULE 1140, 8-2-1985]

[Devices subject to this condition : D170]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

B59.2 The operator shall only use the following material(s) in this device :

diesel fuel or bio-diesel

[**RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]**

[Devices subject to this condition : D224, D225, D226, D227, D228, D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D241, D242, D243, D244, D246, D248, D249, D250, D252, D253, D255, D256, D257, D258, D262, D263, D264, D265, D266, D267, D268, D269, D270, D271, D272, D273, D274, D275]

C. Throughput or Operating Parameter Limits

C1.1 The operator shall limit the operating time to no more than 200 hour(s) in any one year.

[**RULE 1110.2, 6-3-2005; RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 2005, 10-15-1993; RULE 2005, 4-9-1999; RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : D1, D2, D3, D4, D5, D7, D8, D12, D15, D95, D99, D101, D115, D116, D117, D118, D119, D120, D121, D122, D123, D124, D125, D126, D127, D128, D129, D131, D133, D134, D146, D149, D152, D153, D160, D168, D169, D172, D173, D174, D175, D176, D178, D179, D180, D181, D182, D183, D223, D259, D276]

C1.2 The operator shall limit the operating time to no more than 125 hour(s) in any one year.

[**RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996]**

[Devices subject to this condition : D10]

C1.3 The operator shall limit the operating time to no more than 100 hour(s) in any one year.

[**RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996]**

[Devices subject to this condition : D98]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

C1.6 The operator shall limit the gasoline dispensed to no more than 240000 gallon(s) per year.

[RULE 1401, 8-18-2000]

[Devices subject to this condition : D147]

C1.7 The operator shall limit the gasoline dispensed to no more than 20000 gallon(s) in any one calendar month.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition : D147]

C1.8 The operator shall limit the operating time to no more than 199 hour(s) in any one year.

[RULE 1110.2, 6-3-2005; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996]

[Devices subject to this condition : D159, D164]

C1.9 The operator shall limit the coating and solvent usage to no more than 4 gallon(s) per day.

[RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D165]

C1.10 The operator shall limit the coating and solvent usage to no more than 88 gallon(s) per month.

[RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D165]

C1.11 The operator shall limit the maintenance testing to no more than 50 hour(s) in any one year.

[RULE 1303, 10-20-2000; RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1470, 6-1-2007]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D95, D149, D160, D169, D173, D174, D175, D176, D223, D259, D276]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

C1.12 The operator shall limit the operating time to no more than 1092 in any one calendar year.

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D177]

C1.13 The operator shall limit the natural gas fuel usage to no more than 15.569 MM cubic feet in any one calendar month.

The fuel usage limit of 15.569 mmcf/month is the total fuel to be used in the five boilers.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D214, D215, D217, D219, D221]

C1.14 The operator shall limit the operating time to no more than 300 hour(s) in any one month.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005; RULE 2012, 5-6-2005]

[Devices subject to this condition : D224, D225, D226, D227, D228, D229, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D241, D242, D243, D244, D246, D248, D249, D250, D252, D253, D262, D263, D264, D265]

C1.16 The operator shall limit the operating time to no more than 22 hour(s) in any one day.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]

[Devices subject to this condition : D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D255, D256, D257, D258, D262, D263, D264, D265]

C1.17 The operator shall limit the operating time to no more than 12 hour(s) in any one day.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]

[Devices subject to this condition : D243, D244, D248, D252]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

C1.18 The operator shall limit the operating time to no more than 330 hour(s) in any one month.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]

[Devices subject to this condition : D255, D256, D257, D258]

C1.20 The operator shall limit the maintenance testing to no more than 30 hour(s) in any one year.

[RULE 1303, 10-20-2000; RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1470, 6-1-2007]

[Devices subject to this condition : D15, D99, D153, D168]

C1.22 The operator shall limit the maintenance testing to no more than 34 hour(s) in any one year.

[RULE 1470, 6-1-2007]

[Devices subject to this condition : D152, D164, D172]

C1.23 The operator shall limit the operating time to no more than 200 hour(s) in any one calendar month.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D266, D267, D268, D269, D270, D271, D272, D273, D274]

C1.24 The operator shall limit the operating time to no more than 160 hour(s) in any one calendar month.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D275]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

- C6.1 The operator shall use this equipment in such a manner that the differential pressure being monitored, as indicated below, does not exceed 0.25 inches water column.

The operator shall to comply with this condition, monitor the differential pressure as specified in condition D12.2..

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D21, D22, D24, D165]

- C6.2 The operator shall use this equipment in such a manner that the differential pressure being monitored, as indicated below, does not exceed 5 inches water column.

The operator shall to comply with this condition, monitor the differential pressure as specified in condition D12.2..

[RULE 1303, 10-20-2000; RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : C158]

- C177.1 The operator shall set and maintain the fuel injection timing of the engine at 4 degrees retarded relative to standard timing.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : D7, D8, D10, D15, D95, D98, D99, D153, D160, D162, D163]

D. Monitoring/Testing Requirements



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D12.1 The operator shall install and maintain a(n) timer to accurately indicate the elapsed operating time of the engine.

[RULE 1110.2, 6-3-2005; **RULE 1303(b)(1)-Modeling, 5-10-1996**; RULE 1303(b)(1), 10-20-2000; **RULE 1303(b)(2)-Offset, 5-10-1996**; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996**; **RULE 2005, 10-15-1993**; **RULE 2005, 4-9-1999**; **RULE 2012, 12-7-1995**; RULE 2012, 4-9-1999; **RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995**; **RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D1, D2, D3, D4, D5, D7, D8, D10, D12, D15, D95, D98, D99, D101, D115, D116, D117, D118, D119, D120, D121, D122, D123, D124, D125, D126, D127, D128, D129, D131, D133, D134, D146, D149, D152, D153, D159, D160, D162, D163, D164, D168, D169, D172, D173, D174, D175, D176, D177, D178, D179, D180, D181, D182, D183, D223, D259, D276]

D12.2 The operator shall install and maintain a(n) differential pressure gauge to accurately indicate the differential pressure across the filter.

[RULE 1303, 10-20-2000; **RULE 1303(a)(1)-BACT, 5-10-1996**]

[Devices subject to this condition : D21, D22, D24, C158, D165]

D12.3 The operator shall install and maintain a(n) flow meter to accurately indicate the flue gas flow in the flue gas recirculation system.

For the purpose of this condition a flue gas flow regulator that indicates the percent open setting in the FGR system may be used instead of a flow meter.

[**RULE 1303(a)(1)-BACT, 5-10-1996**]

[Devices subject to this condition : D16, D18]

D12.4 The operator shall install and maintain a(n) non-resettable totalizing fuel flow meter to accurately indicate the fuel usage of the equipment.

[**RULE 2012, 12-7-1995**; RULE 2012, 4-9-1999]

[Devices subject to this condition : D16, D17, D18, D19, D206, D207, D209, D211, D214, D215, D217, D219, D221]



FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D12.8 The operator shall install and maintain a(n) timer to accurately indicate the elapsed operating time from the pressure washer.

[**RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005; RULE 2012, 5-6-2005**]

[Devices subject to this condition : D224, D225, D226, D227, D228, D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D241, D242, D243, D244, D246, D248, D249, D250, D252, D253, D255, D256, D257, D258, D262, D263, D264, D265, D266, D267, D268, D269, D270, D271, D272, D273, D274, D275]

D322.1 The operator shall perform a weekly inspection of the equipment and filter media for leaks, broken or torn filter media, and improperly installed filter media.

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D21, D22, D24, C96, D165]

D322.2 The operator shall perform a weekly inspection to check for the water wash integrity.

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D20]

D322.3 The operator shall perform annual inspection of the equipment and filter media for leaks, broken or torn filter media, and improperly installed filter media.

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : C158]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D323.1 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on a semi-annual basis, at least, unless the equipment did not operate during the entire semi-annual period. The routine semi-annual inspection shall be conducted while the equipment is in operation and during daylight hours.

If any visible emissions (not including condensed water vapor) are detected that last more than three minutes in any one hour, the operator shall verify and certify within 24 hours that the equipment causing the emission and any associated air pollution control equipment are operating normally according to their design and standard procedures and under the same conditions under which compliance was achieved in the past, and either:

- 1). Take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit; or
- 2). Have a CARB-certified smoke reader determine compliance with the opacity standard, using EPA Method 9 or the procedures in the CARB manual "Visible Emission Evaluation", within three business days and report any deviations to AQMD.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

- 1). Stack or emission point identification;
- 2). Description of any corrective actions taken to abate visible emissions;
- 3). Date and time visible emission was abated; and
- 4). All visible emission observation records by operator or a certified smoke reader.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : D44, D48, C49, C96, D177]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D330.1 The operator shall have a person that has been trained in accordance with Rule 461 conduct a semi-annual inspection of the gasoline transfer and dispensing equipment. The first inspection shall be in accordance with Rule 461, Attachment B, the second inspection shall be in accordance with Rule 461, Attachment C, and the subsequent inspections shall alternate protocols. The operator shall keep records of the inspection and the repairs in accordance to Rule 461 and Section K of this Permit.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : D36, D40, D88, D89, D90]

D332.1 The operator shall determine compliance with the CO emission limit(s) by conducting a test at least once every five years using a portable analyzer and AQMD-approved test method or, if not available, a non-AQMD approved test method. The test shall be conducted when the equipment is operating under normal conditions to demonstrate compliance with Rule 1146.1 concentration limit. The operator shall comply with all general testing, reporting, and recordkeeping requirements in Sections E and K of this permit.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : D200, D202]

D381.1 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on an annual basis, at least, unless the equipment did not operate during the entire annual period. The routine annual inspection shall be conducted while the equipment is in operation and during daylight hours. If any visible emissions (not including condensed water vapor) are detected, the operator shall take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

- 1). Stack or emission point identification;
- 2). Description of any corrective actions taken to abate visible emissions; and
- 3). Date and time visible emission was abated.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : C158, D170]

E. Equipment Operation/Construction Requirements



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E17.1 The operator shall not use more than 1 of the following items simultaneously:

Device ID: D200 [Heater]

Device ID: D202 [Heater]

[RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D200, D202]

E71.1 The operator shall only operate this equipment during emergencies resulting in an interruption of service of the primary power supply or during stage II or III electrical emergency declared by the California Independent system operator (in addition to maintenance and testing of this engine)..

[RULE 1303, 10-20-2000; RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : D149, D169, D173]

E71.2 The operator shall only operate this equipment using the manufacturers recommendation for the installation, operation and maintenance of the phase one and phase two vapor recovery equipment. The manufacturers manuals shall be readily accessible on site and made available to District representatives upon request.

[RULE 461, 6-3-2005]

[Devices subject to this condition : D147]

E71.3 The operator shall only operate this equipment during operation beyond 50 hours per year for maintenance and testing is allowed only in the event of loss of grid power or up to 30 minutes prior to a rotating outage provided that: 1) the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time; and 2) the engine is located in a utility service block that is subject to the rotating outage.

[RULE 1303, 10-20-2000; RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : D174]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

- E71.4 The operator shall only operate this equipment during operation beyond 50 hours per year for maintenance and testing is allowed only in the event of loss of grid power or up to 30 minutes prior to a rotating outage provided that: 1) the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time; and 2) the engine is located in a utility service block that is subject to the rotating outage.

Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470, 6-1-2007]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D95, D149, D160, D169, D175, D179, D180, D181, D182, D183, D223]

- E71.5 The operator shall only operate this equipment during operation beyond 50 hours per year, this engine shall only operate during emergencies resulting in an interruption of service of the primary power supply or during stage II or III electrical emergency declared by the electrical grid operator. Operators may use this engine as part of interruptible electrical service program.

An interruptible electric service program is a program in which the facility receives payment or reduced rate in return for a requirement to reduce its electric load on the grid when requested to do so by the utility, the grid operator, or other organization.

[RULE 1303(a)-BACT, 5-10-1996]

[Devices subject to this condition : D176, D182, D259, D276]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

- E71.6 The operator shall only operate this equipment during operation beyond 30 hours per year for maintenance and testing is allowed only in the event of loss of grid power or up to 30 minutes prior to a rotating outage provided that: 1) the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time; and 2) the engine is located in a utility service block that is subject to the rotating outage.

Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470, 6-1-2007]

[Devices subject to this condition : D15, D98, D99, D133, D146, D153, D159, D162, D163, D168]

- E71.7 The operator shall only operate this equipment during operation beyond 20 hours per year for maintenance and testing is allowed only in the event of loss of grid power or up to 30 minutes prior to a rotating outage provided that: 1) the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time; and 2) the engine is located in a utility service block that is subject to the rotating outage.

Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470, 6-1-2007]

[Devices subject to this condition : D3, D4, D5, D10]

- E102.1 The operator shall discharge dust collected in this equipment only into closed containers.

[RULE 1303, 10-20-2000; RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : C158]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E116.1 This engine shall not be used as part of a demand response program using interruptible service contract in which a facility receives a payment or reduced rates in return for reducing its electric load on the grid when requested to do so by the utility or the grid operator.

[RULE 1303(a)-BACT, 5-10-1996; RULE 1303(a), 12-6-2002; RULE 1470, 6-1-2007]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D15, D95, D99, D153, D160, D168, D179, D180, D181, D183, D223, D259]

E175.1 The operator shall not use this equipment unless all exhaust air passes through the following:

filter media at least 2 inches thick

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D21, D22, D24]

E175.2 The operator shall not use this equipment unless all exhaust air passes through the following:

filter media at least 1.5 inches thick

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D165]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E193.1 The operator shall operate and maintain this equipment as follows:

ALL PERMIT CONDITIONS APPLICABLE TO THE EQUIPMENT DESCRIBED IN THE PREVIOUS PERMIT TO OPERATE N15788 SHALL REMAIN IN EFFECT UNTIL THE NEW OR MODIFIED EQUIPMENT IS CONSTRUCTED AND OPERATED AS DESCRIBED IN THIS NEW PERMIT. THIS PERMIT TO CONSTRUCT/OPERATE SHALL BECOME INVALID IF THE MODIFICATION AS DESCRIBED IN THE EQUIPMENT DESCRIPTION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE. IF THE MODIFICATION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE OF THE PERMIT

A WRITTEN REQUEST SHALL BE SUBMITTED TO THE AQMD (ATTENTION: RANDY MATSUYAMA) TO REINSTATE THE PREVIOUSLY INACTIVATED PERMIT TO OPERATE. A NEW APPLICATION SHALL BE FILED IF THERE ARE PLANS TO CONTINUE WITH THE MODIFICATION. FURTHERMORE, THIS CONDITION DOES NOT ALLOW ANY TIME EXTENSIONS TO ANY MODIFICATIONS REQUIRED BY THE CALIFORNIA AIR RESOURCES BOARD OR AQMD

[RULE 461, 3-7-2008]

[Devices subject to this condition : D36, D40, D89, D90]

E193.2 The operator shall operate and maintain this equipment as follows:

ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS

[RULE 461, 3-7-2008]

[Devices subject to this condition : D88, D89, D90]

E202.1 The operator shall clean and maintain this equipment according to the following specifications:

Thoroughly clean the ionizers and collector cells quarterly

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : C49]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E202.2 The operator shall clean and maintain this equipment according to the following specifications:

the diesel catalyst shall be inspected once every calendar year and cleaned, if necessary. If cleaning is necessary, all loose soot deposits shall be removed and the catalyst shall be washed according to manufacturers specifications

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D133, D146]

E202.3 The operator shall clean and maintain this equipment according to the following specifications:

the engine shall not be operated without the use of an automatic air to fuel ratio controller which shall be maintained and kept in proper operating conditions at all times as specified by the manufacturer

the catalytic converter temperature and exhaust oxygen concentration shall be maintained within the effective operating range of the catalytic converter as specified by the manufacturer

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 2005, 10-15-1993; RULE 2005, 4-9-1999]

[Devices subject to this condition : D134, D173, D174, D176, D178, D259, D276]

E202.4 The operator shall clean and maintain this equipment according to the following specifications:

Records shall be maintained of inspections and maintenance of the burners

The operator shall follow the procedures specified by the manufacturer to tune-up and maintain the combustion system (including but not limited to the burner and air/fuel control device) of this heater

Manufacturers maintenance procedures shall be kept by the operator and made available at the request of AQMD

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 2005, 4-9-1999]

[Devices subject to this condition : D135, D137, D138, D139]

H. Applicable Rules



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

H23.1 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	1122

[~~RULE 1122~~, 10-1-2004]

[Devices subject to this condition : E105]

H23.2 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	109
PM	District Rule	481

[~~RULE 109~~, 5-2-2003; ~~RULE 481~~, 1-11-2002]

[Devices subject to this condition : D20, D21, D22, D24, D165]

H23.3 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Refrigerants	District Rule	1415
Refrigerants	40CFR82, SUBPART	F

[~~RULE 1415~~, 10-14-1994; ~~40CFR 82 Subpart F~~, 5-14-1993]

[Devices subject to this condition : E102]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

H23.4 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
CO	District Rule	1146

This CO emissions (concentration) shall be tested at least once per year per Rule 1146 (d)(6).

[RULE 1146, 11-17-2000]

[Devices subject to this condition : D16, D17, D18, D19, D135, D137, D138, D139, D206, D207, D209, D211, D214, D215, D217, D219, D221]

H23.5 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM	District Rule	1140

[RULE 1140, 2-1-1980; RULE 1140, 8-2-1985]

[Devices subject to this condition : D170]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

H23.6 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM	District Rule	1470

[RULE 1470, 6-1-2007]

[Devices subject to this condition : D1, D2, D3, D4, D5, D7, D8, D10, D12, D15, D95, D98, D99, D133, D146, D149, D152, D153, D159, D160, D162, D163, D164, D168, D169, D172, D175, D179, D180, D181, D183, D223]

H23.8 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
CO	District Rule	1146.1

[RULE 1146.1, 5-13-1994]

[Devices subject to this condition : D200, D202]

H23.11 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM	District Rule	1472

[RULE 1472, 3-7-2008]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D15, D95, D99, D153, D160, D168]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

H23.12 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
SOX	District Rule	431.1

[RULE 431.1, 6-12-1998]

[Devices subject to this condition : D16, D17, D18, D19, D101, D115, D116, D117, D118, D119, D120, D121, D122, D123, D124, D125, D126, D127, D128, D129, D134, D135, D137, D138, D139, D173, D174, D176, D178, D182, D200, D202, D206, D207, D209, D211, D214, D215, D217, D219, D221, D259]

J. Rule 461

J110.1 The operator shall use, except for diesel transfer, the phase II vapor recovery system in full operation whenever gasoline from this equipment is dispensed to motor vehicles as defined in Rule 461. This system shall be installed, operated and maintained to meet all CARB certification requirements.

[RULE 461, 3-7-2008]

[Devices subject to this condition : D88, D89, D90, D147]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

J373.1 The operator shall comply with the following gasoline transfer and dispensing requirements:

a). At least seventy-two (72) hours prior to back-filling any underground storage tank or piping, the SCAQMD shall be notified by e-mail at r461backfill@aqmd.gov or by facsimile at telephone number (909) 396-3606. Such notification shall include the name of the owner or operator; the name of the contractors; the location of the facility; and the scheduled start and completion dates of the back-filling procedure. The backfilling procedure shall not commence until inspected by a District representative.

b). As required by AQMD Rule 461 or CARB Executive Order, a static pressure leak decay test shall be conducted to demonstrate that the storage tanks, the remote and/or nozzle vapor recovery check valves, associated vapor return piping and fittings are free from vapor leaks. The test shall be conducted in accordance with CARB Test Procedure Method TP-201.3. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of the test.

The AQMD shall be notified by e-mail at R461testing@aqmd.gov or by facsimile at telephone number (909) 396-3606 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractors; the location of the facility; and the scheduled start and completion dates of the static pressure leak decay test.

c). Depending on the system configuration, a pressure integrity test of the drop tube/drain valve assembly shall be conducted to quantify the pressure integrity of both the drop tube and drain valve seal or a pressure integrity test of the drop tube overflow prevention device and spill container drain and the pressure integrity of the spill container drain valve. Either test shall be conducted as a reverification test and the test shall be conducted in accordance with test procedure method TP-201.1C or TP-201.1D, respectively. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of the test.

The AQMD shall be notified by e-mail at r461testing@aqmd.gov or by facsimile at (909) 396-2606 at least 72 hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractor; the location of the facility; and the scheduled start and completion dates of the of the pressure integrity test of drop tube/drain valve assembly or pressure integrity test of the drop tube overflow prevention device and spill container drain valve.

d). A leak rate and cracking pressure test of pressure/vacuum relief vent valves shall be conducted within thirty (30) days after the start of operation of the (add type) Phase I EVR equipment and at least once every three (3) years thereafter to determine the pressure and vacuum at which the pressure/vacuum vent valve actuates, and to determine the volumetric leak rate at a given pressure. The test shall be conducted in accordance with the test procedure method TP-201.1E. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of test. This test result shall be kept on site for three (3) years and made available to district representatives upon request.

The AQMD shall be notified by e-mail at r461testing@aqmd.gov or by facsimile at (909) 396-2606 at least 72 hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractor; the location of the facility; and the scheduled start and completion dates of the leak rate and cracking pressure of pressure/vacuum relief vent valves test.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

e). A static torque test of rotatable Phase I adaptors shall be conducted as a reverification test to quantify the amount of static torque required to start the rotation of the rotatable Phase I adaptors. The test shall be conducted in accordance with the test procedure method outlined in TP-201-1B.. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of the test.

The AQMD shall be notified by e-mail at r461testing@aqmd.gov or by facsimile at (909) 396-2606 at least 72 hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractor; the location of the facility; and the scheduled start and completion dates of the static torque test of rotatable Phase I adaptors.

f). The Phase II vapor recovery systems shall be installed, operated, and maintained such that the maximum allowable pressure through the system including nozzle, vapor hose, swivels, and underground piping does not exceed the dynamic back pressures described by the California Air Resources Board (CARB) Executive Order by which the system was certified:

Nitrogen Flowrates (CFH)	Dynamic Back Pressure (Inches of Water)
60	0.35
80	0.62

As required by AQMD Rule 461 or CARB Executive Order, dynamic back pressure tests shall be conducted to determine the Phase II system vapor recovery back pressures. The tests shall be conducted in accordance with CARB Test Procedure Method TP-201.4. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of the test.

The AQMD shall be notified by e-mail at R461testing@aqmd.gov or by facsimile at telephone number (909) 396-3606 at least seventy two (72) hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractors; the location of the facility; and the scheduled start and completion dates of the dynamic back pressure test.

The test shall be conducted as frequently as that required by the most recent amendment to Rule 461 or CARB Executive Order requirements, whichever is more stringent.

g). If the CARB Executive Order requires the installation of a liquid removal device, a liquid removal rate test shall be conducted to demonstrate the removal of gasoline from the vapor passage of the coaxial hose. The test shall be conducted within thirty days of initial installation and in accordance with CARB test procedure Method TP-201.6. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of the test.

The AQMD shall be notified by e-mail at r461testing@aqmd.gov or by facsimile at telephone number (909) 396-3606 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractors; the location of the facility; and the scheduled start and completion dates of the liquid removal rate test.

The testing frequency for the above mentioned tests shall be conducted in accordance with the most recent AQMD Rule 461 amendment or CARB Executive Order requirements, whichever is more stringent.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

All records and test results that are required to be maintained by Rule 461 shall be kept on site and made available to AQMD representatives upon request.

[RULE 461, 3-7-2008]

[Devices subject to this condition : D36, D40, D88, D89, D90]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

J397.1 The operator shall comply with the following CARB Executive Order G-70-193:

1. The owner or operator of this equipment shall conduct a physical inspection of the equipment and manually monitor the system gauge levels during gasoline dispensing on a daily operating basis per site. The equipment shall operate within the following gauge levels:

- | | |
|------------------------------|--------------------|
| a) Vapor return line vacuum: | 35" to 65" wc |
| b) Gasoline supply pressure: | 27 psig to 35 psig |
| c) Cargo tank pressure: | less than 18" wc |

All physical inspections and gauge observations shall be recorded in a systems log and be kept on board the mobile fueler at all times.

2. If a violation of the gauge ranges specified in conditions 1a, 1b, or 1c occurs, the owner or operator of this equipment shall:

- Record the date, time period, and fuel totalizing meter reading when the system first began to fail to operate within the specified range.
- Record the date and time that contact was made with an authorized representative to have the system inspected and repaired.
- Record the date and time that the authorized representative inspected the system, provide a written description of the repairs performed, and record the fuel totalizing meter reading.

3. This equipment shall cease all gasoline dispensing operations when any one of the following conditions occur:

- One of the jet pumps is disabled;
- Failing to achieve the minimum operating vacuum of 35" wc within five seconds after the system has been activated for three consecutive dispensing episodes;
- A vacuum level below 15" wc for more than three seconds after the system has reached 35" wc;
- A vacuum level above 85" wc during a dispensing episode to non-ORVR vehicles;
- Except during testing operations, a closed valve at the vapor return line connection to each jet pump;
- A pressure in the cargo tank headspace exceeding 18" wc for more than five minutes (accumulated) during any sixty minute gasoline dispensing period;
- Except during repair operations, an open drain valve in the liquid drop out pot;
- Except during testing operations, a closed drain valve at the liquid drop out pot in the liquid removal



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

line;

- i) Any observation of breaks, cracks, or holes in the tank insulation, which affects the insulating properties or durability of the insulation;
 - j) The accumulated length of all tears of the nozzle boot (including rips, slits, cracks, etc.) exceeds 0.5" in length; or
 - k) The faceplate and fill pipe interface cannot achieve a seal of at least 25 percent of the accumulated circumference of the faceplate.
4. Within thirty (30) days of initial operation and at least once every twelve months from the previous test, a vapor return line vacuum integrity test shall be conducted and pass in accordance with Exhibit 3 of CARB Executive Order G-70-193. Results shall be submitted to the AQMD, Office of Engineering and Compliance, within forty-eight (48) hours of test.

The AQMD shall be notified at telephone number (909) 396-3886 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator of this equipment; the name of the testing contractor; the location of the mobile fueler; and the scheduled start and completion dates of the vapor return line vacuum integrity test.

5. Within thirty (30) days of initial operation and at least once every twelve months from the previous test, a fill pipe pressure regulation fueling test shall be conducted and pass in accordance with Exhibit 4 of CARB Executive Order G-70-193. Results shall be submitted to the AQMD, Office of Engineering and Compliance, within forty-eight (48) hours of test.

The AQMD shall be notified at telephone number (909) 396-3886 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator of this equipment; the name of the testing contractor; the location of the mobile fueler; and the scheduled start and completion dates of the fill pipe pressure regulation fueling test.

6. Within thirty (30) days of initial operation and at least once every twelve months from the previous test, a ten gallon per minute flowrate limitation test shall be conducted and pass in accordance with Exhibit 5 of CARB Executive Order G-70-193. Results shall be submitted to the AQMD, Office of Engineering and Compliance, within forty-eight (48) hours of test.

The AQMD shall be notified at telephone number (909) 396-3886 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator of this equipment; the name of the testing contractor; the location of the mobile fueler; and the scheduled start and completion dates of the ten gallon per minute limitation test.

7. The individual and company performing any maintenance on any part of the vapor recovery system shall provide at a minimum for the owner or operator of the mobile fueler, a chronological record consisting of the following information for the mobile fueler's maintenance log. The date of service, name of maintenance technician, a contact phone number, a description of and location of any equipment replaced including appropriate test results, and a description of the system problems repaired.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

9. Except for necessary inspections due to equipment failures, and for scheduled maintenance and repairs; the mobile fueler dome hatch shall remain closed and latched at all times. Furthermore, the mobile fueler dome hatch shall remain closed and latched until the head space pressure is less than 2" wc.
8. A current CARB certification decal shall be displayed on the mobile fueler in a manner approved by the executive officer.
10. All physical inspection and gauge observation records; all test results; and all maintenance records as required by this CARB Executive Order shall be prepared, shall be retained for two years, and shall be kept within the mobile fueler and made available to district representatives upon request.

[RULE 461, 3-7-2008]

[Devices subject to this condition : D147]

K. Record Keeping/Reporting

K67.1 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

For architectural applications where no thinners, reducers, or other VOC containing materials are added, maintain semi-annual records for all coating consisting of (a) coating type, (b) VOC content as supplied in grams per liter (g/l) of materials for low-solids coatings, (c) VOC content as supplied in g/l of coating, less water and exempt solvent, for other coatings.

For architectural applications where thinners, reducers, or other VOC containing materials are added, maintain daily records for each coating consisting of (a) coating type, (b) VOC content as applied in grams per liter (g/l) of materials used for low-solids coatings, (c) VOC content as applied in g/l of coating, less water and exempt solvent, for other coatings.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : E107]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.2 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the filter

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : D21, D22, D24, C96, D165]

K67.3 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the water wash

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : D20]

K67.4 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

date of operation, elapsed time in hours, and reason for operation.

[RULE 1110.2, 6-3-2005; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 2005, 10-15-1993; RULE 2005, 4-9-1999]

[Devices subject to this condition : D115, D116, D119, D124, D125, D126, D127, D128, D129, D131, D133, D134, D146, D149, D159, D162, D163, D164, D169, D172, D173]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.5 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Purchase records of abrasive used or daily records of abrasives used and evidence of ARB certification

If abrasives are re-used, records to demonstrate that such abrasives are tested with CARB Method 371-A

Daily records of the description of items blasted to demonstrate compliance

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : D44]

K67.6 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

All maintenance, monthly and annual gasoline dispensed records, shall be prepared, shall be retained for five years, and shall be kept within the mobile fueler and made available to District representatives upon request.

All daily inspection records shall be completed immediately after the daily inspection.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000; RULE 461, 3-7-2008]

[Devices subject to this condition : D147]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.8 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

The operator shall keep records in accordance with the requirements of rule 109 (record keeping for volatile organic compound emissions). Such records shall be retained for a period of three years and shall be made available to any district representative upon request.

Within 14 calendar days after the end of each month, the operator shall total and record VOC emissions for the month from all permitted equipment covered by the monthly limit. The record shall include any procedures used to account for control device efficiencies and/or waste disposal. It shall be signed and certified for accuracy by the highest ranking individual responsible for operation of equipment subject to the permit.

The operator shall maintain a single list which includes only the name and address of each person from whom the facility acquired VOC-containing material regulated by the district that was used or stored at the facility during the preceding 12 months.

The operator shall retain all purchase invoices for all VOC-containing material used or stored at the facility, and all waste manifest for all waste VOC containing material removed from the facility, for 36 months.

[RULE 109, 5-2-2003; RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D165]

K67.10 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the baghouse

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : C158]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.11 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

copy of MSDS shall be kept for the abrasive material used in this equipment

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D156, D170]

K67.12 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

MSDS for the diesel fuel used in this equipment

[RULE 1303(a)(1)-BACT, 5-10-1996]

[Devices subject to this condition : D172]

K67.13 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

The log shall list the date of operation, the timer reading in hours at the beginning and end of operation, and the reason for operation. The total hours of operation (include hours for manual and automatic operation) shall be recorded sometime during the first 15 days of January of each year.

[RULE 1110.2, 6-3-2005; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 2005, 10-15-1993; RULE 2005, 4-9-1999]

[Devices subject to this condition : D174]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.14 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

An engine operating log shall be kept and maintained on file to record when this engine is started manually. The log shall list the date of operation, the timer reading in hours at the beginning and end of operation, and the reason for operation for a minimum of five calendar years prior to the current year and made available to District personnel upon request. The total hours of operation (include hours for manual and automatic operation) shall be recorded sometime during the first 15 days of January.

[RULE 1110.2, 6-3-2005; **RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1303(b)(2)-Offset, 12-6-2002; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996**; **RULE 2005, 4-20-2001**]

[Devices subject to this condition : D175, D176, D178, D182, D259, D276]

K67.15 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

The hours of operation per year.

[**RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1401, 12-7-1990]

[Devices subject to this condition : D177]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.16 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

An engine operating log shall be maintained which on a monthly basis shall include manual and automatic operation and shall list all engine operations in each of the following areas:

EMERGENCY USE HOURS OF OPERATION.

MAINTENANCE AND TESTING HOURS.

OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION).

In addition, each time the engine is started manually, the log shall include the date of operation and the timer reading in hours at the beginning and end of operation. The log shall be kept for a minimum of three calendar years prior to the current year and made available to District personnel upon request. The total hours of operation for the previous calendar year shall be recorded sometime during the first 15 days of January of each year.

[RULE 1110.2, 6-3-2005; **RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1303(b)(2)-Offset, 12-6-2002; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996**; RULE 1470, 6-1-2007; **RULE 2005, 4-20-2001**]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D15, D95, D99, D153, D160, D168, D179, D180, D181, D183, D223]

K67.18 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Operating time records as required per conditons C1.14, C1.16, C1.17 and C1.18

The records shall be kept for at least five years and made available to District personnel upon request

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]

[Devices subject to this condition : D224, D225, D226, D227, D228, D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D241, D242, D243, D244, D246, D248, D249, D250, D252, D253, D255, D256, D257, D258, D262, D263, D264, D265]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.19 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

IN ACCORDANCE WITH RULE 461(j), THE OWNER/OPERATOR SHALL ADHERE TO THE FOLLOWING TASK COMPLETEION DATES AS SUBMITTED ON FORM 461-CP:

COMPLETE PERMIT APPLICATION PACKAGES TO ALL APPLICABLE GOVERNMENT AGENCIES NO LATER THAN 8/15/08

PURCHASE ORDER FOR CARB CERTIFIED PHASE II EVR SYSTEM NO LATER THAN 8/30/08

SIGN CONTRACT FOR INSTALLATION OF CARB CERTIFIED PHASE II EVER SYSTEM NO LATER THAN 8/11/2008

SIGN CONTRACT FOR TESTING OF CARB CERTIFIED PHASE II EVR SYSTEM NO LATER THAN 8/11/2008

START DATE OF EQUIPMENT INSTALLATION NO LATER THAN 11/15/2008

START DATE OF TESTING PHASE II EVR SYSTEM NO LATER THAN 12/30/2008

[RULE 461, 3-7-2008]

[Devices subject to this condition : D90]

K67.20 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE FOR FIVE YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

[RULE 461, 3-7-2008]

[Devices subject to this condition : D36, D40, D88]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.22 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Operating time records as required per conditions C1.23 and C1.24.

The records shall be kept for at least five years and made available to District personnel upon request

[~~RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002~~]

[Devices subject to this condition : D266, D267, D268, D269, D270, D271, D272, D273, D274, D275]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2 : EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
HEATER, CPI, NO. 1, NATURAL GAS, FULTON, MODEL FT0400-C, WITH LOW NOX BURNER, 5.128 MMBTU/HR A/N: 478416 Permit to Construct Issued: 06/03/08	D260		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002] CO: 400 PPMV (5) [RULE 1146,11-17-2000] ; NOX: 24.57 LBS/MMSCF NATURAL GAS (1) [RULE 2012,5-6-2005] ; NOX: 20 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981] ; PM: (9) [RULE 404,2-7-1986]	C1.19, C1.21, D12.4, D29.1, D29.2, E202.4, H23.9, H23.12
HEATER, CPI, NO. 2, NATURAL GAS, FULTON, MODEL FT0400-C, WITH LOW NOX BURNER, 5.128 MMBTU/HR A/N: 478417 Permit to Construct Issued: 06/03/08	D261		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407,4-2-1982] ; CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,12-6-2002] CO: 400 PPMV (5) [RULE 1146,11-17-2000] ; NOX: 24.57 LBS/MMSCF NATURAL GAS (1) [RULE 2012,5-6-2005] ; NOX: 20 PPMV NATURAL GAS (4) [RULE 2005,5-6-2005] PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981] ; PM: (9) [RULE 404,2-7-1986]	C1.19, C1.21, D12.4, D29.1, D29.2, E202.4, H23.9, H23.12

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 4 : PETROLEUM MARKETING, CONSUMER FLEET FUELING					
STORAGE TANK, UNDERGROUND, RULE 441 RESEARCH PERMIT, GASOLINE, NOT METHANOL COMPATIBLE, WITH OPW (VR-102-E/J), 10000 GALS A/N: 500099 Permit to Construct Issued: 07/10/09	D277				C1.25, D330.1, E193.3, J373.3, K67.21
STORAGE TANK, UNDERGROUND, RULE 441 RESEARCH PERMIT, GASOLINE, METHANOL COMPATIBLE, WITH OPW (VR-102-E/J), 10000 GALS A/N: 500099 Permit to Construct Issued: 07/10/09	D278				C1.25, D330.1, E193.3, J373.3, K67.21
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, RULE 441 RESEARCH PERMIT, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR-201-J) DISPENSING 3 PRODUCTS A/N: 500099 Permit to Construct Issued: 07/10/09	D279				D330.1, E193.3, J373.3
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, RULE 441 RESEARCH PERMIT, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR-201-J) DISPENSING 3 PRODUCTS A/N: 500099 Permit to Construct Issued: 07/10/09	D280				D330.1, E193.3, J373.3

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 4 : PETROLEUM MARKETING, CONSUMER FLEET FUELING					
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, RULE 441 RESEARCH PERMIT, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR-201-J) DISPENSING 3 PRODUCTS A/N: 500099 Permit to Construct Issued: 07/10/09	D281				D330.1, E193.3, J373.3
LOADING ARM, RULE 441 RESEARCH PERMIT, GASOLINE, ONE HOSE WITH DRY BREAK CONNECT COUPLER FOR BOTTOM LOADING A/N: 500099 Permit to Construct Issued: 07/10/09	D282				C1.25, E193.3, J373.3, K67.21
LOADING ARM, RULE 441 RESEARCH PERMIT, GASOLINE, ONE VAPOR RECOVERY HOSE WITH CAMLOCK QUICK CONNECT COUPLER A/N: 500099 Permit to Construct Issued: 07/10/09	D283				C1.25, E193.3, J373.3, K67.21
System 1 : FUEL STORAGE AND DISPENSING SYSTEMS					
STORAGE TANK, UNDERGROUND, GASOLINE, NOT METHANOL COMPATIBLE, WITH OPW (VR-102-E/D), 10000 GALS A/N: 486268 Permit to Construct Issued: 08/19/08	D36				D330.1, E193.1, E193.2, J109.1, J373.2, K67.19, K67.20

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 4 : PETROLEUM MARKETING, CONSUMER FLEET FUELING					
STORAGE TANK, UNDERGROUND, GASOLINE, NOT METHANOL COMPATIBLE, WITH OPW (VR-102-E/I), 10000 GALS A/N: 486268 Permit to Construct Issued: 08/19/08	D40				D330.1, E193.1, E193.2, J109.1, J373.2, K67.19, K67.20
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR-201-G), WITH PHASE II VAPOR RECOVERY SYSTEM A/N: 486268 Permit to Construct Issued: 08/19/08	D88				D330.1, E193.1, E193.2, J110.1, J373.2, K67.19, K67.20
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR-201-G), WITH PHASE II VAPOR RECOVERY SYSTEM A/N: 486268 Permit to Construct Issued: 08/19/08	D89				D330.1, E193.1, E193.2, J110.1, J373.2, K67.19, K67.20
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR0201-G), WITH PHASE II VAPOR RECOVERY SYSTEM A/N: 486268 Permit to Construct Issued: 08/19/08	D90				D330.1, E193.1, E193.2, J373.2, K67.20

- * (1)(1A)(1B) Denotes RECLAIM emission factor
- (3) Denotes RECLAIM concentration limit
- (5)(5A)(5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits
- (2)(2A)(2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: DEVICE ID INDEX

**The following sub-section provides an index
to the devices that make up the facility
description sorted by device ID.**



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: DEVICE ID INDEX

Device Index For Section H				
Device ID		Section H Page No.	Process	System
D36		3	4	1
D40		4	4	1
D88		4	4	1
D89		4	4	1
D90		4	4	1
D260		1	2	0
D261		1	2	0
D277		2	4	0
D278		2	4	0
D279		2	4	0
D280		2	4	0
D281		3	4	0
D282		3	4	0
D283		3	4	0



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

F1.1 The operator shall limit the material processed to no more than 2000 lb(s) in any one year.

For the purpose of this condition, material processed shall be defined as 1,1,1 trichloroethane.

[H&S 44300, 7-1-1988]

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 9-11-1998]

F14.2 The operator shall not purchase diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

[RULE 431.2, 5-4-1990; RULE 431.2, 9-15-2000]

F48.1 The operator shall not operate at this facility non chain driven, uncontrolled charbroiler exceeding the opacity limits specified in Rule 401.

[RULE 401, 3-2-1984; RULE 401, 9-11-1998]

DEVICE CONDITIONS

C. Throughput or Operating Parameter Limits



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

C1.19 The operator shall limit the fuel usage to no more than 6.156 MM cubic feet in any one calendar month.

This limit shall be based on the total combined limit for equipment D260 and D261.

This equipment shall only use natural gas as a fuel.

The operator shall identify the primary and secondary heater fuel usage..

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D260, D261]

C1.21 The operator shall limit the fuel usage to no more than 2.637 MM cubic feet in any one calendar month.

This equipment shall only use natural gas as a fuel.

The operator shall identify the primary and secondary heater.

This condition only applies to the secondary heater.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D260, D261]

C1.25 The operator shall limit the gasoline dispensed to no more than 15000 gallon(s) in any one calendar month.

This condition only applies to bulk loading operations.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D277, D278, D282, D283]

D. Monitoring/Testing Requirements



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

D12.4 The operator shall install and maintain a(n) non-resettable totalizing fuel flow meter to accurately indicate the fuel usage of the equipment.

[**RULE 2012, 12-7-1995; RULE 2012, 4-9-1999**]

[Devices subject to this condition : D260, D261]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

D29.1 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District method 100.1	District-approved averaging time	Outlet
CO emissions	District method 100.1	District-approved averaging time	Outlet

A. SOURCE TESTING SHALL BE CONDUCTED WITHIN 30 DAYS AFTER ACHIEVING MAXIMUM PRODUCTION RATE AT WHICH THE EQUIPMENT WILL BE OPERATED, BUT NO LATER THAN 90 DAYS AFTER INITIAL START-UP

B. THE SOURCE TEST SHALL BE DONE TO VERIFY EMISSIONS LIMITS FOR NOX AND CO CO, 20 PPMV AND 50 PPMV RESPECTIVELY

C. THE TEST SHALL BE CONDUCTED FOR 15 MINUTES EACH WHILE OPERATING AT NORMAL LOAD, HIGH, LOW AND AVERAGE FIRING RATES

D. TWO COMPLETE COPIES OF SOURCE TEST REPORTS (INCLUDE THE APPLICATION NUMBER AND A COPY OF THE PERMIT IN THE REPORT) SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, ATTN: ROY OLIVARES, P.O. BOX 4941, DIAMOND BAR, CA 91765). THE RESULTS IN WRITING SHALL BE SUBMITTED WITHIN 45 DAYS AFTER THE SOURCE TEST IS COMPLETED. IT SHALL INCLUDE, BUT NOT LIMITED TO EMISSIONS RATE IN POUNDS PER HOUR AND CONCENTRATION IN PPMV AT THE OUTLET OF THE HEATER

E. TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST

F. SAMPLING FACILITIES SHALL COMPLY WITH THE ATTACHED AQMD "GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES", PURSUANT TO RULE 217.

[RULE 1146, 11-17-2000; RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]

[Devices subject to this condition : D260, D261]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

D29.2 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
CO emissions	District method 100.1	District-approved averaging time	Outlet

In lieu of the using the above test method for CO, the operator may choose to use a portable monitor as allowed per Rule 1146 (d)(4)

This test should be done at least once per year as per Rule 1146 (d)

[RULE 1146, 11-17-2000; RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]

[Devices subject to this condition : D260, D261]

D330.1 The operator shall have a person that has been trained in accordance with Rule 461 conduct a semi-annual inspection of the gasoline transfer and dispensing equipment. The first inspection shall be in accordance with Rule 461, Attachment B, the second inspection shall be in accordance with Rule 461, Attachment C, and the subsequent inspections shall alternate protocols. The operator shall keep records of the inspection and the repairs in accordance to Rule 461 and Section K of this Permit.

[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : D36, D40, D88, D89, D90, D277, D278, D279, D280, D281]

E. Equipment Operation/Construction Requirements



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

E193.1 The operator shall operate and maintain this equipment as follows:

ALL PERMIT CONDITIONS APPLICABLE TO THE EQUIPMENT DESCRIBED IN THE PREVIOUS PERMIT TO OPERATE N15788 SHALL REMAIN IN EFFECT UNTIL THE NEW OR MODIFIED EQUIPMENT IS CONSTRUCTED AND OPERATED AS DESCRIBED IN THIS NEW PERMIT. THIS PERMIT TO CONSTRUCT/OPERATE SHALL BECOME INVALID IF THE MODIFICATION AS DESCRIBED IN THE EQUIPMENT DESCRIPTION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE. IF THE MODIFICATION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE OF THE PERMIT

A WRITTEN REQUEST SHALL BE SUBMITTED TO THE AQMD (ATTENTION: RANDY MATSUYAMA) TO REINSTATE THE PREVIOUSLY INACTIVATED PERMIT TO OPERATE. A NEW APPLICATION SHALL BE FILED IF THERE ARE PLANS TO CONTINUE WITH THE MODIFICATION. FURTHERMORE, THIS CONDITION DOES NOT ALLOW ANY TIME EXTENSIONS TO ANY MODIFICATIONS REQUIRED BY THE CALIFORNIA AIR RESOURCES BOARD OR AQMD

[RULE 461, 3-7-2008]

[Devices subject to this condition : D36, D40, D88, D89, D90]

E193.2 The operator shall operate and maintain this equipment as follows:

ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS

[RULE 461, 3-7-2008]

[Devices subject to this condition : D36, D40, D88, D89, D90]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

E193.3 The operator shall operate and maintain this equipment as follows:

The following conditions apply to Rule 441 research operation to evaluate a Phase II enhanced vapor recovery (EVR) system installed on a bulk loading operation

This experimental permit to construct shall become invalid on January 1, 2011

This temporary permit is issued only to the equipment described and identified above which is operated as one permit unit. any modification to the equipment shall require prior approval from both the California air resources board (ARB) and the AQMD.

Operation of this equipment shall be in compliance with all data and specifications submitted with the application under which this permit was issued, unless otherwise noted below.

This equipment shall be properly maintained and kept in good operating condition at all times.

Approval from the local fire department authorities shall be obtained for all safety aspects. the name and telephone number of the fire department authority providing approval (or other proof of approval) shall be made available to district representatives upon request.

All operations covered by this permit will be terminated at once should the aqmd, at any time, determine that the operation is creating a public nuisance or a large number of citizen complaints.

All phase I vapor recovery equipment at this facility shall be installed, operated and maintained to meet all California Air Resources board certification requirements

Phase I vapor recovery systems shall be in full operation whenever fuel is being transferred into storage tanks

Phase II vapor recovery systems shall be in full operation whenever fuel is being transferred into motor vehicles, as defined in Rule 461

[RULE 461, 6-3-2005; RULE 461, 3-7-2008; RULE 462, 5-14-1999]

[Devices subject to this condition : D277, D278, D279, D280, D281, D282, D283]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

E202.4 The operator shall clean and maintain this equipment according to the following specifications:

Records shall be maintained of inspections and maintenance of the burners

The operator shall follow the procedures specified by the manufacturer to tune-up and maintain the combustion system (including but not limited to the burner and air/fuel control device) of this heater

Manufacturers maintenance procedures shall be kept by the operator and made available at the request of AQMD

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 2005, 4-9-1999]

[Devices subject to this condition : D260, D261]

H. Applicable Rules

H23.9 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
CO	District Rule	1146.

[RULE 1146, 11-17-2000]

[Devices subject to this condition : D260, D261]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

H23.12 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
SOX	District Rule	431.1

[RULE 431.1, 6-12-1998]

[Devices subject to this condition : D260, D261]

J. Rule 461

J109.1 The operator shall use, except for diesel transfer, the phase I vapor recovery system in full operation whenever this equipment is in use. This system shall be installed, operated and maintained to meet all CARB certification requirements.

[RULE 461, 3-7-2008]

[Devices subject to this condition : D36, D40]

J110.1 The operator shall use, except for diesel transfer, the phase II vapor recovery system in full operation whenever gasoline from this equipment is dispensed to motor vehicles as defined in Rule 461. This system shall be installed, operated and maintained to meet all CARB certification requirements.

[RULE 461, 3-7-2008]

[Devices subject to this condition : D88, D89]



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

J373.2 The operator shall comply with the following gasoline transfer and dispensing requirements:

THE DISTRICT AT ITS DISCRETION MAY WISH TO WITNESS THE INSTALLATION AND/OR PERFORMANCE TESTING OF THE HEALY PHASE II EVR SYSTEM NOT INCLUDING ISD. AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO THE INSTALLATION AND PERFORMANCE TESTING OF THE HEALY PHASE II EVR SYSTEM NOT INCLUDING ISD, THE APPLICANT SHALL NOTIFY THE AQMD AT TELEPHONE NUMBER (866) 770-9140.

NEW EQUIPMENT INSTALLATIONS AND SUBSEQUENT SERVICE AND REPAIRS FOR ANY CERTIFIED COMPONENT FOR WHICH THIS PERMIT WAS ISSUED, SHALL ONLY BE PERFORMED BY A CURRENT AND CERTIFIED PERSON WHO HAS SUCCESSFULLY COMPLETED THE MANUFACTURER'S TRAINING COURSE AND APPROPRIATE INTERNATIONAL CODE COUNCIL (ICC) CERTIFICATION. COMPLETION OF ANY AQMD TRAINING COURSE DOES NOT CONSTITUTE AS A SUBSTITUTE FOR THIS REQUIREMENT. PROOF OF SUCCESSFUL COMPLETION OF ANY MANUFACTURER TRAINING COURSE SHALL BE WITH THE MANUFACTURER.

AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO BACK-FILLING ANY UNDERGROUND STORAGE TANK OR PIPING, THE SCAQMD SHALL BE NOTIFIED BY E-MAIL AT R461BACKFILL@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTORS; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE BACK-FILLING PROCEDURE. THE BACK-FILLING PROCEDURE SHALL NOT COMMENCE UNTIL INSPECTED BY A DISTRICT REPRESENTATIVE.

DEPENDING ON THE SYSTEM CONFIGURATION, A LEAK RATE TEST OF DROP TUBE/DRAIN VALVE ASSEMBLY SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF BOTH THE DROP TUBE AND DRAIN VALVE SEAL OR A LEAK RATE TEST OF DROP TUBE OVERFILL PREVENTION DEVICE AND DRAIN VALVE SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF THE DROP TUBE OVERFILL PREVENTION DEVICE AND THE PRESSURE INTEGRITY OF THE SPILL CONTAINER DRAIN VALVE. EITHER TEST SHALL BE CONDUCTED AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST

THE ABOVE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH TEST PROCEDURE METHOD TP-201.1C (OCTOBER 8, 2003) OR TP-201.1D (OCTOBER 8, 2003), RESPECTIVELY. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

A LEAK RATE AND CRACKING PRESSURE TEST OF PRESSURE/VACUUM RELIEF VENT VALVES SHALL BE CONDUCTED WITHIN TEN DAYS (10) AFTER THE START OF OPERATION OF THE OPW PHASE I EVR EQUIPMENT AND AT LEAST ONCE EVERY THREE (3) YEARS THEREAFTER TO DETERMINE THE PRESSURE AND VACUUM AT WHICH THE PRESSURE/VACUUM VENT VALVE ACTUATES, AND TO DETERMINE THE VOLUMETRIC LEAK RATE AT A GIVEN PRESSURE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD TP-201.1E (OCTOBER 8, 2003).



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

THE RESULTS OF THE ABOVE TEST SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST. THIS TEST RESULT SHALL BE KEPT ON SITE FOR THREE (3) YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

A STATIC TORQUE TEST OF ROTATABLE PHASE I ADAPTORS SHALL BE CONDUCTED TO QUANTIFY THE AMOUNT OF STATIC TORQUE REQUIRED TO START THE ROTATION OF THE ROTATABLE PHASE I ADAPTORS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD OUTLINED IN TP-201.1B (OCTOBER 8, 2003) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST

a). The Phase II vapor recovery systems shall be installed, operated, and maintained such that the maximum allowable pressure through the system including nozzle, vapor hose, swivels, and underground piping does not exceed the dynamic back pressures described by the California Air Resources Board (CARB) Executive Order by which the system was certified:

Nitrogen Flowrates (CFH) Dynamic Back Pressure (Inches of Water)

60 0.5

THE ABOVE DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP-201.4, METHODOLOGY 4 AND 6 (JULY 3, 2002); AS A PERFORMANCE TEST. THIS TEST SHALL BE A ONE-TIME TEST AND THE RESULTS KEPT PERMANENTLY ON SITE. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TESTS.

A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES, ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.3 (MARCH 17, 1999) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

A STATIC PRESSURE PERFORMANCE TEST FOR THE HEALY CLEAN AIR SEPARATOR USING BOTH THE VACUUM DECAY PROCEDURE AND THE POSITIVE PRESSURE PROCEDURE SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TIGHTNESS OF THE HEALY CLEAN AIR SEPARATOR TANK PRESSURE MANAGEMENT SYSTEM. THESE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 4 OF CARB EXECUTIVE ORDER VR-201-G AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOUR

A VAPOR TO LIQUID VOLUME RATIO TEST SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TO LIQUID (V/L) VOLUMETRIC RATIO OF THE HEALY CLEAN AIR SEPARATOR



AQMD

**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

SYSTEM. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 5 OF CARB EXECUTIVE ORDER VR-201-G AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.

A NOZZLE BAG TEST SHALL BE CONDUCTED ON THE HEALY PHASE II EVR NOZZLES TO VERIFY THE INTEGRITY OF THE VAPOR VALVE. THE TEST SHALL BE CONDUCTED ON ANY NEWLY INSTALLED OR REPLACED HEALY PHASE II EVR NOZZLES AND IN ACCORDANCE WITH EXHIBIT 7 OF CARB EXECUTIVE ORDER VR-201-G. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.

THE STATIC PRESSURE LEAK DECAY TEST TP-201.3, SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 8 OF CARB EXECUTIVE ORDER VR-201-G. VERIFICATION OF COMPLETING EACH STEP AS OUTLINED SHALL BE DOCUMENTED BY SUBMITTING A COPY OF EXHIBIT 8 TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.

UNLESS AQMD RULE 461 REQUIRES A MORE FREQUENT TESTING OR INSPECTION SCHEDULE, THE OWNER/OPERATOR SHALL BE RESPONSIBLE TO PERFORM THE SCHEDULED WEEKLY, QUARTERLY, AND ANNUAL INSPECTIONS AS OUTLINED IN THE ARB APPROVED INSTALLATION, OPERATION, AND MAINTENANCE MANUAL FOR THE HEALY PHASE II EVR SYSTEMS, AS WELL AS ALL THE REQUIRED VAPOR RECOVERY SYSTEM TESTS AS PER THE CURRENT AND APPROPRIATE ARB EXECUTIVE ORDER.

A CARB CERTIFIED PHASE II ENHANCED VAPOR RECOVERY SYSTEM SHALL BE FULLY PERMITTED, INSTALLED, AND TESTED BY OCTOBER 1, 2008. FAILURE TO ACHIEVE THIS CONDITION BY OCTOBER 1, 2008, SHALL RESULT IN THE OWNER/OPERATOR TO FILE A DISTRICT APPROVED COMPLIANCE PLAN OUTLINING THE INCREMENTS OF PROGRESS TOWARDS COMPLETING THE INSTALLATION OF A CARB CERTIFIED PHASE II ENHANCED VAPOR RECOVERY SYSTEM BY APRIL 1, 2009.

IF THE OWNER/OPERATOR PLANS TO PERMANENTLY CEASE ALL GASOLINE DISPENSING OPERATIONS BEFORE APRIL 1, 2009, A COMPLIANCE PLAN SHALL BE FILED DECLARING TO IRREVOCABLY SURRENDER THEIR PERMIT TO OPERATE.

THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO ANY OF THE ABOVE MENTIONED TESTING REQUIREMENTS. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE TESTS TO BE PERFORMED.

THE TESTING FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT.



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

SHOULD THE FACILITY DISPENSE MORE THAN 600,000 GALLONS OF GASOLINE PER CALENDAR YEAR AND IF THE FACILITY UNDERGOES A MAJOR MODIFICATION AS DEFINED BY CARB'S ADVISORY LETTER NUMBER 336, "ENHANCED VAPOR RECOVERY IMPLEMENTATION UPDATE" DATED APRIL 15, 2005; THE OPERATOR SHALL IMMEDIATELY CEASE ALL GASOLINE DISPENSING OPERATIONS AND FILE AN APPLICATION FOR A NEW PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM.

THE ABOVE GASOLINE DISPENSING OPERATIONS SHALL NOT RESUME UNTIL THE ISD SYSTEM HAS BEEN GRANTED A PERMIT TO CONSTRUCT/OPERATE AND HAS BEEN FULLY INSTALLED, TESTED, AND OPERATIVE.

SHOULD THE FACILITY DISPENSE MORE THAN 600,000 GALLONS OF GASOLINE IN ANY CALENDAR YEAR AND IF THE FACILITY DOES NOT UNDERGO A MAJOR MODIFICATION AS DEFINED BY CARB'S ADVISORY LETTER NUMBER 336, "ENHANCED VAPOR RECOVERY IMPLEMENTATION UPDATE" DATED APRIL 15, 2005; THE OPERATOR SHALL FILE AN APPLICATION FOR A NEW PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM. THE ISD SYSTEM SHALL BE FULLY INSTALLED, TESTED, AND OPERATIVE BASED ON THE FOLLOWING PARAGRAPH

GASOLINE THROUGHPUT GREATER THAN 1.8 MILLION GALLONS PER CALENDAR NO LATER THAN 9/12/2009. AND GASOLINE THROUGHPUT BETWEEN 600000 AND 1.8 MILLION GALLONS PER YEAR NO LATER THAN 9/1/2010

[RULE 461, 3-7-2008]

[Devices subject to this condition : D36, D40, D88, D89, D90]



FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

J373.3 The operator shall comply with the following gasoline transfer and dispensing requirements:

The following conditions apply to Rule 441 Reasearch operations to evalutate a Phase II enhanced vapor recovery (EVR) system installed on a bulk loading operation.

The AQMD at its discretion may wish to witness the installation and/or performance testing of the pressure data logging system. At least seventy-two (72) hours prior to installation and/or performance testing of the pressure data logging system the AQMD shall be notified by contacting Mr. Randy Matsuyama at telephone number (909) 396-2551 or by e-mail at rmatsuyama@aqmd.gov

As a research & development test site, both ARB and AQMD staff shall have access to the site in order to conduct testing to evaluate system performance and to develop new test procedures applicable to the system. All test data collected at the test site shall be provided to both ARB and AQMD upon request within 15 days after testing.

Unless an extension is granted by the end of the research & development expiration date, all uncertified equipment shall be removed within sixty (60) days of the expiration date. The name of the company or personnel removing the uncertified equipment shall be provided to Mr. Randy Matsuyama of the AQMD at facsimile (909) 396-2999. The research and development test site shall be brought into compliance with all applicable regulations as of the date when the uncertified equipment is removed.

This permit to construct or copy and the current permit to construct, 486268, or copy shall be kept on site during the duration of the research and development time period, and made available to District representatives upon request.

New equipment installations and subsequent service and repairs for any certified component for which this permit was issued, shall only be performed by a current and certified person who has successfully completed the manufacturer's training course and appropriate international code council (icc) certification. Completion of any AQMD training course does not constitute as a substitute for this requirement. Proof of successful completion of any manufacturer training course shall be with the manufacturer.

Depending on the system configuration, a leak rate test of the drop tube/drain valve assembly shall be conducted to quantify the pressure integrity of both the drop tube and drain valve seal or a leak rate test of the drop tube overflow prevention device and drain valve shall be conducted to quantify the pressure integrity of the drop tube overflow prevention device and the pressure integrity of the spill container drain valve.

From the above condition, either test shall be conducted as a performance test and as a reverification test. The test shall be conducted in accordance with test procedure method tp-201.1c (October 8, 2003) or tp-201.1d (October 8, 2003), respectively. Results shall be submitted to the AQMD, office of engineering and compliance, within seventy-two (72) hours of test.

A leak rate and cracking pressure test of pressure/vacuum relief vent valves shall be conducted within thirty days (30) after the start of operation of the OPW phase I EVR equipment and at least once every three (3) years thereafter to determine the pressure and vacuum at which the pressure/vacuum vent valve actuates, and to determine the volumetric leak rate at a given pressure. The test shall be conducted in accordance with the



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

test procedure method tp-201.1e (October 8, 2003).

The above results shall be submitted to the AQMD, office of engineering and compliance, within seventy-two (72) hours of test. This test result shall be kept on site for five (5) years and made available to District representatives upon request

A static torque test of rotatable phase I adaptors shall be conducted to quantify the amount of static torque required to start the rotation of the rotatable phase I adaptors. The test shall be conducted in accordance with the test procedure method outlined in tp-201.1b (October 8, 2003) as a performance test and as a reverification test. Results shall be submitted to the AQMD, office of engineering and compliance, within seventy-two (72) hours of test.

a). The Phase II vapor recovery systems shall be installed, operated, and maintained such that the maximum allowable pressure through the system including nozzle, vapor hose, swivels, and underground piping does not exceed the dynamic back pressures described by the California Air Resources Board (CARB) Executive Order by which the system was certified:

Nitrogen Flowrates (CFH)	Dynamic Back Pressure (Inches of Water)
--------------------------	---

60	0.50
----	------

The above dynamic back pressure tests shall be conducted to determine the phase II system vapor recovery back pressures. The tests shall be conducted in accordance with CARB test procedure tp-201.4, methodology 4 and 6 (July 3, 2002); as a performance test. This test shall be a one-time performance test and the results kept permanently on site. The Results of the above test shall be submitted to the AQMD, office of engineering and compliance, within seventy-two (72) hours of tests.

A static pressure leak decay test shall be conducted to demonstrate that the storage tanks, the remote and/or nozzle vapor recovery check valves, associated vapor return piping and fittings are free from vapor leaks. The test shall be conducted in accordance with CARB test procedure method tp-201.3 (march 17, 1999) as a performance test and as a reverification test. Results shall be submitted to the AQMD, office of engineering and compliance, within seventy-two (72) hours of test.

A static pressure performance test for the healy clean air separator using both the vacuum decay procedure and the positive pressure procedure shall be conducted to quantify the vapor tightness of the healy clean air separator tank pressure management system. The test shall be conducted in accordance with exhibit 4 of CARB executive order vr-201-j as a performance test and reverification test. Results shall be submitted to the AQMD, office of engineering and compliance within seventy-two (72) hours of tes

A vapor to liquid volume ratio test shall be conducted to quantify the vapor to liquid (v/l) volumetric ratio of the healy clean air separator system. The test shall be conducted in accordance with exhibit 5 of CARB executive order vr-201-j as a performance test and reverification test. Results shall be submitted to the AQMD, office of engineering and compliance within seventy-two (72) hours of test.

A nozzle bag test shall be conducted on the healy phase II EVR nozzles to verify the integrity of the vapor valve. the test shall be conducted on any newly installed or replaced healy phase II EVR nozzles and in accordance with exhibit 7 of CARB executive order vr-201-j. Results shall be submitted to the AQMD, office



FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

of engineering and compliance within seventy-two (72) hours of test.

The static pressure leak decay test tp-201.3, shall be conducted in accordance with exhibit 8 of CARB executive order vr-201-j. Verification of completing each step as outlined shall be documented by submitting a copy of exhibit 8 to the AQMD, office of engineering and compliance within seventy-two (72) hours of test.

Unless AQMD rule 461 requires a more frequent testing or inspection schedule, the owner/operator shall be responsible to perform the scheduled weekly, quarterly, and annual inspections as outlined in the ARB approved installation, operation, and maintenance manual for the healy phase II EVR systems, as well as all the required vapor recovery system tests as per the current and appropriate ARB executive order.

The AQMD shall be notified by e-mail at r461testing@aqmd.gov or by facsimile at telephone number (909) 396-3606 at least seventy-two (72) hours prior to any of the above mentioned testing requirements. Such notification shall include the name of the owner or operator; the name of the contractor; the location of the facility; and the scheduled start and completion dates of the tests to be performed

The testing for the above mentioned tests shall be conducted in accordance with the most recent Rule 461 amendment or CARB executive order requirements, whichever is more stringent.

Should the facility dispense more than 600,000 gallons of gasoline in any calendar year, the operator shall file an application for a new permit to construct/operate to install an ARB certified in station diagnostic (ISD) system. The ISD system shall be fully installed, tested, and operative based on gasoline throughput per calendar year greater than 1.8 million gallons by September 1, 2009 or gasoline throughput per calendar year greater than between 600,000 and 1.8 million gallons by September 1, 2010

The bulk loading equipment shall be operated for bottom loading only during the transfer of gasoline fuel from the underground storage tanks into any tank truck. All vapor return lines shall be connected between the underground gasoline storage tanks and tank truck.

The transfer equipment from the bulk loading operations shall be operated and maintained so that there are no overfills, system vapor leaks, or liquid leaks from disconnect operations.

The bulk loading equipment shall be operated so that the backpressure in the vapor recovery system does not exceed 18 inches of water column pressure.

This class "B" bulk loading facility shall be installed, operated, and maintained in accordance with District rule 462.

The bulk loading vapor recovery system shall be certified by ARB as required in district rule 462. The copy of the ARB bulk plant vapor recovery certification test results shall be retained on site and made available to District representatives upon request.

Records of daily and monthly gasoline fuel dispensed for both the gasoline dispensing facility operation and for the bulk loading operation shall be prepared and maintained.

All records and test results that are required to be maintained by district rules 461 and 462 shall be kept on



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

site for five years and made available to District representatives upon request

[RULE 461, 6-3-2005; RULE 461, 3-7-2008; RULE 462, 5-14-1999]

[Devices subject to this condition : D277, D278, D279, D280, D281, D282, D283]

K. Record Keeping/Reporting

K67.19 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

IN ACCORDANCE WITH RULE 461(j), THE OWNER/OPERATOR SHALL ADHERE TO THE FOLLOWING TASK COMPLETEION DATES AS SUBMITTED ON FORM 461-CP:

COMPLETE PERMIT APPLICATION PACKAGES TO ALL APPLICABLE GOVERNMENT AGENCIES NO LATER THAN 8/15/08

PURCHASE ORDER FOR CARB CERTIFIED PHASE II EVR SYSTEM NO LATER THAN 8/30/08

SIGN CONTRACT FOR INSTALLATION OF CARB CERTIFIED PHASE II EVER SYSTEM NO LATER THAN 8/11/2008

SIGN CONTRACT FOR TESTING OF CARB CERTIFIED PHASE II EVR SYSTEM NO LATER THAN 8/11/2008

START DATE OF EQUIPMENT INSTALLATION NO LATER THAN 11/15/2008

START DATE OF TESTING PHASE II EVR SYSTEM NO LATER THAN 12/30/2008

[RULE 461, 3-7-2008]

[Devices subject to this condition : D36, D40, D88, D89]



**FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

K67.20 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE FOR FIVE YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

[RULE 461, 3-7-2008]

[Devices subject to this condition : D36, D40, D88, D89, D90]

K67.21 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Records of monthly fuel dispensed only during bulk loading operations shall be prepared, shall be retained on site for five years, and shall be made available to District representatives upon request.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D277, D278, D282, D283]