



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT

JUL 12 2012

Gerardo C. Rios, Chief
Permits Office (AIR-3)
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

Re: Notice of Final Action - Minor Title V Permit Modification
District Facility # S-1547
Project # 1121227

Dear Mr. Rios:

The Air Pollution Control Officer has modified the Title V permit for Aera Energy LLC by incorporating Authorities to Construct (ATCs) S-1547-59-27, '-60-26, '-78-32, '-123-29, '-125-26, '-146-29, '-697-30, '-722-22, '-725-19, '-757-20, '-759-19, '-802-21, '-808-17, '-809-20, '-836-20, '-837-21, '-1034-16, and '-1035-19. The ATCs authorize clarification of permit conditions relating to Rule 4320 emissions limits applicable to combustion of less than 50% by volume PUC-quality natural gas.

Please note that after review of the PTOs, Aera commented that equipment descriptions for units S-1547-123 and '-808 were incorrect. Reference to piping from TEOR operation S-1547-1079 was deleted from '-123 as deletion of a SOx scrubber (and combustion of TEOR gas) was authorized by a previous ATC. Aera designation of '-808 was corrected from NEV #104 (South Midway) to #11-1H (Belridge).

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on April 26, 2012. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

David Warner
Director of Permit Services

DW:rue
Enclosures

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061
www.valleyair.org

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT

JUL 12 2012

Brent Winn
Aera Energy LLC
PO Box 11164
Bakersfield, CA 93389

Re: Notice of Final Action - Minor Title V Permit Modification
District Facility # S-1547
Project # 1121227

Dear Mr. Winn:


The Air Pollution Control Officer has modified the Title V permit for Aera Energy LLC by incorporating Authorities to Construct (ATCs) S-1547-59-27, '-60-26, '-78-32, '-123-29, '-125-26, '-146-29, '-697-30, '-722-22, '-725-19, '-757-20, '-759-19, '-802-21, '-808-17, '-809-20, '-836-20, '-837-21, '-1034-16, and '-1035-19. The ATCs authorize clarification of permit conditions relating to Rule 4320 emissions limits applicable to combustion of less than 50% by volume PUC-quality natural gas.

Please note that after review of the PTOs, Aera commented that equipment descriptions for units S-1547-123 and '-808 were incorrect. Reference to piping from TEOR operation S-1547-1079 was deleted from '-123 as deletion of a SOx scrubber (and combustion of TEOR gas) was authorized by a previous ATC. Aera designation of '-808 was corrected from NEV #104 (South Midway) to #11-1H (Belridge).

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on April 26, 2012. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,


David Warner
Director of Permit Services

DW:ru
Enclosures

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061
www.valleyair.org

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-59-28

EXPIRATION DATE: 05/31/2016

SECTION: 20 **TOWNSHIP:** 28S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR, WITH FLUE GAS RECIRCULATION AND SO2 SCRUBBER (#72 DIS# 27454-81)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 4301, 5.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
4. For each steam generator site downstream of H2S scavenger chemical injection points, permittee shall monitor H2S content of the gas prior to incineration in affected steam generators on a daily basis. If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 2201] Federally Enforceable Through Title V Permit
5. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. Scrubber shall be located on site. Duct work to steam generators may be blinded off or removed. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Scrubber shall be utilized whenever vapor recovery gas is incinerated in steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit
11. When utilizing scrubber source testing to demonstrate compliance with SO_x emission limit shall be conducted not less than once every 12 months. When not utilizing scrubber, fuel sulfur content shall be certified by a third party fuel supplier or compliance with sulfur compound emission limit shall be demonstrated not less than once every 12 months by fuel gas sulfur content analysis and higher heating value analysis of each fuel source. [District Rule 2201] Federally Enforceable Through Title V Permit
12. When scrubber is in operation, steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Scrubber recirculation liquid pH shall be maintained only by the addition of caustic unless prior approval for an alternative pH maintenance method is received from the District. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Scrubber liquor pH shall be maintained above 6.15 and shall be continuously monitored. Compliance shall be determined on a three-hour rolling average. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC-quality natural gas (as defined by Rule 4320). [District Rule 4320] Federally Enforceable Through Title V Permit
16. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
17. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
18. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM₁₀: 0.058 lb/MMBtu, SO_x (as SO₂): 0.063 lb/MMBtu, VOC: 0.003 lb/MMBtu, NO_x (as NO₂): 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O₂. [District Rules 2201; 4305, 5.1; 4306, 5.1; 4320, 5.2 and 5.4] Federally Enforceable Through Title V Permit
19. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
20. Emission rates shall not exceed any of the following: PM₁₀: 87.0 lb/day, SO_x (as SO₂): 94.5 lb/day, VOC: 4.5 lb/day, NO_x (as NO₂): 54.0 lb/day or 7,665 lb/year, or CO: 45.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
21. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5, & 6.1 and 4306, 5.3 & 6.1] Federally Enforceable Through Title V Permit
22. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. If the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
24. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
27. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
29. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D3246, D4084, D4468 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
32. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070,4.0; 4305, 6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-60-27

EXPIRATION DATE: 05/31/2016

SECTION: 20 **TOWNSHIP:** 28S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A COEN QLN-ULN 3.2 LOW NOX BURNER, FLUE GAS RECIRCULATION, AND SO2 SCRUBBER (#73 DIS# 28624-82)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 4301, 5.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
4. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Scrubber shall be located on site. Duct work to steam generators may be blinded off or removed. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Scrubber shall be utilized whenever vapor recovery gas is incinerated in steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When utilizing scrubber, source testing to demonstrate compliance with SOx emission limit shall be conducted not less than once every 12 months. When not utilizing scrubber, fuel sulfur content shall be certified by a third party fuel supplier or compliance with sulfur compound emission limit shall be demonstrated not less than once every 12 months by fuel gas sulfur content analysis and higher heating value analysis of each fuel source. [District Rule 2201] Federally Enforceable Through Title V Permit
11. When scrubber is in operation, steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Scrubber recirculation liquid pH shall be maintained only by the addition of caustic unless prior approval for an alternative pH maintenance method is received from the District. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Scrubber liquid pH shall be maintained above 6.15 and shall be continuously monitored. Compliance shall be determined on a three-hour rolling average. [District Rule 2201] Federally Enforceable Through Title V Permit
14. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC-quality natural gas (as defined by Rule 4320). [District Rule 4320] Federally Enforceable Through Title V Permit
15. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
16. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
17. Emission rates, except during startup, shutdown, and refractory curing, shall not exceed any of the following: PM₁₀: 0.058 lb/MMBtu, SO_x (as SO₂): 0.063 lb/MMBtu, VOC: 0.003 lb/MMBtu, NO_x (as NO₂): 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O₂. [District Rules 4305, 5.1; 4306, 5.1 and 4320, 5.2 and 5.4] Federally Enforceable Through Title V Permit
18. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
19. Emission rates shall not exceed any of the following: PM₁₀: 87.0 lb/day, SO_x (as SO₂): 94.5 lb/day, VOC: 4.5 lb/day, NO_x (as NO₂): 54.0 lb/day or 7,665 lb/year, or CO: 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Duration of start-up and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
21. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
23. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
25. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
26. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
28. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D3246, D4084, D4468 or double GC for H2S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2, 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
31. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-78-33

EXPIRATION DATE: 05/31/2016

SECTION: NE29 **TOWNSHIP:** 28S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED-STEAM GENERATOR WITH A COEN ULTRA LOW NOX BURNER, WITH FLUE GAS RECIRCULATION, AND PIPING FROM S-1547-1079 (EAST FLANK LEASE), (#89, DIS# 27471-80) (GEN SITE 2972)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
4. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
5. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2.1 and 4801, 3.1] Federally Enforceable Through Title V Permit
6. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC-quality natural gas (as defined by Rule 4320). [District Rule 4320] Federally Enforceable Through Title V Permit
7. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
8. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: PM10: 0.014 lb/MMBtu, SO_x (as SO₂): 0.002 lb/MMBtu, NO_x (as NO₂): 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, or CO: 50 ppmv @ 3% O₂ [District Rules 2201, 4305,5.1; 4306, 5.1 and 4320, 5.2 & 5.4] Federally Enforceable Through Title V Permit
10. Emission rates shall not exceed any of the following: NO_x (as NO₂): 54.0 lb/day or 7,665 lb/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Emission rates during refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
12. Duration of start-up and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
13. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
14. If the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
16. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

17. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
18. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5, 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
20. Measurement shall be made with the FGR system in the mode of operation (closed or open) in which it was used in the preceding 30 days. [District Rules 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
21. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
22. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H2S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2, 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
24. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305,6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-123-30

EXPIRATION DATE: 05/31/2016

SECTION: NE29 **TOWNSHIP:** 28S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A COEN ULTRA LOW NOX BURNER AND A FLUE GAS RECIRCULATION (FGR) SYSTEM (#133, DIS# 28715-83) (GEN SITE 2972)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of supplier-certified gas delivered and copies of quality terms of supplier-certified gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 4301, 5.2.1 and 4801, 3.1] Federally Enforceable Through Title V Permit
4. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC-quality natural gas (as defined by Rule 4320). [District Rule 4320] Federally Enforceable Through Title V Permit
7. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
8. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Emission rates, except during startup, shutdown, and refractory curing, shall not exceed any of the following: PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.002 lb/MMBtu, NOx (as NO2): 0.014 lb/MMBtu or 12 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, CO: 50 ppmv @ 3% O2. [District Rules 2201, 4305, 5.1; 4306 and, 5.1 and 4320, 5.2 & 5.4] Federally Enforceable Through Title V Permit
10. Emission rates shall not exceed any of the following: NOx (as NO2): 54.0 lb/day and 7,665 lb/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Emission rates during refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
12. Duration of start-up and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Measurement shall be made with the FGR system in the mode of operation (closed or open) in which it was used in the preceding 30 days. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
14. If the NOx and/or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
15. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
16. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

17. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months, (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months, (no more than 30 days before or after the required 36 months source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
18. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081,7.1] Federally Enforceable Through Title V Permit
19. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - EPA Methods 6, 6B, or 8, or ARB Methods 8 or 100 and EPA Method 19, fuel gas sulfur content - ASTM D1072, D3246, D4084, D4468 or double GC for H2S and mercaptans, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588, PM10 - EPA Method 201A and 202, or EPA Method 5 (assume all PM is PM10). [District Rules 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
21. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-125-27

EXPIRATION DATE: 05/31/2016

SECTION: NW01 **TOWNSHIP:** 28S **RANGE:** 20E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH A COEN QLN-ULN 3.2 BURNER AND FLUE GAS RECIRCULATION (#135, DIS# 28717-83) (GEN SITE 121)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 4301, 5.2.1 and 4801, 3.1] Federally Enforceable Through Title V Permit
4. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. No less than 3.0 miles of roads shall be paved and properly maintained with hot mix asphalt material at permittee's South Belridge field on Poleline Road - From the intersection of Main Camp Road to 1/2 mile north of Entrance 'D'. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Caltrans Standard Specifications for paving and materials shall be fully satisfied. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Compliance with particulate matter offset requirements shall be demonstrated by District inspection of roads annually 60 days prior to permit anniversary. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Natural gas fuel sulfur content shall not exceed 0.75 gr S/100 scf. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
10. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC-quality natural gas (as defined by Rule 4320). [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
12. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
13. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: PM₁₀: 0.008 lb/MMBtu, VOC: 0.006 lb/MMBtu, NO_x (as NO₂): 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O₂. [District Rules 2201, 4305, 5.1; 4306, 5.1 and 4320, 5.1] Federally Enforceable Through Title V Permit
14. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
15. Emission rates shall not exceed any of the following: PM₁₀: 12.0 lb/day, SO_x (as SO₂): 3.2 lb/day, VOC: 9.0 lb/day, NO_x (as NO₂): 54.0 lb/day or 7,665 lb/year, or CO: 52.5 lb/day or 16,425 lb/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1; 4306, 5.3 & 6.1 and 4320, 5.6 & 6.1] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
18. If the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.5 and 4320, 5.7] Federally Enforceable Through Title V Permit
21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
22. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320; 5.8] Federally Enforceable Through Title V Permit
24. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
25. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
27. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-146-30

EXPIRATION DATE: 05/31/2016

SECTION: NE29 **TOWNSHIP:** 28S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (#124, DIS# 27578-81), WITH A COEN ULN LOW NOX BURNER, O2 CONTROLLER AND FLUE GAS RECIRCULATION (GEN SITE 2972)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of supplier-certified gas delivered and copies of quality terms of supplier-certified gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2, 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
4. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC-quality natural gas (as defined by Rule 4320). [District Rule 4320] Federally Enforceable Through Title V Permit
5. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
6. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
7. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4405, 5.5 & 6.1; 4306, 5.3 & 6.1 and 4320, 5.6 & 6.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: PM10: 0.015 lb/MMBtu, SO_x (as SO₂): 0.002 lb/MMBtu, VOC:0.003 lb/MMBtu, NO_x (as NO₂): 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, or CO: 50 ppmv @ 3% O₂. [District Rules 2201; 4305, 5.1; 4306, 5.1 and 4320, 5.2 & 5.4] Federally Enforceable Through Title V Permit
9. Emission rates during startup, shutdown or refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
10. Emission rates shall not exceed any of the following: NO_x (as NO₂): 54.0 lb/day or 7665 lb/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
12. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100 (amended December 17, 1992), the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
13. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
14. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
15. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

16. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months, (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months, (no more than 30 days before or after the required 36 months source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rule 2201 and District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
18. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
19. Compliance demonstration (source testing) shall be by District witnessed, or authorized. Sample collection shall be by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D3246, D4084, D4468 or double GC for H2S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
21. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
22. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 2201, District Rules 1070, 4.0; 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-697-31

EXPIRATION DATE: 05/31/2016

SECTION: SW01 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, EQUIPPED WITH A COEN QLN-ULN LOW-NOX BURNER AND FLUE GAS RECIRCULATION (#1-1A, DIS# 28617-82)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
4. The concentration of sulfur compounds in the exhaust from this unit shall demonstrate compliance using one of the following: test the sulfur content of each fuel source or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2 and Rule 4801, 3.1] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Natural gas fuel sulfur content shall not exceed 0.75 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC-quality natural gas (as defined by Rule 4320). [District Rule 4320] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
9. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.014 lb/MMBtu or 12 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
11. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
12. Emission rates shall not exceed any of the following: PM10: 12.0 lb/day, SOx (as SO2): 4.5 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 7665 lb/year, or CO: 45.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
13. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
14. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
15. If NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
16. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
17. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

18. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
19. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
20. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
21. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
22. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
24. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-722-23

EXPIRATION DATE: 05/31/2016

SECTION: SW01 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH A GIDEON LOW ULTRA LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) (#1-1C, BELRIDGE)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
3. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
5. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2.1 and 4801.3.1] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. Steam generator shall be operated at no greater than 1,466.7 MMBtu hhw/day heat input. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of higher heating value and daily quantity of natural gas burned in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Natural gas fuel sulfur content shall not exceed 0.75 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC-quality natural gas (as defined by Rule 4320). [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
12. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320] Federally Enforceable Through Title V Permit
13. Emission rates, except during startup, shutdown, and refractory curing, shall not exceed any of the following limits: PM₁₀: 0.005 lb/MMBtu, SO_x (as SO₂): 0.002 lb/MMBtu, VOC: 0.003 lb/MMBtu, NO_x (as NO₂): 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O₂. [District Rules 2201, 2520, 4201, 4301, 4305, 4306, 4405, 4406, 4320, 4801 and Kern County Rules 424 and 425] Federally Enforceable Through Title V Permit
14. Emission rates during startup, shutdown and refractory curing shall not exceed any of the following limits: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4101, 4102, 4301, 4405, 4406, 4801 and Kern County Rules 424 and 425] Federally Enforceable Through Title V Permit
15. Emission rates shall not exceed any of the following limits: PM₁₀: 7.3 lb/day, SO_x (as SO₂): 2.9 lb/day, VOC: 4.4 lb/day, NO_x (as NO₂): 52.8 lb/day or 7495 lb/year, or CO: 44.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
16. During a "shakedown" period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission shall not exceed 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation for at least 5 years. [District Rule 4320] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
18. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
19. Duration of start-up and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
21. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. For each steam generator site downstream of H₂S scavenger chemical injection points, permittee shall monitor sulfur content of the gas prior to incineration in affected steam generators on a daily basis utilizing Draeger tubes calibrated for existing sulfur species or other District-approved fuel sulfur detection method(s) or device(s). If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
25. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
26. Source testing to measure NO_x and CO emissions from this unit shall be conducted within 60 days of initial operation under this ATC. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
28. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, and 4305, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
31. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, and 4306] Federally Enforceable Through Title V Permit
32. Formerly S-1511-47

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-725-20

EXPIRATION DATE: 05/31/2016

SECTION: SW01 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR C.E. NATCO NATURAL GAS STEAM GENERATOR WITH A COEN QLN-ULN LOW-NOX BURNER AND FLUE GAS RECIRCULATION (#1-1B) (BELRIDGE)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
4. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
5. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2 and 4801.3.1] Federally Enforceable Through Title V Permit
6. Natural gas fuel sulfur content shall not exceed 0.75 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Steam generator shall be operated at no greater than 1,466.7 MMBtu hhv/day heat input. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of higher heating value and daily quantity of natural gas burned in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC quality natural gas (as defined in Rule 4320), by volume. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
11. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.002 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.014 lb/MMBtu or 12 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201; 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
12. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
13. Emission rates shall not exceed any of the following: PM10: 7.3 lb/day, SOx (as SO2): 2.9 lb/day, VOC: 4.4 lb/day, NOx (as NO2): 52.8 lb/day or 7495 lb/year, or CO: 44.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of start-up and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5 and 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
18. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

19. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
20. For each steam generator site downstream of H₂S scavenger chemical injection points, permittee shall monitor sulfur content of the gas prior to incineration in affected steam generators on a daily basis utilizing Draeger tubes calibrated for existing sulfur species or other District-approved fuel sulfur detection method(s) or device(s). If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
24. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
25. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2, 4306, 6.2 and 4320, 6.1] Federally Enforceable Through Title V Permit
26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
27. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305,6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit
28. Formerly S-1511-50
29. All equipment, facilities, or systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 78-11] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

30. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in the conditions below. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 78-11] Federally Enforceable Through Title V Permit
31. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions below, and the methods utilized to restore normal operations. [PSD SJ 78-11] Federally Enforceable Through Title V Permit
32. Facility shall operate this unit in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable federal, State and local air quality regulations. [PSD SJ 78-11] Federally Enforceable Through Title V Permit
33. Exhaust gases shall be ducted through operating scrubber(s) at all times during the operation of this unit. [PSD SJ 78-11] Federally Enforceable Through Title V Permit
34. Facility shall conduct annual performance tests for SOx and furnish the EPA and the District a written report of the results of such tests. Performance testing may be conducted at any other time specified by the EPA. The tests shall be conducted at the maximum operating capacity of the unit. [PSD SJ 78-11] Federally Enforceable Through Title V Permit
35. Performance tests for SOx (as SO2) shall be conducted and the results reported in accordance with the test methods in 40 CFR 60, Part 60.8 and 60.46. [PSD SJ 78-11] Federally Enforceable Through Title V Permit
36. EPA shall be notified in writing at least 30 days prior to performance tests. [PSD SJ 78-11] Federally Enforceable Through Title V Permit
37. All correspondence as required by this permit shall be forwarded to: a) Director, Air Management Division, Compliance Section (Attn: A-3-3), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; and c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726. [PSD SJ 78-11] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-757-21

EXPIRATION DATE: 05/31/2016

SECTION: SW02 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR WITH A COEN QLN-ULN ULTRA LOW NOX BURNER AND FLUE GAS RECIRCULATION (#2-5J) (BELRIDGE)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
4. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2.1 and Rule 4801, 3.1] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Steam generator shall be operated at no greater than 1,466.7 MMBtu hhv/day heat input. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of higher heating value and daily quantity of natural gas burned in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Natural gas fuel sulfur content shall not exceed 0.75 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
9. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC quality natural gas (as defined in Rule 4320), by volume. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
11. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
12. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
13. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: PM-10: 0.005 lb/MMBtu, SO₂: 0.002 lb/MMBtu, VOC: 0.003 lb/MMBtu, NO_x (as NO₂): 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O₂. [District Rules 2201, 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
14. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
15. Emission rates shall not exceed any of the following: PM₁₀: 7.3 lb/day, SO_x (as SO₂): 2.9 lb/day, VOC: 4.4 lb/day, NO_x (as NO₂): 52.8 lb/day or 7495 lb/year, or CO: 44.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.5 and 4320, 5.7] Federally Enforceable Through Title V Permit
18. If the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
22. For each steam generator site downstream of H₂S scavenger chemical injection points, permittee shall monitor sulfur content of the gas prior to incineration in affected steam generators on a daily basis utilizing Draeger tubes calibrated for existing sulfur species or other District-approved fuel sulfur detection method(s) or device(s). If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 2201] Federally Enforceable Through Title V Permit
23. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
24. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
26. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
27. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1, 4305,6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.5] Federally Enforceable Through Title V Permit
29. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit
30. Note: Formerly S-1511-114

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-759-20

EXPIRATION DATE: 05/31/2016

SECTION: SW02 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR WITH FLUE GAS RECIRCULATION (#2-5H)
(BELRIDGE)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
4. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2.1 and Rule 4801, 3.1] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Natural gas fuel sulfur content shall not exceed 0.75 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
7. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H₂S: ASTM D6228 or grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
8. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC quality natural gas (as defined in Rule 4320), by volume. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
9. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
11. Emission rates, except during startup, shutdown or refractory curing, shall not exceed any of the following: PM-10: 0.005 lb/MMBtu, SO₂: 0.002 lb/MMBtu, NO_x: 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO 1.3 ppmv @ 3% O₂. [District Rules 2201, 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
12. Steam generator shall be operated at no greater than 1,466.7 MMBtu hhw/day heat input. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
14. Permittee shall maintain records of higher heating value and daily quantity of natural gas burned in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
15. For each steam generator site downstream of H₂S scavenger chemical injection points, permittee shall monitor sulfur content of the gas prior to incineration in affected steam generators on a daily basis utilizing Draeger tubes calibrated for existing sulfur species or other District-approved fuel sulfur detection method(s) or device(s). If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
17. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months, (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months, (no more than 30 days before or after the required 36 months source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
18. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.7] Federally Enforceable Through Title V Permit
19. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
21. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NO_x and CO. [District 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
22. Note: Formerly S-1511-116

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-802-22

EXPIRATION DATE: 05/31/2016

SECTION: NW11 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/TEOR GAS FIRED STEAM GENERATOR (11-1G, BELRIDGE) WITH FLUE GAS RECIRCULATION AND COEN QLN-ULN 3.2 LOW-NOX BURNER

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
4. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 4301, 5.2 and Rule 4801, 3.1] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Steam generator shall be equipped with an operational fuel gas volumetric flow meter. [District Rule 2201] Federally Enforceable Through Title V Permit
7. When TEOR gas is connected to this unit, steam generator shall be equipped with an operational volumetric TEOR gas flow meter. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Permittee shall notify the District, in writing, at least 15 days prior to burning TEOR gas and when discontinuing the burning of TEOR gas. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Annual heat input to steam generator shall not exceed 525.6 billion BTU hhv. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC quality natural gas (as defined in Rule 4320), by volume. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
12. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320, 5.7 and 6.2] Federally Enforceable Through Title V Permit
13. Emission rates shall not exceed any of the following: PM-10: 0.005 lb/MMBtu, NO_x (as NO₂): 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, SO_x (as SO₂): 0.002 lb/MMBtu, VOC: 0.003 lb/MMBtu or CO: 1.9 ppmv @ 3% O₂. [District Rules 2201, 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
14. Permittee shall maintain records of higher heating value and daily quantity of natural gas and vapor recovery gas burned in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
16. For each steam generator site downstream of H₂S scavenger chemical injection points, permittee shall monitor sulfur content of the gas prior to incineration in affected steam generators on a daily basis utilizing Draeger tubes calibrated for existing sulfur species or other District-approved fuel sulfur detection method(s) or device(s). If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months, (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months, (no more than 30 days before or after the required 36 months source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
19. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.7] Federally Enforceable Through Title V Permit
20. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
22. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NO_x and CO. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.5] Federally Enforceable Through Title V Permit
23. Formerly S-1511-172

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-808-18

EXPIRATION DATE: 05/31/2016

SECTION: NW11 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR, WITH COEN QLN-ULN BURNER, FLUE GAS RECIRCULATION (#11-1H) (BELRIDGE)

PERMIT UNIT REQUIREMENTS

1. Steam generator shall be equipped with operational fuel gas volumetric flow meter . [District Rule 2201] Federally Enforceable Through Title V Permit
2. When TEOR gas is connected to this unit, steam generator shall be equipped with an operational volumetric TEOR gas flow meter. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Permittee shall notify the District, in writing, at least 15 days prior to burning TEOR gas and when discontinuing the burning of TEOR gas. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC quality natural gas (as defined in Rule 4320), by volume. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
5. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
6. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
7. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: PM₁₀ - 0.005 lb/MMBtu; SO_x (as SO₂) - 0.002 lb/MMBtu; VOC - 0.003 lb/MMBtu; NO_x (as NO₂) - 0.014 lb/MMBtu or 12 ppmv @ 3% O₂; or CO - 0.030 lb/MMBtu or 40.0 ppmv @ 3% O₂. [District Rule 2201 and District Rules 2201; 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
8. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
9. Emission rates shall not exceed any of the following: PM₁₀ - 7.5 lb/day; SO_x (as SO₂) - 3.0 lb/day; VOC - 4.5 lb/day; NO_x (as NO₂) - 51.0 lb/day or 7665 lb/year; or CO - 45.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
11. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
12. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
13. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
14. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
15. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
17. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

18. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
19. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
21. For each steam generator site downstream of H₂S scavenger chemical injection points, permittee shall monitor sulfur content of the gas prior to incineration in affected steam generators on a daily basis utilizing Draeger tubes calibrated for existing sulfur species or other District-approved fuel sulfur detection method(s) or device(s). If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
24. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2; 4306, 6.2 and 4320, 6.1] Federally Enforceable Through Title V Permit
25. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: fire the unit only on PUC or FERC regulated natural gas, test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2.1 and Rule 4801, 3.1] Federally Enforceable Through Title V Permit
26. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
27. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record all dates on which this unit is fired on any noncertified fuel and record the specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of higher heating value and daily quantity of natural gas and vapor recovery gas burned in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
29. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306 and 4320, 6.1] Federally Enforceable Through Title V Permit
30. Note: Formerly S-1511-189

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-809-21

EXPIRATION DATE: 05/31/2016

SECTION: SW01 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR GAS-FIRED C.E. NATCO STEAM GENERATOR, WITH A COEN MODEL ULN LOW NOX BURNER, FLUE GAS RECIRCULATION AND OXYGEN ANALYZER/CONTROLLER. (#1-1D) (BELRIDGE)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
4. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2 and Rule 4801, 3.1] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Steam generator shall be equipped with operational fuel gas volumetric flow meter. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of higher heating value and daily quantity of natural gas and vapor recovery gas burned in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC quality natural gas (as defined in Rule 4320), by volume. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
9. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320] Federally Enforceable Through Title V Permit
11. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: PM₁₀: 0.005 lb/MMBtu, SO_x (as SO₂): 0.002 lb/MMBtu, VOC: 0.003 lb/MMBtu, NO_x (as NO₂): 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O₂. [District Rules 2201; 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
12. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
13. Emission rates shall not exceed any of the following: PM₁₀: 7.5 lb/day, SO_x (as SO₂): 3.0 lb/day, VOC: 4.5 lb/day, NO_x (as NO₂): 51.0 lb/day or 7665 lb/year, or CO: 45.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
15. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
16. If the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
18. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

19. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
20. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rule 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
26. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit
27. Formerly S-1511-190

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-836-21

EXPIRATION DATE: 05/31/2016

SECTION: SW01 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A COEN QLN-ULN 3.2 LOW-NOX BURNER, WITH FLUE GAS RECIRCULATION (FGR) AND NON-CONDENSABLE PIPING FROM VAPOR CONTROL SYSTEM, (#1-1E) (BELRIDGE)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
5. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 4301, 5.2.1 and Rule 4801, 3.1] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. Steam generator shall be equipped with operational fuel gas volumetric flow meter . [District Rule 2201] Federally Enforceable Through Title V Permit
8. When TEOR gas is connected to this unit, steam generator shall be equipped with an operational volumetric TEOR gas flow meter. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Permittee shall notify the District, in writing, at least 15 days prior to burning TEOR gas and when discontinuing the burning of TEOR gas. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Maximum TEOR gas flow rate for this unit shall not exceed 1,300 Mcf/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC quality natural gas (as defined in Rule 4320), by volume. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
12. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
13. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
14. When fired exclusively on natural gas, except during startup, shutdown, and refractory curing, emissions from this unit shall not exceed either of the following limits: PM₁₀: 0.005 lb/MMBtu or SO_x (as SO₂): 0.002 lb/MMBtu. [District Rule 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
15. When natural gas and TEOR gas fired, except during startup, shutdown, and refractory curing, maximum PM₁₀ emissions shall not exceed the lb/hr limit calculated as follows: $PM_{10} = \{(7.0 \text{ lb/day}) + (249.2 \text{ lb/day}) \times (\text{fraction of total TEOR gas incinerated in this unit during testing})\} / (24 \text{ hr/day})$. [District Rules 2201 and 4201, 3.0] Federally Enforceable Through Title V Permit
16. Steam generator shall be operated at no greater than 1,466.7 MMBtu h_hv/day heat input. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: VOC: 0.003 lb/MMBtu, NO_x (as NO₂): 0.014 lb/MMBtu or 12 ppmv @ 3% O₂, or CO: 0.030 lb/MMBtu or 40.0 ppmv @ 3% O₂. [District Rule 2201; 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
18. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO₂; sulfur - 200 pounds of SO₂ per hour, or 2000 ppmv as SO₂, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO₂ - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4201, 3.0; 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
19. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
21. If the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.7] Federally Enforceable Through Title V Permit
25. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
27. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D3246, D4084, D4468 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.5] Federally Enforceable Through Title V Permit
30. Only natural gas or a combination of natural gas and scrubbed non-condensable gas from sulfur scrubbing system(s) S-1547-359 shall be used as fuel in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
31. For each steam generator site downstream of H₂S scavenger chemical injection points, permittee shall monitor sulfur content of the gas prior to incineration in affected steam generators on a daily basis utilizing Draeger tubes calibrated for existing sulfur species or other District-approved fuel sulfur detection method(s) or device(s). If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
33. Sample collection for compliance demonstration (source testing) shall be by an ARB certified testing laboratory and shall be District witnessed or authorized. [District Rule 1081] Federally Enforceable Through Title V Permit
34. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 4305, 6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit
35. Permittee shall maintain accurate records of heating values (in Btu/scf) and daily consumption of natural gas/TEOR waste gas. [District Rule 2201, District Rules 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
36. NOTE: There are no sulfur compounds daily emission limits (DELs) expressed on this permit for incineration of TEOR gas, sulfur compounds emissions are limited by DELs on permit S-1547-359.
37. Formerly S-1511-253

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-837-22

EXPIRATION DATE: 05/31/2016

SECTION: NW11 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR WITH A COEN ULN LOW NOX BURNER, FLUE GAS RECIRCULATION, AND NON-CONDENSIBLE PIPING FROM VAPOR CONTROL SYSTEM S-1547-359. (#11-1F) (BELRIDGE)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. Emissions from gaseous fired units shall not exceed 200 lb sulfur compounds/hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 4301, 5.2.1, and 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
5. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2.1 and Rule 4801, 3.1] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. Steam generator shall be equipped with operational fuel gas volumetric flow meter . [District Rule 2201] Federally Enforceable Through Title V Permit
8. Steam generator shall be equipped with operational vapor control system gas supply volumetric flow meter whenever unit is connected to the vapor control system gas supply. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Maximum TEOR gas flow rate for this unit shall not exceed 1,300 Mcf/day. [District Rule 2201] Federally Enforceable Through Title V Permit
10. When fired exclusively on natural gas, except during startup, shutdown, and refractory curing, emissions from this unit shall not exceed either of the following limits: PM10: 0.005 lb/MMBtu or SOx (as SO2): 0.002 lb/MMBtu. [District Rules 2201; 4201, 3.0; and 4320, 5.4] Federally Enforceable Through Title V Permit
11. When natural gas and TEOR gas fired, except during startup, shutdown, and refractory curing, maximum PM10 emissions shall not exceed the lb/hr limit calculated as follows: $PM10 = \{(7.0 \text{ lb/day}) + (249.2 \text{ lb/day}) \times (\text{fraction of total TEOR gas incinerated in this unit during testing})\} / (24 \text{ hr/day})$. [District Rules 2201, 2520, 4201 and 4301] Federally Enforceable Through Title V Permit
12. Steam generator shall be operated at no greater than 1,466.7 MMBtu hhw/day heat input. [District Rule 2201] Federally Enforceable Through Title V Permit
13. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC quality natural gas (as defined in Rule 4320), by volume. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
14. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
15. Fuel H2S, total sulfur, and methane content shall be determined semi-annually using the test methods specified in this permit. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
16. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, the following test methods (or other approved methods listed in this permit) shall be used; H2S: ASTM D6228 or grab sample analysis by double GC for H2S and mercaptans performed in the laboratory; total sulfur: ASTM 1072, D3246, D4084 or D6228; and methane content: ASTM D1945. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
17. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.014 lb/MMBtu or 12 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40.0 ppmv @ 3% O2. [District Rule 2201; 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
18. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4201, 3.0; 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
19. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 5.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. If the NOx or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NOx and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 5.7] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.7] Federally Enforceable Through Title V Permit
25. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4320, 6.3] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
27. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.5] Federally Enforceable Through Title V Permit
30. Only natural gas or a combination of natural gas and scrubbed non-condensable gas from sulfur scrubbing system(s) S-1547-359 shall be used as fuel in this steam generator. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
31. For each steam generator site downstream of H₂S scavenger chemical injection points, permittee shall monitor sulfur content of the gas prior to incineration in affected steam generators on a daily basis utilizing Draeger tubes calibrated for existing sulfur species or other District-approved fuel sulfur detection method(s) or device(s). If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 4320] Federally Enforceable Through Title V Permit
32. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
33. Sample collection for compliance demonstration (source testing) shall be by an ARB certified testing laboratory and shall be District witnessed or authorized. [District Rule 1081] Federally Enforceable Through Title V Permit
34. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 4305, 6.1; 4306, 6.1 and 4320, 6.1] Federally Enforceable Through Title V Permit
35. Permittee shall maintain accurate records of heating values (in Btu/scf) and daily consumption of natural gas/TEOR waste gas. [District Rule 4320, District Rules 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
36. NOTE: There are no sulfur compounds daily emission limits (DELs) expressed on this permit for incineration of TEOR gas, sulfur compounds emissions are limited by DELs on permit S-1547-359.
37. Formerly S-1511-253

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-1034-17

EXPIRATION DATE: 05/31/2016

SECTION: NW11 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH A FLUE GAS RECIRCULATION (#11-1I)
(BELRIDGE) WITH A COEN MODEL QLN-ULN LOW NOX BURNER

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
4. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2.1 and Rule 4801, 3.1] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Natural gas fuel sulfur content shall not exceed 0.47 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC quality natural gas (as defined in Rule 4320), by volume. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
9. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.0013 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.014 lb/MMBtu or 12 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201; 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
11. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
12. Emission rates shall not exceed any of the following: PM10: 7.5 lb/day, SOx (as SO2): 2.0 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 7665 lb/year, or CO: 45.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
13. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
14. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
15. If the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
16. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 432, 5.8] Federally Enforceable Through Title V Permit
17. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

18. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
19. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
20. For each steam generator site downstream of H₂S scavenger chemical injection points, permittee shall monitor sulfur content of the gas prior to incineration in affected steam generators on a daily basis utilizing Draeger tubes calibrated for existing sulfur species or other District-approved fuel sulfur detection method(s) or device(s). If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
26. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1547-1035-20

EXPIRATION DATE: 05/31/2016

SECTION: NW11 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR WITH WITH A COEN MODEL QLN-ULN LOW NOX BURNER AND FLUE GAS RECIRCULATION (#11-1J) (BELRIDGE)

PERMIT UNIT REQUIREMENTS

1. Copies of all fuel invoices showing quantity and delivery points of gas delivered and copies of quality terms of gas delivery contracts shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
4. The operator shall demonstrate compliance with this unit's sulfur compound exhaust concentration limit(s) using one of the following: test the sulfur content of each fuel source, or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 2520, 9.4.2, 4301, 5.2.1 and Rule 4801, 3.1] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Natural gas fuel sulfur content shall not exceed 0.47 gr S/100 scf. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The total gas fired in this unit, on a monthly volume basis, shall be less than 50% PUC quality natural gas (as defined in Rule 4320), by volume. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of the volume of PUC quality natural gas (as defined in Rule 4320) and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320, 5.2] Federally Enforceable Through Title V Permit
9. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the test methods (or other approved methods listed in this permit) H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Emission rates, except during startup, shutdown, and refractory curing shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.0013 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 0.014 lb/MMBtu or 12 ppmv @ 3% O2, or CO: 0.030 lb/MMBtu or 40 ppmv @ 3% O2. [District Rules 2201; 4305, 5.1; 4306, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
11. Emission rates during startup, shutdown and refractory curing shall not exceed: particulate matter - 10 pounds per hour, or 0.1 grains/dscf calculated to 12% CO2; sulfur - 200 pounds of SO2 per hour, or 2000 ppmv as SO2, or 0.11 pounds sulfur (as S) per MMBtu on average-wide basis for all units in Rule 4406 plan; NO2 - 140 pounds per hour or 0.14 pounds per MMBtu. [District Rules 4301, 5.2; 4405, 5.2; 4406, 4.2 and 4801, 3.1] Federally Enforceable Through Title V Permit
12. Emission rates shall not exceed any of the following: PM10: 7.5 lb/day, SOx (as SO2): 2.0 lb/day, VOC: 4.5 lb/day, NOx (as NO2): 54.0 lb/day or 7665 lb/year, or CO: 45.0 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
13. Duration of startup and shutdown (as defined in Rule 4320) shall not exceed 2 hours each per occurrence. Refractory curing period is defined as a maintenance-based reduced-load period of time during which a unit is brought from a shutdown status to staged rates of firing for the sole purpose of curing new refractory lining of the unit, and shall not exceed 30 hours per occurrence. The operator shall maintain records of the duration of start-up, shutdown, and refractory curing periods. [District Rules 4305, 5.5; 4306, 5.3 and 4320, 5.6] Federally Enforceable Through Title V Permit
14. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
15. If the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit
16. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5; 4306, 5.5 and 432, 5.8] Federally Enforceable Through Title V Permit
17. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4; 4306, 5.4 and 4320, 5.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

18. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
19. Compliance with fuel sulfur limit(s) can be demonstrated either by monitoring sulfur content at location(s) after all fuel sources are combined prior to incineration, or by monitoring the sulfur content and volume of each fuel source and performing mass balance calculations. Records of monitoring locations, detected sulfur concentrations, and mass balance calculations, if necessary, shall be maintained and kept onsite and made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
20. For each steam generator site downstream of H₂S scavenger chemical injection points, permittee shall monitor sulfur content of the gas prior to incineration in affected steam generators on a daily basis utilizing Draeger tubes calibrated for existing sulfur species or other District-approved fuel sulfur detection method(s) or device(s). If compliance with fuel sulfur content limit(s) for the affected steam generators is demonstrated for 5 consecutive days, then the monitoring frequency shall be weekly. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; 4306, 6.3 and 4306, 6.3] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 8 or 100 or EPA Method 6, 6B or 8 or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - ASTM D1072, D4468, D3246, D4084 or double GC for H₂S and mercaptans performed in laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081, 6.1; 4305, 6.2; 4306, 6.2 and 4320, 6.2] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5; 4306, 5.5 and 4320, 5.8] Federally Enforceable Through Title V Permit
26. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4.0; 4305, 6.1; 4306, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.