



# South Coast Air Quality Management District



21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

March 12, 2010

Mr. Harry L. Spencer  
East Los Angeles College  
1301 Avenida Cesar Chavez  
Monterey Park, CA 91754-6099

Subject: Title V Permit to Operate Revision  
East Los Angeles College  
ID 013854 A/N 501389

Dear Mr. Spencer:

Please find your revised facility permit. The permit reflects the addition of six boilers (A/N's 501193-501198) and an emergency internal combustion engine (A/N 501199). The boilers under A/N's 193945, 361749 and 361750 were taken out of service and the respective permits to operate deleted from the facility permit. This revision is considered a "de minimis significant revision" to the Title V Permit.

Please insert the enclosed sections into your facility permit and discard the earlier versions. Questions concerning these changes should be directed to the processing engineer, Maria Vibal at (909) 396-2422 or mvibal@aqmd.gov.

Sincerely,

Michael D. Mills, P.E.  
Senior Manager  
General Commercial and Energy Team  
Engineering and Compliance

MDM:RGC:MV

Enclosure

cc: (w/o Enclosures)  
Title V Facility File  
Title V Admin File

Certified Mail  
Return receipt Requested



## FACILITY PERMIT TO OPERATE

**EAST LOS ANGELES COLLEGE  
1301 AVENIDA CESAR CHAVEZ  
MONTEREY PARK, CA 91754**

### NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.  
EXECUTIVE OFFICER

By Mike Mills for  
Mohsen Nazemi, P.E.  
Deputy Executive Officer  
Engineering & Compliance



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	0	06/23/2004
B	RECLAIM Annual Emission Allocation	0	06/23/2004
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	5	03/12/2010
E	Administrative Conditions	0	06/23/2004
F	RECLAIM Monitoring and Source Testing Requirements	0	06/23/2004
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	0	06/23/2004
H	Permit To Construct and Temporary Permit to Operate	0	06/23/2004
I	Compliance Plans & Schedules	0	06/23/2004
J	Air Toxics	0	06/23/2004
K	Title V Administration	4	03/12/2010
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	0	06/23/2004
B	Rule Emission Limits	3	03/12/2010



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**Facility Equipment and Requirements  
(Section D)**

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**PERMITTED EQUIPMENT LIST**

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application number	Permit number	Equipment description
G01840	P41684	SPRAY BOOTH PAINT AND SOLVENT
193942	D15060	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL
193946	D10247	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
193947	D10248	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
193948	D10249	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
193949	D10250	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
193950	D10251	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
193951	D10252	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
333662	F10776	IC ENGINE (51-500 HP) NON-EMERGENCY PORTABLE NON-RENTAL DIESEL
417691	F64460	IC ENGINE (51-500 HP) EMERGENCY FIRE FIGHTING – DIESEL
431843	F70563	IC ENGINE (51-500 HP) EMERGENCY FIRE FIGHTING – DIESEL
467491	F94158	IC ENGINE (51-500 HP) EMERGENCY FIRE FIGHTING – DIESEL
487973	G3214	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL
491292	N24749	GASOLINE STORAGE AND DISPENSING EQUIPMENT
492405	G3209	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN – DIESEL
496061	G3544	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501193	G7589	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

501194	G7594	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501195	G7593	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501196	G7592	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501197	G7591	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501198	G7590	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
501199	G7588	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL

**NOTE:** EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### FACILITY WIDE CONDITION(S)

**Condition(s):**

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
  - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGELMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
  - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.  
[RULE 401]
  
2. THE OPERATOR SHALL NOT PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT AS SUPPLIED BY THE SUPPLIER.  
[RULE 431.2]
  
3. THE OPERATOR SHALL NOT USE NATURAL GAS CONTAINING SULFUR COMPOUNDS, CALCULATED AS H<sub>2</sub>S, IN EXCESS OF 16 PPMV. THE OPERATOR SHALL NOT USE OR SELL GASEOUS FUEL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 40 PPMV CALCULATED AS HYDROGEN SULFIDE AVERAGED OVER FOUR HOURS.  
[RULE 431.1]



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**PERMIT TO OPERATE**

**Permit No. P41684  
A/N G01840**

**Equipment Description:**

SPRAY BOOTH, BINKS, MODEL NO. FF-10-7-T, FLOOR FILTER TYPE, 10'-0" W. X 7'-0" L. X 9'-8" H., WITH A 1-HP EXHAUST FAN.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES  
[RULE 204]
3. THIS SPRAY BOOTH SHALL NOT BE OPERATED UNLESS ALL EXHAUST AIR PASSES THROUGH FILTER MEDIA AT LEAST TWO INCHES THICK.  
[RULE 1303(a)(1)-BACT]
4. A GAUGE SHALL BE INSTALLED AND MAINTAINED TO INDICATE, IN INCHES OF WATER, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE EXHAUST FILTERS. IN OPERATION, THE PRESSURE DIFFERENTIAL SHALL NOT EXCEED 0.25 INCH OF WATER.  
[RULE 1303(a)(1)-BACT]
5. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 1107, 1136, 1145 AND 1171.  
[RULE 1107, RULE 1136, RULE 1145, RULE 1171]

**Periodic Monitoring:**

6. THE OPERATOR SHALL PERFORM A WEEKLY INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):
  - A. THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA;
  - B. THE DATE, TIME AND RESULTS OF THE INSPECTION; AND
  - C. THE DATE, TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION.  
[RULE 3004 (a)(4)]
7. THE OPERATOR SHALL DETERMINE AND RECORD THE PRESSURE DROP ACROSS THE FILTER



---

## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

---

MEDIA ONCE EVERY WEEK.  
[RULE 3004 (a)(4)]

**Emissions And Requirements:**

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 109  
VOC: RULE 1107, SEE APPENDIX B FOR EMISSION LIMITS  
VOC: RULE 1136, SEE APPENDIX B FOR EMISSION LIMITS  
VOC: RULE 1145, SEE APPENDIX B FOR EMISSION LIMITS  
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS  
VOC: RULE 481  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO OPERATE

Permit No. D15060  
A/N 193942

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 4BT3.9, 4 CYLINDERS, FOUR CYCLE, TURBOCHARGED, 86 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.  
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304 (a)(4)-MODELING AND OFFSET, RULE 1470]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.  
[RULE 1470]
6. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
7. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

#### Periodic Monitoring:

8. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 3004 (a)(4)]



---

**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

---

**Emissions And Requirements:**

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO OPERATE

Permit No. D10247  
A/N 193946

#### Equipment Description:

BOILER, BRYAN, SECTIONAL TYPE, MODEL NO. 24C-23, SERIAL NO. ZX25735, RATED AT 2,310,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A BRYAN GAS BURNER.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]

#### Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409  
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS  
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS



---

**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

---

**PERMIT TO OPERATE**

**Permit No. D10248  
A/N 193947**

**Equipment Description:**

BOILER, BRYAN, WATER TUBE TYPE, MODEL NO. CL-300-WG, SERIAL NO. 49402, RATED AT 3,000,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A BRYAN GAS BURNER.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]

**Emissions And Requirements:**

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409  
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS  
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO OPERATE

Permit No. D10249  
A/N 193948

#### Equipment Description:

BOILER, BRYAN, WATER TUBE TYPE, MODEL NO. CL-300-WG, SERIAL NO. 49404, RATED AT 3,000,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A BRYAN GAS BURNER.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]

#### Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409  
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS  
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS



---

**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

---

**PERMIT TO OPERATE**

**Permit No. D10250  
A/N 193949**

**Equipment Description:**

BOILER NO. 2, NATIONAL, SECTIONAL TYPE, MODEL NO. 17-309, RATED AT 2,720,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A NATIONAL GAS BURNER.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]

**Emissions And Requirements:**

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409  
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS  
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO OPERATE

Permit No. D10251  
A/N 193950

#### Equipment Description:

BOILER NO. 1, NATIONAL, SECTIONAL TYPE, MODEL NO. 17-309, RATED AT 2,720,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A NATIONAL GAS BURNER.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]

#### Emissions And Requirements:

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409  
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS  
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS



---

**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

---

**PERMIT TO OPERATE**

**Permit No. D10252  
A/N 193951**

**Equipment Description:**

BOILER, BRYAN, WATER TUBE TYPE, MODEL NO. L36S-15, SERIAL NO. 49664, RATED AT 2,450,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH A BRYAN GAS BURNER.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]

**Emissions And Requirements:**

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409  
NOx: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS  
CO: RULE 1146.1, SEE SEC. I FOR REQUIREMENTS



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**PERMIT TO OPERATE**

**Permit No. F10776  
A/N 333662**

**Equipment Description:**

PORTABLE INTERNAL COMBUSTION ENGINE, JOHN DEERE, MODEL NO. SERIES 300, DIESEL-FUELED, NATURALLY ASPIRATED, 4 CYLINDERS, 78 BHP, COMPRESSOR DRIVER FOR A JACKHAMMER.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS EQUIPMENT SHALL NOT BE OPERATED FOR MORE THAN 12 MONTHS IN ANY ONE YEAR AT ANY ONE LOCATION IN THE DISTRICT.  
[RULE 1110.2]

**Emissions And Requirements:**

4. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
NOx: 770 PPM, RULE 1110.2  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO OPERATE

Permit No. F64460  
A/N 417691

#### Equipment Description:

(located at the Technology Bldg.)

INTERNAL COMBUSTION ENGINE, CLARKE, DIESEL-FUELED, EMERGENCY FIRE PUMP DRIVER, MODEL NO. VMFP-L6HR, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, FOUR CYCLE, 160 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION OF THIS ENGINE. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.  
[RULE 1470]
7. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

8. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST .  
[RULE 1470, RULE 431.2]

**Emissions And Requirements:**

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**PERMIT TO OPERATE**

**Permit No. F70563  
A/N 431843**

**Equipment Description:**

(located at Bldg. G-3)

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY FIRE PUMP DRIVER, MODEL NO. 6BT5.9-G6, SERIAL NO. 45879748, TURBOCHARGED, 6 CYLINDERS, FOUR CYCLE, 113 BHP.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING. THE ANNUAL HOURS OF OPERATION FOR MAINTENANCE AND TESTING SHALL BE REDUCED TO NO MORE THAN 30 HOURS PER YEAR BY JANUARY 1, 2006 AS REQUIRED IN RULE 1470(C)(3).  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTING ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION OF THIS ENGINE. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.  
[RULE 1303(b)(2)-OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.  
[RULE 1470]



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

7. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
  
8. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

### Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**PERMIT TO OPERATE**

**Permit No. F94158  
A/N 467491**

**Equipment Description:**

(located at the E-1 Bldg.)

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY FIRE PUMP DRIVER, MODEL NO. C-9 DITA, SERIAL NO. CLJ03854, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, 4-CYCLE, 275 BHP, EQUIPPED WITH A DIESEL PARTICULATE FILTER, CLEAN AIR SYSTEMS, CLEAN AIR PERMIT FILTER AND A HIBACK DATA LOGGING AND ALARM SYSTEM.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. THIS ENGINE SHALL NOT BE OPERATED FOR NON-EMERGENCY USE BETWEEN THE HOURS OF 7:30 A.M. AND 3:30 P.M. ON DAYS WHEN SCHOOL IS IN SESSION.  
[RULE 1470]
6. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS ITS EXHAUST IS VENTED TO A DIESEL PARTICULATE FILTER SYSTEM WHICH IS IN FULL OPERATION AND IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 1303(a)(1)-BACT]
7. THE OPERATOR SHALL OPERATE THE DIESEL PARTICULATE FILTER SYSTEM ONLY WITH AN OPERATIONAL HIBACK DATA LOGGING AND ALARM SYSTEM.  
[RULE 1303(a)(1)-BACT]
8. THE HIBACK LOGGING AND ALARM SYSTEM SHALL BE PROGRAMMED TO INTERFACE WITH THE ENGINE CONTROL SYSTEM TO AUTOMATICALLY SHUT THE ENGINE DOWN OR SWITCH IT



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

TO POWER DE-RATING MODE WHENEVER THE BACKPRESSURE OF THE DIESEL PARTICULATE FILTER SYSTEM EXCEEDS THE MAXIMUM BACKPRESSURE SETTING OF 40 INCHES OF WATER.  
[RULE 1303(a)(1)-BACT]

9. DURING MAINTENANCE AND PERFORMANCE TESTING, THE FIRE PUMP SHALL BE OPERATED WITH A WATER FLOWRATE OF AT LEAST 300 GAL/MIN.  
[RULE 1303(a)(1)-BACT]
10. THE OPERATOR SHALL KEEP MONTHLY RECORDS OF TEMPERATURE, PRESSURE, DATE AND TIME FOR THE DUTY CYCLE OF THE ENGINE AS DOWNLOADED FROM THE HIBACK LOGGING SYSTEM. THE OPERATOR SHALL ALSO RECORD THE FLOW RATE OF WATER, IN GAL/MIN, TO THE FIRE PUMP FOR THIS DUTY CYCLE. THESE MONTHLY RECORDS SHALL BE KEPT IN A FORMAT APPROVED BY THE EXECUTIVE OFFICER AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS. THE RECORDS SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1303(a)(1)-BACT]
11. THE OPERATOR SHALL MANUALLY TEST THE LED ALARM SYSTEM FOLLOWING THE PROCEDURES DESCRIBED IN THE MANUFACTURER'S INSTRUCTION MANUAL "TESTING THE SYSTEM WITH THE OPTIONAL TEST KIT". THE TEST SHALL BE CONDUCTED WITHIN SIX MONTHS FROM THE DATE OF THE ISSUANCE OF THIS PERMIT AND ANNUALLY THEREAFTER. THE TEST RECORDS SHALL BE KEPT ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1303(a)(1)-BACT]
12. THE OPERATOR SHALL REGENERATE THE DIESEL PARTICULATE FILTER AFTER EVERY 24 COLD ENGINE START-UPS OR WHENEVER A "YELLOW" WARNING SIGNAL IS RECEIVED FROM THE HIBACK ALARM SYSTEM, WHICHEVER OCCURS FIRST. IN ORDER TO ACHIEVE FILTER REGENERATION, THE OPERATOR SHALL RUN THE ENGINE UNTIL THE EXHAUST TEMPERATURE EXCEEDS 572 DEGREES FAHRENHEIT AND THE BACKPRESSURE MONITORING SYSTEM INDICATES A NORMAL BACKPRESSURE READING.  
[RULE 1303(a)(1)-BACT]
13. AFTER EVERY 5,000 HOURS OF NORMAL ENGINE OPERATION (EXCLUDING IDLING SESSIONS), THE OPERATOR SHALL INSPECT THE INTEGRITY OF THE FILTER AND, IF NECESSARY, REPLACE IT.  
[RULE 1303(a)(1)-BACT]
14. THE OPERATOR SHALL KEEP RECORDS OF PARTICULATE FILTER INSPECTIONS, REPLACEMENTS AND MANUAL REGENERATIONS. THE OPERATOR SHALL MAINTAIN THESE RECORDS FOR A MINIMUM OF FIVE YEARS AND MAKE THEM AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1303(a)(1)-BACT]
15. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:
  - A. EMERGENCY USE HOURS OF OPERATION
  - B. MAINTENANCE AND TESTING HOURS



---

## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

---

### C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

16. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470.  
[RULE 1470]
17. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
18. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

#### Emissions And Requirements:

19. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**PERMIT TO OPERATE**

**Permit No. G3214  
A/N 487973**

**Equipment Description:**

[located at Parking Structure 3]

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. QSB5-G3, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, 145 BHP.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING, AND NO MORE THAN 4.2 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING.  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTING ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1470]



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

7. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS :
  - A. EMERGENCY USE
  - B. MAINTENANCE AND TESTING
  - C. OTHERS (SPECIFY)

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READINGS (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
8. ON OR BEFORE JANUARY 15<sup>TH</sup> OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG :
  - A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
  - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
9. ENGINE OPERATION LOGS SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.  
[RULE 1470]
10. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.  
[RULE 1470, RULE 1472]
11. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
12. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

**Emissions And Requirements:**

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO OPERATE

Permit No. N24749  
A/N 491292

#### Equipment Description:

Fuel Storage and Dispensing Facility Consisting of:

- 1) 1 - GASOLINE BELLOWS-LESS NOZZLE DISPENSING 1 PRODUCT, EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM, HEALY PHASE II ENHANCED VAPOR RECOVERY (EVR) SYSTEM NOT INCLUDING ISD (VR-201-I).
- 2) 1 - GASOLINE UNDERGROUND STORAGE TANK, 6,000-GALLON CAPACITY, EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM OPW (VR-102-D/1), 1 METHANOL COMPATIBLE.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT WAS ISSUED, UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. ALL PERMIT CONDITIONS APPLICABLE TO THE EQUIPMENT DESCRIBED IN THE PREVIOUS PERMIT TO OPERATE N14836 SHALL REMAIN IN EFFECT UNTIL THE NEW OR MODIFIED EQUIPMENT IS CONSTRUCTED AND OPERATED AS DESCRIBED IN THIS NEW PERMIT. THIS PERMIT TO CONSTRUCT/OPERATE SHALL BECOME INVALID IF THE MODIFICATION AS DESCRIBED IN THE EQUIPMENT DESCRIPTION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE. IF THE MODIFICATION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE OF THE PERMIT, A WRITTEN REQUEST SHALL BE SUBMITTED TO THE AQMD (ATTENTION: RANDY MATSUYAMA) TO REINSTATE THE PREVIOUSLY INACTIVATED PERMIT TO OPERATE. A NEW APPLICATION SHALL BE FILED IF THERE ARE PLANS TO CONTINUE WITH THE MODIFICATION. FURTHERMORE, THIS CONDITION DOES NOT ALLOW ANY TIME EXTENSIONS TO ANY MODIFICATIONS REQUIRED BY THE CALIFORNIA AIR RESOURCES BOARD OR AQMD.  
[RULE 203]
4. EXCEPT FOR DIESEL TRANSFERS, PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS.  
[RULE 461, RULE 1303(a)(1)-BACT]
5. EXCEPT FOR DIESEL TRANSFERS, PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES, AS DEFINED IN RULE 461.



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

[RULE 461, RULE 1303(a)(1)-BACT]

6. ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS.  
[RULE 461, RULE 1303(a)(1)-BACT]
7. THE DISTRICT AT ITS DISCRETION MAY WISH TO WITNESS THE INSTALLATION AND/OR PERFORMANCE TESTING OF THE HEALY PHASE II EVR SYSTEM NOT INCLUDING ISD. AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO THE INSTALLATION AND PERFORMANCE TESTING OF THE HEALY PHASE II EVR SYSTEM NOT INCLUDING ISD, THE APPLICANT SHALL NOTIFY THE AQMD AT TELEPHONE NUMBER (866) 770-9140.  
[RULE 461]
8. NEW EQUIPMENT INSTALLATIONS AND SUBSEQUENT SERVICE AND REPAIRS FOR ANY CERTIFIED COMPONENT FOR WHICH THIS PERMIT WAS ISSUED, SHALL ONLY BE PERFORMED BY A CURRENT AND CERTIFIED PERSON WHO HAS SUCCESSFULLY COMPLETED THE MANUFACTURER'S TRAINING COURSE AND APPROPRIATE INTERNATIONAL CODE COUNCIL (ICC) CERTIFICATION. COMPLETION OF ANY AQMD TRAINING COURSE DOES NOT CONSTITUTE AS A SUBSTITUTE FOR THIS REQUIREMENT. PROOF OF SUCCESSFUL COMPLETION OF ANY MANUFACTURER TRAINING COURSE SHALL BE WITH THE MANUFACTURER.  
[RULE 461]
9. AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO BACK-FILLING ANY UNDERGROUND STORAGE TANK OR PIPING, THE SCAQMD SHALL BE NOTIFIED BY E-MAIL AT [R461BACKFILL@AQMD.GOV](mailto:R461BACKFILL@AQMD.GOV) OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTORS; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE BACK-FILLING PROCEDURE. THE BACK-FILLING PROCEDURE SHALL NOT COMMENCE UNTIL INSPECTED BY A DISTRICT REPRESENTATIVE.  
[RULE 461]
10. DEPENDING ON THE SYSTEM CONFIGURATION, A LEAK RATE TEST OF DROP TUBE/DRAIN VALVE ASSEMBLY SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF BOTH THE DROP TUBE AND DRAIN VALVE SEAL OR A LEAK RATE TEST OF DROP TUBE OVERFILL PREVENTION DEVICE AND DRAIN VALVE SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF THE DROP TUBE OVERFILL PREVENTION DEVICE AND THE PRESSURE INTEGRITY OF THE SPILL CONTAINER DRAIN VALVE. EITHER TEST SHALL BE CONDUCTED AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH TEST PROCEDURE METHOD TP-201.1C (OCTOBER 8, 2003) OR TP-201.1D (OCTOBER 8, 2003), RESPECTIVELY. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.  
[RULE 461]
11. A LEAK RATE AND CRACKING PRESSURE TEST OF PRESSURE/VACUUM RELIEF VENT VALVES SHALL BE CONDUCTED WITHIN TEN DAYS (10) AFTER THE START OF OPERATION OF THE OPW PHASE I EVR EQUIPMENT AND AT LEAST ONCE EVERY THREE (3) YEARS THEREAFTER TO DETERMINE THE PRESSURE AND VACUUM AT WHICH THE PRESSURE/VACUUM VENT VALVE



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

ACTUATES, AND TO DETERMINE THE VOLUMETRIC LEAK RATE AT A GIVEN PRESSURE. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD TP-201.1E (OCTOBER 8, 2003). RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST. THIS TEST RESULT SHALL BE KEPT ON SITE FOR THREE (3) YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

[RULE 461]

12. A STATIC TORQUE TEST OF ROTATABLE PHASE I ADAPTORS SHALL BE CONDUCTED TO QUANTIFY THE AMOUNT OF STATIC TORQUE REQUIRED TO START THE ROTATION OF THE ROTATABLE PHASE I ADAPTORS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD OUTLINED IN TP-201.1B (OCTOBER 8, 2003) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

[RULE 461]

13. THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED, OPERATED, AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE RISER, AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURE DESCRIBED BY THE CALIFORNIA AIR RESOURCES BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED:

NITROGEN FLOWRATES  
(CFH)  
60

DYNAMIC BACK PRESSURE  
(INCHES OF WATER)  
0.50

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP-201.4, METHODOLOGY 4 AND 6 (JULY 3, 2002); AS A PERFORMANCE TEST. THIS TEST SHALL BE A ONE-TIME TEST AND THE RESULTS KEPT PERMANENTLY ON SITE. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TESTS.

[RULE 461]

14. A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES, ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.3 (MARCH 17, 1999) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TEST.

[RULE 461]



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

15. A STATIC PRESSURE PERFORMANCE TEST FOR THE HEALY CLEAN AIR SEPARATOR USING BOTH THE VACUUM DECAY PROCEDURE AND THE POSITIVE PRESSURE PROCEDURE SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TIGHTNESS OF THE TANK PRESSURE MANAGEMENT SYSTEM. THESE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 4 OF CARB EXECUTIVE ORDER VR-201-I AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.  
[RULE 461]
16. A VAPOR TO LIQUID VOLUME RATIO TEST SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TO LIQUID (V/L) VOLUMETRIC RATIO OF THE HEALY CLEAN AIR SEPARATOR SYSTEM. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 5 OF CARB EXECUTIVE ORDER VR-201-I AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.  
[RULE 461]
17. A NOZZLE BAG TEST SHALL BE CONDUCTED ON THE HEALY PHASE II EVR NOZZLES TO VERIFY THE INTEGRITY OF THE VAPOR VALVE. THE TEST SHALL BE CONDUCTED ON ANY NEWLY INSTALLED OR REPLACED HEALY PHASE II EVR NOZZLES AND IN ACCORDANCE WITH EXHIBIT 7 OF CARB EXECUTIVE ORDER VR-201-I. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.  
[RULE 461]
18. THE STATIC PRESSURE LEAK DECAY TEST TP-201.3, SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 8 OF CARB EXECUTIVE ORDER VR-201-I. VERIFICATION OF COMPLETING EACH STEP AS OUTLINED SHALL BE DOCUMENTED BY SUBMITTING A COPY OF EXHIBIT 8 TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST.  
[RULE 461]
19. UNLESS AQMD RULE 461 REQUIRES A MORE FREQUENT TESTING OR INSPECTION SCHEDULE, THE OWNER/OPERATOR SHALL BE RESPONSIBLE TO PERFORM THE SCHEDULED WEEKLY, QUARTERLY, AND ANNUAL INSPECTIONS AS OUTLINED IN THE ARB APPROVED INSTALLATION, OPERATION, AND MAINTENANCE MANUAL FOR THE HEALY PHASE II EVR SYSTEMS, AS WELL AS ALL THE REQUIRED VAPOR RECOVERY SYSTEM TESTS AS PER THE CURRENT AND APPROPRIATE ARB EXECUTIVE ORDER.  
[RULE 461]
20. A CARB CERTIFIED PHASE II ENHANCED VAPOR RECOVERY SYSTEM SHALL BE FULLY PERMITTED, INSTALLED, AND TESTED BY OCTOBER 1, 2008. FAILURE TO ACHIEVE THIS CONDITION BY OCTOBER 1, 2008, SHALL RESULT IN THE OWNER/OPERATOR TO FILE A DISTRICT APPROVED COMPLIANCE PLAN OUTLINING THE INCREMENTS OF PROGRESS TOWARDS COMPLETING THE INSTALLATION OF A CARB CERTIFIED PHASE II ENHANCED VAPOR RECOVERY SYSTEM BY APRIL 1, 2009.  
[RULE 461]



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

- 21. IF THE OWNER/OPERATOR PLANS TO PERMANENTLY CEASE ALL GASOLINE DISPENSING OPERATIONS BEFORE APRIL 1, 2009, A COMPLIANCE PLAN SHALL BE FILED DECLARING TO IRREVOCABLY SURRENDER THEIR PERMIT TO OPERATE.  
[RULE 461]
- 22. THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396-3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO ANY OF THE ABOVE MENTIONED TESTING REQUIREMENTS. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR; THE NAME OF THE CONTRACTOR; THE LOCATION OF THE FACILITY; AND THE SCHEDULED START AND COMPLETION DATES OF THE TESTS TO BE PERFORMED.  
[RULE 461]
- 23. THE TESTING FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT.  
[RULE 461]
- 24. ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE FOR FIVE YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.  
[RULE 461]
- 25. SHOULD THE FACILITY DISPENSE MORE THAN 600,000 GALLONS OF GASOLINE PER CALENDAR YEAR AND IF THE FACILITY UNDERGOES A MAJOR MODIFICATION AS DEFINED BY CARB'S ADVISORY LETTER NUMBER 336, "ENHANCED VAPOR RECOVERY IMPLEMENTATION UPDATE" DATED APRIL 15, 2005; THE OPERATOR SHALL IMMEDIATELY CEASE ALL GASOLINE DISPENSING OPERATIONS AND FILE AN APPLICATION FOR A NEW PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM. GASOLINE DISPENSING OPERATIONS SHALL NOT RESUME UNTIL THE ISD SYSTEM HAS BEEN GRANTED A PERMIT TO CONSTRUCT/OPERATE AND HAS BEEN FULLY INSTALLED, TESTED, AND OPERATIVE.  
[RULE 461]
- 26. SHOULD THE FACILITY DISPENSE MORE THAN 600,000 GALLONS OF GASOLINE IN ANY CALENDAR YEAR AND IF THE FACILITY DOES NOT UNDERGO A MAJOR MODIFICATION AS DEFINED BY CARB'S ADVISORY LETTER NUMBER 336, "ENHANCED VAPOR RECOVERY IMPLEMENTATION UPDATE" DATED APRIL 15, 2005; THE OPERATOR SHALL FILE AN APPLICATION FOR A NEW PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM. THE ISD SYSTEM SHALL BE FULLY INSTALLED, TESTED, AND OPERATIVE BASED ON THE FOLLOWING TABLE:

<u>GASOLINE THROUGHPUT PER CALENDAR YEAR</u>	<u>DATE</u>
GREATER THAN 1.8 MILLION GALLONS	SEPTEMBER 1, 2009
BETWEEN 600,000 AND 1.8 MILLION GALLONS	SEPTEMBER 1, 2010

[RULE 461]

**Periodic Monitoring:**

- 27. THE OPERATOR SHALL HAVE A PERSON THAT HAS BEEN TRAINED IN ACCORDANCE WITH RULE 461(d)(4) CONDUCT A SEMI-ANNUAL INSPECTION OF THE GASOLINE TRANSFER AND



---

## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

---

DISPENSING EQUIPMENT. THE FIRST INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT B, THE SECOND INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT C, AND THE SUBSEQUENT INSPECTIONS SHALL ALTERNATE PROTOCOLS. THE OPERATOR SHALL KEEP RECORDS OF THE INSPECTION AND THE REPAIRS IN ACCORDANCE TO RULE 461 AND SECTION K OF THIS PERMIT.  
[RULE 3004 (a)(4)]

### Emissions And Requirements:

28. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 461

VOC: RULE 1170



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**PERMIT TO CONSTRUCT/OPERATE**

**Permit No. G3209  
A/N 492405**

**Equipment Description:**

[located at the Performing and Fine Arts Complex]

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6063-HV35, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, 550 BHP.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING, AND NO MORE THAN 4.2 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING.  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1470]



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

7. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS :

- A. EMERGENCY USE
- B. MAINTENANCE AND TESTING
- C. OTHERS (SPECIFY)

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READINGS (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.

[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. ON OR BEFORE JANUARY 15<sup>TH</sup> OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG :

- A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
- B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

9. ENGINE OPERATION LOGS SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

[RULE 1470]

10. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.

[RULE 1470, RULE 1472]

11. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.

[RULE 1470, RULE 431.2]

12. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST

[RULE 1470, RULE 431.2]

### Emissions And Requirements:

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**PERMIT TO CONSTRUCT/OPERATE**

**Permit No. G3544  
A/N 496061**

**Equipment Description:**

(Located at Bldg. E-9)

BOILER PARKER, WATER TUBE TYPE, MODEL NO. 105-90LR, RATED AT 3,780,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE PARKER PREMIX METAL FIBER LOW NOX BURNER, MODEL NO. PB-36LN.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR.  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
6. THIS BOILER SHALL USE NO MORE THAN 6,900 THERMS (655,000 CU. FT.) OF NATURAL GAS FUEL PER MONTH.  
[RULE 1303(b)(2)-OFFSET]
7. A NON-RESETTABLE TOTALIZING FUEL METER SHALL BE INSTALLED IN THE FUEL SUPPLY LINE TO THIS BOILER AND MAINTAINED IN GOOD OPERATING CONDITION.  
[RULE 1303(b)(2)-OFFSET]
8. RECORDS OF MONTHLY NATURAL GAS FUEL USAGE FOR THIS BOILER SHALL BE PREPARED, SHALL BE RETAINED ON SITE FOR FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.  
[RULE 1303(b)(2)-OFFSET]



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

9. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:
- A. SOURCE TESTING SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.
  - B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NO<sub>x</sub> AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.
  - C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE FIRING RATES.
  - D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT.
  - E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE HEATER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:
    - I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
    - II. THE FIRING RATES, IN BTU PER HOUR.
    - III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
    - IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
    - V. THE FUEL FLOW RATE.
  - F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.
  - G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

### Emissions And Requirements:

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- NO<sub>x</sub>: 30 PPMV, RULE 1146.1
  - NO<sub>x</sub>: 12 PPMV, RULE 1303(a)(1)-BACT
  - CO: 400 PPMV, RULE 1146.1
  - CO: 100 PPMV, RULE 1303(a)(1)-BACT



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 Copley Drive, Diamond Bar, CA 91765

Section D	Page 35
Facility I.D.:	013854
Revision #:	5
Date:	March 12, 2010

**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**PERMIT TO CONSTRUCT/OPERATE**

**Permit No. G7589  
A/N 501193**

**Equipment Description:**

(Located at the Central Plant)

BOILER NO. 1, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO<sub>x</sub> BURNER.

**Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR.  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub> AND CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS, OR 0.011 LB NO<sub>x</sub> PER MILLION BTU OF HEAT INPUT.  
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.  
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:
  - A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

- B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.
- C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.
- D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.
- E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:
- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
  - II. THE FIRING RATES, IN BTU PER HOUR.
  - III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
  - IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
  - V. THE FUEL FLOW RATE.
- F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.
- G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

### Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- NOx: 30 PPMV, RULE 1146.1  
NOx: 12 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146.1  
CO: 100 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO CONSTRUCT/OPERATE

Permit No. G7594  
A/N 501194

#### Equipment Description:

(Located at the Central Plant)

BOILER NO. 2, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO<sub>x</sub> BURNER.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR.  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub> AND CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS, OR 0.011 LB NO<sub>x</sub> PER MILLION BTU OF HEAT INPUT.  
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.  
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:  
  
A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

### Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1  
NOx: 12 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146.1  
CO: 100 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO CONSTRUCT/OPERATE

Permit No. G7593  
A/N 501195

#### Equipment Description:

(Located at the Central Plant)

BOILER NO. 3, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO<sub>x</sub> BURNER.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR.  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub> AND CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS, OR 0.011 LB NO<sub>x</sub> PER MILLION BTU OF HEAT INPUT.  
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.  
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:  
  
A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

### Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1  
NOx: 12 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146.1  
CO: 100 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO CONSTRUCT/OPERATE

Permit No. G7592  
A/N 501196

#### Equipment Description:

(Located at the Central Plant)

BOILER NO. 4, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO<sub>x</sub> BURNER.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR.  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub> AND CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS, OR 0.011 LB NO<sub>x</sub> PER MILLION BTU OF HEAT INPUT.  
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.  
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:  
  
A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

**Emissions And Requirements:**

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1  
NOx: 12 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146.1  
CO: 100 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO CONSTRUCT/OPERATE

Permit No. G7591  
A/N 501197

#### Equipment Description:

(Located at the Central Plant)

BOILER NO. 5, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO<sub>x</sub> BURNER.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR.  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub> AND CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS, OR 0.011 LB NO<sub>x</sub> PER MILLION BTU OF HEAT INPUT.  
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.  
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:  
  
A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

### Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1  
NOx: 12 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146.1  
CO: 100 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO CONSTRUCT/OPERATE

Permit No. G7590  
A/N 501198

#### Equipment Description:

(Located at the Central Plant)

BOILER NO. 6, CAMUS, WATER TUBE TYPE, MODEL NO. DYNAFLAME DFNH-5001, RATED AT 4,999,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE DYNAFLAME METAL FIBER LOW NO<sub>x</sub> BURNER.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 100 PPMV OF CARBON MONOXIDE (CO), ALL CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS AND AVERAGED OVER ONE (1) HOUR.  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
5. ON OR AFTER JANUARY 1, 2014, THIS BOILER SHALL EMIT NO MORE THAN 9 PPMV OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub> AND CORRECTED TO 3% O<sub>2</sub> ON A DRY BASIS, OR 0.011 LB NO<sub>x</sub> PER MILLION BTU OF HEAT INPUT.  
[RULE 1146.1]
6. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE SOURCE TESTING REQUIREMENTS OF RULE 1146.1(d)(6) AND (7).  
[RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]
7. THIS BOILER SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1146.1.  
[RULE 1146.1]
8. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT SOURCE TESTS UNDER THE FOLLOWING CONDITIONS:
  - A. SOURCE TESTING, IN ACCORDANCE WITH AN APPROVED SOURCE TEST PROTOCOL, SHALL BE CONDUCTED WITHIN 60 DAYS AFTER INITIAL START-UP UNLESS OTHERWISE APPROVED IN WRITING BY THE EXECUTIVE OFFICER.



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

B. THE SOURCE TESTS SHALL BE PERFORMED TO VERIFY COMPLIANCE WITH THE NOX AND CO EMISSION LIMITS SPECIFIED BY THIS PERMIT.

C. THE TESTS SHALL BE CONDUCTED WHILE THE BOILER IS FIRING AT MAXIMUM, MINIMUM AND AVERAGE LOADS USING NATURAL GAS. THE SAMPLING TIMES SHALL BE AT LEAST 15 CONSECUTIVE MINUTES FOR MAXIMUM AND MINIMUM LOADS AND AT LEAST ONE (1) HOUR FOR NORMAL OPERATING LOAD.

D. WRITTEN NOTICE OF THE SOURCE TESTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) AT LEAST 10 DAYS PRIOR TO TESTING SO THAT AN OBSERVER MAY BE PRESENT. THE TEST PROTOCOL SHALL BE SUBMITTED TO SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO TESTING.

E. TWO COMPLETE COPIES OF THE SOURCE TEST REPORTS SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, P.O. BOX 4941, DIAMOND BAR, CA 91765) WITHIN 30 DAYS AFTER THE TEST. THE REPORT SHALL INCLUDE, BUT NOT BE LIMITED TO EMISSIONS RATES IN POUNDS PER HOUR AND CONCENTRATIONS IN PPMV AT THE OUTLET OF THE BOILER, MEASURED ON A DRY BASIS AT 3% OXYGEN. THE FOLLOWING OPERATING DATA SHALL ALSO BE INCLUDED FOR EACH FIRING RATE:

- I. THE EXHAUST FLOW RATES, IN ACTUAL CUBIC FEET PER MINUTE (ACFM).
- II. THE FIRING RATES, IN BTU PER HOUR.
- III. THE EXHAUST TEMPERATURE, IN DEGREES FAHRENHEIT.
- IV. THE OXYGEN CONTENT OF THE EXHAUST GASES, IN PERCENT.
- V. THE FUEL FLOW RATE.

F. A TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST.

G. SAMPLING FACILITIES SHALL COMPLY WITH THE DISTRICT GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES, PURSUANT TO RULE 217. [RULE 1146.1, RULE 1303(a)(1)-BACT, RULE 1303(b)(2)-OFFSET]

### Emissions And Requirements:

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146.1  
NOx: 12 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146.1  
CO: 100 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### PERMIT TO CONSTRUCT/OPERATE

Permit No. G7588  
A/N 501199

#### Equipment Description:

(located at the Central Plant)

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. C-9, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, 4-CYCLE, 398 BHP, EQUIPPED WITH A DIESEL PARTICULATE FILTER, CLEAN AIR SYSTEMS, CLEAN AIRPERMIT FILTER, AND A HIBACK DATA LOGGING AND ALARM SYSTEM.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING, AND NO MORE THAN 4.2 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING .  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1470]

7. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS ITS EXHAUST IS VENTED TO A DIESEL PARTICULATE FILTER SYSTEM WHICH IS IN FULL OPERATION AND IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 1470]
8. THE OPERATOR SHALL OPERATE THE DIESEL PARTICULATE FILTER SYSTEM ONLY WITH AN OPERATIONAL HIBACK DATA LOGGING AND ALARM SYSTEM.  
[RULE 1470]
9. THE HIBACK LOGGING AND ALARM SYSTEM SHALL BE PROGRAMMED TO INTERFACE WITH THE ENGINE CONTROL SYSTEM TO AUTOMATICALLY SHUT THE ENGINE DOWN OR SWITCH IT TO POWER DE-RATING MODE WHENEVER THE BACKPRESSURE OF THE DIESEL PARTICULATE FILTER SYSTEM EXCEEDS THE MAXIMUM BACKPRESSURE SETTING OF 24 INCHES OF WATER.  
[RULE 1470]
10. THE TEMPERATURE OF THE ENGINE EXHAUST GAS AT THE INLET TO THE DIESEL PARTICULATE FILTER SYSTEM SHALL BE GREATER THAN OR EQUAL TO 300 DEGREES CELSIUS (572 DEGREES FAHRENHEIT) FOR 30% OF THE OPERATING TIME.  
[RULE 1470]
11. THE OPERATOR SHALL KEEP MONTHLY RECORDS OF TEMPERATURE, PRESSURE, DATE AND TIME FOR THE DUTY CYCLE OF THE ENGINE AS DOWNLOADED FROM THE HIBACK LOGGING SYSTEM. THESE MONTHLY RECORDS SHALL BE KEPT IN A FORMAT APPROVED BY THE EXECUTIVE OFFICER AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS. THE RECORDS SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1470]
12. THE OPERATOR SHALL MANUALLY TEST THE LED ALARM SYSTEM FOLLOWING THE PROCEDURES DESCRIBED IN THE MANUFACTURER'S INSTRUCTION MANUAL "TESTING THE SYSTEM WITH THE OPTIONAL TEST KIT". THE TEST SHALL BE CONDUCTED WITHIN SIX MONTHS FROM THE DATE OF THE ISSUANCE OF THIS PERMIT AND ANNUALLY THEREAFTER. THE TEST RECORDS SHALL BE KEPT ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1470]
13. THE OPERATOR SHALL REGENERATE THE DIESEL PARTICULATE FILTER AFTER EVERY 24 COLD ENGINE START-UPS OR WHENEVER A "YELLOW" WARNING SIGNAL IS RECEIVED FROM THE HIBACK ALARM SYSTEM, WHICHEVER OCCURS FIRST. IN ORDER TO ACHIEVE FILTER REGENERATION, THE OPERATOR SHALL RUN THE ENGINE UNTIL THE EXHAUST TEMPERATURE EXCEEDS 572 DEGREES FAHRENHEIT AND THE BACKPRESSURE MONITORING SYSTEM INDICATES A NORMAL BACKPRESSURE READING.  
[RULE 1470]



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

14. AFTER EVERY 5,000 HOURS OF NORMAL ENGINE OPERATION (EXCLUDING IDLING SESSIONS), THE OPERATOR SHALL INSPECT THE INTEGRITY OF THE FILTER AND, IF NECESSARY, REPLACE IT.  
[RULE 1470]
15. THE OPERATOR SHALL KEEP RECORDS OF PARTICULATE FILTER INSPECTIONS, REPLACEMENTS AND MANUAL REGENERATIONS. THE OPERATOR SHALL MAINTAIN THESE RECORDS FOR A MINIMUM OF FIVE YEARS AND MAKE THEM AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1470]
16. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS :
  - A. EMERGENCY USE
  - B. MAINTENANCE AND TESTING
  - C. OTHERS (SPECIFY)

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READINGS (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
17. ON OR BEFORE JANUARY 15<sup>TH</sup> OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG :
  - A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
  - B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
18. ENGINE OPERATION LOGS SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.  
[RULE 1470]
19. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULE 1470 AND 1472.  
[RULE 1470, RULE 1472]
20. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
21. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

[RULE 1470, RULE 431.2]

**Emissions And Requirements:**

22. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### RULE 219 EQUIPMENT

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

**Periodic Monitoring:**

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF:

- A. COATING TYPE,
- B. VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS,
- C. VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF:

- A. COATING TYPE,
- B. VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS,
- C. VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.  
[RULE 3004 (a) (4)]

**Emissions And Requirements:**

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS  
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### RULE 219 EQUIPMENT

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, HAND WIPING OPERATIONS.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



---

## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

---

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, BOILER, > 1 MMBTU/HR BUT < 2 MMBTU/HR.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409  
NOx: 30 PPMV, RULE 1146.2  
CO: 400 PPMV, RULE 1146.2  
CO: 2000 PPMV, RULE 407



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, AIR CONDITIONING UNITS

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT:      RULE 1415  
REFRIGERANT:      40CFR 82 SUBPART F



---

**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

---

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, REFRIGERATION UNITS

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT: RULE 1415  
REFRIGERANT: 40CFR 82 SUBPART F



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERANT RECOVERY AND/OR RECYCLING UNITS.

### Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

REFRIGERANT:           RULE 1415  
REFRIGERANT:           40CFR 82 SUBPART F



---

## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

---

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, PRINTING EQUIPMENT, LOW USE OR EMISSIONS, WITH RELATED COATING, LAMINATING AND DRYING EQUIPMENT.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
VOC: RULE 1130, SEE APPENDIX B FOR EMISSION LIMITS  
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, SPRAY COATING ENCLOSURES, < 8 FT<sup>3</sup> INTERNAL VOLUME.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**SECTION K: TITLE V Administration**

**GENERAL PROVISIONS**

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

**Permit Renewal and Expiration**

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]  
  
(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

**Duty to Provide Information**

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

**Payment of Fees**

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**SECTION K: TITLE V Administration**

**Reopening for Cause**

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
- (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
  - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
  - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

**COMPLIANCE PROVISIONS**

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
  - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
  - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
  - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
  - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
  - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]
  
10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]
  
11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]
  
12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]
  
13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]



## FACILITY PERMIT TO OPERATE EAST LOS ANGELES COLLEGE

### SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
  - (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
  - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
  - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
  - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
  - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
  - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**SECTION K: TITLE V Administration  
EMERGENCY PROVISIONS**

17. An emergency<sup>1</sup> constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
    - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
    - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
    - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
    - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
  - (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

---

<sup>1</sup> "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**SECTION K: TITLE V Administration  
RECORDKEEPING PROVISIONS**

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:

- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
- (B) The date(s) analyses were performed;
- (C) The company or entity that performed the analyses;
- (D) The analytical techniques or methods used;
- (E) The results of such analyses; and
- (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]

20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]

21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

**REPORTING PROVISIONS**

22. The operator shall comply with the following requirements for prompt reporting of deviations:

- (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**SECTION K: TITLE V Administration**

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
  - (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
  - (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**SECTION K: TITLE V Administration**

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn:  
Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

- 25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

**PERIODIC MONITORING**

- 26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**SECTION K: TITLE V Administration**

*FACILITY RULES*

*This facility is subject to the following rules and regulations*

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

<b>RULE SOURCE</b>	<b>Adopted/Amended Date</b>	<b>FEDERAL Enforceability</b>
RULE 109	5-2-2003	Federally enforceable
RULE 1107	1-6-2006	Non federally enforceable
RULE 1107	11-9-2001	Federally enforceable
RULE 1110.2	2-1-2008	Non federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	7-13-2007	Non federally enforceable
RULE 1130	10-8-1999	Federally enforceable
RULE 1136	6-14-1996	Federally enforceable
RULE 1145	12-3-2004	Non federally enforceable
RULE 1145	2-14-1997	Federally enforceable
RULE 1146	11-17-2000	Federally enforceable
RULE 1146	9-5-2008	Non federally enforceable
RULE 1146.1	5-13-1994	Federally enforceable
RULE 1146.1	9-5-2008	Non federally enforceable
RULE 1146.2	5-5-2006	Federally enforceable
RULE 1170	5-6-1988	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	5-1-2009	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**SECTION K: TITLE V Administration**

<b>RULE SOURCE</b>	<b>Adopted/Amended Date</b>	<b>FEDERAL Enforceability</b>
RULE 1401	12-7-1990	Non federally enforceable
RULE 1401	3-7-2008	Non federally enforceable
RULE 1401	5-2-2003	Non federally enforceable
RULE 1401	6-5-2009	Non federally enforceable
RULE 1401	8-13-1999	Non federally enforceable
RULE 1401	8-18-2000	Non federally enforceable
RULE 1415	10-14-1994	Non federally enforceable
RULE 1470	6-1-2007	Non federally enforceable
RULE 1472	3-7-2008	Non federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 212	11-14-1997	Non federally enforceable
RULE 212	12-7-1995	Federally enforceable
RULE 3004(a)(4)-Periodic Monitoring	12-12-1997	Federally enforceable
RULE 401	11-9-2001	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 431.1	6-12-1998	Federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 461	3-7-2008	Non federally enforceable
RULE 461	6-3-2005	Federally enforceable
RULE 481	1-11-2002	Federally enforceable
40CFR 82 Subpart F	5-14-1993	Federally enforceable



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1107 01-06-2006]**

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1107 01-06-2006]**

VOC LIMITS								
Less Water and Less Exempt Compounds								
Effective Dates, cont.								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5



---

**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

---

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1107 01-06-2006]**

- (2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.



**FACILITY PERMIT TO OPERATE  
 EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1107 11-09-2001]**

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1107 11-09-2001]**

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1107 11-09-2001]**

VOC LIMITS								
Less Water and Less Exempt Compounds								
Effective Dates, cont.								
Coating	Air-Dried				Baked			
	gm/l		lb/gal		gm/l		lb/gal	
	Current	7/1/07	Current	7/1/07	Current	7/1/07	Current	7/1/07
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5

- (2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1113 11-08-1996]**

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

**TABLE OF STANDARDS**

**VOC LIMITS**

**Grams of VOC Per Liter of Coating,  
Less Water And Less Exempt Compounds**

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior Coatings	350	450		350			
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250						
Graphic Arts (Sign) Coatings	500				100		50



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1113 11-08-1996]**

Industrial Maintenance						
Primers and Topcoats						
Alkyds	420					
Catalyzed Epoxy	420					
Bituminous Coatings	420					
Materials						
Inorganic Polymers	420					
Vinyl Chloride Polymers	420					
Chlorinated Rubber	420					
Acrylic Polymers	420					
Urethane Polymers	420					
Silicones	420					
Unique Vehicles	420					
Japans/Faux Finishing	350	700		350		
Coatings						
Magnesite Cement Coatings	600			450		
Mastic Coatings	300					
Metallic Pigmented Coatings	500					
Multi-Color Coatings	420					
Pigmented Lacquer	680		250		275	
Pre-Treatment Wash Primers	780		550			
Primers, Sealers, and	350					
Undercoaters						
Quick-Dry Enamels	400					
Roof Coatings	300					
Shellac						
Clear	730					
Pigmented	550					
Stains	350					
Swimming Pool Coatings						
Repair	650					
Other	340					
Traffic Coatings	250		150			
Waterproofing Sealers	400					
Wood Preservatives						
Below-Ground	350					
Other	350					

\* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

**TABLE OF STANDARDS (cont.)**

**VOC LIMITS**

**Grams of VOC Per Liter of Material**

COATING	Limit
Low-Solids Coating	120



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1113 07-13-2007]**

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings, except anti-graffiti coatings, for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1113 07-13-2007]  
TABLE OF STANDARDS  
VOC LIMITS**

**Grams of VOC Per Liter of Coating,  
Less Water and Less Exempt Compounds**

COATING CATEGORY	Ceiling Limit	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350							
Clear Wood Finishes	350					275		
Varnish	350					275		
Sanding Sealers	350					275		
Lacquer	680	550			275			
Clear Brushing Lacquer	680				275			
Concrete-Curing Compounds	350						100	
Concrete-Curing Compounds For Roadways and Bridges**	350							
Dry-Fog Coatings	400						150	
Fire-Proofing Exterior Coatings	450	350						
Fire-Retardant Coatings***								
Clear	650							
Pigmented	350							
Flats	250	100						50
Floor Coatings	420		100			50		
Graphic Arts (Sign) Coatings	500							
Industrial Maintenance (IM) Coatings	420			250		100		
High Temperature IM Coatings			420					
Zinc-Rich IM Primers	420		340			100		
Japans/Faux Finishing Coatings	700	350						
Magnesite Cement Coatings	600	450						
Mastic Coatings	300							
Metallic Pigmented Coatings	500							
Multi-Color Coatings	420	250						
Nonflat Coatings	250		150			50		



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1113 07-13-2007]**

COATING CATEGORY	Ceiling Limit	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Nonflat High Gloss	250		150				50	
Pigmented Lacquer	680	550			275			
Pre-Treatment Wash Primers	780		420					
Primers, Sealers, and Undercoaters	350		200			100		
Quick-Dry Enamels	400		250			150	50	
Quick-Dry Primers, Sealers, and Undercoaters	350		200			100		
Recycled Coatings			250					
Roof Coatings	300		250		50			
Roof Coatings, Aluminum	500				100			
Roof Primers, Bituminous	350		350					
Rust Preventative Coatings	420		400			100		
Shellac								
Clear	730							
Pigmented	550							
Specialty Primers	350					250	100	
Stains	350		250				100	
Stains, Interior	250							
Swimming Pool Coatings								
Repair	650		340					
Other	340							
Traffic Coatings	250	150					100	
Waterproofing Sealers	400		250			100		
Waterproofing Concrete/Masonry Sealers	400					100		
Wood Preservatives								
Below-Ground	350							
Other	350							

\* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.

\*\* Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

\*\*\* The Fire-Retardant Coating category will be eliminated on January 1, 2007 and subsumed by the coating category for which they are formulated.



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1113 07-13-2007]  
TABLE OF STANDARDS (cont.)  
VOC LIMITS**

**Grams of VOC Per Liter of Material**

COATING	Limit
Low-Solids Coating	120



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1130 10-08-1999]**

(Amended October 8, 1999)

**RULE 1130. GRAPHIC ARTS**

Except as otherwise provided in Rule 1130

(1) VOC Content of Graphic Arts Materials

The operator shall not apply any graphic arts material, including any VOC-containing materials added to the original graphic arts materials, which contains a total VOC in excess of the limits specified below:

<u>GRAPHIC ARTS MATERIAL</u>	<b>VOC LIMIT</b>	
	Grams per Liter of Coating (or Ink or Adhesive), Less Water and Less Exempt Compounds	
	<u>(October 8, 1999)</u>	<u>Effective January 1, 2000</u>
Lithographic Ink	300	300
Letterpress Ink	300	300
Gravure Ink	300	300
Flexographic Ink Non-Porous Substrate	300	300
Flexographic Ink Porous Substrate	300	225
Flexographic Fluorescent Ink	300	300
Coating	300	300
Adhesive	300	150



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1130 10-08-1999]**

(2) VOC Content of Fountain Solution

Through December 31, 1999, the operator shall not apply in any graphic arts operation any fountain solution, including any VOC-containing materials added to the original fountain solution, which contains a total VOC in excess of 100 grams per liter of material. Effective January 1, 2000, the VOC content of fountain solution, including any VOC containing material added to the original fountain solution as applied, shall be:

- (A) no greater than 80 grams per liter of material, or
- (B) no greater than 100 grams per liter of material, if a refrigerated chiller is used.



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1136 06-14-1996]**

Except as otherwise provided in Rule 1136

- (a) The operator shall not apply any coating to a wood product which has a VOC content, including any VOC-containing material added to the original coating supplied by the manufacturer, which exceeds the applicable limit specified below:

(1)

**VOC LIMITS**

Grams Per Liter (lb/gal) of Coating, [lbs VOC/lb of solids],  
Less Water and Less Exempt Compounds

<u>COATING</u>	<u>Current Limit</u>		<u>On and After</u>
	<u>I</u>	<u>or</u>	<u>7/1/2005</u>
		<u>II</u>	
Clear Sealers	550 (4.6) [1.39]	680 (5.7) [3.36]	275 (2.3) [0.36]
Clear Topcoat	550 (4.6) [1.37]	275 (2.3) [0.35]	275 (2.3) [0.35]
Pigmented Primers, Sealers & Undercoats	550 (4.6) [1.06]	600 (5.0) [1.08]	275 (2.3) [0.21]
Pigmented Topcoats	550 (4.6) [1.10]	275 (2.3) [0.25]	275 (2.3) [0.25]

The operator shall use coatings on a wood product that comply with either all VOC limits in column I or all VOC limits in column II. The operator that applies a primer, sealer or undercoat, but not a topcoat, to a wood product, shall be subject to column I for that wood product.

- (2) Notwithstanding the requirements of clause (a)(1), an operator that applies a topcoat and a primer, sealer or undercoat to a shutter may, until July 1, 2005, choose to comply with the VOC limits specified below for that shutter:



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1136 06-14-1996]**

**VOC LIMITS**

Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],  
Less Water and Less Exempt Compounds

**COATING**

Clear Sealers	275 (2.3) [0.36]
Clear Topcoat	680 (5.7) [2.99]
Pigmented Primers, Sealers & Undercoats	275 (2.3) [0.33]
Pigmented Topcoats	600 (5.0) [1.38]

(3)

**VOC LIMITS**

Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],  
Less Water and Less Exempt Compounds

**On and After**

**COATING**

	<b><u>Current Limit</u></b>	<b><u>7/1/2005</u></b>
Barrier Coat - Plastic Components	760 (6.3) [3.9]	275 (2.3) [0.28]
Composite Wood Edge Filler	550 (4.6) [1.15]	275 (2.3) [0.31]
Extreme Performance Coatings	420 (3.5) [0.51]	275 (2.3) [0.33]
Fillers	500 (4.2) [0.66]	275 (2.3) [0.18]
High-Solid Stains	550 (4.6) [1.23]	350 (2.9) [0.42]
Inks	500 (4.2) [0.96]	500 (4.2) [0.96]
Mold-Seal Coatings	750 (6.3) [4.2]	750 (6.3) [4.2]
Multi-Colored Coatings	685 (5.7) [2.6]	275 (2.3) [0.33]

**VOC LIMITS**

Grams Per Liter (lb/gal) of Material

**On and After**

**COATING**

	<b><u>Current Limit</u></b>	<b><u>7/1/2005</u></b>
Low-Solids Barrier Coat - Plastic Components	760 (6.3)	120 (1.0)
Low-Solid Stains, Toners, and Washcoats	480 (4.0)	120 (1.0)



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1136 06-14-1996]**

Any coating subject to this rule that meets any of the three VOC limit formats (grams per liter, lb/gal, or lbs VOC/lb of solids) is in compliance with this subparagraph.

- (4) The VOC limit for japan coatings is 700 grams per liter of coatings, less water and exempt compounds, as applied.
- (b) A person shall not use a stripper on wood products unless:
  - (1) it contains less than 350 grams of VOC per liter of material; or
  - (2) the VOC composite vapor pressure is 2 mm Hg (0.04 psia) or less at 20°C (68°F).





**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1145 02-14-1997]**

Except as otherwise provided in Rule 1145, the operator shall not apply on plastics, glass, or rubber any coatings which are applied with a VOC content in excess of the limits specified below:

COATING	VOC LIMITS			
	<u>Less Water and Less Exempt</u>			
	<u>Compounds</u>			
	<u>Current</u>		<u>On and After 1-1-98</u>	
	<u>g/L</u>	<u>lbs/gal</u>	<u>g/L</u>	<u>lbs/gal</u>
General Coatings				
One-component	275	2.3	275	2.3
Two-component	420	3.5	420	3.5
Military Spec. Coating				
One-component	340	2.8	340	2.8
Two-component	420	3.5	420	3.5
Multi-Colored Coatings	685	5.7	685	5.7
Mold Seal Coatings	750	6.3	750	6.3
Vacuum Metalizing Coatings	800	6.7	800	6.7
Mirror Backing				
Curtain Coated	500	4.2	500	4.2
Roll Coated	430	3.6	430	3.6
Optical Coatings	800	6.7	800	6.7
Electric Dissipating Coatings and Shock-				
Free Coatings	800	6.7	360	3.0
Metallic Coatings	420	3.5	420	3.5



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1171 11-07-2003]**

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1171 11-07-2003]**

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1171 11-07-2003]**

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)




**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1171 05-01-2009]**

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	<b>CURRENT LIMITS*</b>	<b>EFFECTIVE 1/1/2010</b>
<b>SOLVENT CLEANING ACTIVITY</b>	<b>VOC g/l (lb/gal)</b>	<b>VOC g/l (lb/gal)</b>
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)	
(B) Repair and Maintenance Cleaning		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	



**FACILITY PERMIT TO OPERATE  
 EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1171 05-01-2009]**

	<b>CURRENT LIMITS*</b>	<b>EFFECTIVE 1/1/2010</b>
<b>SOLVENT CLEANING ACTIVITY (cont.)</b>	<b>VOC g/l (lb/gal)</b>	<b>VOC g/l (lb/gal)</b>
(iii) Medical Devices & Pharmaceuticals		
(A) Tools, Equipment, & Machinery	800 (6.7)	
(B) General Work Surfaces	600 (5.0)	
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)	
(D) Cleaning of Ink Application Equipment		
(i) General	25 (0.21)	
(ii) Flexographic Printing	25 (0.21)	
(iii) Gravure Printing		
(A) Publication	100 (0.83)	
(B) Packaging	25 (0.21)	
(iv) Lithographic (Offset) or Letter Press Printing		
(A) Roller Wash, Blanket Wash, & On-Press Components	100 (0.83)	



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1171 05-01-2009]**

	<b>CURRENT LIMITS*</b>	<b>EFFECTIVE 1/1/2010</b>
<b>SOLVENT CLEANING ACTIVITY (cont.)</b>	<b>VOC g/l (lb/gal)</b>	<b>VOC g/l (lb/gal)</b>
(B) Removable Press Components	25 (0.21)	
(v) Screen Printing	100 (0.83)	
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)	

\* The specified limits remain in effect unless revised limits are listed in subsequent columns.



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 404 02-07-1986]**

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a). Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

**TABLE 404(a)**

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445



**FACILITY PERMIT TO OPERATE  
EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 404 02-07-1986]**

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148



**FACILITY PERMIT TO OPERATE  
 EAST LOS ANGELES COLLEGE**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 404 02-07-1986]**

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100