

South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

April 14, 2009

Mr. Gerardo Rios
Chief, Permits Office
USEPA – Region IX
75 Hawthorne Blvd.
San Francisco, CA 94105

Dear Mr. Rios,

Enclosed is the proposed revision to the Title V permit (Section D pages 60 through 63) for the facility listed below:

Facility ID #	Facility Name	Address
147371	Inland Empire Utilities Agency (IEUA), Regional Plant No. 5	6063 Kimball Avenue, Chino, CA 91710

The proposed revised Title V permit includes permits to construct /operate two, identical, emergency diesel fueled compression internal combustion engines (A/Ns 489261 & 489264). The proposed emergency engines are EPA/CARB certified under the provisions of 40 CFR 89, Tier 2 compliant, Non-road engines.

The permit revision is considered a de-minimis significant permit revision to the Title V permit. A public notice is not required. We respectfully request for your expedited review instead of the normal 45-day review and commentary period.

If there are specific questions on the revised permit, please contact Charles Tupac, AQAC Supervisor, at (909) 396-2684.

Sincerely,



Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery and Waste Management Permitting

JC: CDT: AIS

Enclosures

cc: Randy Lee, IEUA

A/N 489260- TV permit revision-02 folder.