

## **FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES**

### **Facility Equipment and Requirements (Section D)**

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY:

Application Number	Permit number	Equipment Description
144994	M54932	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN - DIESEL
144995	M54933	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN - DIESEL
223866	D67217	BOILER (5-20 MMBTU/HR) COMB GAS-DISTILLATE OIL
223867	D67725	BOILER (5-20 MMBTU/HR) COMB GAS-DISTILLATE OIL
234203	D67157	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
247315	D49145	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
247316	D49146	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - GASOLINE
247317	D49147	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - GASOLINE
274072	D70984	ETHYLENE OXIDE STERILIZATION CONTROL (HOSPITAL)
274073	D70985	ETHYLENE OXIDE STERILIZATION HOSPITAL
277249	D69912	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
281637	D74631	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
285593	D77807	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN - DIESEL
285594	D77808	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN - DIESEL
290011	F17461	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
290012	F17456	BOILER (5-20 MMBTU/HR) NATURAL GAS ONLY
327464	F7030	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN - DIESEL
364505	F31202	BOILER (5-20 MMBTU/HR) NATURAL GAS ONLY
371884	F39510	BOILER (5-20 MMBTU/HR) NATURAL GAS ONLY

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

372304	F39511	BOILER (5-20 MMBTU/HR) NATURAL GAS ONLY
389016	F50847	BOILER (5-20 MMBTU/HR) NATURAL GAS ONLY
389017	F43165	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN - DIESEL
414010	F64572	BOILER (5-20 MMBTU/HR) COMB GAS-DISTILLATE OIL
420087	F63642	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
420088	F63643	BOILER (<5 MMBTU/HR) NATURAL GAS ONLY
420481	F63782	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN - DIESEL
420639	F64654	BOILER (5-20 MMBTU/HR) NATURAL GAS ONLY
421325	F66092	BOILER (5-20 MMBTU/HR) NATURAL GAS ONLY
421326	F66093	BOILER (5-20 MMBTU/HR) NATURAL GAS ONLY
431730	F73815	CREMATORY, ANIMAL REMAINS
433571	F70274	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
443531	F80108	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
443878	F85190	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL
471089	F94546	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
471971	F94545	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
472960	F94543	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
472961	F94544	IC ENGINE (51-500 HP) EMERGENCY ELEC GEN - DIESEL
492932	Permit to Construct/Operate	IC ENGINE (> 500 HP) EMERGENCY ELEC GEN- - DIESEL

**NOTE:** EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### FACILITY WIDE CONDITION(S)

**Condition(s):**

1. EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS, THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS:
  - A. AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO. 1 ON THE RINGELMANN CHART, AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES; OR
  - B. OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION.  
[RULE 401]
  
2. THE OPERATOR SHALL NOT PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT AS SUPPLIED BY THE SUPPLIER.  
[RULE 431.2]
  
3. THE OPERATOR SHALL NOT USE NATURAL GAS CONTAINING SULFUR COMPOUNDS, CALCULATED AS H<sub>2</sub>S, IN EXCESS OF 16 PPMV. THE OPERATOR SHALL NOT USE OR SELL GASEOUS FUEL CONTAINING SULFUR COMPOUNDS IN EXCESS OF 40 PPMV CALCULATED AS HYDROGEN SULFIDE AVERAGED OVER FOUR HOURS.  
[RULE 431.1]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. M54932  
A/N 144994**

#### **Equipment Description:**

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3412, SERIAL NO. 58BH5189, 12 CYLINDERS, FOUR CYCLE, TURBOCHARGED, AFTERCOOLED, 890 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL BE OPERATED ONLY DURING UTILITY POWER FAILURE AND FOR 1 HOUR PER WEEK FOR MAINTENANCE TESTING PURPOSES.  
[RULE 1303(b)(2)-OFFSET]
4. THE OPERATING RECORDS OF THIS EQUIPMENT SHALL BE KEPT ON FILE AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1303(b)(2)-OFFSET, RULE 1470]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING. THE ANNUAL HOURS OF OPERATION FOR MAINTENANCE AND TESTING SHALL BE REDUCED TO NO MORE THAN 20 HOURS PER YEAR BY JANUARY 1, 2006 AS REQUIRED IN RULE 1470(c)(3).  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.  
[RULE 1470, RULE 1472]
7. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
8. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### **Periodic Monitoring:**

9. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 3004 (a)(4)]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

Permit No. M54933  
A/N 144995

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3412, SERIAL NO. 58BH5182, 12 CYLINDERS, FOUR CYCLE, TURBOCHARGED, AFTERCOOLED, 890 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL BE OPERATED ONLY DURING UTILITY POWER FAILURE AND FOR 1 HOUR PER WEEK FOR MAINTENANCE TESTING PURPOSES.  
[RULE 1303(b)(2)-OFFSET]
4. THE OPERATING RECORDS OF THIS EQUIPMENT SHALL BE KEPT ON FILE AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1303(b)(2)-OFFSET, RULE 1470]
5. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING. THE ANNUAL HOURS OF OPERATION FOR MAINTENANCE AND TESTING SHALL BE REDUCED TO NO MORE THAN 20 HOURS PER YEAR BY JANUARY 1, 2006 AS REQUIRED IN RULE 1470(c)(3).  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.  
[RULE 1470, RULE 1472]
7. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
8. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### **Periodic Monitoring:**

9. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 3004 (a)(4)]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

Permit No. D67217  
A/N 223866

#### Equipment Description:

BOILER, KEWANEE, MODEL NO. KX-86, SERIAL NO. N4005, RATED AT 10,920,000 BTU/HR, NATURAL GAS OR OIL-FIRED, WITH A KEWANEE BURNER, MODEL NO. KF-7.5-1162, WITH A 7.5-HP COMBUSTION AIR BLOWER AND EQUIPPED WITH A 7.5-HP FORCED DRAFT FLUE GAS RECIRCULATION SYSTEM.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS AND ONLY USE FUEL OIL DURING MAINTENANCE TESTING (NOT TO EXCEED 1/2 HOUR PER MONTH), SOURCE TESTING OR PERIODS OF NATURAL GAS CURTAILMENT.  
[RULE 1146, RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT]
4. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WITHIN ONE MINUTE AFTER THE MAIN FLAME IS ESTABLISHED. THE OXIDES OF NITROGEN CONCENTRATIONS IN THE FLUE GAS SHALL NOT EXCEED 30 PPM WHEN THE BOILER IS FIRED ON NATURAL GAS AND 40 PPM WHEN THE BOILER IS FIRED ON FUEL OIL, ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub> AND AVERAGED OVER A MINIMUM OF 15 CONSECUTIVE MINUTES.  
[RULE 1303(a)(1)-BACT, RULE 1146, RULE 1303(b)(2)-OFFSET]

#### Periodic Monitoring:

5. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF FUEL OIL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
  - A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT;  
OR

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

- B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORD BY A CERTIFIED SMOKE READER.  
[RULE 3004 (a)(4)]

6. FOR UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS, OR GREATER THAN 336 HOURS OF OPERATION BUT NOT EXCEEDING 2,000,000 GALLONS IN ANY ONE YEAR, THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.  
[RULE 3004 (a)(4)]

### **Emissions And Requirements:**

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NO<sub>x</sub>: 30 PPMV, RULE 1146 (using natural gas)  
NO<sub>x</sub>: 30 PPMV, RULE 1303(a)(1)-BACT  
NO<sub>x</sub>: 40 PPMV, RULE 1146 (using fuel oil)  
CO: 400 PPMV, RULE 1146  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

Permit No. D67725  
A/N 223867

#### Equipment Description:

BOILER, KEWANEE, SCOTCH MARINE TYPE, MODEL NO. L3S350G02, RATED AT 14,650,000 BTU PER HOUR, NATURAL GAS OR OIL-FIRED, WITH A KEWANEE BURNER, MODEL NO. KFC-10-1162, WITH A 10-HP COMBUSTION AIR BLOWER AND EQUIPPED WITH A 10-HP FORCED DRAFT FLUE GAS RECIRCULATION SYSTEM.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WITHIN ONE MINUTE AFTER THE MAIN FLAME IS ESTABLISHED.  
[RULE 1303(b)(2)-OFFSET, RULE 1146]
4. THIS BOILER SHALL COMPLY WITH RULE 1146.  
[RULE 1146]

#### Periodic Monitoring:

5. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF FUEL OIL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
  - A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT;  
OR
  - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
  - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
  - C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
  - D. VISIBLE EMISSION OBSERVATION RECORD BY A CERTIFIED SMOKE READER.  
[RULE 3004 (a)(4)]
6. FOR UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS, OR GREATER THAN 336 HOURS OF OPERATION BUT NOT EXCEEDING 2,000,000 GALLONS IN ANY ONE YEAR, THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.  
[RULE 3004 (a)(4)]

### **Emissions And Requirements:**

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

NOx: 30 PPMV, RULE 1146 (using natural gas)  
NOx: 40 PPMV, RULE 1146 (using fuel oil)  
CO: 400 PPMV, RULE 1146  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

Permit No. D67157  
A/N 234203

#### Equipment Description:

LIQUID HEATER, HITACHI, HORIZONTAL TUBE TYPE, MODEL NO. HAU-F-15G2, RATED AT 3,840,000 BTU PER HOUR, NATURAL GAS-FIRED, WITH ONE COEN BURNER, MODEL NO. SDAF-8.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS HEATER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1, RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT]
4. THIS HEATER SHALL EMIT NO MORE THAN 30 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(a)(1)-BACT, RULE 1146.1, RULE 1303(b)(2)-OFFSET]
5. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL MAINTAIN DISTRICT APPROVED RECORDS WHICH DEMONSTRATES THAT THE EQUIPMENT HAS MET, AND WILL CONTINUE TO MEET, CONDITION 4. THESE RECORDS SHALL BE MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1146.1, RULE 1303(b)(2)-OFFSET, RULE 1303(a)(1)-BACT]

#### Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
NO<sub>x</sub>: 30 PPMV, RULE 1146.1  
NO<sub>x</sub>: 30 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146.1  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

Permit No. R-D49145  
A/N 247315

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6BT5.9-G1, SERIAL NO. 44310862, TURBOCHARGED, 6 CYLINDERS, FOUR CYCLE, 135 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.  
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING. THE ANNUAL HOURS OF OPERATION FOR MAINTENANCE AND TESTING SHALL BE REDUCED TO NO MORE THAN 20 HOURS PER YEAR BY JANUARY 1, 2006 AS REQUIRED IN RULE 1470(c)(3).  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.  
[RULE 1470, RULE 1472]
6. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
7. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

#### Periodic Monitoring:

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

8. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 3004 (a)(4)]

**Emissions And Requirements:**

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## PERMIT TO OPERATE

**Permit No. R-D49146  
A/N 247316**

### **Equipment Description:**

INTERNAL COMBUSTION ENGINE, FORD, GASOLINE-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. LSG87516005A, SERIAL NO. 11987 K-3-TT, NATURALLY ASPIRATED, 8 CYLINDERS, FOUR CYCLE, 122 BHP.

### **Conditions:**

1. OPERATION OF THIS EQUIPMENT MUST BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT MUST BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.  
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.  
[RULE 1304(a)-MODELING AND OFFSET]

### **Periodic Monitoring:**

5. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 3004 (a)(4)]

### **Emissions And Requirements:**

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. R-D49147**  
**A/N 247317**

#### **Equipment Description:**

INTERNAL COMBUSTION ENGINE, WHITE, GASOLINE-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. G3400, SERIAL NO. NB3320278, NATURALLY ASPIRATED, 6 CYLINDERS, FOUR CYCLE, 105 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THE IGNITION TIMING OF THIS ENGINE SHALL BE INSPECTED, ADJUSTED, AND CERTIFIED AT A MINIMUM OF ONCE EVERY THREE YEARS OF OPERATION. INSPECTIONS, ADJUSTMENTS, AND CERTIFICATIONS MUST BE PERFORMED BY A QUALIFIED MECHANIC AND DONE IN ACCORDANCE WITH THE ENGINE MANUFACTURER'S SPECIFICATIONS AND PROCEDURES.  
[RULE 1303(a)(1)-BACT]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.  
[RULE 1304(a)-MODELING AND OFFSET]

#### **Periodic Monitoring:**

5. THE OPERATOR SHALL INSTALL AND MAINTAIN A NON-RESETTABLE ELAPSED TIME METER TO ACCURATELY INDICATE THE ELAPSED OPERATING TIME OF THE ENGINE.  
[RULE 3004 (a)(4)]

#### **Emissions And Requirements:**

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## PERMIT TO OPERATE

**Permit No. D70984**  
**A/N 274072**

### Equipment Description:

AIR POLLUTION CONTROL SYSTEM CONSISTING OF:

1. CATALYTIC OXIDIZER, DONALDSON, MODEL NO. ETX00-6550, SERIAL NO. 701075, 2'-3" W. X 3'-5" L. X 2'-2" H. (EXTERNAL DIMENSIONS), WITH AN AIR PREFILTER AND A 6-KW ELECTRIC HEATER.
2. EXHAUST SYSTEM WITH A 0.6-H.P. BLOWER VENTING AN ETHYLENE OXIDE STERILIZER/AERATOR.

### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THE TEMPERATURE OF THE EXHAUST FROM THE CATALYST BED SHALL BE MAINTAINED BETWEEN 280 AND 550 DEGREES FAHRENHEIT AS INDICATED BY A PROPER TEMPERATURE GAUGE AND/OR RECORDER.  
[RULE 1405]
4. THE OWNER OR OPERATOR OF THIS EQUIPMENT SHALL CONDUCT ANNUAL SOURCE TESTS PER AQMD RULE 1405(d)(6).  
[RULE 1405]
5. RECORDS SHALL BE MAINTAINED TO SHOW COMPLIANCE WITH CONDITION NUMBERS 3 AND 4. THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1405]

### Emissions And Requirements:

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR EMISSION LIMIT REQUIREMENTS  
ETHYLENE OXIDE: 40CFR 63 SUBPART O  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

Permit No. R-D70985  
A/N 274073

#### Equipment Description:

STERILIZER/AERATOR, ETHYLENE OXIDE GAS, 3M STERI-VAC, MODEL NO. 5XLP, SERIAL NO. 411393, 1'-6" W. X 2'-0" L. X 1'-4" H. (INTERNAL DIMENSIONS), STEAM-HEATED, WITH A 1.1-KW ELECTRIC HEATER.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THE MAXIMUM NUMBER OF LOADS PROCESSED IN THIS EQUIPMENT SHALL NOT EXCEED TWO IN ANY ONE DAY AND TWENTY-FIVE IN ANY CALENDAR MONTH.  
[RULE 1405]
4. THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS THE STERILIZER IS VENTED ONLY TO AIR POLLUTION CONTROL EQUIPMENT WHICH IS IN FULL USE AND HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER  
[RULE 1405]
5. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO. 3. THE RECORDS SHALL BE KEPT FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1405]
6. THIS EQUIPMENT SHALL COMPLY WITH RULE 1405.  
[RULE 1405]

#### Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :  
  
ETHYLENE OXIDE: RULE 1405(d), SEE RULE FOR EMISSION LIMIT REQUIREMENTS  
ETHYLENE OXIDE: 40CFR 63 SUBPART O  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

Permit No. D69912  
A/N 277249

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, GENERAC, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 43D, SERIAL NO. 2002298, NATURALLY ASPIRATED, 6 CYLINDERS, FOUR CYCLE, 64 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. EXCEPT FOR MAINTENANCE TESTING PURPOSES, THIS ENGINE SHALL ONLY OPERATE DURING UTILITY FAILURE PERIODS.  
[RULE 1304(a)-MODELING AND OFFSET]
7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.  
[RULE 1470, RULE 1472]
8. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

9. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

**Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. D74631**  
**A/N 281637**

#### **Equipment Description:**

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 6V-92TA, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS, 415 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING. THE ANNUAL HOURS OF OPERATION FOR MAINTENANCE AND TESTING SHALL BE REDUCED TO NO MORE THAN 30 HOURS PER YEAR BY JANUARY 1, 2006 AS REQUIRED IN RULE 1470(c)(3).  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.  
[1303(a)(1)-BACT]
7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.  
[RULE 1470, RULE 1472]
8. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

9. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

**Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. D77807**  
**A/N 285593**

#### **Equipment Description:**

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3508TA, SERIAL NO. 23Z04625, TURBOCHARGED/AFTERCOOLED, 8 CYLINDERS, FOUR CYCLE, 1025 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING. THE ANNUAL HOURS OF OPERATION FOR MAINTENANCE AND TESTING SHALL BE REDUCED TO NO MORE THAN 20 HOURS PER YEAR BY JANUARY 1, 2006 AS REQUIRED IN RULE 1470(c)(3).  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. EXCEPT FOR MAINTENANCE TESTING PURPOSES, THIS ENGINE SHALL ONLY OPERATE DURING UTILITY FAILURE PERIODS.  
[RULE 1304(a)-MODELING AND OFFSET]
7. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.  
[1303(a)(1)-BACT]
8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

[RULE 1470, RULE 1472]

]

9. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]

10. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

### **Emissions And Requirements:**

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. D77808**  
**A/N 285594**

#### **Equipment Description:**

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3508TA, SERIAL NO. 23Z04629, TURBOCHARGED/AFTERCOOLED, 8 CYLINDERS, FOUR CYCLE, 1025 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING. THE ANNUAL HOURS OF OPERATION FOR MAINTENANCE AND TESTING SHALL BE REDUCED TO NO MORE THAN 20 HOURS PER YEAR BY JANUARY 1, 2006 AS REQUIRED IN RULE 1470(c)(3).  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. EXCEPT FOR MAINTENANCE TESTING PURPOSES, THIS ENGINE SHALL ONLY OPERATE DURING UTILITY FAILURE PERIODS.  
[RULE 1304(a)-MODELING AND OFFSET]
7. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.  
[1303(a)(1)-BACT]
8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

[RULE 1470, RULE 1472]

9. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
10. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

### **Emissions And Requirements:**

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## PERMIT TO OPERATE

**Permit No. F17461  
A/N 290011**

### **Equipment Description:**

(located at Kenneth Norris, Jr. Cancer Center)

BOILER NO. 2, KEWANEE, FIRE TUBE TYPE, MODEL NO. H3X-60-X, SERIAL NO. 840962, RATED AT 2,511,000 BTU PER HOUR, NATURAL GAS FIRED, WITH ONE COMBUSTION SPECIALTIES MODEL NO. 60-N3 NOXMIZER BURNER.

### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 30 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(a)(1)-BACT, RULE 1146.1, RULE 1303(b)(2)-OFFSET]

### **Emissions And Requirements:**

5. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NO<sub>x</sub>: 30 PPMV, RULE 1146.1  
NO<sub>x</sub>: 30 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146.1  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## PERMIT TO OPERATE

**Permit No. F17456  
A/N 290012**

### **Equipment Description:**

(located at Kenneth Norris, Jr. Cancer Center)

BOILER NO. 1, KEWANEE, FIRE TUBE TYPE, MODEL NO. L38-200-X, SERIAL NO. 840961, RATED AT 8,370,000 BTU PER HOUR, NATURAL GAS FIRED, WITH ONE COMBUSTION SPECIALTIES MODEL NO. 300-N3 MICRONIX BURNER.

### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146]
4. THIS BOILER SHALL EMIT NO MORE THAN 30 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(a)(1)-BACT, RULE 1146, RULE 1303(b)(2)-OFFSET]

### **Emissions And Requirements:**

5. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
NO<sub>x</sub>: 30 PPMV, RULE 1146  
NO<sub>x</sub>: 30 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. F7030**  
**A/N 327464**

#### **Equipment Description:**

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 8083-7405 (8V-92TA), SERIAL NO. 50441, TURBOCHARGED, AFTERCOOLED, 8 CYLINDERS, 568 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
4. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR.  
[RULE 1304(a)-MODELING AND OFFSET]
5. THIS ENGINE SHALL BE OPERATED LESS THAN 50 HOURS PER YEAR FOR MAINTENANCE AND PERFORMANCE TESTING. THE ANNUAL HOURS OF OPERATION FOR MAINTENANCE AND TESTING SHALL BE REDUCED TO NO MORE THAN 20 HOURS PER YEAR BY JANUARY 1, 2006 AS REQUIRED IN RULE 1470(c)(3).  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING.  
[1303(a)(1)-BACT]
8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.  
[RULE 1470, RULE 1472]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

9. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
10. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

### **Emissions And Requirements:**

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. F31202**  
**A/N 364505**

#### Equipment Description:

BOILER, KEWANEE, FIRETUBE TYPE, MODEL NO. KPC-86, SERIAL NO. M367, RATED AT 10,400,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE INDUSTRIAL COMBUSTION LOW NOX BURNER, MODEL NO. LNDG-125P-B, AND INDUCED FLUE GAS RECIRCULATION.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146]
4. THIS BOILER SHALL COMPLY WITH RULE 1146.  
[RULE 1146]
5. THIS BOILER SHALL EMIT NO MORE THAN 30 PPM OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]
6. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND FGR AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]
7. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 6 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST  
[RULE 1146, RULE 1303(b)(2)-OFFSET]

#### Emissions And Requirements:

## **FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES**

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146  
CO: 400 PPMV, RULE 1146  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## PERMIT TO OPERATE

**Permit No. F39510  
A/N 371884**

### Equipment Description:

(located at Seaver Student Residence Hall)

BOILER NO. 2, KEWANEE, FIRE TUBE TYPE, MODEL NO. KPC-86, SERIAL NO. M368, RATED AT 10,172,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE INDUSTRIAL COMBUSTION LOW NOX BURNER, MODEL NO. LNDG-145S-20, AND FLUE GAS RECIRCULATION.

### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146]
4. THIS BOILER SHALL COMPLY WITH RULE 1146.  
[RULE 1146]
5. THIS BOILER SHALL EMIT NO MORE THAN 20 PPM OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 50 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(b)(2)-OFFSET]
6. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND FGR AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]
7. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 6 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST  
[RULE 1146, RULE 1303(b)(2)-OFFSET]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

8. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]

**Emissions And Requirements:**

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NO<sub>x</sub>: 30 PPMV, RULE 1146  
NO<sub>x</sub>: 20 PPMV, RULE 1303(b)(2)-OFFSET  
CO: 400 PPMV, RULE 1146  
CO: 50 PPMV, RULE 1303(b)(2)-OFFSET  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## PERMIT TO OPERATE

**Permit No. F39511  
A/N 372304**

### Equipment Description:

(located at Seaver Student Residence Hall)

BOILER NO. 3, KEWANEE, FIRE TUBE TYPE, MODEL NO. KPC-86, SERIAL NO. M366, RATED AT 10,172,000 BTU/HR., NATURAL GAS-FIRED, WITH ONE INDUSTRIAL COMBUSTION LOW NOX BURNER, MODEL NO. LNDG-145S-20, AND FLUE GAS RECIRCULATION.

### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146]
4. THIS BOILER SHALL COMPLY WITH RULE 1146.  
[RULE 1146]
5. THIS BOILER SHALL EMIT NO MORE THAN 20 PPM OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 50 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(b)(2)-OFFSET]
6. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND FGR AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]
7. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 6 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST  
[RULE 1146, RULE 1303(b)(2)-OFFSET]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

8. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE BOILER IS IN OPERATION.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]

**Emissions And Requirements:**

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NO<sub>x</sub>: 30 PPMV, RULE 1146  
NO<sub>x</sub>: 20 PPMV, RULE 1303(b)(2)-OFFSET  
CO: 400 PPMV, RULE 1146  
CO: 50 PPMV, RULE 1303(b)(2)-OFFSET  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## PERMIT TO OPERATE

**Permit No. F50847**  
**A/N 389016**

### Equipment Description:

(Located at the USC Neurogenetic Research Facility)

PROCESS HEATER, FULTON THERMAL CORPORATION, MODEL NO. FT-600C, RATED AT 7,500,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE FULTON THERMAL CORPORATION LOW NOX BURNER AND INDUCED FLUE GAS RECIRCULATION SYSTEM.

### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS HEATER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146]
4. THIS HEATER SHALL EMIT NO MORE THAN 20 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 100 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(a)(1)-BACT]
5. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND FGR AS THE HEATER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]
6. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 5 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST  
[RULE 1146, RULE 1303(b)(2)-OFFSET]
7. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THE HEATER IS IN OPERATION.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### **Emissions And Requirements:**

8. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NOx: 30 PPMV, RULE 1146  
NOx: 20 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146  
CO: 100 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. F43165  
A/N 389017**

#### **Equipment Description:**

INTERNAL COMBUSTION ENGINE, DETROIT DIESEL, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. T123-7K36 (1641 KW), TURBOCHARGED, AFTERCOOLED, 12 CYLINDERS, 2200 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION, THE ELAPSED TIME IN HOURS, AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.  
[RULE 1470, RULE 1472]
7. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
8. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

#### **Emissions And Requirements:**

## **FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES**

9. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. F64572  
A/N 414010**

#### **Equipment Description:**

BOILER, KEWANEE, SCOTCH MARINE TYPE, MODEL NO. L3S350G02, SERIAL NO. R2975, RATED AT 14,700,000 BTU/HR, NATURAL GAS OR OIL-FIRED, WITH ONE INDUSTRIAL COMBUSTION LOW NOX BURNER, MODEL NO. LNDLG 175P-20, SERIAL NO. 41786-1, EQUIPPED WITH A 20-HP COMBUSTION AIR BLOWER AND INDUCED DRAFT FLUE GAS RECIRCULATION SYSTEM.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS AND ONLY USE FUEL OIL DURING PERIODS OF NATURAL GAS CURTAILMENT.  
[RULE 1303(b)(2)-OFFSET]
4. THIS BOILER SHALL COMPLY WITH RULE 1146.  
[RULE 1146]
5. THE FLUE GAS RECIRCULATION SYSTEM SHALL BE IN FULL USE WHENEVER THIS BOILER IS IN OPERATION.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]
6. WHEN OPERATING ON NATURAL GAS, THIS BOILER SHALL EMIT NO MORE THAN 30 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>. WHEN OPERATING ON AMBER 363, THIS BOILER SHALL EMIT NO MORE THAN 40 PPM OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 400 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]
7. THE BURNER SHALL BE EQUIPPED WITH A CONTROL SYSTEM TO AUTOMATICALLY REGULATE COMBUSTION AIR, FUEL AND FGR AS THE BOILER LOAD VARIES. THIS AUTOMATIC CONTROL SYSTEM SHALL BE ADJUSTED AND TUNED AT LEAST TWICE A YEAR ACCORDING TO MANUFACTURER'S SPECIFICATIONS TO ASSURE ITS ABILITY TO REPEAT THE SAME PERFORMANCE AT THE SAME FIRING RATE.  
[RULE 1146, RULE 1303(b)(2)-OFFSET]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

8. RECORDS OF SUCH ADJUSTMENTS, TUNE-UPS AND CALIBRATIONS AS STATED IN CONDITION NO. 7 SHALL BE KEPT FOR AT LEAST FIVE YEARS AND BE MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST.  
[RULE 1303(b)(2)-OFFSET]

### Periodic Monitoring:

9. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSION FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THIS EQUIPMENT HAS COMBUSTED ONE MILLION GALLONS OF FUEL OIL, TO BE COUNTED CUMULATIVELY OVER A FIVE YEAR PERIOD. THE INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR, THE OPERATOR SHALL EITHER:
- A. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN THE SAME FASHION AS DEVIATIONS ARE REQUIRED TO BE REPORTED IN SECTION K OF THIS PERMIT; OR
  - B. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

IN ADDITION, THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
- B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
- C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
- D. VISIBLE EMISSION OBSERVATION RECORD BY A CERTIFIED SMOKE READER.

[RULE 3004 (a)(4)]

10. FOR UNITS WITH A HEAT INPUT GREATER THAN 10 MMBTU/HR AND ANNUAL OIL USAGE GREATER THAN 1,000,000 GALLONS, OR GREATER THAN 336 HOURS OF OPERATION BUT NOT EXCEEDING 2,000,000 GALLONS IN ANY ONE YEAR, THE OPERATOR SHALL CONDUCT AN ANNUAL MAINTENANCE INSPECTION CHECK OF THE OPERATING PRESSURE, TEMPERATURE, AIR SUPPLY, VENT, SMOKE SPOT, BURNER CONDITION, HEAT-TRANSFER SURFACE CONDITION, WATER TREATMENT, BLOWDOWN AND LEAKAGE

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. DATE WHEN ANNUAL MAINTENANCE INSPECTION WAS CONDUCTED.

[RULE 3004 (a)(4)]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### **Emissions And Requirements:**

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS :

NOx: 30 PPMV, RULE 1146 (using natural gas)  
NOx: 40 PPMV, RULE 1146 (using fuel oil)  
CO: 400 PPMV, RULE 1146  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## PERMIT TO OPERATE

**Permit No. F63642**  
**A/N 420087**

### Equipment Description:

(Located at HCC II)

BOILER NO. 1, PARKER, WATER TUBE TYPE, MODEL NO. T2970LR, RATED AT 2,970,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE PARKER NIT STRIPE PREMIX METAL FIBER LOW NOX BURNER, MODEL NO. PB-36LN.

### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 100 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(a)(1)-BACT]

### Emissions And Requirements:

5. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
NO<sub>x</sub>: 30 PPMV, RULE 1146.1  
NO<sub>x</sub>: 12 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146.1  
CO: 100 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## PERMIT TO OPERATE

**Permit No. F63643  
A/N 420088**

### Equipment Description:

(Located at HCC II)

BOILER NO. 2, PARKER, WATER TUBE TYPE, MODEL NO. T2970LR, RATED AT 2,970,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE PARKER NIT STRIPE PREMIX METAL FIBER LOW NOX BURNER, MODEL NO. PB-36LN.

### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146.1]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 100 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(a)(1)-BACT]

### Emissions And Requirements:

5. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
NO<sub>x</sub>: 30 PPMV, RULE 1146.1  
NO<sub>x</sub>: 12 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146.1  
CO: 100 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. F63782  
A/N 420481**

#### **Equipment Description:**

(located at HCC II)

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION. MODEL NO. 3456 DITA AA, TURBOCHARGED, AFTERCOOLED, 6 CYLINDERS. FOUR CYCLE, 536 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. THE OPERATION OF THIS ENGINE BEYOND 50 HOURS PER YEAR FOR MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION OF THIS ENGINE. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.  
[RULE 1470, RULE 1472]
8. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
9. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. F64654  
A/N 420639**

#### **Equipment Description:**

(located at the HMR)

BOILER, KEWANEE, FIRE TUBE TYPE, MODEL NO. KX-86, SERIAL NO. N4004, RATED AT 10,172,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE INDUSTRIAL COMBUSTION LOW NOX BURNER, MODEL NO. LNDG-145P-20, SERIAL NO 42830-1, EQUIPPED WITH A 15-HP COMBUSTION AIR BLOWER AND INDUCED DRAFT FLUE GAS RECIRCULATION SYSTEM.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146]
4. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE ANNUAL SOURCE TESTING REQUIREMENTS IN SUBDIVISION (d) – COMPLIANCE DETERMINATION OF RULE 1146.  
[RULE 1146]
5. THIS BOILER SHALL EMIT NO MORE THAN 20 PPM OF OXIDES OF NITROGEN (NO<sub>x</sub>), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 50 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(b)(2)-OFFSET]

#### **Emissions And Requirements:**

6. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NO<sub>x</sub>: 30 PPMV, RULE 1146  
NO<sub>x</sub>: 20 PPMV, RULE 1303(b)(2)-OFFSET  
CO: 400 PPMV, RULE 1146  
CO: 50 PPMV, RULE 1303(b)(2)-OFFSET  
CO: 2000 PPMV, RULE 407  
PM: 0.1 GR/SCF, RULE 409

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## PERMIT TO OPERATE

**Permit No. F66092**  
**A/N 421325**

### Equipment Description:

(Located at the Zilkha Neurogenetic Institute)

BOILER NO. 2, CLEAVER BROOKS, WATER TUBE TYPE, MODEL NO. FLX-600, SERIAL NO. BT7627, RATED AT 6,000,000 BTU/HR , NATURAL GAS-FIRED, WITH ONE ALZETA LOW NOX BURNER, MODEL NO. CSB60, SERIAL NO. JO 20219-1.

### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 50 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(a)(1)-BACT]
5. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE ANNUAL SOURCE TESTING REQUIREMENTS IN SUBDIVISION (d) – COMPLIANCE DETERMINATION OF RULE 1146.  
[RULE 1146]
6. THIS BOILER SHALL COMPLY WITH RULE 1146.  
[RULE 1146]

### Emissions And Requirements:

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
NO<sub>x</sub>: 30 PPMV, RULE 1146  
NO<sub>x</sub>: 12 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146  
CO: 50 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407

**FACILITY PERMIT TO OPERATE  
UNIVERSITY SO CALIFORNIA HEALTH SCIENCES**

PM: 0.1 GR/SCF, RULE 409

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. F66093**  
**A/N 421326**

#### **Equipment Description:**

(Located at the Zilkha Neurogenetic Institute)

BOILER NO. 1, CLEAVER BROOKS, WATER TUBE TYPE, MODEL NO. FLX-600, SERIAL NO. BT7626, RATED AT 6,000,000 BTU/HR, NATURAL GAS-FIRED, WITH ONE ALZETA LOW NOX BURNER, MODEL NO. CSB60, SERIAL NO. JO 20219-2.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS BOILER SHALL BE FIRED WITH NATURAL GAS ONLY.  
[RULE 1146]
4. THIS BOILER SHALL EMIT NO MORE THAN 12 PPM OF OXIDES OF NITROGEN (NOX), CALCULATED AS NO<sub>2</sub>, AND NO MORE THAN 50 PPM OF CARBON MONOXIDE (CO), ALL MEASURED BY VOLUME ON A DRY BASIS AT 3% O<sub>2</sub>.  
[RULE 1303(a)(1)-BACT]
5. THE OPERATOR OF THIS BOILER SHALL COMPLY WITH THE ANNUAL SOURCE TESTING REQUIREMENTS IN SUBDIVISION (d) – COMPLIANCE DETERMINATION OF RULE 1146.  
[RULE 1146]
6. THIS BOILER SHALL COMPLY WITH RULE 1146.  
[RULE 1146]

#### **Emissions And Requirements:**

7. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
NO<sub>x</sub>: 30 PPMV, RULE 1146  
NO<sub>x</sub>: 12 PPMV, RULE 1303(a)(1)-BACT  
CO: 400 PPMV, RULE 1146  
CO: 50 PPMV, RULE 1303(a)(1)-BACT  
CO: 2000 PPMV, RULE 407

**FACILITY PERMIT TO OPERATE  
UNIVERSITY SO CALIFORNIA HEALTH SCIENCES**

PM: 0.1 GR/SCF, RULE 409

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. F73815**  
**A/N 431730**

#### **Equipment Description:**

CREMATORY, ANIMAL REMAINS, CERTIFIED INCINERATOR COMPANY, 200 LBS. PER HOUR MULTIPLE CHAMBER RETORT, MODEL NO. MCR 200-B, NATURAL GAS-FIRED, WITH TWO INCINOMITE MODEL J83-DS 800,000 BTU/HR BURNERS IN THE MAIN IGNITION CHAMBER, AN INCINOMITE MODEL J83-DS 800,000 BTU/HR BURNER IN THE MIXING CHAMBER, AND A 20" DIAMETER BAROMETRIC DAMPER AT THE BASE OF THE STACK.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES  
[RULE 204]
3. THIS EQUIPMENT SHALL ONLY BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.  
[RULE 204]
4. THE MIXING CHAMBER BURNER SHALL BE USED THROUGHOUT THE BURNING PERIOD.  
[RULE 1303 (b)(2)-OFFSET]
5. ONLY ANIMALS OR ANIMAL PARTS SHALL BE CHARGED TO THIS CREMATORY.  
[RULE 1303 (b)(2)-OFFSET]
6. THE TOTAL AMOUNT OF ANIMAL REMAINS CHARGED TO THIS CREMATORY SHALL NOT EXCEED 200 POUNDS IN ANY ONE BATCH.  
[RULE 1303 (b)(2)-OFFSET]
7. A TEMPERATURE MEASUREMENT AND RECORDING DEVICE WITH AN ACCURACY OF PLUS OR MINUS 20 DEGREES FAHRENHEIT SHALL BE INSTALLED AND MAINTAINED IN THE SECONDARY CHAMBER. THE INDICATING INSTRUMENT SHALL BE CALIBRATED AT LEAST ONCE PER YEAR.  
[RULE 1303 (b)(2)-OFFSET]
8. A TEMPERATURE OF NOT LESS THAN 1500 DEGREES FAHRENHEIT SHALL BE MAINTAINED IN THE SECONDARY CHAMBER WHENEVER THIS CREMATORY IS IN OPERATION.  
[RULE 1303 (b)(2)-OFFSET]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

9. RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NOS. 5, 6, 7 AND 8. THESE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST.  
[RULE 1303 (b)(2)-OFFSET]

### Periodic Monitoring:

10. THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS, WHENEVER VISIBLE EMISSIONS ARE OBSERVED, AND ON A MONTHLY BASIS, AT LEAST, UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE MONTHLY PERIOD. THE ROUTINE MONTHLY INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS. IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE-HOUR, THE OPERATOR SHALL EITHER:
- A. VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST;
  - B. TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT; OR
  - C. HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL "VISIBLE EMISSION EVALUATION", WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD.

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS:

- A. STACK OR EMISSION POINT IDENTIFICATION;
  - B. DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS;
  - C. DATE AND TIME VISIBLE EMISSION WAS ABATED; AND
  - D. VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER.
- [RULE 3004 (a)(4)]

### Emissions And Requirements:

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- CO: 2000 PPMV, RULE 407
  - PM: 0.1 GR/SCF, RULE 409
  - PM: 0.23 GRAM/CUBIC METER, RULE 473
  - PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
  - PM: RULE 405, SEE APPENDIX B FOR EMISSION LIMITS

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. F70274**  
**A/N 433571**

#### **Equipment Description:**

INTERNAL COMBUSTION ENGINE, KOHLER, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. D250 9.6A60, TURBOCHARGED/AFTERCOOLED, 6 CYLINDERS, 394 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

6. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION OF THIS ENGINE. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (BOTH MANUAL AND AUTOMATIC) FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED ANYTIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
7. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.  
[RULE 1470, RULE 1472]
8. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 1470, RULE 431.2]
9. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 1470, RULE 431.2]

### **Emissions And Requirements:**

10. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

**Permit No. F80108**  
**A/N 443531**

#### **Equipment Description:**

(located at the McKibben Addition)

INTERNAL COMBUSTION ENGINE, PERKINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 1004-40T, SERIAL NO. U272058J TURBOCHARGED, 4 CYLINDERS, 95 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 30 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. OPERATION BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1470]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

A. EMERGENCY USE HOURS OF OPERATION

B. MAINTENANCE AND TESTING HOURS

C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.

[RULE 1470, RULE 1472]

9. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.

[RULE 1470, RULE 431.2]

10. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST

[RULE 1470, RULE 431.2]

### **Emissions And Requirements:**

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

Permit No. F85190  
A/N 443878

#### Equipment Description:

(located at the Harlynnne Norris Research Tower)

INTERNAL COMBUSTION ENGINE, CATERPILLAR, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 3512B-DITA, SERIAL NO. 1GZ02105, TURBOCHARGED, AFTERCOOLED, 12 CYLINDERS, FOUR CYCLE, 2155 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1470]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

A. EMERGENCY USE HOURS OF OPERATION

B. MAINTENANCE AND TESTING HOURS

C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.

[RULE 1470, RULE 1472]

9. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.

[RULE 1470, RULE 431.2]

10. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST

[RULE 1470, RULE 431.2]

### **Emissions And Requirements:**

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO OPERATE

Permit No. F94546  
A/N 471089

#### Equipment Description:

[located at the Mudd Medical Research Bldg. (MMR)]

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. 4BT3.9-G4, SERIAL NO. 46069357, TURBOCHARGED, FOUR CYLINDERS, 4-CYCLE, 102 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 30 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. OPERATION BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1470]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

A. EMERGENCY USE HOURS OF OPERATION

B. MAINTENANCE AND TESTING HOURS

C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.

[RULE 1470, RULE 1472]

9. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.

[RULE 1470, RULE 431.2]

10. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST

[RULE 1470, RULE 431.2]

### **Emissions And Requirements:**

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO CONSTRUCT/OPERATE

Permit No. F94545  
A/N 471971

#### Equipment Description:

[located at the Bishop Medical Teaching Bldg. (BMT)]

INTERNAL COMBUSTION ENGINE, CUMMINS, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. QSL9-G2, SERIAL NO. 21768778, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, 364 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. OPERATION BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1470]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

A. EMERGENCY USE HOURS OF OPERATION

B. MAINTENANCE AND TESTING HOURS

C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.

[RULE 1470, RULE 1472]

9. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.

[RULE 1470, RULE 431.2]

10. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST

[RULE 1470, RULE 431.2]

### **Emissions And Requirements:**

11. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO CONSTRUCT/OPERATE

Permit No. F94543  
A/N 472960

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, PORTABLE (INTRA-FACILITY), JOHN DEERE, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATOR DRIVER, MODEL NO. 6068HF485, SERIAL NO. PE6068L003941, TURBOCHARGED, AIR-TO-AIR INTERCOOLED, SIX CYLINDERS, 4-CYCLE, 315 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, CCR TITLE 17]
5. THE OPERATION OF THIS ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR MAINTENANCE AND PERFORMANCE TESTING SHALL BE ALLOWED ONLY TO PROVIDE ELECTRICAL POWER TO PORTABLE OPERATIONS OR EMERGENCY POWER TO STATIONARY SOURCES. PORTABLE OPERATIONS ARE THOSE WHERE IT CAN BE DEMONSTRATED THAT BECAUSE OF THE NATURE OF THE OPERATION, IT IS NECESSARY TO PERIODICALLY MOVE THE EQUIPMENT FROM ONE LOCATION TO ANOTHER. EMERGENCIES AT STATIONARY SOURCES ARE THOSE THAT RESULT IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING STAGE II OR III ELECTRICAL EMERGENCIES DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR.  
[RULE 1304(a)-MODELING AND OFFSET]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1304(a)-MODELING AND OFFSET]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

A. EMERGENCY USE HOURS OF OPERATION

B. MAINTENANCE AND TESTING HOURS

C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[CCR TITLE 17]

8. THIS ENGINE AND ITS REPLACEMENT UNIT INTENDED TO PERFORM THE SAME OR SIMILAR FUNCTION SHALL NOT RESIDE AT ANY ONE LOCATION FOR MORE THAN 12 CONSECUTIVE MONTHS. THE PERIOD DURING WHICH THE ENGINE OR ITS REPLACEMENT IS MAINTAINED AT A STORAGE FACILITY SHALL BE EXCLUDED FROM THE RESIDENCY TIME REQUIREMENT.  
[RULE 1110.2]
9. THIS ENGINE SHALL NOT BE REMOVED FROM ONE LOCATION FOR A PERIOD AND THEN IT OR ITS EQUIVALENT RETURNED TO THE SAME LOCATION THEREBY CIRCUMVENTING THE PORTABLE ENGINE RESIDENCE TIME REQUIREMENTS.  
[RULE 1110.2]
10. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 431.2]
11. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 431.2]

### **Emissions And Requirements:**

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO CONSTRUCT/OPERATE

Permit No. F94544  
A/N 472961

#### Equipment Description:

INTERNAL COMBUSTION ENGINE, PORTABLE (INTRA-FACILITY), KOMATSU, DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATOR DRIVER, MODEL NO. SAA6D125E5, SERIAL NO. 00563271, TURBOCHARGED, AIR-TO-AIR INTERCOOLED, SIX CYLINDERS, 4-CYCLE, 399 BHP.

#### Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS FOR MAINTENANCE AND PERFORMANCE TESTING.  
[RULE 1304(a)-MODELING AND OFFSET]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1304(a)-MODELING AND OFFSET, CCR TITLE 17]
5. THE OPERATION OF THIS ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR MAINTENANCE AND PERFORMANCE TESTING SHALL BE ALLOWED ONLY TO PROVIDE ELECTRICAL POWER TO PORTABLE OPERATIONS OR EMERGENCY POWER TO STATIONARY SOURCES. PORTABLE OPERATIONS ARE THOSE WHERE IT CAN BE DEMONSTRATED THAT BECAUSE OF THE NATURE OF THE OPERATION, IT IS NECESSARY TO PERIODICALLY MOVE THE EQUIPMENT FROM ONE LOCATION TO ANOTHER. EMERGENCIES AT STATIONARY SOURCES ARE THOSE THAT RESULT IN AN INTERRUPTION OF SERVICE OF THE PRIMARY POWER SUPPLY OR DURING STAGE II OR III ELECTRICAL EMERGENCIES DECLARED BY THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR.  
[RULE 1304(a)-MODELING AND OFFSET]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.  
[RULE 1304(a)-MODELING AND OFFSET]

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

7. AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS:

A. EMERGENCY USE HOURS OF OPERATION

B. MAINTENANCE AND TESTING HOURS

C. OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION. THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

[CCR TITLE 17]

8. THIS ENGINE AND ITS REPLACEMENT UNIT INTENDED TO PERFORM THE SAME OR SIMILAR FUNCTION SHALL NOT RESIDE AT ANY ONE LOCATION FOR MORE THAN 12 CONSECUTIVE MONTHS. THE PERIOD DURING WHICH THE ENGINE OR ITS REPLACEMENT IS MAINTAINED AT A STORAGE FACILITY SHALL BE EXCLUDED FROM THE RESIDENCY TIME REQUIREMENT.  
[RULE 1110.2]
9. THIS ENGINE SHALL NOT BE REMOVED FROM ONE LOCATION FOR A PERIOD AND THEN IT OR ITS EQUIVALENT RETURNED TO THE SAME LOCATION THEREBY CIRCUMVENTING THE PORTABLE ENGINE RESIDENCE TIME REQUIREMENTS.  
[RULE 1110.2]
10. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.  
[RULE 431.2]
11. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST  
[RULE 431.2]

### **Emissions And Requirements:**

12. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### PERMIT TO CONSTRUCT/OPERATE

**Permit No.**  
**A/N 492932**

#### **Equipment Description:**

(located at the PSC)

INTERNAL COMBUSTION ENGINE, CUMMINS , DIESEL-FUELED, EMERGENCY ELECTRICAL GENERATION, MODEL NO. QSX15-G9, TURBOCHARGED, AFTERCOOLED, SIX CYLINDERS, 4-CYCLE, 755 BHP.

#### **Conditions:**

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING, AND NO MORE THAN 1.7 HOURS IN ANY ONE MONTH FOR MAINTENANCE AND TESTING .  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
4. AN OPERATIONAL NON-RESETTABLE ELAPSED TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470, RULE 1472]
5. OPERATION BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.  
[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]
6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

[RULE 1470]

7. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS :

A. EMERGENCY USE

B. MAINTENANCE AND TESTING

C. OTHERS (SPECIFY)

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READINGS (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.

[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

8. ON OR BEFORE JANUARY 15<sup>TH</sup> OF EACH YEAR, THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG :

A. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND

B. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

[RULE 1303(b)(2)-OFFSET, RULE 1304(a)-MODELING AND OFFSET, RULE 1470]

9. ENGINE OPERATION LOGS SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE UPON REQUEST.

[RULE 1470]

10. THIS EQUIPMENT SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 1470 AND 1472.

[RULE 1470, RULE 1472]

11. THE OPERATOR SHALL ONLY USE LOW SULFUR DIESEL FUEL WITH A SULFUR CONTENT OF 15 PPM OR LESS BY WEIGHT.

[RULE 1470, RULE 431.2]

12. MATERIAL SAFETY DATA SHEETS FOR THE DIESEL FUEL USED IN THIS ENGINE SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST

[RULE 1470, RULE 431.2]

### **Emissions And Requirements:**

13. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM: RULE 1470

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## RULE 219 EQUIPMENT

### Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS.

### Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S):

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN SEMI-ANNUAL RECORDS OF ALL COATINGS CONSISTING OF:

- A. COATING TYPE,
- B. VOC CONTENT AS SUPPLIED IN GRAMS PER LITER (g/l) OF MATERIALS FOR LOW-SOLIDS COATINGS,
- C. VOC CONTENT AS SUPPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS, REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED, MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF:

- A. COATING TYPE,
- B. VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW-SOLIDS COATINGS,
- C. VOC CONTENT AS APPLIED IN g/l OF COATING, LESS WATER AND EXEMPT SOLVENT, FOR OTHER COATING.  
[RULE 3004 (a) (4)]

### Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1113, SEE APPENDIX B FOR EMISSION LIMITS  
VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## RULE 219 EQUIPMENT

### **Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, HAND WIPING OPERATIONS.

### **Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION:

VOC: RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### RULE 219 EQUIPMENT

**Equipment Description:**

RULE 219 EXEMPT EQUIPMENT, BOILER, > 400,000 BTU/HR BUT < 2 MMBTU/HR.

**Emissions And Requirements:**

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

PM: 0.1 gr/scf, RULE 409  
NOx: 30 PPMV, RULE 1146.2  
CO: 400 PPMV, RULE 1146.2  
CO: 2000 PPMV, RULE 407

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## RULE 219 EQUIPMENT

### Equipment Description:

RULE 219 EXEMPT EQUIPMENT, AIR CONDITIONING UNITS

### Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
REFRIGERANT: RULE 1411  
REFRIGERANT: 40CFR 82 SUBPART F  
REFRIGERANT: 40CFR 82 SUBPART G

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## RULE 219 EQUIPMENT

### Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERATION UNITS

### Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
REFRIGERANT: RULE 1415  
REFRIGERANT: 40CFR 82 SUBPART F  
REFRIGERANT: 40CFR 82 SUBPART G

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## RULE 219 EQUIPMENT

### Equipment Description:

RULE 219 EXEMPT EQUIPMENT, REFRIGERANT RECOVERY AND/OR RECYCLING UNITS.

### Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
REFRIGERANT: RULE 1415  
REFRIGERANT: 40CFR 82 SUBPART F  
REFRIGERANT: 40CFR 82 SUBPART G

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## RULE 219 EQUIPMENT

### Equipment Description:

RULE 219 EXEMPT EQUIPMENT, FIRE EXTINGUISHING EQUIPMENT

### Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

HALON:           RULE 1418

# FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

## RULE 219 EQUIPMENT

### Equipment Description:

RULE 219 EXEMPT EQUIPMENT, COOLING TOWERS

### Emissions And Requirements:

1. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
CR<sup>+6</sup>: RULE 1404

## FACILITY PERMIT TO OPERATE UNIVERSITY SO CALIFORNIA HEALTH SCIENCES

### RULE 219 EQUIPMENT

#### Equipment Description:

RULE 219 EXEMPT EQUIPMENT, CHARBROILER.

#### Periodic Monitoring:

1. THE OPERATOR SHALL KEEP RECORDS, IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETERS:
  - A. DATE
  - B. DAILY OPERATING HOURS
  - C. DAILY AMOUNT OF MEAT COOKED (OR CASHIER'S RECEIPTS WHICH SHOW THE QUANTITY OF CHARBROILER PRODUCTS SOLD EACH DAY)  
[RULE 3004 (a)(4)]

#### Emissions And Requirements:

2. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:  
PM: 0.1 GR/SCF, RULE 409  
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS  
VOC: RULE 1174