

32. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3538. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-45-10

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 27.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (SN 22-4) WITH A NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER: INSTALL FLUE GAS RECIRCULATION, LOWER NOX LIMIT TO 9 PPMV @ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

B-1128-45-10 : Jun 15 2010 1:59PM - RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. In months when PUC quality gas is burned, the permittee shall maintain records on a calendar month basis of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50% or greater than or equal to 50%. [District Rule 4320]
9. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 2201 & 4320] Federally Enforceable Through Title V Permit
10. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when this unit is burning 50% or greater by volume PUC quality gas on a monthly average basis: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
11. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when the unit is burning less than 50% by volume PUC quality gas on a monthly average basis: 12 ppmvd NO_x @ 3% O₂ or 0.014 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
12. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
14. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 15 ppmvd @ 3% O₂ or 0.0182 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
17. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 23.8 lb-NO_x/day, 3,373 lb-NO_x/yr, 55.4 lb-CO/day, and 9,034 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

19. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
25. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
26. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
27. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
28. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
29. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
30. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
32. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
33. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
34. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
35. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
36. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
37. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
38. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 2520, 9.3.2 and 4320 6.2.1] Federally Enforceable Through Title V Permit
39. The applicable NO_x and CO emissions concentration for each month shall be determined based on the volume and type of fuel combusted in the unit (< 50% by volume PUC quality gas or >= 50% by volume PUC quality gas). Permittee shall maintain supporting records that demonstrate the type of fuel combusted. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
40. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. The NO_x limit in effect at the time of the startup source testing will be determined based on the volume and type of fuel combusted (>= 50% PUC quality or < 50% PUC quality gas) and shall be identified in the source test protocol. Whenever the fuel type is switched from the fuel type combusted during the initial startup of this unit, compliance source testing for NO_x and CO shall be conducted within 90 days of the date the fuel type is switched. [District Rules 2201 and 4320]
41. Source testing is required at least once every twelve (12) months from the initial source test date of each fuel type (>= 50% PUC quality gas or < 50% PUC quality gas). After an initial compliance demonstration with the NO_x and CO emission limits for each fuel type on two (2) consecutive source tests, the unit shall be tested not less than once every thirty-six (36) months from the last test date for that fuel type. Testing shall not be required for any fuel type not in use during the 36 month period until such time the fuel type is switched, after which testing shall be performed within 90 days of switching fuel types. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

42. Compliance source testing after switching fuel types is not required if the unit continues to demonstrate compliance with 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas. In which case, source testing shall only be required every thirty-six(36) months for the less than 50% by PUC quality gas. If the result of a source test demonstrates that the unit does not meet 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas, the source test frequency shall revert to at least one test every 36 months for each fuel type. [District Rules 2201 and 4320, 6.3.1] Federally Enforceable Through Title V Permit
43. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NO_x and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rule 2201, 2520, 4320] Federally Enforceable Through Title V Permit
44. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
45. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-45-6. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-45-11

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 27.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (SN 22-4) WITH A NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER: RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-45-11 : Jun 15 2010 2:00PM - RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 2201 & 4320] Federally Enforceable Through Title V Permit
9. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
10. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
12. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 23.8 lb-NO_x/day, 4,384 lb-NO_x/yr, 55.4 lb-CO/day, and 9,034 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
15. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
18. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
21. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
23. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
24. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
25. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
29. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
30. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
31. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
34. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
35. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-45-6. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-47-8

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 25 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 25.2 MMBTU/HR STEAM GENERATOR WITH NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER: INSTALL FLUE GAS RECIRCULATION, LOWER NOX LIMIT TO 9 PPMV@ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320]
9. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, double GC for H₂S and mercaptans or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320]
10. In months when PUC quality gas is burned, the permittee shall maintain records on a calendar month basis of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50% or greater than or equal to 50%. [District Rule 4320]
11. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
12. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when this unit is burning 50% or greater by volume PUC quality gas on a monthly average basis: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
13. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when the unit is burning less than 50% by volume PUC quality gas on a monthly average basis: 12 ppmvd NO_x @ 3% O₂ or 0.014 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, and 4351, 5.1] Federally Enforceable Through Title V Permit
16. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 15 ppmvd @ 3% O₂ or 0.0182 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6 and 4306, 5.3]
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
19. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 21.8 lb-NO_x/day, 3,127 lb-NO_x/yr, 50.8 lb-CO/day, and 8,278 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
27. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
28. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
29. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
30. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
32. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
33. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
34. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
35. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
37. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
38. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
39. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 2520, 9.3.2 and 4320 6.2.1] Federally Enforceable Through Title V Permit
40. The applicable NO_x and CO emissions concentration for each month shall be determined based on the volume and type of fuel combusted in the unit (< 50% by volume PUC quality gas or >= 50% by volume PUC quality gas). Permittee shall maintain supporting records that demonstrate the type of fuel combusted. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
41. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. The NO_x limit in effect at the time of the startup source testing will be determined based on the volume and type of fuel combusted (>= 50% PUC quality or < 50% PUC quality gas) and shall be identified in the source test protocol. Whenever the fuel type is switched from the fuel type combusted during the initial startup of this unit, compliance source testing for NO_x and CO shall be conducted within 90 days of the date the fuel type is switched. [District Rules 2201 and 4320]
42. Source testing is required at least once every twelve (12) months from the initial source test date of each fuel type (>= 50% PUC quality gas or < 50% PUC quality gas). After an initial compliance demonstration with the NO_x and CO emission limits for each fuel type on two (2) consecutive source tests, the unit shall be tested not less than once every thirty-six (36) months from the last test date for that fuel type. Testing shall not be required for any fuel type not in use during the 36 month period until such time the fuel type is switched, after which testing shall be performed within 90 days of switching fuel types. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

43. Compliance source testing after switching fuel types is not required if the unit continues to demonstrate compliance with 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas. In which case, source testing shall only be required every thirty-six(36) months for the less than 50% by PUC quality gas. If the result of a source test demonstrates that the unit does not meet 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas, the source test frequency shall revert to at least one test every 36 months for each fuel type. [District Rules 2201 and 4320, 6.3.1] Federally Enforceable Through Title V Permit
44. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NO_x and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rule 2201, 2520, 4320] Federally Enforceable Through Title V Permit
45. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
46. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
47. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-47-4. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-47-9

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 25 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 25.2 MMBTU/HR STEAM GENERATOR WITH NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER: RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-47-9 : Jun 15 2010 2:00PM - RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
9. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
10. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6 and 4306, 5.3]
12. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 21.8 lb-NO_x/day, 4,018 lb-NO_x/yr, 50.8 lb-CO/day, and 8,278 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
15. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
18. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
21. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
23. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
24. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
25. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
29. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
30. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
31. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
35. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-47-4. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-48-28

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 50-4-26C) EQUIPPED WITH A NORTH AMERICAN MAGNAFLAME GLE ULTRA-LOW NOX BURNER WITH SO2 SCRUBBER AND FLUE GAS RECIRCULATION: LOWER NOX LIMIT TO 9 PPMV @ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND REDUCE SOX EMISSIONS BY AT LEAST 95% OR LIMIT EXHAUST SO2 EMISSIONS TO 9 PPMV @ 3% O2 ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-48-28 : Jun 15 2010 2:00PM - RINALDIR : Joint Inspection NOT Required

6. Steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Scrubber recirculation liquid pH shall be maintained only by the addition of caustic unless prior approval for an alternative pH maintenance method is received from the District. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Scrubber liquor pH shall be maintained between 6 and 8, and shall be continuously monitored. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Scrubber mist eliminator shall be properly cleaned and maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Scrubber recirculation liquor liquid to gas ratio shall be maintained at no less than 8.0 gpm/1000 acfm. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
12. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
13. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
14. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3246, D 4084, D 4468, D6667, or double GC for H₂S and mercaptans. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
15. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; 4320 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
16. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
17. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
18. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320]

CONDITIONS CONTINUE ON NEXT PAGE

19. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, double GC for H₂S and mercaptans or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320]
20. In months when PUC quality gas is burned, the permittee shall maintain records on a calendar month basis of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50% or greater than or equal to 50%. [District Rule 4320]
21. Emissions from the steam generator shall not exceed any of the following limits: 0.324 lb-SO_x/MMBtu, 0.037 lb-PM₁₀/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when this unit is burning 50% or greater by volume PUC quality gas on a monthly average basis: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
23. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when the unit is burning less than 50% by volume PUC quality gas on a monthly average basis: 12 ppmvd NO_x @ 3% O₂ or 0.014 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
24. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
25. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 15 ppmvd @ 3% O₂ or 0.0182 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
26. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
27. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NO_x/day, 7,665 lb-NO_x/yr, 31.5 lb-CO/day, and 11,498 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1 and 4320] Federally Enforceable Through Title V Permit
29. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
30. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
33. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
34. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
35. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, SO_x (lb/MMBtu) - EPA Method 6 or ARB Method 100 and EPA Method 19. [District Rules 1081, 4305 and 4320] Federally Enforceable Through Title V Permit
36. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
37. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
38. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
39. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
40. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
41. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District NSR Rule] Federally Enforceable Through Title V Permit
42. Testing for vapor recovery gas sulfur content shall be conducted no less than monthly. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

43. The permittee shall keep daily records of the amount of natural gas and vapor recovery gas combusted, and the date and duration of scrubber operation, for a period of five years, and shall make records available for inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
44. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
45. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
46. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
47. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
48. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
49. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in the conditions below. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
50. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions below, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
51. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR 52, 60 and 61 and all other applicable Federal, State and local regulations. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
52. Permittee shall have installed a hydrocarbon vapor recovery system, having a collection efficiency of 85% on the following: (143) steam drive producing wells designated in this PSD permit, plus (16) existing steam drive producing wells located in Section 16, T30S, R22E, M.D.B. & M. This system shall be installed on existing wells prior to project start-up, and on new or modified wells before venting steam to the atmosphere. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
53. At such times as specified by the USEPA, permittee shall conduct performance tests for HC and furnish the District and the USEPA a written report of the results of such tests. The tests for HC shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
54. Performance tests shall be conducted for each vapor recovery system listed above in the Cymric and Taft areas. The USEPA shall be notified at least 30 days in advance of such test to allow an observer to be present. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
55. Permittee shall not discharge or cause the discharge of VOC into the atmosphere in excess of 50.6 lbs/day for each well in the system. [PSD SJ 77-31] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

56. Permittee shall operate and maintain operable scrubbers on the equipment designated below: (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. Exhaust gases from the above units shall be ducted through operating scrubbers. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
57. Permittee shall not discharge into the atmosphere SO₂ in excess of 0.145 lb/MMBtu (maximum 2-hour average) for the steam generators designated in the previous condition. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
58. Permittee shall operate, and maintain operable excess oxygen control equipment on the units designated below: (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. The concentration of excess oxygen in the exhaust gases shall not exceed 3% for the above units on a 24-hour average basis. The excess oxygen level shall be recorded continuously in a permanent record and shall be available for periodic inspection by the USEPA. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
59. Permittee shall not discharge into the atmosphere NO_x in excess of 0.50 lb/MMBtu (maximum 2-hour average) for the 50 MMBtu/hr steam generators and 0.57 lb/MMBtu (maximum 2-hour average) for the 22 MMBtu/hr steam generators designated in the previous condition. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
60. At such times as specified by the USEPA, permittee shall conduct performance tests for SO₂ and NO_x, and furnish the District and the USEPA a written report of the results of such tests. The tests for SO₂ and NO_x shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
61. The performance tests shall be conducted for the equipment designated below: for SO₂ the units designated in condition 41; for NO_x the units designated in condition 43. Performance tests for the emissions of SO₂ and NO_x shall be conducted and results reported in accordance with the methods set forth in Parts 60.8 and 60.46 of the Standards of Performance for New Sources on the equipment named above. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for an observer to be present and to allow time for development of an approvable performance test plan. Such prior approval will minimize the possibility of USEPA rejection of test results for procedural deficiencies. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
62. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; and c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
63. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
64. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 2520, 9.3.2 and 4320 6.2.1] Federally Enforceable Through Title V Permit
65. The applicable NO_x and CO emissions concentration for each month shall be determined based on the volume and type of fuel combusted in the unit (< 50% by volume PUC quality gas or ≥ 50% by volume PUC quality gas). Permittee shall maintain supporting records that demonstrate the type of fuel combusted. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

66. A source test to demonstrate compliance with NOx and CO emission limits shall be performed within 60 days of startup of this unit. The NOx limit in effect at the time of the startup source testing will be determined based on the volume and type of fuel combusted ($\geq 50\%$ PUC quality or $< 50\%$ PUC quality gas) and shall be identified in the source test protocol. Whenever the fuel type is switched from the fuel type combusted during the initial startup of this unit, compliance source testing for NOx and CO shall be conducted within 90 days of the date the fuel type is switched. [District Rules 2201 and 4320]
67. Source testing is required at least once every twelve (12) months from the initial source test date of each fuel type ($\geq 50\%$ PUC quality gas or $< 50\%$ PUC quality gas). After an initial compliance demonstration with the NOx and CO emission limits for each fuel type on two (2) consecutive source tests, the unit shall be tested not less than once every thirty-six (36) months from the last test date for that fuel type. Testing shall not be required for any fuel type not in use during the 36 month period until such time the fuel type is switched, after which testing shall be performed within 90 days of switching fuel types. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
68. Compliance source testing after switching fuel types is not required if the unit continues to demonstrate compliance with 9 ppmvd NOx @ 3% O₂ or 0.011 lb-NOx/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas. In which case, source testing shall only be required every thirty-six(36) months for the less than 50% by PUC quality gas. If the result of a source test demonstrates that the unit does not meet 9 ppmvd NOx @ 3% O₂ or 0.011 lb-NOx/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas, the source test frequency shall revert to at least one test every 36 months for each fuel type. [District Rules 2201 and 4320, 6.3.1] Federally Enforceable Through Title V Permit
69. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rule 2201, 2520, 4320] Federally Enforceable Through Title V Permit
70. SOx emissions shall be reduced by 95% or to 9 ppmvd SOx @ 3% O₂ in exhaust with scrubber. [District Rule 2201] Federally Enforceable Through Title V Permit
71. Source testing to measure NOx and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rule 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
72. This Authority to Construct shall be implemented according to the date proposed in the District Approved Rule 4320 Emission Control Plan. [District Rule 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-48-29

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 TOWNSHIP: 32S RANGE: 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 50-4-26C) EQUIPPED WITH A NORTH AMERICAN MAGNAFLAME GLE ULTRA-LOW NOX BURNER WITH SO2 SCRUBBER AND FLUE GAS RECIRCULATION: REDUCE SOX EMISSIONS BY AT LEAST 95% OR LIMIT EXHAUST SO2 EMISSIONS TO 9 PPMV @ 3% O2 ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
6. Steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

06/15/2010 10:29 AM Jun 15 2010 2:00PM - RINALDIR : Joint Inspection NOT Required

7. Scrubber recirculation liquid pH shall be maintained only by the addition of caustic unless prior approval for an alternative pH maintenance method is received from the District. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Scrubber liquor pH shall be maintained between 6 and 8, and shall be continuously monitored. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Scrubber mist eliminator shall be properly cleaned and maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Scrubber recirculation liquor liquid to gas ratio shall be maintained at no less than 8.0 gpm/1000 acfm. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
12. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
13. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
14. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3246, D 4084, D 4468, D6667, or double GC for H₂S and mercaptans. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
15. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; 4320 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
16. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
17. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
18. Emissions from the steam generator shall not exceed any of the following limits: 0.324 lb-SO_x/MMBtu, 0.037 lb-PM₁₀/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb/MMBtu, 29 ppmvd CO @ 3% O₂ or 0.021 lb/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
21. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
22. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NO_x/day, 9,855 lb-NO_x/yr, 31.5 lb-CO/day, and 11,498 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
23. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1 and 4320] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
25. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
28. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
29. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

30. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, SO_x (lb/MMBtu) - EPA Method 6 or ARB Method 100 and EPA Method 19. [District Rules 1081, 4305 and 4320] Federally Enforceable Through Title V Permit
31. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
32. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
33. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
34. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
35. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
36. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District NSR Rule] Federally Enforceable Through Title V Permit
37. Testing for vapor recovery gas sulfur content shall be conducted no less than monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
38. The permittee shall keep daily records of the amount of natural gas and vapor recovery gas combusted, and the date and duration of scrubber operation, for a period of five years, and shall make records available for inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
39. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. The requirements of SJVUAPCD Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 77-31] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

44. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in the conditions below. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 77- 31] Federally Enforceable Through Title V Permit
45. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions below, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
46. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR 52, 60 and 61 and all other applicable Federal, State and local regulations. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
47. Permittee shall have installed a hydrocarbon vapor recovery system, having a collection efficiency of 85% on the following: (143) steam drive producing wells designated in this PSD permit, plus (16) existing steam drive producing wells located in Section 16, T30S, R22E, M.D.B. & M. This system shall be installed on existing wells prior to project start-up, and on new or modified wells before venting steam to the atmosphere. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
48. At such times as specified by the USEPA, permittee shall conduct performance tests for HC and furnish the District and the USEPA a written report of the results of such tests. The tests for HC shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
49. Performance tests shall be conducted for each vapor recovery system listed above in the Cymric and Taft areas. The USEPA shall be notified at least 30 days in advance of such test to allow an observer to be present. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
50. Permittee shall not discharge or cause the discharge of VOC into the atmosphere in excess of 50.6 lbs/day for each well in the system. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
51. Permittee shall operate and maintain operable scrubbers on the equipment designated below: (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. Exhaust gases from the above units shall be ducted through operating scrubbers. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
52. Permittee shall not discharge into the atmosphere SO₂ in excess of 0.145 lb/MMBtu (maximum 2-hour average) for the steam generators designated in the previous condition. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
53. Permittee shall operate, and maintain operable excess oxygen control equipment on the units designated below: (2) 22 MMBtu/hr steam generators to be located in Section 1, T11N, R24W; (5) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 2, T11N, R24W; (1) 50 MMBtu/hr steam generator to be located in Section 31, T12N, R23W; (3) 50 MMBtu/hr steam generators and (1) 22 MMBtu/hr steam generator to be located in Section 25, T32S, R23E; and (1) 50 MMBtu/hr steam generator and (2) 22 MMBtu/hr steam generators to be located in Section 26, T32S, R23E. The concentration of excess oxygen in the exhaust gases shall not exceed 3% for the above units on a 24-hour average basis. The excess oxygen level shall be recorded continuously in a permanent record and shall be available for periodic inspection by the USEPA. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
54. Permittee shall not discharge into the atmosphere NO_x in excess of 0.50 lb/MMBtu (maximum 2-hour average) for the 50 MMBtu/hr steam generators and 0.57 lb/MMBtu (maximum 2-hour average) for the 22 MMBtu/hr steam generators designated in the previous condition. [PSD SJ 77- 31] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

55. At such times as specified by the USEPA, permittee shall conduct performance tests for SO₂ and NO_x, and furnish the District and the USEPA a written report of the results of such tests. The tests for SO₂ and NO_x shall be conducted on an annual basis and at the maximum operating capacity of the facilities being tested. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
56. The performance tests shall be conducted for the equipment designated below: for SO₂ the units designated in condition 41; for NO_x the units designated in condition 43. Performance tests for the emissions of SO₂ and NO_x shall be conducted and results reported in accordance with the methods set forth in Parts 60.8 and 60.46 of the Standards of Performance for New Sources on the equipment named above. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for an observer to be present and to allow time for development of an approvable performance test plan. Such prior approval will minimize the possibility of USEPA rejection of test results for procedural deficiencies. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
57. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; and c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726. [PSD SJ 77-31] Federally Enforceable Through Title V Permit
58. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
59. SO_x emissions shall be reduced by 95% or to 9 ppmvd SO_x @ 3% O₂ in exhaust with scrubber. [District Rule 2201] Federally Enforceable Through Title V Permit
60. This Authority to Construct shall be implemented according to the date proposed in the District Approved Rule 4320 Emission Control Plan. [District Rule 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-56-18

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN GLE ULTRA-LOW NOX BURNER AND SO2 SCRUBBER (CUSA ID# 50-5-26C, DIS# 43303-80): INSTALL FLUE GAS RECIRCULATION AND LOWER NOX LIMIT TO 9 PPMV@ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND LIMIT FUEL GAS TO NO MORE THAN 5 GR S/100 SCF OR REDUCE SOX EMISSIONS BY AT LEAST 95% OR LIMIT EXHAUST SO2 EMISSIONS TO 9 PPMV @ 3% O2 ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services
S-1128-56-18 : Jun 15 2010 2:00PM - RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. Steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Scrubber recirculation liquid pH shall be maintained only by the addition of caustic unless prior approval for an alternative pH maintenance method is received from the District. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Scrubber liquor pH shall be maintained between 6 and 8 and shall be continuously monitored and recorded during operation of this unit. [District Rules 2201 and 2520, 9.4.1] Federally Enforceable Through Title V Permit
11. Scrubber mist eliminator shall be properly cleaned and maintained per the recommendations of the manufacturer. Each occurrence of the cleaning and maintenance shall be recorded. [District Rules 2201 and 2520, 9.4.1] Federally Enforceable Through Title V Permit
12. Scrubber recirculation liquor liquid to gas ratio shall be maintained at no less than 8.0 gpm/1000 acfm. The scrubber recirculation liquor liquid to gas ratio shall be recorded on a weekly basis. [District Rules 2201 and 2520, 9.4.1] Federally Enforceable Through Title V Permit
13. Testing for vapor recovery gas sulfur content shall be conducted no less than monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
14. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320]
15. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, double GC for H₂S and mercaptans or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320]
16. In months when PUC quality gas is burned, the permittee shall maintain records on a calendar month basis of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50% or greater than or equal to 50%. [District Rule 4320]
17. Emissions from the steam generator shall not exceed any of the following limits: 0.070 lb-SO_x/MMBtu, 0.036 lb-PM₁₀/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
18. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when this unit is burning 50% or greater by volume PUC quality gas on a monthly average basis: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
19. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when the unit is burning less than 50% by volume PUC quality gas on a monthly average basis: 12 ppmvd NO_x @ 3% O₂ or 0.014 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
20. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
21. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, 0.070 lb-SO_x/MMBtu, 0.036 lb-PM₁₀/MMBtu, 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 15 ppmvd @ 3% O₂ or 0.0182 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
23. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
24. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
25. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NO_x/day, 7,665 lb-NO_x/yr, 56.3 lb-CO/day, and 20,531 lb-CO/yr [District Rule 2201] Federally Enforceable Through Title V Permit
26. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, and 4351, 6.3.1] Federally Enforceable Through Title V Permit
27. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
29. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
30. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
32. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

34. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
35. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
36. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
37. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
38. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
39. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
40. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
41. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
42. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
43. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
44. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
45. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

46. Records of the scrubber liquor pH, occurrences of the cleaning and maintenance of the scrubber mist eliminator, and the scrubber liquid-to-gas ratio shall be maintained. The records shall include identification of the equipment, date of inspection, corrective action taken, and identification of the individual performing the inspection. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
47. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 2520, 9.3.2 and 4320 6.2.1] Federally Enforceable Through Title V Permit
48. The applicable NO_x and CO emissions concentration for each month shall be determined based on the volume and type of fuel combusted in the unit (< 50% by volume PUC quality gas or >= 50% by volume PUC quality gas). Permittee shall maintain supporting records that demonstrate the type of fuel combusted. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
49. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. The NO_x limit in effect at the time of the startup source testing will be determined based on the volume and type of fuel combusted (>= 50% PUC quality or < 50% PUC quality gas) and shall be identified in the source test protocol. Whenever the fuel type is switched from the fuel type combusted during the initial startup of this unit, compliance source testing for NO_x and CO shall be conducted within 90 days of the date the fuel type is switched. [District Rules 2201 and 4320]
50. Source testing is required at least once every twelve (12) months from the initial source test date of each fuel type (>= 50% PUC quality gas or < 50% PUC quality gas). After an initial compliance demonstration with the NO_x and CO emission limits for each fuel type on two (2) consecutive source tests, the unit shall be tested not less than once every thirty-six (36) months from the last test date for that fuel type. Testing shall not be required for any fuel type not in use during the 36 month period until such time the fuel type is switched, after which testing shall be performed within 90 days of switching fuel types. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
51. Compliance source testing after switching fuel types is not required if the unit continues to demonstrate compliance with 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas. In which case, source testing shall only be required every thirty-six (36) months for the less than 50% by volume PUC quality gas. If the result of a source test demonstrates that the unit does not meet 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas, the source test frequency shall revert to at least one test every 36 months for each fuel type. [District Rules 2201 and 4320, 6.3.1] Federally Enforceable Through Title V Permit
52. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NO_x and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rule 2201, 2520, 4320] Federally Enforceable Through Title V Permit
53. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
54. Fuel gas sulfur content shall not exceed 5 gr-S/100 dscf unless SO_x is reduced by 95% or to 9 ppmvd SO_x @ 3% O₂ in exhaust with scrubber. [District Rule 2201] Federally Enforceable Through Title V Permit
55. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
56. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-56-13. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-56-19

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN GLE ULTRA-LOW NOX BURNER AND SO2 SCRUBBER (CUSA ID# 50-5-26C, DIS# 43303-80): LIMIT FUEL GAS TO NO MORE THAN 5 GR S/100 SCF OR REDUCE SOX EMISSIONS BY AT LEAST 95% OR LIMIT EXHAUST SO2 EMISSIONS TO 9 PPMV @ 3% O2 ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

S-1128-56-19 : Jun 15 2010 2:00PM -- RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. Steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Scrubber recirculation liquid pH shall be maintained only by the addition of caustic unless prior approval for an alternative pH maintenance method is received from the District. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Scrubber liquor pH shall be maintained between 6 and 8 and shall be continuously monitored and recorded during operation of this unit. [District Rules 2201 and 2520, 9.4.1] Federally Enforceable Through Title V Permit
11. Scrubber mist eliminator shall be properly cleaned and maintained per the recommendations of the manufacturer. Each occurrence of the cleaning and maintenance shall be recorded. [District Rules 2201 and 2520, 9.4.1] Federally Enforceable Through Title V Permit
12. Scrubber recirculation liquor liquid to gas ratio shall be maintained at no less than 8.0 gpm/1000 acfm. The scrubber recirculation liquor liquid to gas ratio shall be recorded on a weekly basis. [District Rules 2201 and 2520, 9.4.1] Federally Enforceable Through Title V Permit
13. Testing for vapor recovery gas sulfur content shall be conducted no less than monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Emissions from the steam generator shall not exceed any of the following limits: 0.070 lb-SO_x/MMBtu, 0.036 lb-PM₁₀/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
15. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
16. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
19. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NO_x/day, 9,965 lb-NO_x/yr, 56.3 lb-CO/day, and 20,531 lb-CO/yr [District Rule 2201] Federally Enforceable Through Title V Permit
20. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, and 4351, 6.3.1] Federally Enforceable Through Title V Permit
21. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
24. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
28. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
29. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
30. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
31. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
32. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
33. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

34. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
35. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
36. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
38. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
39. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
40. Records of the scrubber liquor pH, occurrences of the cleaning and maintenance of the scrubber mist eliminator, and the scrubber liquid-to-gas ratio shall be maintained. The records shall include identification of the equipment, date of inspection, corrective action taken, and identification of the individual performing the inspection. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
42. Fuel gas sulfur content shall not exceed 5 gr-S/100 dscf unless SO_x is reduced by 95% or to 9 ppmvd SO_x @ 3% O₂ in exhaust with scrubber. [District Rule 2201] Federally Enforceable Through Title V Permit
43. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
44. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-56-13. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-57-18

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL GLE 4231 LOW NOX BURNER AND FGR (#50-6 DIS #43012-81): LOWER NOX LIMIT TO 9 PPMV @ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND LIMIT FUEL GAS TO NO MORE THAN 5 GR S/100 SCF OR REDUCE SOX EMISSIONS BY AT LEAST 95% OR LIMIT EXHAUST SO2 EMISSIONS TO 9 PPMV @ 3% O2 ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services
S-1128-57-18 : Jun 15 2010 2:00PM - RINALDIR : Joint Inspection NOT Required

6. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
7. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320]
8. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3245, double GC for H₂S and mercaptans or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320]
9. In months when PUC quality gas is burned, the permittee shall maintain records on a calendar month basis of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50% or greater than or equal to 50%. [District Rule 4320]
10. Emissions from the steam generator shall not exceed any of the following limits: 0.087 lb-SO_x/MMBtu, 0.045 lb-PM₁₀/MMBtu, or 0.013 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when this unit is burning 50% or greater by volume PUC quality gas on a monthly average basis: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
12. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when the unit is burning less than 50% by volume PUC quality gas on a monthly average basis: 12 ppmvd NO_x @ 3% O₂ or 0.014 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
16. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 15 ppmvd @ 3% O₂ or 0.0182 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
17. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NO_x/day, 7,665 lb-NO_x/yr, 56.3 lb-CO/day, and 20,531 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

19. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
25. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
26. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
27. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
28. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
29. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
30. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
32. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
33. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
34. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
35. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit
36. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
37. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
38. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
39. This Authority to Construct shall be implemented according to the date proposed in the District Approved Rule 4320 Emission Control Plan. [District Rule 4320] Federally Enforceable Through Title V Permit
40. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 2520, 9.3.2 and 4320 6.2.1] Federally Enforceable Through Title V Permit
41. The applicable NO_x and CO emissions concentration for each month shall be determined based on the volume and type of fuel combusted in the unit (< 50% by volume PUC quality gas or >= 50% by volume PUC quality gas). Permittee shall maintain supporting records that demonstrate the type of fuel combusted. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
42. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. The NO_x limit in effect at the time of the startup source testing will be determined based on the volume and type of fuel combusted (>= 50% PUC quality or < 50% PUC quality gas) and shall be identified in the source test protocol. Whenever the fuel type is switched from the fuel type combusted during the initial startup of this unit, compliance source testing for NO_x and CO shall be conducted within 90 days of the date the fuel type is switched. [District Rules 2201 and 4320]

CONDITIONS CONTINUE ON NEXT PAGE

43. Source testing is required at least once every twelve (12) months from the initial source test date of each fuel type (\geq 50% PUC quality gas or $<$ 50% PUC quality gas). After an initial compliance demonstration with the NO_x and CO emission limits for each fuel type on two (2) consecutive source tests, the unit shall be tested not less than once every thirty-six (36) months from the last test date for that fuel type. Testing shall not be required for any fuel type not in use during the 36 month period until such time the fuel type is switched, after which testing shall be performed within 90 days of switching fuel types. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
44. Compliance source testing after switching fuel types is not required if the unit continues to demonstrate compliance with 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas. In which case, source testing shall only be required every thirty-six (36) months for the less than 50% by volume PUC quality gas. If the result of a source test demonstrates that the unit does not meet 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas, the source test frequency shall revert to at least one test every 36 months for each fuel type. [District Rules 2201 and 4320, 6.3.1] Federally Enforceable Through Title V Permit
45. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NO_x and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rule 2201, 2520, 4320] Federally Enforceable Through Title V Permit
46. Fuel gas sulfur content shall not exceed 5 gr-S/100 dscf unless SO_x is reduced by 95% or to 9 ppmvd SO_x @ 3% O₂ in exhaust with scrubber. [District Rule 2201] Federally Enforceable Through Title V Permit
47. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
48. Source testing to measure NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rule 2201, 4305, 4306, and 4320]
49. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-57-19

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL GLE 4231 LOW NOX BURNER AND FGR (#50-6 DIS #43012-81): LIMIT FUEL GAS TO NO MORE THAN 5 GR S/100 SCF OR REDUCE SOX EMISSIONS BY AT LEAST 95% OR LIMIT EXHAUST SO2 EMISSIONS TO 9 PPMV @ 3% O2 ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

S-1128-57-19 : Jun 15 2010 2:00PM -- RINALDIR : Joint Inspection NOT Required

6. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
7. Emissions from the steam generator shall not exceed any of the following limits: 0.087 lb-SO_x/MMBtu, 0.045 lb-PM₁₀/MMBtu, or 0.013 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
9. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
11. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
12. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NO_x/day, 9,965 lb-NO_x/yr, 56.3 lb-CO/day, and 20,531 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
16. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
18. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

19. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
20. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
22. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
23. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
24. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
27. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
28. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
30. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
32. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
33. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
34. This Authority to Construct shall be implemented according to the date proposed in the District Approved Rule 4320 Emission Control Plan. [District Rule 4320] Federally Enforceable Through Title V Permit
35. Fuel gas sulfur content shall not exceed 5 gr-S/100 dscf unless SO_x is reduced by 95% or to 9 ppmvd SO_x @ 3% O₂ in exhaust with scrubber. [District Rule 2201] Federally Enforceable Through Title V Permit
36. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
37. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-58-18

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR #50-7 DIS# 43013-81 WITH NORTH AMERICAN GLE ULTRA-LOW NOX BURNER AND FGR: LOWER NOX LIMIT TO 9 PPMV @ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND LIMIT FUEL GAS TO NO MORE THAN 5 GR S/100 SCF OR REDUCE SOX EMISSIONS BY AT LEAST 95% OR LIMIT EXHAUST SO2 EMISSIONS TO 9 PPMV @ 3% O2 ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
6. No emission factor and no emission shall be greater for the alternate equipment than for the proposed equipment. No changes in the hours of operation, operating rate, throughput, or firing rate may be authorized for any alternate equipment. [District Rule 2201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-58-18 : Jun 15 2010 2:01PM - RINALDIR : Joint Inspection NOT Required

7. Steam generator shall be equipped with the following operational instrumentation: fuel gas volume flowmeter and vapor recovery gas volume flowmeter. [District Rules 2201, 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
8. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit
9. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
10. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
11. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
12. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
13. During a "shakedown" period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rates shall not exceed 15 ppmvd @ 3% O₂ or 0.018 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rule 4320] Federally Enforceable Through Title V Permit
14. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320]
15. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, double GC for H₂S and mercaptans or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320]
16. In months when PUC quality gas is burned, the permittee shall maintain records on a calendar month basis of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50% or greater than or equal to 50%. [District Rule 4320]
17. Emission rates shall not exceed any of the following: SO_x (as SO₂): 0.087 lb/MMBtu; PM₁₀: 0.045 lb/MMBtu; or VOC: 0.013 lb/MMBtu. [District Rules 2201, 4201, 3.1, 4301, 5.2, 4406 and 4801] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

18. Emission rates, except during startup and shutdown, shall not exceed any of the following: NO_x (as NO₂): 0.018 lb/MMBtu or 15 ppmvd @ 3% O₂, or CO: 0.025 lb/MMBtu or 33.8 ppmvd @ 3% O₂. [District Rules 2201, 2520, 9.3.2, 4201, 3.1, 4301, 5.2, 5.3, and 5.5, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
19. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when this unit is burning 50% or greater by volume PUC quality gas on a monthly average basis: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 33.8 ppmvd CO @ 3% O₂ or 0.025 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
20. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when the unit is burning less than 50% by volume PUC quality gas on a monthly average basis: 12 ppmvd NO_x @ 3% O₂ or 0.014 lb-NO_x/MMBtu and 33.8 ppmvd CO @ 3% O₂ or 0.025 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
21. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320]
22. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rules 2201 and 4301] Federally Enforceable Through Title V Permit
23. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54.0 lb-NO_x/day, 7,655 lb-NO_x/yr, 37.5 lb-CO/day, and 13,688 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rule 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3 and Kern County Rules 404 and 408] Federally Enforceable Through Title V Permit
26. Source testing to measure NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
29. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

30. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion ASTM D3246, a grab sample analysis by double GC performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by double GC performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
32. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [Kern County Rule 407; District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. Permittee shall measure and record the fuel gas sulfur content and BTU content at the time of NO_x testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
34. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
35. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
36. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NO_x and CO. [District Rules 2520, 9.3.2, 4305 and 4320] Federally Enforceable Through Title V Permit
37. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
38. Compliance demonstration (source testing) shall be conducted by independent testing laboratories and shall be witnessed, or authorized by the District. Sample collection shall be done by ARB certified testing laboratory. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
39. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
40. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

41. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
42. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 and EPA Method 19. [District Rules 1081, 4305 and 4306] Federally Enforceable Through Title V Permit
43. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
44. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
45. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; 4306, 6.2.1 and 4320] Federally Enforceable Through Title V Permit
46. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
47. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
48. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
49. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
50. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
51. The permittee shall keep daily records of the amount of natural gas and vapor recovery gas combusted, permit number(s) of vapor recovery systems providing gas for incineration, and shall make records available for inspection upon request. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
52. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401] Federally Enforceable Through Title V Permit
53. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 2520, 9.3.2 and 4320 6.2.1] Federally Enforceable Through Title V Permit
54. The applicable NO_x and CO emissions concentration for each month shall be determined based on the volume and type of fuel combusted in the unit (< 50% by volume PUC quality gas or >= 50% by volume PUC quality gas). Permittee shall maintain supporting records that demonstrate the type of fuel combusted. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

55. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. The NO_x limit in effect at the time of the startup source testing will be determined based on the volume and type of fuel combusted ($\geq 50\%$ PUC quality or $< 50\%$ PUC quality gas) and shall be identified in the source test protocol. Whenever the fuel type is switched from the fuel type combusted during the initial startup of this unit, compliance source testing for NO_x and CO shall be conducted within 90 days of the date the fuel type is switched. [District Rules 2201 and 4320]
56. Source testing is required at least once every twelve (12) months from the initial source test date of each fuel type ($\geq 50\%$ PUC quality gas or $< 50\%$ PUC quality gas). After an initial compliance demonstration with the NO_x and CO emission limits for each fuel type on two (2) consecutive source tests, the unit shall be tested not less than once every thirty-six (36) months from the last test date for that fuel type. Testing shall not be required for any fuel type not in use during the 36 month period until such time the fuel type is switched, after which testing shall be performed within 90 days of switching fuel types. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
57. Compliance source testing after switching fuel types is not required if the unit continues to demonstrate compliance with 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas. In which case, source testing shall only be required every thirty-six (36) months for the less than 50% by PUC quality gas. If the result of a source test demonstrates that the unit does not meet 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas, the source test frequency shall revert to at least one test every 36 months for each fuel type. [District Rules 2201 and 4320, 6.3.1] Federally Enforceable Through Title V Permit
58. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NO_x and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rule 2201, 2520, 4320] Federally Enforceable Through Title V Permit
59. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
60. Fuel gas sulfur content shall not exceed 5 gr-S/100 dscf unless SO_x is reduced by 95% or to 9 ppmvd SO_x @ 3% O₂ in exhaust with scrubber. [District Rule 2201] Federally Enforceable Through Title V Permit
61. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-58-17. [District Rule 2201] Federally Enforceable Through Title V Permit
62. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
63. This Authority to Construct shall be implemented according to the date proposed in the District Approved Rule 4320 Emission Control Plan. [District Rule 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-58-19

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR #50-7 DIS# 43013-81 WITH NORTH AMERICAN GLE ULTRA-LOW NOX BURNER AND FGR: LIMIT FUEL GAS TO NO MORE THAN 5 GR S/100 SCF OR REDUCE SOX EMISSIONS BY AT LEAST 95% OR LIMIT EXHAUST SO2 EMISSIONS TO 9 PPMV @ 3% O2 ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
5. No emission factor and no emission shall be greater for the alternate equipment than for the proposed equipment. No changes in the hours of operation, operating rate, throughput, or firing rate may be authorized for any alternate equipment. [District Rule 2201]
6. Steam generator shall be equipped with the following operational instrumentation: fuel gas volume flowmeter and vapor recovery gas volume flowmeter. [District Rules 2201, 4305,5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-58-19 : Jun 15 2010 2:01PM - RINALDIR : Joint Inspection NOT Required

7. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit
8. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
9. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
10. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
11. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
12. Emission rates shall not exceed any of the following: SOX (as SO₂): 0.087 lb/MMBtu; PM₁₀: 0.045 lb/MMBtu; or VOC: 0.013 lb/MMBtu. [District Rules 2201, 4201, 3.1, 4301, 5.2, 4406 and 4801] Federally Enforceable Through Title V Permit
13. Emission rates, except during startup and shutdown, shall not exceed any of the following: NO_x (as NO₂): 0.018 lb/MMBtu or 15 ppmvd @ 3% O₂, or CO: 0.025 lb/MMBtu or 33.8 ppmvd @ 3% O₂. [District Rules 2201, 2520, 9.3.2, 4201, 3.1, 4301, 5.2, 5.3, and 5.5, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
14. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320]
15. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rules 2201 and 4301] Federally Enforceable Through Title V Permit
16. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 54 lb-NO_x/day, 9,855 lb-NO_x/yr, 37.5 lb-CO/day, and 13,688 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rule 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

18. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3 and Kern County Rules 404 and 408] Federally Enforceable Through Title V Permit
19. Source testing to measure NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
20. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
22. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion ASTM D3246, a grab sample analysis by double GC performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by double GC performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [Kern County Rule 407; District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall measure and record the fuel gas sulfur content and BTU content at the time of NO_x testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
27. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

29. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NOx and CO. [District Rules 2520, 9.3.2, 4305 and 4320] Federally Enforceable Through Title V Permit
30. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
31. Compliance demonstration (source testing) shall be conducted by independent testing laboratories and shall be witnessed, or authorized by the District. Sample collection shall be done by ARB certified testing laboratory. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
32. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
33. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
34. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
35. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 100 and EPA Method 19. [District Rules 1081, 4305 and 4306] Federally Enforceable Through Title V Permit
36. Stack gas velocities for source test purposes shall be determined using EPA Method 2. [District Rule 1081] Federally Enforceable Through Title V Permit
37. Stack gas moisture content for source test purposes shall be determined using EPA Method 4. [District Rule 1081] Federally Enforceable Through Title V Permit
38. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; 4306, 6.2.1 and 4320] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351 (Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

43. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel sources, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
44. The permittee shall keep daily records of the amount of natural gas and vapor recovery gas combusted, permit number(s) of vapor recovery systems providing gas for incineration, and shall make records available for inspection upon request. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
45. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401] Federally Enforceable Through Title V Permit
46. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
47. Fuel gas sulfur content shall not exceed 5 gr-S/100 dscf unless SO_x is reduced by 95% or to 9 ppmvd SO_x @ 3% O₂ in exhaust with scrubber. [District Rule 2201] Federally Enforceable Through Title V Permit
48. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-58-17. [District Rule 2201] Federally Enforceable Through Title V Permit
49. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
50. This Authority to Construct shall be implemented according to the date proposed in the District Approved Rule 4320 Emission Control Plan. [District Rule 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-61-10

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 27.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (SN 22-2) WITH NORTH AMERICAN GLE MAGNA-FLAME ULTRA LOW NOX BURNER: INSTALL FLUE GAS RECIRCULATION, LOWER NOX LIMIT TO 9 PPMV @ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rules 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

S-1128-61-10: Jun 15 2010 2:01PM - RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320]
9. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, double GC for H₂S and mercaptans or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320]
10. In months when PUC quality gas is burned, the permittee shall maintain records on a calendar month basis of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50% or greater than or equal to 50%. [District Rule 4320]
11. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
12. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when this unit is burning 50% or greater by volume PUC quality gas on a monthly average basis: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
13. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when the unit is burning less than 50% by volume PUC quality gas on a monthly average basis: 12 ppmvd NO_x @ 3% O₂ or 0.014 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
16. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 15 ppmvd @ 3% O₂ or 0.0182 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
19. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 23.8 lb-NO_x/day, 3,373 lb-NO_x/yr, 55.4 lb-CO/day, and 9,034 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
21. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
24. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
28. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
29. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
30. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
32. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
33. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
34. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
35. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
36. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
38. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
39. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
40. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 2520, 9.3.2 and 4320 6.2.1] Federally Enforceable Through Title V Permit
41. The applicable NO_x and CO emissions concentration for each month shall be determined based on the volume and type of fuel combusted in the unit (< 50% by volume PUC quality gas or >= 50% by volume PUC quality gas). Permittee shall maintain supporting records that demonstrate the type of fuel combusted. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
42. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. The NO_x limit in effect at the time of the startup source testing will be determined based on the volume and type of fuel combusted (>= 50% PUC quality or < 50% PUC quality gas) and shall be identified in the source test protocol. Whenever the fuel type is switched from the fuel type combusted during the initial startup of this unit, compliance source testing for NO_x and CO shall be conducted within 90 days of the date the fuel type is switched. [District Rules 2201 and 4320]
43. Source testing is required at least once every twelve (12) months from the initial source test date of each fuel type (>= 50% PUC quality gas or < 50% PUC quality gas). After an initial compliance demonstration with the NO_x and CO emission limits for each fuel type on two (2) consecutive source tests, the unit shall be tested not less than once every thirty-six (36) months from the last test date for that fuel type. Testing shall not be required for any fuel type not in use during the 36 month period until such time the fuel type is switched, after which testing shall be performed within 90 days of switching fuel types. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

44. Compliance source testing after switching fuel types is not required if the unit continues to demonstrate compliance with 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas. In which case, source testing shall only be required every thirty-six(36) months for the less than 50% by PUC quality gas. If the result of a source test demonstrates that the unit does not meet 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas, the source test frequency shall revert to at least one test every 36 months for each fuel type. [District Rules 2201 and 4320, 6.3.1] Federally Enforceable Through Title V Permit
45. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NO_x and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rule 2201, 2520, 4320] Federally Enforceable Through Title V Permit
46. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
47. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-61-6. [District Rule 2201] Federally Enforceable Through Title V Permit
48. Source testing to measure NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
49. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-61-11

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 27.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (SN 22-2) WITH NORTH AMERICAN GLE MAGNA-FLAME ULTRA LOW NOX BURNER: RESTATE SOX LIMIT EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rules 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

8-1128-61-11 : Jun 15 2010 2:01PM -- RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
9. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
10. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
12. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 23.8 lb-NO_x/day, 4,384 lb-NO_x/yr, 55.4 lb-CO/day, and 9,034 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
15. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
22. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
23. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
24. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
25. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
26. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
32. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
34. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
35. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-61-6. [District Rule 2201] Federally Enforceable Through Title V Permit
36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-335-9

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 27.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (SN 22-6) WITH A NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER: INSTALL FLUE GAS RECIRCULATION, LOWER NOX LIMIT TO 9 PPMV@ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-335-9 : Jun 15 2010 2:01PM - RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320]
9. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, double GC for H₂S and mercaptans or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320]
10. In months when PUC quality gas is burned, the permittee shall maintain records on a calendar month basis of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50% or greater than or equal to 50%. [District Rule 4320]
11. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
12. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when this unit is burning 50% or greater by volume PUC quality gas on a monthly average basis: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
13. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when the unit is burning less than 50% by volume PUC quality gas on a monthly average basis: 12 ppmvd NO_x @ 3% O₂ or 0.014 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
16. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 15 ppmvd @ 3% O₂ or 0.0182 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
19. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 23.8 lb-NO_x/day, 3,373 lb-NO_x/yr, 55.4 lb-CO/day, and 9,034 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
27. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
28. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
29. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
30. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
32. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
33. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
34. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
35. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
37. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
38. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
39. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
40. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 2520, 9.3.2 and 4320 6.2.1] Federally Enforceable Through Title V Permit
41. The applicable NO_x and CO emissions concentration for each month shall be determined based on the volume and type of fuel combusted in the unit (< 50% by volume PUC quality gas or >= 50% by volume PUC quality gas). Permittee shall maintain supporting records that demonstrate the type of fuel combusted. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
42. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. The NO_x limit in effect at the time of the startup source testing will be determined based on the volume and type of fuel combusted (>= 50% PUC quality or < 50% PUC quality gas) and shall be identified in the source test protocol. Whenever the fuel type is switched from the fuel type combusted during the initial startup of this unit, compliance source testing for NO_x and CO shall be conducted within 90 days of the date the fuel type is switched. [District Rules 2201 and 4320]
43. Source testing is required at least once every twelve (12) months from the initial source test date of each fuel type (>= 50% PUC quality gas or < 50% PUC quality gas). After an initial compliance demonstration with the NO_x and CO emission limits for each fuel type on two (2) consecutive source tests, the unit shall be tested not less than once every thirty-six (36) months from the last test date for that fuel type. Testing shall not be required for any fuel type not in use during the 36 month period until such time the fuel type is switched, after which testing shall be performed within 90 days of switching fuel types. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

44. Compliance source testing after switching fuel types is not required if the unit continues to demonstrate compliance with 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas. In which case, source testing shall only be required every thirty-six(36) months for the less than 50% by PUC quality gas. If the result of a source test demonstrates that the unit does not meet 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas, the source test frequency shall revert to at least one test every 36 months for each fuel type. [District Rules 2201 and 4320, 6.3.1] Federally Enforceable Through Title V Permit
45. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NO_x and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rule 2201, 2520, 4320] Federally Enforceable Through Title V Permit
46. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
47. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-335-5. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-335-10

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 27.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (SN 22-6) WITH A NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER: RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-335-10 : Jun 15 2010 2:01PM - RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
9. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
10. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
12. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 23.8 lb-NO_x/day, 4,384 lb-NO_x/yr, 55.4 lb-CO/day, and 9,034 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
15. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
18. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
21. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
23. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
24. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
25. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
29. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
30. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
31. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
34. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
35. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-335-5. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-336-9

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 25 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 27.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (SN 22-7) WITH A NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER: INSTALL FLUE GAS RECIRCULATION, LOWER NOX LIMIT TO 9 PPMV @ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-336-9 : Jun 15 2010 2:01PM - RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320]
9. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, double GC for H₂S and mercaptans or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320]
10. In months when PUC quality gas is burned, the permittee shall maintain records on a calendar month basis of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50% or greater than or equal to 50%. [District Rule 4320]
11. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when this unit is burning 50% or greater by volume PUC quality gas on a monthly average basis: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
13. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when the unit is burning less than 50% by volume PUC quality gas on a monthly average basis: 12 ppmvd NO_x @ 3% O₂ or 0.014 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
16. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 15 ppmvd @ 3% O₂ or 0.0182 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
19. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 23.8 lb-NO_x/day, 3,373 lb-NO_x/yr, 55.4 lb-CO/day, and 9,034 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
21. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
24. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
28. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
29. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
30. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
32. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
33. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
34. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
35. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
36. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
38. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
39. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
40. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
41. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 2520, 9.3.2 and 4320 6.2.1] Federally Enforceable Through Title V Permit
42. The applicable NO_x and CO emissions concentration for each month shall be determined based on the volume and type of fuel combusted in the unit (< 50% by volume PUC quality gas or ≥ 50% by volume PUC quality gas). Permittee shall maintain supporting records that demonstrate the type of fuel combusted. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
43. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. The NO_x limit in effect at the time of the startup source testing will be determined based on the volume and type of fuel combusted (≥ 50% PUC quality or < 50% PUC quality gas) and shall be identified in the source test protocol. Whenever the fuel type is switched from the fuel type combusted during the initial startup of this unit, compliance source testing for NO_x and CO shall be conducted within 90 days of the date the fuel type is switched. [District Rules 2201 and 4320]

CONDITIONS CONTINUE ON NEXT PAGE

44. Source testing is required at least once every twelve (12) months from the initial source test date of each fuel type (\geq 50% PUC quality gas or $<$ 50% PUC quality gas). After an initial compliance demonstration with the NO_x and CO emission limits for each fuel type on two (2) consecutive source tests, the unit shall be tested not less than once every thirty-six (36) months from the last test date for that fuel type. Testing shall not be required for any fuel type not in use during the 36 month period until such time the fuel type is switched, after which testing shall be performed within 90 days of switching fuel types. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
45. Compliance source testing after switching fuel types is not required if the unit continues to demonstrate compliance with 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas. In which case, source testing shall only be required every thirty-six (36) months for the less than 50% by volume PUC quality gas. If the result of a source test demonstrates that the unit does not meet 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas, the source test frequency shall revert to at least one test every 36 months for each fuel type. [District Rules 2201 and 4320, 6.3.1] Federally Enforceable Through Title V Permit
46. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NO_x and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rule 2201, 2520, 4320] Federally Enforceable Through Title V Permit
47. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
48. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-336-5. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-336-10

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 25 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 27.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (SN 22-7) WITH A NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER: INSTALL FLUE GAS RECIRCULATION, LOWER NOX LIMIT TO 9 PPMV@ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

8-1128-336-10 : Jun 15 2010 2:01PM - RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
10. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
12. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 23.8 lb-NO_x/day, 4,384 lb-NO_x/yr, 55.4 lb-CO/day, and 9,034 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
15. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

21. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
22. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
23. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
24. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
25. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
26. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
31. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
32. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

33. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
34. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
35. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
36. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-336-5. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-337-13

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 27.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#22-5-26C) WITH NORTH AMERICAN GLE MAGNA-FLAME ULTRA LOW NOX BURNER: INSTALL FLUE GAS RECIRCULATION, LOWER NOX LIMIT TO 9 PPMV@ 3% O2 (0.011 LB/MM BTU) OR 12 PPMV @ 3% O2 (0.014 LB/MM BTU) AND RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU ALL FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-337-13 : Jun 15 2010 2:01PM - RINALDIR : Joint Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320]
9. Fuel H₂S, total sulfur, and methane content shall be determined semi-annually using the following test methods H₂S: ASTM D6228; total sulfur: ASTM D1072; ASTM D3246, double GC for H₂S and mercaptans or ASTM D6228; and methane content: ASTM D1945. [District Rule 4320]
10. In months when PUC quality gas is burned, the permittee shall maintain records on a calendar month basis of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50% or greater than or equal to 50%. [District Rule 4320]
11. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
12. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when this unit is burning 50% or greater by volume PUC quality gas on a monthly average basis: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
13. Except during startup, shutdown and the shakedown period, emissions shall not exceed any of the following limits when the unit is burning less than 50% by volume PUC quality gas on a monthly average basis: 12 ppmvd NO_x @ 3% O₂ or 0.014 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4320 and 4351, 5.1] Federally Enforceable Through Title V Permit
16. During a shakedown period not to exceed 60 calendar days from initial operation of the modifications authorized by this ATC, NO_x emission rate shall not exceed 15 ppmvd @ 3% O₂ or 0.0182 lb/MMBtu. The shakedown period shall be concluded prior to the applicable Rule 4306 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and shall make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
19. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 23.8 lb-NO_x/day, 3,373 lb-NO_x/yr, 24.8 lb-CO/day, and 9,034 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
21. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
24. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
28. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
29. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
30. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
32. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
33. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
34. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
35. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
36. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
38. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
39. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
40. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
41. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
44. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 2520, 9.3.2 and 4320 6.2.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

45. The applicable NO_x and CO emissions concentration for each month shall be determined based on the volume and type of fuel combusted in the unit (< 50% by volume PUC quality gas or >= 50% by volume PUC quality gas). Permittee shall maintain supporting records that demonstrate the type of fuel combusted. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
46. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. The NO_x limit in effect at the time of the startup source testing will be determined based on the volume and type of fuel combusted (>= 50% PUC quality or < 50% PUC quality gas) and shall be identified in the source test protocol. Whenever the fuel type is switched from the fuel type combusted during the initial startup of this unit, compliance source testing for NO_x and CO shall be conducted within 90 days of the date the fuel type is switched. [District Rules 2201 and 4320]
47. Source testing is required at least once every twelve (12) months from the initial source test date of each fuel type (>= 50% PUC quality gas or < 50% PUC quality gas). After an initial compliance demonstration with the NO_x and CO emission limits for each fuel type on two (2) consecutive source tests, the unit shall be tested not less than once every thirty-six (36) months from the last test date for that fuel type. Testing shall not be required for any fuel type not in use during the 36 month period until such time the fuel type is switched, after which testing shall be performed within 90 days of switching fuel types. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
48. Compliance source testing after switching fuel types is not required if the unit continues to demonstrate compliance with 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas. In which case, source testing shall only be required every thirty-six(36) months for the less than 50% by PUC quality gas. If the result of a source test demonstrates that the unit does not meet 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu and 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu while firing on less than 50% by volume PUC quality gas, the source test frequency shall revert to at least one test every 36 months for each fuel type. [District Rules 2201 and 4320, 6.3.1] Federally Enforceable Through Title V Permit
49. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NO_x and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rule 2201, 2520, 4320] Federally Enforceable Through Title V Permit
50. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-337-9. [District Rule 2201] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1128-337-14

ISSUANCE DATE: 06/15/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: P O BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY

SECTION: 26 **TOWNSHIP:** 32S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 27.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR (#22-5-26C) WITH NORTH AMERICAN GLE MAGNA-FLAME ULTRA LOW NOX BURNER: RESTATE SOX LIMITS EXPRESSED AS 0.75 GR S/100 SCF TO 0.00285 LB/MMBTU FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District NSR Rule] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 4306, 6.4 and 4320] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

S-1128-337-14 : Jun 15 2010 2:02PM - RINALDIR : Jobt Inspection NOT Required

7. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
8. Emissions from the steam generator shall not exceed any of the following limits: 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
9. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.0182 lb-NO_x/MMBtu or 51 ppmvd CO @ 3% O₂ or 0.0375 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, 4351, 5.1 and 4320] Federally Enforceable Through Title V Permit
10. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown that exceeds two hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320]
12. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25, 3.22 and 4320] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 23.8 lb-NO_x/day, 4,384 lb-NO_x/yr, 24.8 lb-CO/day, and 9,034 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
15. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing has occurred within the previous 12 months. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the fuel gas being fired in the steam generator shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested quarterly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which quarterly testing may resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
22. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
23. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320] Federally Enforceable Through Title V Permit
24. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
25. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
26. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2 and 4320] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4320] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
32. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any non-certified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
34. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
36. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
37. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
38. This ATC shall be implemented concurrently with or subsequent to ATC S-1128-337-9. [District Rule 2201] Federally Enforceable Through Title V Permit