

<b>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</b>  <b>ENGINEERING AND COMPLIANCE DIVISION</b>  <b>PERMIT APPLICATION EVALUATION AND CALCULATIONS</b>	PAGES 1	PAGE 1
	APPL NO 508844	DATE 03/29/2011
	PROCESSED BY AS08	CHECKED BY

### TITLE V PERMIT (REV No. 06) EVALUATION

**Applicant's Name** Eastern Municipal Water District (EMWD)  
Temecula Valley Regional Water Reclamation Facility

**Mailing Address** 2270 Trumble Road  
P.O. Box 8300  
Perris, CA 92580-8300

**Equipment Location** 42565 Avenida Alvarado  
Temecula, CA 92590

**FACILITY ID 001703**  
**APPLICATION 508844- Title V Minor Permit Revision**  
**Background**

Eastern Municipal Water District (EMWD) A/N 508844 was submitted for Title V permit revision (06). The Title V permit revision includes permit applications 518817, 518818, and 518819 which were submitted for the replacement of the catalytic converter for the engine used to drive aeration blowers (518817) and the replacement of the air to fuel ratio controller for engines used to drive aeration blower (518818 & 518819). The proposed equipment will be located at Eastern Municipal Water District Temecula Valley Regional Water Reclamation Facility (EMWD-TVRWRF) in Temecula.

Public notice is not required. For additional information please refer to the attached evaluation prepared for the EPA review. Note: Title V Revision 05 (A/N 482161) was issued February 10, 2011.

**Rules Evaluation**

Reg. XXX:  
Replacement of a catalytic converter and the replacement of two air to fuel ratio controllers for ICE engines used to drive aeration blowers is considered a Title V Minor permit revision under Rule 3000(b)(12), since there is no emission increase and the modification of the equipment does not result in new or additional NSPS or NESHAP requirements and will be subject to an EPA review (Rule 3003 (j)). A public notice is not required.  
Compliance is expected.

**Conclusions and Recommendations**

A Permit to Operate is recommended for application 518817. A Permit to Construct is recommended for applications 518818 and 518819. A revised Title V permit is recommended after the completion of EPA review.