

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT ENGINEERING AND COMPLIANCE DIVISION PERMIT APPLICATION EVALUATION AND CALCULATIONS	PAGES 1	PAGE 1
	APPL NO 508839	DATE 10/20/2010
	PROCESSED BY AS08	CHECKED BY

TITLE V PERMIT (REV 04) EVALUATION

Applicant's Name Eastern Municipal Water District (EMWD)
San Jacinto Valley Regional Water Reclamation Facility

Mailing Address 2270 Trumble Road
P.O. Box 8300
Perris, CA 92580-8300

Equipment Location 770 N Sanderson Avenue
San Jacinto, CA 92582

FACILITY ID 019159,
APPLICATION 508839- Title V De Minimis Significant Permit Revision

Background/Process Description

Eastern Municipal Water District (EMWD) A/N 508839 was submitted for Title V permit revision (04) on March 16, 2009. Application 512190 was submitted for the alteration of an anaerobic sewage treatment plant (>5 MGD) to update the equipment description and alter the secondary digester to be converted into a cold sludge storage tank. The proposed equipment will be located at Eastern Municipal Water District (EMWD) San Jacinto Valley Regional Water Reclamation Facility (SJVRWRF) in San Jacinto.

Public notice is not required. For additional information and permit evaluation please refer to the attached evaluation prepared for EPA review.

Note: Title V Revision 03 (A/N 503047) was issued March 9, 2010.

Rules Evaluation

Reg. XXX:

The alteration of the anaerobic sewage treatment plant is considered a Title V De Minimis Significant permit revision under Rule 3000(b)(6), since the cumulative emission increases of non-RECLAIM pollutants or HAPs do not exceed the emissions in Table 5-4 of the Draft Title V TDG March 2005 and does not result in new or additional NSPS or NESHAP requirements and will be subject to an EPA review (Rule 3003(j)). A public notice is not required. Compliance is expected.

Conclusions and Recommendations

A Permit to Construct is recommended for application 512190. A revised Title V permit is recommended after the completion of EPA review.