




South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 25, 2008

Gerardo Rios
Chief – Permits Office
U.S. EPA – Region IX – Air 3
75 Hawthorne Street
San Francisco, CA 94105

Re: Transmittal of Renewal Title V Permit, PurEnergy LLC Id 132191, A/N 455476 [661 S Cooley Drive, Colton CA 92324]

Dear Mr. Rios: 

Enclosed is one final renewal Title V permit issued by the South Coast Air Quality Management District (AQMD). The draft copy of this permit was submitted to EPA Region IX for a 45-day review and made available to the public for a 30-day public comment period on July 16, 2008. The AQMD did not receive any public comments on the draft permit. As of September 25, 2008, this Title V permit replaces the initial Title V permit.

If there are specific questions on the final permit, please contact permitting engineer Mr. Chandrashekhar S. Bhatt of our General Commercial and Energy team at (909) 396-2653. Questions on the AQMD's Title V permitting program may be referred to me at (909) 396-2662 or Michael D. Mills, the Senior Manager of the team, at (909) 396-2578.

Sincerely,



Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering and Compliance

MN:MDM:MYL:RGC:CSB

Enclosure

cc: Title V Facility File
Title V Admin File

C:/purEnergy-Final-Title V-renewal-permit-132191-455476-EPA-cover-ltr.doc

Cleaning the air that we breathe.



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 25, 2008

Mr. Thomas R. Murphy
Vice President
PurEnergy Operating Services, LLC
1732 West Genesee Street
Syracuse, NY 13204

SUBJECT: Title V Renewal Permit, Id 132191, A/N 455476 [661 S Cooley Drive, Colton CA 92324]

Dear Mr. Murphy:

Please find attached your Title V Permit renewal for equipment located at 661 S. Cooley Drive, Colton CA 92324. The Title V permit renewal is issued for a new 5 year term beginning September 25, 2008 and ending on September 24, 2013.

The following modifications were made to the permit as per the data provided by Mr. Joel Lepoutre's e-mail of June 25, 2008 in response to our request:

- 1) Condition D12.3 has been updated to maintain the ammonia flow rate between 1 and 7 lbs/hr.
- 2) Condition D12.5 has been updated to maintain the pressure drop across the SCR bed between 2 and 5 inches of water column.

Thank you for providing the necessary information that allowed the AQMD to complete the evaluation of your facility with respect to the federal Title V requirements. Questions concerning your Title V permit should be directed Chandrashekhar S. Bhatt of the General Commercial and Energy Team at (909) 396-2653 or cbhatt@aqmd.gov.

Sincerely,

Michael D. Mills, P.E.
Senior Manager
General Commercial and Energy Team
Engineering and Compliance

Enclosure
MDM:MYL:RGC:csb

CC: Joel Lepoutre (w/Encl., PurEnergy)
Title V Administration, w/o attachment
Compliance
Energy Unit File

c:\purEnergy-455476-tv-renewal-permit-cover-ltr.doc

Cleaning the air that we breathe.



FACILITY PERMIT TO OPERATE

**PUREENERGY OPERATING SERVICES, LLC
661 S COOLEY DR
COLTON, CA 92324**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.


Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By 
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance



AQMD

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765






**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	4	09/25/2008
B	RECLAIM Annual Emission Allocation	6	09/25/2008
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	6	09/25/2008
E	Administrative Conditions	4	09/25/2008
F	RECLAIM Monitoring and Source Testing Requirements	4	09/25/2008
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	4	09/25/2008
H	Permit To Construct and Temporary Permit to Operate	6	09/25/2008
I	Compliance Plans & Schedules	4	09/25/2008
J	Air Toxics	4	09/25/2008
K	Title V Administration	4	09/25/2008
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	4	09/25/2008
B	Rule Emission Limits	4	09/25/2008



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765





**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR: PUREENERGY OPERATING SERVICES, LLC

LEGAL OPERATOR (if different than owner):

EQUIPMENT LOCATION: 661 S COOLEY DR.
COLTON, CA 92324

MAILING ADDRESS: 1732 WEST GENESEE STREET
SYRACUSE, NY 13204

RESPONSIBLE OFFICIAL: THOMAS MURPHY

TITLE: VICE PRESIDENT

TELEPHONE NUMBER: (315) 448-2266

CONTACT PERSON: RODNEY LEE

TITLE: PLANT MANAGER

TELEPHONE NUMBER: (909) 824-1942

TITLE V PERMIT ISSUED: September 25, 2008


TITLE V PERMIT EXPIRATION DATE: September 24, 2013

TITLE V	RECLAIM
YES	NOx: YES
	SOx: NO
	CYCLE: 1
	ZONE: INLAND



AQMD

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765





**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NO_x RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NO_x emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year		Zone	NO _x RTC Initially Allocated	NO _x RTC ¹ Holding as of 09/25/08 (pounds)	Non-Tradable ² Non-Usable RTCs (pounds)
Begin (month/year)	End				
1/2006	12/2006	Coastal	0	0	0
1/2006	12/2006	Inland	0	0	0
7/2006	6 /2007	Coastal	0	12245	0
1/2007	12/2007	Coastal	0	0	0
1/2008	12/2008	Coastal	0	12560	0
7/2007	6 /2008	Inland	0	1344	0
7/2008	6 /2009	Coastal	0	9000	0
1/2009	12/2009	Coastal	0	6764	0

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION C: FACILITY PLOT PLAN

(TO BE DEVELOPED)



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION					
System 1 : POWER GENERATION, UNIT NO. 1					
TURBINE, NO.1, NATURAL GAS, GENERAL ELECTRIC, MODEL 10B1, SIMPLE CYCLE, 136.5 MMBTU/HR WITH A/N: 463514	D1	C4 C5	NOX: MAJOR SOURCE**	CO: 2000 PPMV (5) [RULE 407,4-2-1982] ; CO: 6 PPMV (4) [RULE 1303(a)(1)-BACT,5- 10-1996;RULE 1303(a)(1)- BACT,10-20-2000] NOX: 79 PPMV (8) [40CFR 60 Subpart GG,3-6-1981] ; NOX: 5 PPMV (4) [RULE 2005,4-9- 1999] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981] PM: 11 LBS/HR (5A) [RULE 475,10-8-1976;RULE 475,8-7-1978] ; PM: 0.01 GRAINS/SCF (5B) [RULE 475,10-8-1976;RULE 475,8-7-1978] SOX: 150 PPMV (8) [40CFR 60 Subpart GG,3-6-1981] ; VOC: 2 PPMV (4) [RULE 1303(a)(1)- BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	A63.1, A63.2, A99.1, A99.2, A99.5, A195.1, A195.2, A327.1, C1.1, C1.2, D12.1, D12.2, D29.1, D82.1, D82.2, E57.1, E481.1, H23.1
GENERATOR, NO. 1, 10.5 MW					

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION					
CO OXIDATION CATALYST, NO. 1, SERVING GAS TURBINE NO. 1, TECHNIP OR EQUIVALENT, PRECIOUS METAL (PD, PT) ON METAL FOIL, WITH 40-50 CUBIC FEET OF TOTAL CATALYST VOLUME, 22 FT H X 13.5 FT L X 10.5 FT W A/N: 400872	C4	D1 C5			
SELECTIVE CATALYTIC REDUCTION, NO.1 SERVING GAS TURBINE NO. 1, TECHNIP, MONO-NOX VANADIA/TITANNIA 275 CUBIC FEET, WIDTH: 10 FT 6 IN; HEIGHT: 22 FT; LENGTH: 13 FT 6 IN WITH AMMONIA INJECTION A/N: 400872	C5	D1 C4		NH3: 5 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	A99.3, A195.3, D12.3, D12.4, D12.5, D28.1, E73.1, E179.1, E179.2
STACK, NO. 1 A/N: 463514	S7				
System 2 : POWER GENERATION, UNIT NO. 2					
TURBINE, NO.2, NATURAL GAS, GENERAL ELECTRIC, MODEL 10B1, SIMPLE CYCLE, 136.5 MMBTU/HR WITH A/N: 463517	D8	C11 C12	NOX: MAJOR SOURCE**	CO: 2000 PPMV (5) [RULE 407,4-2-1982] ; CO: 6 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	A63.1, A63.2, A99.1, A99.2, A99.5, A195.1, A195.2, A327.1, C1.1, C1.2, D12.1, D12.2, D29.1,

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION					
GENERATOR, NO. 2, 10.5 MW				NOX: 79 PPMV (8) [40CFR 60 Subpart GG,3-6-1981] ; NOX: 5 PPMV (4) [RULE 2005,4-9-1999] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981] PM: 11 LBS/HR (5A) [RULE 475,10-8-1976;RULE 475,8-7-1978] ; PM: 0.01 GRAINS/SCF (5B) [RULE 475,10-8-1976;RULE 475,8-7-1978] SOX: 150 PPMV (8) [40CFR 60 Subpart GG,3-6-1981] ; VOC: 2 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	D82.1, D82.2, E57.1, E481.1, H23.1
CO OXIDATION CATALYST, NO. 2, SERVING GAS TURBINE NO. 2, TECNIP OR EQUIVALENT, PRECIOUS METAL (PD, PT) ON METAL FOIL, WITH 40-50 CUBIC FEET OF TOTAL CATALYST VOLUME, 22 FT H X 13.5 FT L X 10.5 FT W A/N: 400874	C11	D8 C12			

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
 (5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION					
SELECTIVE CATALYTIC REDUCTION, NO.2 SERVING GAS TURBINE NO. 2, TECHNIP, MONO-NOX VANADIA/TITANNIA 275 CUBIC FEET, WIDTH: 10 FT 6 IN; HEIGHT: 22 FT; LENGTH: 13 FT 6 IN WITH A/N: 400874 AMMONIA INJECTION	C12	D8 C11		NH3: 5 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	A99.3, A195.3, D12.3, D12.4, D12.5, D28.1, E73.1, E179.1, E179.2
STACK, NO. 2 A/N:463517	S14				
System 3 : POWER GENERATION, UNIT NO. 3					
TURBINE, NO.3, NATURAL GAS, GENERAL ELECTRIC, MODEL 10B1, SIMPLE CYCLE, 136.5 MMBTU/HR WITH A/N: 463519	D15	C18 C19	NOX: MAJOR SOURCE**	CO: 2000 PPMV (5) [RULE 407,4-2-1982] ; CO: 6 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000] NOX: 79 PPMV (8) [40CFR 60 Subpart GG,3-6-1981] ; NOX: 5 PPMV NATURAL GAS (4) [RULE 2005,4-9-1999] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981]	A63.1, A63.2, A99.1, A99.2, A99.5, A195.1, A195.2, A327.1, C1.1, C1.2, D12.1, D12.2, D29.1, D82.1, D82.2, E57.1, E481.1, H23.1

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION					
GENERATOR, NO. 3, 10.5 MW				PM: 11 LBS/HR (5A) [RULE 475,10-8-1976;RULE 475,8-7-1978] ; PM: 0.01 GRAINS/SCF (5B) [RULE 475,10-8-1976;RULE 475,8-7-1978] SOX: 150 PPMV (8) [40CFR 60 Subpart GG,3-6-1981] ; VOC: 2 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	
CO OXIDATION CATALYST, NO. 3, SERVING GAS TURBINE NO. 3, TECNIP OR EQUIVALENT, PRECIOUS METAL (PD, PT) ON METAL FOIL, WITH 40-50 CUBIC FEET OF TOTAL CATALYST VOLUME, 22 FT H X 13.5 FT L X 10.5 FT W A/N: 400876	C18	D15 C19			
SELECTIVE CATALYTIC REDUCTION, NO.3 SERVING GAS TURBINE NO. 3, TECHNIP, MONO-NOX VANADIA/TITANNINIA 275 CUBIC FEET, WIDTH: 10 FT 6 IN; HEIGHT: 22 FT; LENGTH: 13 FT 6 IN WITH AMMONIA INJECTION A/N: 400876	C19	D15 C18		NH3: 5 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	A99.3, A195.3, D12.3, D12.4, D12.5, D28.1, E73.1, E179.1, E179.2

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
 (5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
 (7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
 (9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION					
STACK, NO. 3 A/N: 463519	S21				
System 4 : POWER GENERATION, UNIT NO. 4					
TURBINE, NO.4, NATURAL GAS, GENERAL ELECTRIC, MODEL 10B1, SIMPLE CYCLE, 136.5 MMBTU/HR WITH A/N: 463521	D22	C25 C26	NOX: MAJOR SOURCE**	CO: 2000 PPMV (5) [RULE 407.4-2-1982] ; CO: 6 PPMV (4) [RULE 1303(a)(1)-BACT,5- 10-1996;RULE 1303(a)(1)- BACT,10-20-2000] NOX: 79 PPMV (8) [40CFR 60 Subpart GG,3-6-1981] ; NOX: 5 PPMV (4) [RULE 2005,4-9- 1999] ; PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981] PM: 11 LBS/HR (5A) [RULE 475,10-8-1976;RULE 475,8-7-1978] ; PM: 0.01 GRAINS/SCF (5B) [RULE 475,10-8-1976;RULE 475,8-7-1978] SOX: 150 PPMV (8) [40CFR 60 Subpart GG,3-6-1981] ; VOC: 2 PPMV (4) [RULE 1303(a)(1)- BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	A63.1, A63.2, A99.1, A99.2, A99.5, A195.1, A195.2, A327.1, C1.1, C1.2, D12.1, D12.2, D29.1, D82.1, D82.2, E57.1, E481.1, H23.1
GENERATOR, NO. 4, 10.5 MW					

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COMBUSTION					
CO OXIDATION CATALYST, NO. 4, SERVING GAS TURBINE NO. 4, TECNIP OR EQUIVALENT, PRECIOUS METAL (PD, PT) ON METAL FOIL, WITH 40-50 CUBIC FEET OF TOTAL CATALYST VOLUME, 22 FT H X 13.5 FT L X 10.5 FT W A/N: 400878	C25	D22 C26			
SELECTIVE CATALYTIC REDUCTION, NO.4 SERVING GAS TURBINE NO. 4, TECHNIP, MONO-NOX VANADIA/TITANNINIA 275 CUBIC FEET, WIDTH: 10 FT 6 IN; HEIGHT: 22 FT; LENGTH: 13 FT 6 IN WITH AMMONIA INJECTION A/N: 400878	C26	D22 C25		NH3: 5 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	A99.3, A195.3, D12.3, D12.4, D12.5, D28.1, E73.1, E179.1, E179.2
STACK, NO. 4 A/N: 463521	S28				
Process 2 : INORGANIC CHEMICAL STORAGE					
STORAGE TANK, FIXED ROOF, WITH VAPOR RETURN LINE, AQUEOUS AMMONIA, 19% SOLUTION, 10,000 GALLONS OR SMALLER A/N: 400430	D29				C157.1, E144.1

* (1)(1A)(1B) Denotes RECLAIM emission factor (2)(2A)(2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5)(5A)(5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8)(8A)(8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
 PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 3 : R-219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECIFIC RULES					
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS	E30			ROG: (9) [RULE 1113,11-8-1996;RULE 1113,7-13-2007;RULE 1171,11-7-2003;RULE 1171,2-1-2008]	K67.2

- * (1)(1A)(1B) Denotes RECLAIM emission factor
- (3) Denotes RECLAIM concentration limit
- (5)(5A)(5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits
- (2)(2A)(2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8)(8A)(8B) Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
- (10) See Section J for NESHAP/MACT requirements

** Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: DEVICE ID INDEX

**The following sub-section provides an index
to the devices that make up the facility
description sorted by device ID.**



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D1	1	1	1
C4	2	1	1
C5	2	1	1
S7	2	1	1
D8	2	1	2
C11	3	1	2
C12	4	1	2
S14	4	1	2
D15	4	1	3
C18	5	1	3
C19	5	1	3
S21	6	1	3
D22	6	1	4
C25	7	1	4
C26	7	1	4
S28	7	1	4
D29	7	2	0
E30	8	3	0



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

F2.1 The operator shall limit emissions from this facility as follows:

CONTAMINANT	EMISSIONS LIMIT
NOX	Less than or equal to 23280 LBS IN ANY ONE YEAR

PurEnergy shall possess, prior to each compliance year, NOx RTCs in the amount of 23,280 lbs for the upcoming compliance year.

The emission limit applies based on a calendar year basis for each compliance year.

In addition, this facility shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the first RECLAIM compliance year, the facility holds sufficient RTCs in the amount equal to the annual emissions increase.

[RULE 2005, 4-9-1999; RULE 2005, 4-20-2001]

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 9-11-1998]

DEVICE CONDITIONS

A. Emission Limits



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

A63.1 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
CO	Less than or equal to 4984 LBS IN ANY ONE MONTH
PM10	Less than or equal to 2380 LBS IN ANY ONE MONTH
VOC	Less than or equal to 972 LBS IN ANY ONE MONTH
SOX	Less than or equal to 1224 LBS IN ANY ONE MONTH

For the purposes of this condition, the limit(s) shall be based on the total combined facility emissions.

The operator shall calculate the emission limit(s) using monthly fuel usage and the following emission factors: PM10 6.731 lb/mmcf, VOC 2.69 lb/mmcf and SOx 3.469 lb/mmcf

The operator shall calculate the emission limit(s) for the compliance with the monthly CO emission limit through valid CEMS data. In absence of valid CEMS data, the operator shall calculate the monthly CO emissions using monthly fuel use data and the following emission factor: CO 12.25 lbs/mmcf

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition : D1, D8, D15, D22]



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

A63.2 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
CO	Less than or equal to 166 LBS IN ANY ONE DAY
PM10	Less than or equal to 79 LBS IN ANY ONE DAY
VOC	Less than or equal to 32 LBS IN ANY ONE DAY
SOX	Less than or equal to 41 LBS IN ANY ONE DAY

The operator shall calculate the emission limit(s) using daily fuel usage and the following emission factors:
PM10 6.731 lbs/mmcsf, VOC 2.69 lbs/mmcsf and SOx 3.469 lbs/mmcsf

The operator shall calculate the emission limit(s) for compliance with daily CO emission limit using valid CEMS data. In absence of valid CEMS data, the operator shall calculate the daily CO emissions using daily fuel usage and the following emission factor: CO 12.25 lbs/mmcsf.

For the purposes of this condition, the limit(s) shall be based on the total combined facility emissions.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(1)-Modeling, 5-10-1996]

[Devices subject to this condition : D1, D8, D15, D22]

A99.1 The 5 PPM NOX emission limit(s) shall not apply during retuning of turbines resulting from maintenance or repair of combustion systems, startup and shutdown periods. The Start-up time shall not exceed 60 minutes for each start-up and shutdown time shall not exceed 15 minutes for each shutdown. Retuning of turbines shall not exceed 8 hours per turbine per year. Written records of retuning, start-ups and shutdown shall be maintained and made available upon request from the Executive Officer.

[RULE 2005, 4-9-1999]

[Devices subject to this condition : D1, D8, D15, D22]



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

A99.2 The 6 PPM CO emission limit(s) shall not apply during retuning of turbines resulting from maintenance or repair of combustion systems, startup and shutdown periods. The Start-up time shall not exceed 60 minutes for each start-up and shutdown time shall not exceed 15 minutes for each shutdown. Retuning of turbines shall not exceed 8 hours per turbine per year. Written records of retuning, start-ups and shutdown shall be maintained and made available upon request from the Executive Officer.

[**RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002**]

[Devices subject to this condition : D1, D8, D15, D22]

A99.3 The 5 PPM NH3 emission limit(s) shall not apply during retuning of turbines resulting from maintenance or repair of combustion systems, startup and shutdown periods. The Start-up time shall not exceed 60 minutes for each start-up and shutdown time shall not exceed 15 minutes for each shutdown. Retuning of turbines shall not exceed 8 hours per turbine per year. Written records of retuning, start-ups and shutdown shall be maintained and made available upon request from the Executive Officer.

[**RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002**]

[Devices subject to this condition : C5, C12, C19, C26]

A99.5 The 18.45 LBS/MMSCF CO emission limit(s) shall only apply to report CO emissions during any startup or shutdown period when CO emissions are not being measured by a certified or provisionally certified CEMS.

[**RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002**]

[Devices subject to this condition : D1, D8, D15, D22]

A195.1 The 5 PPMV NOX emission limit(s) is averaged over 60 minutes at 15 percent O2 dry.

[**RULE 2005, 4-9-1999**]

[Devices subject to this condition : D1, D8, D15, D22]

A195.2 The 6 PPMV CO emission limit(s) is averaged over 60 minutes at 15 percent oxygen dry.

[**RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000**]

[Devices subject to this condition : D1, D8, D15, D22]



FACILITY PERMIT TO OPERATE PUREENERGY OPERATING SERVICES, LLC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

A195.3 The 5 PPMV NH₃ emission limit(s) is averaged over 60 mins at 15 percent O₂ dry. The operator shall calculate and continuously record the NH₃ slip concentration using the following: $NH_3 \text{ (ppmv)} = [a - (b * (c * 1.2)/1000000)] * (1000000/b)$, where a = NH₃ injection rate (lb/hr)/(17 lb/lb-mole), b = dry exhaust gas flow rate (lb/hr)/(29 lb/lb-mole) and c = change in measured NO_x across the SCR (ppmv at 15 percent O₂).

The operator shall install and maintain a NO_x analyzer to measure the SCR inlet NO_x ppmv accurate to plus or minus 5 percent and calibrated at least once every 12 months.

The determination of ammonia slip based on the above formula shall be adjusted with correction factors. The operator shall determine a equipment-specific procedure for the correction of the formula by comparing the results of the formula with the actual ammonia slip measurement during the performance testing. New correction factors and any changes to the factors are subject to AQMD approval.

The operator shall use the above described method or another alternative method approved by the Executive Officer.

The ammonia slip calculation procedure described above shall not be used for compliance determination or emission information without corroborative data using an approved reference method for determination of ammonia.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : C5, C12, C19, C26]

A327.1 For the purpose of determining compliance with District Rule 475, combustion contaminant emissions may exceed the concentration limit or the mass emission limit listed, but not both limits at the same time.

[RULE 475, 10-8-1976; RULE 475, 8-7-1978]

[Devices subject to this condition : D1, D8, D15, D22]

C. Throughput or Operating Parameter Limits



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

C1.1 The operator shall limit the fuel usage to no more than 354 MM cubic feet in any one calendar month.

For the purpose of this condition, fuel usage shall be defined as the total natural gas usage of all four turbines.

The operator shall maintain records in a manner approved by the District, to demonstrate compliance with this condition.

[RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D1, D8, D15, D22]

C1.2 The operator shall limit the fuel usage to no more than 1188 MM cubic feet per year.

For the purpose of this condition, fuel usage shall be defined as the total natural gas usage of all four turbines.

The operator shall maintain records in a manner approved by the District, to demonstrate compliance with this condition.

[RULE 1303(b)(2)-Offset, 5-10-1996]

[Devices subject to this condition : D1, D8, D15, D22]

C157.1 The operator shall install and maintain a pressure relief valve set at 20 or higher psig.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : D29]

D. Monitoring/Testing Requirements



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D12.1 The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the turbine.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition : D1, D8, D15, D22]

D12.2 The operator shall install and maintain a(n) non-resettable totalizing fuel flow meter to accurately indicate the fuel usage being supplied to the turbine.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition : D1, D8, D15, D22]

D12.3 The operator shall install and maintain a(n) flow meter to accurately indicate the flow rate of the total hourly throughput of injected ammonia (NH₃).

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

The operator shall maintain the ammonia injection rate between 1 and 7 lbs per hour

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : C5, C12, C19, C26]

D12.4 The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature of the exhaust at the inlet to the SCR reactor.

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 2005, 4-9-1999]

[Devices subject to this condition : C5, C12, C19, C26]



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D12.5 The operator shall install and maintain a(n) pressure gauge to accurately indicate the pressure across the SCR catalyst bed in inches of water column.

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

The operator shall maintain the pressure drop across the SCR bed between 2 and 5 inches of water column

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : C5, C12, C19, C26]

D28.1 The operator shall conduct source test(s) in accordance with the following specifications:

The test shall be conducted and the results submitted to the District within 60 days after the test date.

The test shall be conducted at least quarterly during the first twelve months of operation and at least annually thereafter.

The District shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit.

The test shall be conducted to determine the NH₃ emissions using District Method 207.1 and 5.3 or EPA Method 17 measured over a 60-minute averaging time period. The NO_x concentration, as determined by reading the CEMS, shall be simultaneously recorded during the test. If the CEMS is inoperable, a test shall be conducted to determine the NO_x emissions using District Method 100.1 measured over a 60-minute averaging time period.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : C5, C12, C19, C26]



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D29.1 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
CO emissions	District method 100.1	1 hour	Outlet of the SCR serving this equipment
NOX emissions	District method 100.1	1 hour	Outlet of the SCR serving this equipment
PM10 emissions	District Method 5.2 Modified with EPA Method 201A Cyclone (filterables compliance, condensables information)	1 hour	Outlet of the SCR serving this equipment
ROG emissions	Approved District method	1 hour	Outlet of the SCR serving this equipment

The test(s) shall be conducted at least once every three years and as per District approved protocol. within 60 days after the source test, the operator shall submit the source test report to the District..

[RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 12-6-2002; **RULE 2005, 5-6-2005**]

[Devices subject to this condition : D1, D8, D15, D22]



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D82.1 The operator shall install and maintain a CEMS to measure the following parameters:

CO concentration in ppmv

Concentrations shall be corrected to 15 percent oxygen on a dry basis.

The CEMS will convert the actual CO concentrations to mass emission rates (lbs/hr) and record the hourly emission rates on a continuous basis.

The CEMS shall be installed, operated and maintained in accordance with an approved AQMD Rule 218 CEMS plan application. The operator shall not install CEMS prior to receiving the initial approval from AQMD

The CEMS shall be installed and operated to measure CO concentrations over a 15-minute averaging period

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition : D1, D8, D15, D22]

D82.2 The operator shall install and maintain a CEMS to measure the following parameters:

NOX concentration in ppmv

The CEMS shall be installed and operating no later than 12 months after the initial start-up of the turbine. During the interim period between the initial start-up and the provisional certification date of the CEMS, the operator shall comply with the monitoring requirements of Rule 2012(h)(2) and 2012(h)(3). Within 2 weeks of the turbine start-up date, the operator shall provide written notification to the District of the exact start-up date

[RULE 2012, 5-11-2001; RULE 2012, 12-5-2003]

[Devices subject to this condition : D1, D8, D15, D22]

E. Equipment Operation/Construction Requirements



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E57.1 The operator shall vent this equipment to the CO oxidation and SCR control whenever the turbine is in operation.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000; RULE 2005, 4-9-1999]

[Devices subject to this condition : D1, D8, D15, D22]

E73.1 Notwithstanding the requirements of Section E conditions, the operator may, at his discretion, choose not to use ammonia injection if any of the following requirement(s) are met::

The inlet temperature to the SCR reactor is 800 Degrees F or less, not to exceed 1 hour during start-ups and not to exceed 15 minutes during shutdowns.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : C5, C12, C19, C26]

E144.1 The operator shall vent this equipment, during filling, only to the vessel from which it is being filled.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : D29]

E179.1 For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour.

Condition Number D 12- 3

Condition Number D 12- 4

Condition Number A 195- 3

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : C5, C12, C19, C26]



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E179.2 For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every month and shall be calculated based upon the average of the continuous monitoring for that month.

Condition Number D 12- 5

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition : C5, C12, C19, C26]

E481.1 This device qualifies as an intermittently operated source. The operator may postpone the due date of a semi-annual assessment for the continuous emission monitoring system (CEMS) serving this device to the end of the next calendar quarter by conducting an alternative relative accuracy test audit during the same quarter the semi-annual assessment is due. The semi-annual assessment due date shall only be postponed if the alternative relative accuracy test audit is conducted according to and meet the criteria specified under Rule 2012, Appendix A, Attachment C, Subparagraph B.2.d, as amended January 7, 2005.

[RULE 2012, 5-6-2005]

[Devices subject to this condition : D1, D8, D15, D22]

H. Applicable Rules

H23.1 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Sulfur compounds	District Rule	431.1

[RULE 431.1, 6-12-1998]

[Devices subject to this condition : D1, D8, D15, D22]

K. Record Keeping/Reporting



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

K67.2 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

For architectural applications where no thinners, reducers, or other VOC containing materials are added, maintain semi-annual records for all coating consisting of (a) coating type, (b) VOC content as supplied in grams per liter (g/l) of materials for low-solids coatings, (c) VOC content as supplied in g/l of coating, less water and exempt solvent, for other coatings.

For architectural applications where thinners, reducers, or other VOC containing materials are added, maintain daily records for each coating consisting of (a) coating type, (b) VOC content as applied in grams per liter (g/l) of materials used for low-solids coatings, (c) VOC content as applied in g/l of coating, less water and exempt solvent, for other coatings.



[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition : E30]



AGMD

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765





FACILITY PERMIT TO OPERATE PUREENERGY OPERATING SERVICES, LLC

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
 - a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
 - b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
 - c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statutes of other governmental agencies. [204]
4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]
5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]
6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least: [204]



FACILITY PERMIT TO OPERATE PUREENERGY OPERATING SERVICES, LLC

SECTION E: ADMINISTRATIVE CONDITIONS

- a. Three years for a facility not subject to Title V; or
 - b. Five years for a facility subject to Title V.
7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]
- a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134, 204]
 - b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
 - c. For a large NO_x source, compliance with a RECLAIM concentration limit shall be measured over a continuous 60 minutes for that source; [2012]
 - d. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]
 - e. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO₂) and be averaged over 15 consecutive minutes; [407]
 - f. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO₂) at standard conditions and averaged over 15 consecutive minutes. [409]
 - g. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O₂) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]
8. All equipment operating under the RECLAIM program shall comply concurrently with all provisions of AQMD Rules and Regulations, except those listed in Table 1 of Rule 2001 for NO_x RECLAIM sources and Table 2 of Rule 2001 for SO_x RECLAIM sources. Those provisions listed in Tables 1 or 2 shall not apply to NO_x or SO_x emissions after the date the facility has demonstrated compliance with all monitoring and reporting requirements of Rules 2011 or 2012, as applicable. Provisions of the listed AQMD rules in Tables 1 or 2 which have initial implementation dates in 1994 shall not apply to a RECLAIM NO_x or SO_x source, respectively. [2001]



FACILITY PERMIT TO OPERATE PURENERGY OPERATING SERVICES, LLC

SECTION E: ADMINISTRATIVE CONDITIONS

9. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]
 - a. Brief description of the equipment tested.
 - b. Brief process description, including maximum and normal operating temperatures, pressures, through-put, etc.
 - c. Operating conditions under which the test will be performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
 - f. Description of calibration and quality assurance procedures.
 - g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (no conflict of interest).

10. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD Rules or equipment-specific conditions. The report shall contain the following information: [204]
 - a. The results of the source test.
 - b. Brief description of the equipment tested.
 - c. Operating conditions under which test will be performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Field and laboratory data forms, strip charts and analyses.
 - f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.

11. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]




**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION E: ADMINISTRATIVE CONDITIONS

12. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182.
[204]



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765





FACILITY PERMIT TO OPERATE PUREENERGY OPERATING SERVICES, LLC

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

The Facility shall comply with all applicable monitoring and source testing requirements in Regulation XX. These requirements may include but are not limited to the following:

I. NOx Monitoring Conditions

A. The Operator of a NOx Major Source, as defined in Rule 2012, shall, as applicable:

1. Install, maintain, and operate an AQMD certified direct or time-shared monitoring device or an approved alternative monitoring device for each major NOx source to continuously measure the concentration of NOx emissions and all other applicable variables specified in Rule 2012, Table 2012-1 and Rule 2012, Appendix A, Table 2-A to determine the NOx emissions rate from each source. The time-sharing of CEMS among NOx sources may be allowed by the Executive Officer in accordance with the requirements for time sharing specified in Appendix A. [2012]
2. Install, maintain, and operate a totalizing fuel meter approved by the Executive Officer for each major source. [2012]
3. If the facility is operating existing CEMS and fuel meters, continue to follow recording and reporting procedures required by AQMD Rules and Regulations in effect prior to October 15, 1993 until the CEMS is certified pursuant to Rule 2012. [2012]
4. Use valid data collected by an AQMD certified or provisionally certified CEMS in proper operation that meets all the requirements of Appendix A of Rule 2012, unless final certification of the CEMS is denied, to determine mass emissions for all purposes, including, but not limited to, determining: [2012]
 - a. compliance with the annual Allocation;
 - b. excess emissions;
 - c. the amount of penalties; and
 - d. fees.
5. Follow missing data procedures as specified in Rule 2012 Appendix A whenever valid data is not available or collected to determine mass emissions for all purposes, including, but not limited to, determining: [2012]
 - a. compliance with the annual Allocation;
 - b. excess emissions;
 - c. the amount of penalties; and
 - d. fees.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

B. The Operator of a NO_x Large Source, as defined in Rule 2012, shall, as applicable:

Not Applicable

C. The Operator of a NO_x Process Unit, as defined in Rule 2012, shall, as applicable:


Not Applicable

II. NO_x Source Testing and Tune-up Conditions

1. The operator shall conduct all required NO_x source testing in compliance with an AQMD-approved source test protocol. [2012]
2. The operator shall, as applicable, conduct source tests for every large NO_x source no later than December 31, 1996 and every 3 years thereafter. The source test shall include the determination of NO_x concentration and a relative accuracy audit of the exhaust stack flow determination (e.g. in-stack flow monitor or fuel flow monitor based F-factor calculation). Such source test results shall be submitted per the schedule described by APEP. In lieu of submitting the first source test report, the facility permit holder may submit the results of a source test not more than 3 years old which meets the requirements when conducted. [2012]
3. All NO_x large sources and NO_x process units shall be tuned-up in accordance with the schedule specified in Rule 2012, Appendix A, Chapter 5, Table 5-B. [2012]



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765





**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

**SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR
RECLAIM SOURCES**

The Facility shall comply with all applicable reporting and recordkeeping requirements in Regulation XX. These requirements may include but are not limited to the following:

I. Recordkeeping Requirements for all RECLAIM Sources

1. The operator shall maintain all monitoring data required to be measured or reported pursuant to Rule 2011 and Rule 2012, whichever is applicable. All records shall be made available to AQMD staff upon request and be maintained for at least:
 - a. Three years after each APEP report is submitted to AQMD for a facility not subject to Title V, unless a different time period is required in Rule 2011 or Rule 2012 [2011 & 2012]; or
 - b. Five years after each APEP report is submitted to AQMD for a facility subject to Title V. [3004(a)(4)(E)]
 - c. Notwithstanding the above, all data gathered or computed for intervals of less than 15 minutes shall only be maintained a minimum of 48 hours. [2011 & 2012]
2. The operator shall store on site and make available to the Executive Officer upon request: records used to determine emissions, maintenance records, sources test reports, relative accuracy test audit reports, relative accuracy audit reports and fuel meter calibration records. [2011 & 2012]

II. Reporting Requirements for all RECLAIM Sources

1. The operator shall submit a quarterly certification of emissions including the facility's total NO_x or SO_x emissions, whichever is applicable, for the quarter within 30 days after the end of the first three quarters and 60 days after the end of the fourth quarter of a compliance year. [2011 & 2012]

NO_x Reporting Requirements

- A. The Operator of a NO_x Major Source, as defined in Rule 2012, shall, as applicable:
 1. No later than 12 months after entry into the RECLAIM program or after the initial operation of a new major source, whichever is later, install, maintain, and operate a reporting device to electronically report everyday to the AQMD central station for each major NO_x source, the total daily mass emissions of NO_x and daily status codes. Such data



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

**SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR
RECLAIM SOURCES**

shall be transmitted by 5:00 p.m. of the following day. If the facility experiences a power, computer, or other system failure that prevents the submittal of the daily report, the Facility Permit holder shall be granted 24 hours extension to submit the report. [2012]

2. Calculate NOx emissions pursuant to missing data procedures set forth in Appendix A, Chapter 2 of Rule 2012 if the Facility Permit holder fails to meet the deadline for submitting the daily report. [2012]
3. Submit an electronic report within 15 days following the end of each month totaling NOx emissions from all major NOx sources during the month. [2012]
4. For those facilities with existing CEMS and fuel meters as of October 15, 1993, continue to follow recording and reporting procedures required by AQMD Rules and Regulations in effect until the CEMS is certified pursuant to Rule 2011 and/or Rule 2012, as applicable. [2012]

B. The Operator of a NOx Large Source, as defined in Rule 2012, shall:

Not Applicable

C. The Operator of a NOx Process Unit, as defined in Rule 2012, shall:

Not Applicable




**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

NONE



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765





**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION J: AIR TOXICS

NOT APPLICABLE



**FACILITY PERMIT TO OPERATE
PURENERGY OPERATING SERVICES, LLC**

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under Section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:

(A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION K: TITLE V Administration

- (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
- (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

- 8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
 - (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
 - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

- 9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
 - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]
- 10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION K: TITLE V Administration

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]
12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]
13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]
14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
 - (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION K: TITLE V Administration

commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION K: TITLE V Administration

EMERGENCY PROVISIONS

17. An emergency¹ constitutes an affirmative defense to an action brought for non-compliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 - Breakdown Provisions, or subdivision (i) of Rule 2004 - Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

¹ "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.



**FACILITY PERMIT TO OPERATE
PURENERGY OPERATING SERVICES, LLC**

SECTION K: TITLE V Administration

RECORDKEEPING PROVISIONS

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
 - (B) The date(s) analyses were performed;
 - (C) The company or entity that performed the analyses;
 - (D) The analytical techniques or methods used;
 - (E) The results of such analyses; and
 - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]
21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:
- (A) Breakdowns shall be reported as required by Rule 430 - Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.
 - (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION K: TITLE V Administration

- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
 - (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;
 - (B) The compliance status during the reporting period;
 - (C) Whether compliance was continuous or intermittent;
 - (D) The method(s) used to determine compliance over the reporting period and currently, and
 - (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn: Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION K: TITLE V Administration

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the Title V application file. [3004(a)(4)]



**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations:


With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	7-13-2007	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	2-1-2008	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(1)-Modeling	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 2005	4-20-2001	Federally enforceable
RULE 2005	4-9-1999	Federally enforceable
RULE 2005	5-6-2005	Federally enforceable
RULE 2012	12-5-2003	Federally enforceable
RULE 2012	5-11-2001	Federally enforceable
RULE 2012	5-6-2005	Federally enforceable
RULE 3004(a)(4)-Periodic Monitoring	12-12-1997	Federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 431.1	6-12-1998	Federally enforceable
RULE 475	10-8-1976	Federally enforceable
RULE 475	8-7-1978	Non federally enforceable
40CFR 60 Subpart GG	3-6-1981	Federally enforceable



AQMD

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive, Diamond Bar, CA 91765





**FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC**

**APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN
PERMIT PURSUANT TO RULE 219**

NONE



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 11-8-1996]

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

TABLE OF STANDARDS

VOC LIMITS

**Grams of VOC Per Liter of Coating,
Less Water And Less Exempt Compounds**

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior Coatings	350	450		350			
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250				100		50
Graphic Arts (Sign) Coatings	500						
Industrial Maintenance							



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 11-8-1996]

Primers and Topcoats						
Alkyds	420					
Catalyzed Epoxy	420					
Bituminous Coatings	420					
Materials						
Inorganic Polymers	420					
Vinyl Chloride Polymers	420					
Chlorinated Rubber	420					
Acrylic Polymers	420					
Urethane Polymers	420					
Silicones	420					
Unique Vehicles	420					
Japans/Faux Finishing	350	700		350		
Coatings						
Magnesite Cement Coatings	600			450		
Mastic Coatings	300					
Metallic Pigmented Coatings	500					
Multi-Color Coatings	420		250			
Pigmented Lacquer	680		550		275	
Pre-Treatment Wash Primers	780					
Primers, Sealers, and Undercoaters	350					
Quick-Dry Enamels	400					
Roof Coatings	300					
Shellac						
Clear	730					
Pigmented	550					
Stains	350					
Swimming Pool Coatings						
Repair	650					
Other	340					
Traffic Coatings	250		150			
Waterproofing Sealers	400					
Wood Preservatives						
Below-Ground	350					
Other	350					

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 11-8-1996]

TABLE OF STANDARDS (cont.)

VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 7-13-2007]

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings, except anti-graffiti coatings, for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 7-13-2007]

TABLE OF STANDARDS
VOC LIMITS

**Grams of VOC Per Liter of Coating,
Less Water and Less Exempt Compounds**

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350							
Clear Wood Finishes	350					275		
Varnish	350					275		
Sanding Sealers	350					275		
Lacquer	680	550			275			
Clear Brushing Lacquer	680				275			
Concrete-Curing Compounds	350						100	
Concrete-Curing Compounds For Roadways and Bridges**	350							
Dry-Fog Coatings	400						150	
Fire-Proofing Exterior Coatings	450	350						
Fire-Retardant Coatings***								
Clear	650							
Pigmented	350							
Flats	250	100						50
Floor Coatings	420		100			50		
Graphic Arts (Sign) Coatings	500							
Industrial Maintenance (IM) Coatings	420			250		100		
High Temperature IM Coatings			420					
Zinc-Rich IM Primers	420		340			100		
Japans/Faux Finishing Coatings	700	350						
Magnesite Cement Coatings	600	450						
Mastic Coatings	300							
Metallic Pigmented Coatings	500							
Multi-Color Coatings	420	250						
Nonflat Coatings	250		150			50		
Nonflat High Gloss	250		150				50	



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 7-13-2007]

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Pigmented Lacquer	680	550			275			
Pre-Treatment Wash Primers	780		420					
Primers, Sealers, and Undercoaters	350		200			100		
Quick-Dry Enamels	400		250			150	50	
Quick-Dry Primers, Sealers, and Undercoaters	350		200			100		
Recycled Coatings			250					
Roof Coatings	300		250		50			
Roof Coatings, Aluminum	500				100			
Roof Primers, Bituminous	350		350					
Rust Preventative Coatings	420		400			100		
Shellac								
Clear	730							
Pigmented	550							
Specialty Primers	350					250	100	
Stains	350		250				100	
Stains, Interior	250							
Swimming Pool Coatings								
Repair	650		340					
Other	340							
Traffic Coatings	250	150					100	
Waterproofing Sealers	400		250			100		
Waterproofing	400					100		
Concrete/Masonry Sealers								
Wood Preservatives								
Below-Ground	350							
Other	350							

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.

** Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

*** The Fire-Retardant Coating category will be eliminated on January 1, 2007 and subsumed by the coating category for which they are formulated.



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 7-13-2007]

TABLE OF STANDARDS (cont.)
VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-7-2003]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-7-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-7-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 2-1-2008]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	CURRENT LIMITS*	EFFECTIVE 1/1/2008*	EFFECTIVE 1/1/2009
SOLVENT CLEANING ACTIVITY	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application			
(i) General	25 (0.21)		
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)		
(iii) Medical Devices & Pharmaceuticals	800 (6.7)		
(B) Repair and Maintenance Cleaning			
(i) General	25 (0.21)		
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)		



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 2-1-2008]

	CURRENT LIMITS*	EFFECTIVE 1/1/2008*	EFFECTIVE 1/1/2009
SOLVENT CLEANING ACTIVITY (cont.)	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals			
(A) Tools, Equipment, & Machinery	800 (6.7)		
(B) General Work Surfaces	600 (5.0)		
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)		
(D) Cleaning of Ink Application Equipment			
(i) General	25 (0.21)		
(ii) Flexographic Printing	25 (0.21)		
(iii) Gravure Printing			
(A) Publication	100 (0.83)		
(B) Packaging	25 (0.21)		
(iv) Lithographic (Offset) or Letter Press Printing			
(A) Roller Wash, Blanket Wash, & On-Press Components			
(I) Newsprint	100 (0.83)		



FACILITY PERMIT TO OPERATE
PUREENERGY OPERATING SERVICES, LLC

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 2-1-2008]

	CURRENT LIMITS*	EFFECTIVE 1/1/2008*	EFFECTIVE 1/1/2009
SOLVENT CLEANING ACTIVITY (cont.)	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(II) Other Substrates	500 (4.2)	100 (0.83)	
(B) Removable Press Components	25 (0.21)		
(v) Screen Printing	500 (4.2)	100 (0.83)	
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)		
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)		

* The specified limits remain in effect unless revised limits are listed in subsequent columns.