

19. All units in a group for which representative units are annually source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-1548-359.
32. Formerly permit number S-3898-44.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-390-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 33 **TOWNSHIP:** 12N **RANGE:** 22W

## **EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 298504) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER POWERING A FLUID PUMP - YOWLUMNE 57-33

## **PERMIT UNIT REQUIREMENTS**

1. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
2. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. If the NOx and/or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-390-1; Jan 26 2010 9:57AM -- SIONGCOJ

6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081 and 4701] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
18. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. All units in a group for which representative units are annually source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-1548-360.
32. Formerly permit number S-3898-45.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-391-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 4 **TOWNSHIP:** 11N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 399561) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

---

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. When dormant the fuel supply line shall be physically disconnected from this unit. [District Rules 2080] Federally Enforceable Through Title V Permit
3. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 & 4702] Federally Enforceable Through Title V Permit
4. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit. [District Rule 1070] Federally Enforceable Through Title V Permit
5. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
6. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District Rules 4701, and 4702] Federally Enforceable Through Title V Permit
7. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-391-1 Jan 28 2010 9:57AM -- SIOGCOJ

8. If the NO<sub>x</sub> and/or CO concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
11. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
12. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
14. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
19. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
22. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. All units in a group for which representative units are annually source tested for NO<sub>x</sub> and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The number of representative units source tested for NO<sub>x</sub> and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
26. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
27. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
31. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NO<sub>x</sub> and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
32. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

33. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
34. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
35. Formerly permit number S-1548-361.
36. Formerly permit number S-3898-46.

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-392-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 3 **TOWNSHIP:** 11N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 353348) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
2. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. If the NOx and/or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-392-1: Jan 28 2010 9:57AM -- SIONGCOJ

6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081, 4701 and 4702] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
18. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. All units in a group for which representative units are annually source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-1548-362.
32. Formerly permit number S-3898-47.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-393-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 33 **TOWNSHIP:** 12N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 338528) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. When this unit is not operated, the fuel line shall be physically disconnected from this unit. [District Rule 4702] Federally Enforceable Through Title V Permit
2. Permittee shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit. [District Rule 4702] Federally Enforceable Through Title V Permit
3. Upon recommencing operation, this IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
4. Upon recommencing operation, emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NO<sub>x</sub> (as NO<sub>2</sub>): 25 ppmvd @15% O<sub>2</sub>; VOC (as CH<sub>4</sub>): 40 ppmvd @15% O<sub>2</sub>; CO: 140 ppmvd @15% O<sub>2</sub>; or SO<sub>x</sub> (as SO<sub>2</sub>): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NO<sub>x</sub> (as NO<sub>2</sub>), CO, and O<sub>2</sub> at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
6. Upon recommencing operation, if the NO<sub>x</sub> and/or CO concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-393-1 : Jan 28 2010 9:57AM - SIONGCOJ

7. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. A source test to demonstrate compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be performed within 60 days of recommencing operation of the dormant unit, except as provided below. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
9. Upon recommencing operation, source test to show compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be conducted once every 24 months by District-witnessed sample collection by independent testing laboratory. [District NSR Rule, 4701 and 4702] Federally Enforceable Through Title V Permit
10. Upon recommencing operation, compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
12. Upon recommencing operation, should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
14. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
17. Upon recommencing operation, permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
18. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Upon recommencing operation, all units in a group for which representative units are annually source tested for NO<sub>x</sub> and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Upon recommencing operation, the number of representative units source tested for NO<sub>x</sub> and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. Upon recommencing operation, sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
24. Upon recommencing operation, particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
25. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
29. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NO<sub>x</sub> and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
30. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
31. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
32. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. Formerly permit number S-1548-363.
34. Formerly permit number S-3898-48.

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-394-2

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 4 **TOWNSHIP:** 11N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

.162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 381170) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
2. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. If the NOx and/or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081 and 4701] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
18. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. All units in a group for which representative units are annually source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-3898-49.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-395-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 33 **TOWNSHIP:** 12N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

DORMANT 162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 328571) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without Authority to Construct for that modification(s), except for changes specified in conditions below. [District Rule 2080] Federally Enforceable Through Title V Permit
2. When this unit is not operated the fuel supply line shall be physically disconnected from this unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. A source test to demonstrate compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be performed within 60 days of recommencing operation of this unit. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall notify the District at least seven (7) calendar days prior to recommencing operation. [District Rule 1070] Federally Enforceable Through Title V Permit
5. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 of T11N/R22W, and Sections 32, 33, 34 of T12N/R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
6. Emissions rates shall not exceed any of the following: PM<sub>10</sub>: 0.01 g/bhp-hr; NO<sub>x</sub> (as NO<sub>2</sub>): 25 ppmvd @15% O<sub>2</sub>; VOC (as CH<sub>4</sub>): 40 ppmvd @15% O<sub>2</sub>; CO: 140 ppmvd @15% O<sub>2</sub>; or SO<sub>x</sub> (as SO<sub>2</sub>): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
7. The permittee shall monitor and record the stack concentration of NO<sub>x</sub> (as NO<sub>2</sub>), CO, and O<sub>2</sub> at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-395-1 - Jan 28 2010 9:57AM - SIONGCOJ

8. If the NO<sub>x</sub> and/or CO concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
12. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
14. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
19. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
22. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. All units in a group for which representative units are annually source tested for NO<sub>x</sub> and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The number of representative units source tested for NO<sub>x</sub> and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
26. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
27. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
31. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NO<sub>x</sub> and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
32. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
34. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
35. Formerly permit number S-1548-365.
36. Formerly permit number S-3898-50.

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-396-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 4 **TOWNSHIP:** 11N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 32563) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
2. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. If the NOx and/or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-396-1; Jan 28 2010 9:57AM -- SIONGCOJ

6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules, 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
18. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. All units in a group for which representative units are annually source tested for NO<sub>x</sub> and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The number of representative units source tested for NO<sub>x</sub> and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NO<sub>x</sub> and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-1548-366.
32. Formerly permit number S-3898-51.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-397-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 33 **TOWNSHIP:** 12N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 327689) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

DRAFT

## PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. When dormant the fuel supply line shall be physically disconnected from this unit. [District Rules 2080] Federally Enforceable Through Title V Permit
3. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 & 4702] Federally Enforceable Through Title V Permit
4. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit. [District Rule 1070] Federally Enforceable Through Title V Permit
5. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
6. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [Districts NSR Rule, 4701, and 4702] Federally Enforceable Through Title V Permit
7. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-397-1 : Jan 28 2010 9:57AM :: SIOGCOJ

DRAFT

8. If the NO<sub>x</sub> and/or CO concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
11. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
12. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
14. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
19. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rule 4701, 4702, and 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

20. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub> and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
22. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. All units in a group for which representative units are annually source tested for NO<sub>x</sub> and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The number of representative units source tested for NO<sub>x</sub> and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
26. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
27. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
31. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NO<sub>x</sub> and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
32. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
34. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
35. Formerly permit number S-1548-367.
36. Formerly permit number S-3898-52.

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-398-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 34 **TOWNSHIP:** 12N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 BHP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 39653) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER POWERING A FLUID PUMP - YOWLUMNE 25-34 (DORMANT)

## PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for that modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. A source test, to demonstrate compliance with Rule 4702 emission limits, shall be performed within 60 days of recommencing operation of this unit. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Operator shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
6. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule, 4701 and 4702] Federally Enforceable Through Title V Permit
8. Upon recommencing operation, permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the NOx and/or CO concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Upon recommencing operation, compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
15. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081 and 4701] Federally Enforceable Through Title V Permit
16. Upon recommencing operation, permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
17. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
18. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
19. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
20. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. Upon recommencing operation, if the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. Upon recommencing operation, if the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
25. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
26. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
27. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
28. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
29. Formerly permit number S-1548-347.
30. Formerly permit number S-3898-53.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-399-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 33 **TOWNSHIP:** 12N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 BHP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 317685) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER (DORMANT)

## PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for that modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. A source test, to demonstrate compliance with Rule 4702 emission limits, shall be performed within 60 days of recommencing operation of this unit. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Operator shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
6. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule, 4701 and 4702] Federally Enforceable Through Title V Permit
8. Upon recommencing operation, permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the NO<sub>x</sub> and/or CO concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Upon recommencing operation, compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
15. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
16. Upon recommencing operation, permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
17. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
18. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
19. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
20. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. Upon recommencing operation, if the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. Upon recommencing operation, if the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
25. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
26. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
27. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
28. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
29. Formerly permit number S-1548-347.
30. Formerly permit number S-3898-54.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-400-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 11 **TOWNSHIP:** 11N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 307940) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

DRAFT

## PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for that modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. When dormant, the fuel supply line shall be physically disconnected from this unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. A source test to demonstrate compliance with Rule 4702 emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Operator shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
6. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule, 4701, and 4702] Federally Enforceable Through Title V Permit
7. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-400-1 - Jan 28 2010 9 58AM - SONGCOJ

DRAFT

8. If the NO<sub>x</sub> and/or CO concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
11. Upon recommencing operation, compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
12. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
14. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
19. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
22. The following conditions must be met for representative units to be used to test for pollutant (NOx) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. All units in a group for which representative units are annually source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
26. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
27. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
31. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
32. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

33. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
34. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
35. Formerly permit number S-1548-370 and S-3898-55.

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-401-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 5 **TOWNSHIP:** 11N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 7461) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
2. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. If the NOx and/or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-401-1 : Jan 28 2010 9:58AM - SIONGCOJ

6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081 and 4701] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
18. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. All units in a group for which representative units are annually source tested for NO<sub>x</sub> and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The number of representative units source tested for NO<sub>x</sub> and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NO<sub>x</sub> and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-1548-371.
32. Formerly permit number S-3898-56.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1738-402-1

EXPIRATION DATE: 02/28/2009

SECTION: 34 TOWNSHIP: 12N RANGE: 22W

## EQUIPMENT DESCRIPTION:

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 413832) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
2. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. If the NOx and/or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE.

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-402-1 : Jan 28 2010 9:58AM - SONGCOJ

6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
8. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
9. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
10. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
18. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

19. All units in a group for which representative units are annually source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-1548-372.
32. Formerly permit number S-3898-57.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-403-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 33 **TOWNSHIP:** 12N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 319378) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
2. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. If the NOx and/or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE.WESTERN KERN COUNTY.KERN COUNTY, CA

S-1738-403-1: Jan 28 2010 9:58AM - SIONGCOJ

6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
18. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. All units in a group for which representative units are annually source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-1548-373.
32. Formerly permit number S-3898-58.

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-404-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 33 **TOWNSHIP:** 12N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 70302) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

---

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. When dormant the fuel supply line shall be physically disconnected from this unit. [District Rules 2080] Federally Enforceable Through Title V Permit
3. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 & 4702] Federally Enforceable Through Title V Permit
4. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit. [District Rule 1070] Federally Enforceable Through Title V Permit
5. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
6. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule, 4701, and 4702] Federally Enforceable Through Title V Permit
7. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-404-1; Jan 28 2010 9:58AM -- SIONGCOJ

8. If the NO<sub>x</sub> and/or CO concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
11. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
12. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
14. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
19. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rule 4701 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
22. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. All units in a group for which representative units are annually source tested for NO<sub>x</sub> and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The number of representative units source tested for NO<sub>x</sub> and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
26. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
27. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
31. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NO<sub>x</sub> and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
32. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
34. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
35. Formerly permit number S-1548-375.
36. Formerly permit number S-3898-60.

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-405-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 32 **TOWNSHIP:** 12N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 298503) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
2. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. If the NOx and/or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
18. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. All units in a group for which representative units are annually source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-1548-376.
32. Formerly permit number S-3898-61.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1738-406-1

EXPIRATION DATE: 02/28/2009

SECTION: 11 TOWNSHIP: 11N RANGE: 22W

## EQUIPMENT DESCRIPTION:

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 335150) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. When dormant the fuel supply line shall be physically disconnected from this unit. [District Rules 2080] Federally Enforceable Through Title V Permit
3. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit. [District Rule 1070] Federally Enforceable Through Title V Permit
5. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
6. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule, 4701, and 4702] Federally Enforceable Through Title V Permit
7. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-406-1; Jan 28 2010 9:58AM - SONGCOJ

8. If the NO<sub>x</sub> and/or CO concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
9. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, and O<sub>2</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub> and CO concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
10. The permittee shall install and operate a nonresettable fuel meter and a nonresettable elapsed operating time meter. In lieu of installing a nonresettable fuel meter, the owner or operator may use a non-resettable elapsed operating time meter in conjunction with the engine manufacturer's maximum rated fuel consumption to determine annual fuel usage. [District Rule 4702] Federally Enforceable Through Title V Permit
11. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Upon recommencing operation, compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
13. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
14. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
15. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
16. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081 and 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rule 4701 for a period of five years and shall make such records readily available for District inspection upon request. [District Rule 4701 and 4702] Federally Enforceable Through Title V Permit
21. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
23. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. All units in a group for which representative units are annually source tested for NO<sub>x</sub> and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. The number of representative units source tested for NO<sub>x</sub> and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
27. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
28. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
32. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NO<sub>x</sub> and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

33. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
34. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
35. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
36. Formerly permit number S-1548-377.
37. Formerly permit number S-3898-62.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-407-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 32 **TOWNSHIP:** 12N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA 1197 NATURAL GAS-FIRED IC ENGINE (S/N 2055) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
2. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. If the NOx and/or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
18. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. All units in a group for which representative units are annually source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NOx and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-1548-378.
32. Formerly permit number S-3898-63.

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-408-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 04 **TOWNSHIP:** 11N **RANGE:** 22W

**EQUIPMENT DESCRIPTION:**

360 BHP AJAX NATURAL GAS-FIRED EMERGENCY STANDBY I C ENGINE COMPRESSOR. YOWLUMNE LEASE, YUB #6

## PERMIT UNIT REQUIREMENTS

---

1. The permittee shall operate a nonresettable elapsed operating time meter. [District NSR Rule, 4701, and 4702] Federally Enforceable Through Title V Permit
2. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
3. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance and testing purposes shall not exceed 100 hours per year, as determined by an operational nonresettable elapsed operating time meter. [District NSR Rule, 4701, and 4702] Federally Enforceable Through Title V Permit
4. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
6. {2414} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
7. The permittee shall maintain records of hours of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (e.g., load testing, weekly testing, rolling blackout, general area power outage, etc.), records of operational characteristics monitoring, and the type and quantity (cubic feet of gas or gallons of liquid) of fuel used. Such records shall be retained on-site for a period of at least five years and made available for District inspection upon request. [District Rule 1070, 4701 and 4702] Federally Enforceable Through Title V Permit
8. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702] Federally Enforceable Through Title V Permit
9. Formerly permit number S-1136-315-1.
10. Formerly permit number S-1548-258-0.
11. Formerly permit number S-3898-64.

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-408-1 - Jan 28 2010 9:58AM - SIONGCOJ

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-409-1

**EXPIRATION DATE:** 02/28/2009

**EQUIPMENT DESCRIPTION:**

TRANSPORTABLE 300 BHP CATERPILLAR MODEL D334PC DIESEL-FIRED EMERGENCY STANDBY IC ENGINE  
POWERING AN ELECTRICAL GENERATOR

## PERMIT UNIT REQUIREMENTS

1. The equipment may be operated at any site within the District except for any site within 1,000 feet of any K-12 school. [CH&SC 41700]
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rule 4801, Kern County Rule 407, and 17 CCR 93115] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
7. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
8. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
9. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
10. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
12. Formerly permit number S-1136-630-0.
13. Formerly permit number S-1548-292-0.
14. Formerly permit number S-3898-65.

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE WESTERN, KERN COUNTY, KERN COUNTY, CA

S-1738-409-1; Jan 28 2010 9:58AM - SIONGCOJ

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-410-1

**EXPIRATION DATE:** 02/28/2009

**EQUIPMENT DESCRIPTION:**

162 HP WAUKESHA MODEL F1197 NATURAL GAS-FIRED IC ENGINE (S/N 52732) WITH CATALYTIC CONVERTER AND AIR/FUEL RATIO CONTROLLER

## PERMIT UNIT REQUIREMENTS

1. This IC engine is approved to operate at various unspecified locations within the Yowlumne field (Sections 3, 4, 5, 10, 11, 13, and 14 T11N, R22W, and Sections 32, 33, 34, T12N, R22W). No IC engine shall operate within 183 meters of a receptor. Only two IC engines may operate within 500 meters of a receptor, one of which can operate within 249 meters of a receptor. Receptor means any residence or any business (not including permittee). Permittee shall maintain records to demonstrate compliance with this requirement. [District Rule 4102]
2. Emissions rates shall not exceed any of the following: PM10: 0.01 g/bhp-hr; NOx (as NO2): 25 ppmvd @15% O2; VOC (as CH4): 40 ppmvd @15% O2; CO: 140 ppmvd @15% O2; or SOx (as SO2): 0.001 g/bhp-hr. Emission limits are on a 15 minute average. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall monitor and record the stack concentration of NOx (as NO2), CO, and O2 at least once every calendar quarter using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 1 day of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
4. If the NOx and/or CO concentrations corrected to 15% O2, as measured by the portable analyzer, exceed the permitted emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 15% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-410-1, Jan 28 2010 9:59AM -- SIOGCOJ

7. Compliance with NO<sub>x</sub>, CO, and VOC emission limits shall be demonstrated not less than once every 24 months, except as provided below. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. Compliance with NO<sub>x</sub>, CO, and VOC emission limits may be demonstrated by submission of annual source test results from one or more representative IC engines as approved by the APCO. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
9. For representative testing, an engine operating log shall be maintained for each engine in the group. The log shall include, on a monthly basis, the total hours of operation, and maintenance or modifications performed. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. Should any representative engines exceed the required emission limits, each engine in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested engines being considered in violation of this rule. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of either operating hours per day, location (e.g. well number) at which IC engine is operated, source test results, monitoring data, and other information deemed necessary by the APCO to demonstrate compliance with Rules 4701 and 4702 for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
16. Portable analyzers will be maintained and calibrated according to the manufacturer's specifications in order to ensure they operate properly and their accuracy remains within specification. EPA protocol calibration gases will be utilized to ensure proper calibration. After a successful calibration, the accuracy of the analyzer may be verified by utilizing reference gases that most closely approximate the emission limit to be checked. Between calibrations, the analyzer shall be checked before each use with reference gases to ensure its sensor cells are operational and accurate. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO<sub>x</sub>, and CO. [District Rule 1081, 4701, and 4702] Federally Enforceable Through Title V Permit
18. The following conditions must be met for representative units to be used to test for pollutant (NO<sub>x</sub>) emissions for a group of units: 1) all units are initially source tested and emissions from each unit in the group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in the group are similar in terms of rated brake horsepower, make and series, operational conditions, fuel used, and control method, 3) the group is owned by a single owner and located at a single stationary source, and 4) the selection of the representative units is approved by the District prior to testing. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. All units in a group for which representative units are annually source tested for NO<sub>x</sub> and CO emissions shall have received the same maintenance and tune-up procedures as the representative units. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. The number of representative units source tested for NO<sub>x</sub> and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated; such that in 3 years, all units in the entire group will have been tested at least once. [District Rule 4702 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
22. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
23. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D1072, D3031, D4084 or D3246. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Permittee shall monitor and record, on a monthly basis, the catalyst inlet and outlet temperatures. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The acceptable catalyst temperature differential shall be established by source testing this unit or other representative units as approved by the District. The normal range/level shall be any temperature increase across the catalyst unless compliance with applicable NO<sub>x</sub> and CO emissions limits have been demonstrated through source testing at a similar temperature drop. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of the date and time of temperature measurements and the measured temperatures. The records shall also include a description of any corrective action taken to maintain the temperature differential at the acceptable level. [District Rule 4702] Federally Enforceable Through Title V Permit
29. If the catalyst temperature differential is outside of the normal range/level, the permittee shall notify the District and take corrective action (i.e. temperature differential returned to normal range/level) with one (1) hour of detection. If the catalyst temperature differential rate is not immediately corrected, the permittee shall conduct a source test within 60 days, to demonstrate compliance with the applicable emissions limits at the new temperature differential. [District Rule 4702] Federally Enforceable Through Title V Permit
30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. Formerly permit number S-3898-66.

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1738-411-1

EXPIRATION DATE: 02/28/2009

SECTION: 4 TOWNSHIP: 11N RANGE: 22W

## EQUIPMENT DESCRIPTION:

GASOLINE DISPENSING OPERATION WITH ONE 4,000 GALLON UNDERGROUND STORAGE TANK SERVED BY AN OPW PHASE I VAPOR RECOVERY SYSTEM, SINGLE FILL CONFIGURATION (VR-102-E), AND 1 FUELING POINT WITH 1 GASOLINE DISPENSING NOZZLE SERVED BY A BALANCE PHASE II VAPOR RECOVERY SYSTEM (G-70-52-AM)

## PERMIT UNIT REQUIREMENTS

1. {2366} This gasoline storage and dispensing equipment shall not be used in retail sales, where gasoline dispensed by the unit is subject to payment of California sales tax on gasoline sales. [District Rule 2520, 9.1] Federally Enforceable Through Title V Permit
2. {2367} To ensure that all components of the certified Phase II vapor recovery system are maintained in proper operating condition, the non-retail service station operator shall conduct a maintenance inspection one day per month. [District Rule 4622, 5.4.2] Federally Enforceable Through Title V Permit
3. {2370} The operator shall maintain all records of required monitoring data, facility monthly gasoline throughput, and support information for District inspection for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. {2371} Loading and vapor collection equipment shall be maintained and operated such that there are no liquid component leaks under any conditions, nor any excess organic liquid drainage at disconnect. [District Rule 4621, 5.0] Federally Enforceable Through Title V Permit
5. {2372} The operator shall not transfer or permit the transfer of gasoline from any delivery vessel into any stationary storage container unless such container is equipped with a permanent submerged fill pipe and a certified Phase I vapor recovery system which is maintained and operated according to the manufacturers specifications. [District Rule 4621, 5.1.1] Federally Enforceable Through Title V Permit
6. The permittee shall perform and pass a Static Leak Test for Underground Tanks using ARB TP-201.3 at least once every 12 months. [District Rule 4621, 5.1.1] Federally Enforceable Through Title V Permit
7. The permittee shall perform and pass a Pressure Integrity of Drop Tube Drain Valve Assembly Test using ARB TP-201.1C or a Pressure Integrity of Drop Tube Overfill Protection Devices Test using ARB TP-201.1D if an overfill protection device is installed, at least once every three years. [District Rule 4621, 5.1.1] Federally Enforceable Through Title V Permit
8. The permittee shall perform and pass a "Static Torque of Rotatable Phase I Adaptors" test using ARB procedure TP-201.1B at least once every three years. [District Rule 4621, 5.1.1] Federally Enforceable Through Title V Permit
9. {2373} Any open vent pipe on a stationary gasoline storage tank shall be equipped with a certified pressure-vacuum relief valve set at  $3.0 \pm 0.5$  inches water column pressure relief and  $8.0 \pm 2.0$  inches water column vacuum relief unless otherwise specified in the applicable CARB executive order. The vent pipes may be manifolded, as per the applicable CARB executive order, to a single pressure-vacuum relief valve meeting the aforementioned specifications. [District Rule 4621, 5.1.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-411-1, Jan 28 2010 9:56AM - SIONGCOJ

10. {2374} No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo tank, which attest to the vapor integrity of the tank. [District Rule 4621, 5.2.1] Federally Enforceable Through Title V Permit
11. {2375} The operator shall not store gasoline in or otherwise use or operate any gasoline delivery vessel unless such vessel is designed and maintained to be vapor tight. Any delivery vessel into which gasoline vapors have been transferred shall be filled only at a loading facility that is equipped with a certified system that prevents at least 95% by weight of the gasoline vapors displaced from entering the atmosphere. [District Rule 4621, 5.2.2] Federally Enforceable Through Title V Permit
12. {2376} The hatch on a delivery vessel shall not be opened for visual inspection unless at least three minutes have elapsed since loading or unloading has stopped. The dome hatch, once opened, shall not be held open longer than three minutes. [District Rule 4621, 5.2.3] Federally Enforceable Through Title V Permit
13. {2377} Gasoline vapors from this unit shall not be purged into the atmosphere. [District Rule 4621, 5.2.4] Federally Enforceable Through Title V Permit
14. {2378} The vapor recovery system shall not create a backpressure in excess of the pressure limits of the delivery vessel certification leak test (18 inches water column). [District Rule 4621, 5.2.5] Federally Enforceable Through Title V Permit
15. {2379} The Reid Vapor Pressure of gasoline stored at this facility shall be determined in accordance with ASTM D 5191. [District Rule 4621, 6.2.1 and 4622, 6.3.3] Federally Enforceable Through Title V Permit
16. {2380} When determining vapor leaks with a portable analyzer the following must occur: 1) The probe inlet shall be 2.5 cm from the potential leak source. 2) The probe shall be moved slowly (approximately 4 cm/sec). If there is any meter deflection at the potential leak source, the probe shall be moved to locate the point of highest meter response. 3) To the greatest extent possible, the probe inlet shall be positioned in the path of the vapor flow from a leak so as to maximize the measured concentration. 4) The detector response time must be equal to or less than 30 seconds and the detector shall not probe any potential leak source for longer than twice the detector response time. 5) As an alternative to the preceding procedures, operators may use the soap bubble method described in the Alternative Screening Procedure in EPA Method 21. [District Rule 4621, 6.2.2] Federally Enforceable Through Title V Permit
17. {2381} The test method to determine vapor tightness of delivery vessels and storage tanks shall be EPA Method 21. [District Rule 4621, 6.2.3 and District Rule 4622, 6.3.4] Federally Enforceable Through Title V Permit
18. The operator of this gasoline dispensing facility, which has installed a permitted certified Phase II vapor recovery system, shall continue to use such a system and shall maintain the system and all of its components in good repair in order that such a system can continue to comply with the certification recovery efficiency. Any certified Phase II vapor recovery system that has been installed shall not be removed regardless of the amount of gasoline dispensed or how the gasoline is delivered to the facility. [District Rule 4622, 5.3] Federally Enforceable Through Title V Permit
19. As long as this unit's gasoline throughput is less than or equal to 24,000 gal per calendar year and less than or equal to 10,000 gal in any consecutive 30-day period, except for the provisions of Sections 6.1.1 and 6.1.2, this unit is exempt from District Rule 4622 (as amended 9/19/02). [District Rule 4622, 4.1, 4.2] Federally Enforceable Through Title V Permit
20. The permittee shall maintain gasoline throughput records which will allow the gasoline throughput for any 30-day period to be continuously determined. These records shall be maintained on the premises as long as exempt status is claimed. [District Rule 4622, 6.1.1] Federally Enforceable Through Title V Permit
21. Any gasoline dispensing facility previously exempt under Section 4.0 of District Rule 4622 (as amended 9/19/02) whose gasoline throughput exceeds the exemption levels in Section 4.1 and 4.2 shall notify the District within 30 days. [District Rule 4622, 6.1.2] Federally Enforceable Through Title V Permit
22. {2400} Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of SJVUAPCD Rule 4403 (as amended February 16, 1995) because units that qualify to use this template are not components serving light crude oil or gases at light crude oil and gas production facilities and are not components at natural gas processing facilities. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. {2401} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rules 412 (Fresno, Kings, Merced, San Joaquin, and Stanislaus County), Rules 413 (Tulare and Kern County), and 419 (Madera County). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
24. {2402} The requirements of District Rule 4623 (as amended December 20, 2001) do not apply to this permit unit because units that qualify to use this template are exempt under section 4.1.2. This section states that the provisions of the Rule do not apply to gasoline storage tanks with a capacity of less than 19,800 gallons that are subject to the requirements of Rule 4621 (as amended June 18, 1998). Units that apply for this template are subject to the requirements of Rule 4621. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
25. {2403} The requirements of District Rule 4624 (as amended December 17, 1992) do not apply to this permit unit because units that qualify to use this template are exempt under section 4.2. This section states that the provisions of the Rule do not apply to loading facilities subject to the requirements of Rule 4621 (as amended June 18, 1998). Units that apply for this template are subject to the requirements of Rule 4621. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
26. {2404} The requirements of 40 CFR 60 Subpart XX do not apply to this permit unit because this unit is not a bulk gasoline terminal. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
27. Formerly permit number S-3898-67.

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-414-2

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE34 **TOWNSHIP:** 12N **RANGE:** 21W

**EQUIPMENT DESCRIPTION:**

42,000 GALLON FIXED ROOF CRUDE OIL STORAGE TANK TK# 117029 - BATSON LEASE

## PERMIT UNIT REQUIREMENTS

---

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. All organic liquids shall be drained from the tank. [District Rule 4623] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623 and all other applicable District regulations. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Upon recommencing operation, crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623] Federally Enforceable Through Title V Permit
6. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-414-2 : Jan 28 2010 9:59AM -- SINGCOJ

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-415-2

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE34 **TOWNSHIP:** 12N **RANGE:** 21W

**EQUIPMENT DESCRIPTION:**

42,000 GALLON FIXED ROOF CRUDE OIL STORAGE TANK TK# 117030 - BATSON LEASE

## PERMIT UNIT REQUIREMENTS

---

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. All organic liquids shall be drained from the tank. [District Rule 4623] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623 and all other applicable District regulations. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Upon recommencing operation, crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623] Federally Enforceable Through Title V Permit
6. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-415-2; Jan 28 2010 9:55AM - SIONGCJJ

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-416-2

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE34 **TOWNSHIP:** 12N **RANGE:** 21W

**EQUIPMENT DESCRIPTION:**

31,500 GALLON FIXED ROOF CRUDE OIL STORAGE TANK TK# 031 - BATSON LEASE

## PERMIT UNIT REQUIREMENTS

---

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. All organic liquids shall be drained from the tank. [District Rule 4623] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4623 and all other applicable District regulations. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Upon recommencing operation, crude oil throughput shall not exceed 50 barrels per day based on a monthly average. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Permittee shall maintain monthly records of average daily crude oil throughput and shall submit such information to the APCO 30 days prior to the expiration date indicated in the Permit to Operate. [District Rule 4623] Federally Enforceable Through Title V Permit
6. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-416-2; Jan 28 2010 9:56AM -- SJONGCOJ

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-417-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

42,000 GALLON PETROLEUM STORAGE TANK (#5) EQUIPPED WITH VAREC VAPOR CONTROL SYSTEM INCLUDING VAPOR COMPRESSOR SHARED WITH S-1738-418, '-419, '-420 & '-421 (LAYMAN)

## PERMIT UNIT REQUIREMENTS

1. Formerly S-2804-1.
2. Vapor recovery system shall be shared with permit unit S-1738-418, -419, -420, & -421. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Vapor recovery system shall be maintained in a leak-free (as defined in Rule 4623) condition and shall consist of a closed vent system that collects all VOCs from the storage tank and discharges to an open flare (permit unit S-1738-427) that reduces the inlet VOC emissions by at least 95 percent by weight as determined by the test method specified in District Rule 4623, Section 6.4.6. [District Rule 4623, 5.6.1 & District NSR Rule] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on this tank shall be equipped with a leak-free (as defined in Rule 4623) cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
5. All piping valves, flanges, connectors, and fittings shall be constructed and maintained in a leak-free (as defined in Rule 4623) condition. [District Rule 4623, 5.6.3 & District NSR Rule] Federally Enforceable Through Title V Permit
6. There shall be no leaks in excess of 10,000 ppmv when measured with an portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this is considered a violation of this permit. [District NSR Rule & 4623] Federally Enforceable Through Title V Permit
7. Fugitive VOC emissions rate, calculated using EPA Publication 453/R-95-017, "Table 2-4 Oil and Gas Operations Average Emission Factors, from the total number of components in liquid service, tank vapor space, vapor piping to vapor recovery system manifold, and vapor recovery system shall not exceed 19.7 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
9. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-417-1 Jan 28 2010 9:59AM -- SIOGCOJ

10. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
14. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-418-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

42,000 GALLON PETROLEUM STORAGE TANK (#6) CONNECTED TO VAPOR RECOVERY SYSTEM SHARED WITH S-1738-417, '-419, '-420 & '-421 (LAYMAN)

## PERMIT UNIT REQUIREMENTS

---

1. Formerly S-2804-2.
2. Vapor recovery system shall be shared with permit unit S-1738-417, -419, -420, & -421. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Vapor recovery system shall be maintained in a leak-free (as defined in Rule 4623) condition and shall consist of a closed vent system that collects all VOCs from the storage tank and discharges to an open flare (permit unit S-1738-427) that reduces the inlet VOC emissions by at least 95 percent by weight as determined by the test method specified in District Rule 4623, Section 6.4.7. [District Rule 4623, 5.6.1 & District NSR Rule] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on this tank shall be equipped with a leak-free (as defined in Rule 4623) cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
5. All piping valves, flanges, connectors, and fittings shall be constructed and maintained in a leak-free (as defined in Rule 4623) condition. [District Rule 4623, 5.6.3 & District NSR Rule] Federally Enforceable Through Title V Permit
6. There shall be no leaks in excess of 10,000 ppmv when measured with an portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this is considered a violation of this permit. [District NSR Rule & 4623] Federally Enforceable Through Title V Permit
7. Fugitive VOC emissions rate, calculated using EPA Publication 453/R-95-017," Table 2-4 Oil and Gas Operations Average Emission Factors, from the total number of components in liquid service, tank vapor space, and vapor piping to vapor recovery system manifold shall not exceed 10.1 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
9. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
14. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-419-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

42,000 GALLON PETROLEUM STORAGE TANK (#36) CONNECTED TO VAPOR RECOVERY SYSTEM SHARED WITH S-1738-417, '-418, '-420 & '-421 (LAYMAN)

## PERMIT UNIT REQUIREMENTS

1. Formerly S-2804-3.
2. Vapor recovery system shall be shared with permit unit S-1738-417, -418, -420, & -421. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Vapor recovery system shall be maintained in a leak-free (as defined in Rule 4623) condition and shall consist of a closed vent system that collects all VOCs from the storage tank and discharges to an open flare (permit unit S-1738-427) that reduces the inlet VOC emissions by at least 95 percent by weight as determined by the test method specified in District Rule 4623, Section 6.4.7. [District Rule 4623, 5.6.1 & District NSR Rule] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on this tank shall be equipped with a leak-free (as defined in Rule 4623) cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
5. All piping valves, flanges, connectors, and fittings shall be constructed and maintained in a leak-free (as defined in Rule 4623) condition. [District Rule 4623, 5.6.3 & District NSR Rule] Federally Enforceable Through Title V Permit
6. There shall be no leaks in excess of 10,000 ppmv when measured with a portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this is considered a violation of this permit. [District NSR Rule & 4623] Federally Enforceable Through Title V Permit
7. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
8. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
9. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-419-1; Jan 28 2010 9:59AM; SIOGCGOJ

10. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
14. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-420-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

63,000 GALLON WASH TANK (#51) CONNECTED TO VAPOR RECOVERY SYSTEM SHARED WITH S-1738-417, '-418, '-419 & '-421 (LAYMAN)

## PERMIT UNIT REQUIREMENTS

1. Formerly S-2804-5.
2. Vapor recovery system shall be shared with permit unit S-1738-417, -418, -419, & -421. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Vapor recovery system shall be maintained in a leak-free (as defined in Rule 4623) condition and shall consist of a closed vent system that collects all VOCs from the storage tank and discharges to an open flare (permit unit S-1738-427) that reduces the inlet VOC emissions by at least 95 percent by weight as determined by the test method specified in District Rule 4623, Section 6.4.7. [District Rule 4623, 5.6.1 & District NSR Rule] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on this tank shall be equipped with a leak-free (as defined in Rule 4623) cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
5. All piping valves, flanges, connectors, and fittings shall be constructed and maintained in a leak-free (as defined in Rule 4623) condition. [District Rule 4623, 5.6.3 & District NSR Rule] Federally Enforceable Through Title V Permit
6. There shall be no leaks in excess of 10,000 ppmv when measured with an portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this is considered a violation of this permit. [District NSR Rule & 4623] Federally Enforceable Through Title V Permit
7. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
8. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
9. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-420-1, Jan 28 2010 9:55AM - SONGCO

10. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
14. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-421-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

7,980 GALLON TEST TANK (#2) CONNECTED TO VAPOR RECOVERY SYSTEM SHARED WITH S-1738-417, '-418, '-419, & '-420 (LAYMAN)

**DRAFT**

## PERMIT UNIT REQUIREMENTS

---

1. Formerly S-2804-8.
2. Vapor recovery system shall be shared with permit unit S-1738-417, -418, -419, & -421. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Vapor recovery system shall be maintained in a leak-free (as defined in Rule 4623) condition and shall consist of a closed vent system that collects all VOCs from the storage tank and discharges to an open flare (permit unit S-1738-427) that reduces the inlet VOC emissions by at least 95 percent by weight as determined by the test method specified in District Rule 4623, Section 6.4.7. [District Rule 4623, 5.6.1 & District NSR Rule] Federally Enforceable Through Title V Permit
4. Any tank gauging or sampling device on this tank shall be equipped with a leak-free (as defined in Rule 4623) cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
5. All piping valves, flanges, connectors, and fittings shall be constructed and maintained in a leak-free (as defined in Rule 4623) condition. [District Rule 4623, 5.6.3 & District NSR Rule] Federally Enforceable Through Title V Permit
6. There shall be no leaks in excess of 10,000 ppmv when measured with an portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this is considered a violation of this permit. [District NSR Rule & 4623] Federally Enforceable Through Title V Permit
7. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
8. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
9. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

**DRAFT**

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
14. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-422-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** NE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

42,000 GALLON BLENDED OIL STORAGE TANK (#13613) INCLUDING SHARED VAPOR CONTROL SYSTEM BETWEEN S-1738-422 THROUGH S-1738-426, INCLUDING VAPOR COMPRESSOR AND VAPOR PIPING TO FLARE S-1738-427 (HONOLULU)

## PERMIT UNIT REQUIREMENTS

---

1. Formerly S-2804-13.
2. Vapor recovery system shall be maintained in a leak-free (as defined in Rule 4623) condition and shall consist of a closed vent system that collects all VOCs from the storage tank and discharges to an open flare (permit unit S-1738-427) that reduces the inlet VOC emissions by at least 95 percent by weight as determined by the test method specified in District Rule 4623, Section 6.4.7. [District Rule 4623, 5.6.1 & District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on this tank shall be equipped with a leak-free (as defined in Rule 4623) cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
4. All piping valves, flanges, connectors, and fittings shall be constructed and maintained in a leak-free (as defined in Rule 4623) condition. [District Rule 4623, 5.6.3 & District NSR Rule] Federally Enforceable Through Title V Permit
5. There shall be no leaks in excess of 10,000 ppmv when measured with a portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this is considered a violation of this permit. [District NSR Rule & 4623] Federally Enforceable Through Title V Permit
6. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
7. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
8. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-422-1; Jan 28 2010 9:55AM -- SONGCOJ

9. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
10. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-423-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** NE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

42,000 GALLON BLENDED OIL STORAGE TANK (#13416) SERVED BY VAPOR RECOVERY SYSTEM SHARED WITH S-1738-422 (HONOLULU)

## PERMIT UNIT REQUIREMENTS

---

1. Formerly S-2804-15.
2. Vapor recovery system shall be maintained in a leak-free (as defined in Rule 4623) condition and shall consist of a closed vent system that collects all VOCs from the storage tank and discharges to an open flare (permit unit S-1738-427) that reduces the inlet VOC emissions by at least 95 percent by weight as determined by the test method specified in District Rule 4623, Section 6.4.7. [District Rule 4623, 5.6.1 & District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on this tank shall be equipped with a leak-free (as defined in Rule 4623) cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
4. All piping valves, flanges, connectors, and fittings shall be constructed and maintained in a leak-free (as defined in Rule 4623) condition. [District Rule 4623, 5.6.3 & District NSR Rule] Federally Enforceable Through Title V Permit
5. There shall be no leaks in excess of 10,000 ppmv when measured with a portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this is considered a violation of this permit. [District NSR Rule & 4623] Federally Enforceable Through Title V Permit
6. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
7. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
8. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-423-1 - Jan 28 2010 9:55AM - SIONGCOJ

9. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
10. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-424-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** NE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

42,000 GALLON BLENDED OIL STORAGE TANK (#13449) SERVED BY VAPOR RECOVERY SYSTEM SHARED WITH S-1738-422 (HONOLULU)

## PERMIT UNIT REQUIREMENTS

---

1. Formerly S-2804-16.
2. Vapor recovery system shall be maintained in a leak-free (as defined in Rule 4623) condition and shall consist of a closed vent system that collects all VOCs from the storage tank and discharges to an open flare (permit unit S-1738-427) that reduces the inlet VOC emissions by at least 95 percent by weight as determined by the test method specified in District Rule 4623, Section 6.4.7. [District Rule 4623, 5.6.1 & District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on this tank shall be equipped with a leak-free (as defined in Rule 4623) cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
4. All piping valves, flanges, connectors, and fittings shall be constructed and maintained in a leak-free (as defined in Rule 4623) condition. [District Rule 4623, 5.6.3 & District NSR Rule] Federally Enforceable Through Title V Permit
5. There shall be no leaks in excess of 10,000 ppmv when measured with an portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this is considered a violation of this permit. [District NSR Rule & 4623] Federally Enforceable Through Title V Permit
6. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
7. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
8. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-424-1, Jan 28 2010 9:59AM -- SIOGCOJ

9. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
10. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-425-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** NE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

42,000 GALLON BLENDED OIL STORAGE TANK (#13975) SERVED BY VAPOR RECOVERY SYSTEM SHARED WITH S-1738-422 (HONOLULU)

## PERMIT UNIT REQUIREMENTS

---

1. Formerly S-2804-17.
2. Vapor recovery system shall be maintained in a leak-free (as defined in Rule 4623) condition and shall consist of a closed vent system that collects all VOCs from the storage tank and discharges to an open flare (permit unit S-1738-427) that reduces the inlet VOC emissions by at least 95 percent by weight as determined by the test method specified in District Rule 4623, Section 6.4.7. [District Rule 4623, 5.6.1 & District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on this tank shall be equipped with a leak-free (as defined in Rule 4623) cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
4. All piping valves, flanges, connectors, and fittings shall be constructed and maintained in a leak-free (as defined in Rule 4623) condition. [District Rule 4623, 5.6.3 & District NSR Rule] Federally Enforceable Through Title V Permit
5. There shall be no leaks in excess of 10,000 ppmv when measured with an portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this is considered a violation of this permit. [District NSR Rule & 4623] Federally Enforceable Through Title V Permit
6. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
7. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
8. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-425-1 Jan 28 2010 10 06AM - SIONGCOJ

9. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
10. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-426-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** NE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

42,000 GALLON BLENDED OIL STORAGE TANK (#13430) SERVED BY VAPOR RECOVERY SYSTEM SHARED WITH S-1738-422 (HONOLULU)

## PERMIT UNIT REQUIREMENTS

---

1. Formerly S-2804-18.
2. Vapor recovery system shall be maintained in a leak-free (as defined in Rule 4623) condition and shall consist of a closed vent system that collects all VOCs from the storage tank and discharges to an open flare (permit unit S-1738-427) that reduces the inlet VOC emissions by at least 95 percent by weight as determined by the test method specified in District Rule 4623, Section 6.4.7. [District Rule 4623, 5.6.1 & District NSR Rule] Federally Enforceable Through Title V Permit
3. Any tank gauging or sampling device on this tank shall be equipped with a leak-free (as defined in Rule 4623) cover which shall be closed at all times except during gauging or sampling. [District Rule 4623, 5.6.2] Federally Enforceable Through Title V Permit
4. All piping valves, flanges, connectors, and fittings shall be constructed and maintained in a leak-free (as defined in Rule 4623) condition. [District Rule 4623, 5.6.3 & District NSR Rule] Federally Enforceable Through Title V Permit
5. There shall be no leaks in excess of 10,000 ppmv when measured with a portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this is considered a violation of this permit. [District NSR Rule & 4623] Federally Enforceable Through Title V Permit
6. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
7. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
8. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
10. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-427-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** NE18 **TOWNSHIP:** 28S **RANGE:** 20E

**EQUIPMENT DESCRIPTION:**

10 MMBTU/HR WASTE GAS FLARE USED TO INCINERATE PRODUCED GAS, AND VAPORS FROM TANK VAPOR CONTROL SYSTEM LISTED ON S-1738-417 (LAYMAN TANK BATTERY) AND S-1738-422 (HONOLULU TANK BATTERY)

## PERMIT UNIT REQUIREMENTS

---

1. Formerly S-2804-19.
2. Operation shall include 25 foot tall Mactronic elevated waste gas flare with 1 h.p. air assist combustion blower and electronic pilot light re-ignition system. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Gas line to flare shall be equipped with an operational volumetric flow rate indicator. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Pilot light shall be lit and fully extended to ignition position prior to routing waste gas to flare. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Total gas flow rate to flare shall not exceed 235,000 scf per day on a monthly basis. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Operator shall immediately utilize air assisted combustion if flare exhibits smoke greater than 0% opacity. [District NSR Rule and 4101] Federally Enforceable Through Title V Permit
7. Emission rates shall not exceed any of the following: NO<sub>x</sub> (as NO<sub>2</sub>) - 0.068 lb/MMBtu, VOC - 0.034 lb/MMBtu, PM<sub>10</sub> - 7.6 lb/MMscf, or CO - 0.370 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
8. SO<sub>x</sub> (as SO<sub>2</sub>) emission rate shall not exceed 112.3 lbs/day. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Permittee shall measure and record the total volume of gas flared on a monthly basis. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Measurement of gas sulfur content (H<sub>2</sub>S) shall be conducted at least once every twelve (12) months. If the result of the 12-month measurement demonstrates that the unit does not meet the applicable emission limits, the measurement frequency shall revert to once every month until three (3) consecutive measurements show compliance with the applicable emission limits, at which time measurement frequency may revert back to once every twelve (12) months. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Permittee shall determine sulfur content of gas flared using ASTM method D3246 or double GC for H<sub>2</sub>S and mercaptans. [District NSR Rule] Federally Enforceable Through Title V Permit
12. Permittee shall maintain records of monthly amount of total gas flared, annual records (or monthly records as required by this permit) of sulfur content of gas, and calculated average daily SO<sub>2</sub> emissions. Records shall be kept for a minimum of 5 years and shall be made readily available for District inspection upon request. [District NSR Rule and 1070] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

13. The flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit
14. The outlet shall be equipped with an automatic ignition system, or, shall operate with a pilot flame present at all times when combustible gases are vented through the flare, except during purge periods for automatic-ignition equipped flares. [District Rule 4311, 5.3] Federally Enforceable Through Title V Permit
15. Except for flares equipped with a flow-sensing ignition system, a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an equivalent device, capable of continuously detecting at least one pilot flame or the flare flame is present shall be installed and operated. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit
16. {2332} Flares that use flow-sensing automatic ignition systems and which do not use a continuous flame pilot shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit
17. The permittee shall maintain, and make available for District inspection, all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-428-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE19 **TOWNSHIP:** 29S **RANGE:** 21E

**EQUIPMENT DESCRIPTION:**

ONE 42,000 GALLON FIXED ROOF WASH TANK (#215061) EQUIPPED WITH PRESSURE/VACUUM RELIEF VALVE (ANDERSON COMMUNITY)

## PERMIT UNIT REQUIREMENTS

---

1. Formerly S-2803-4-0.
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
3. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall maintain monthly records of average daily crude oil throughput and shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
9. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-429-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE19 **TOWNSHIP:** 29S **RANGE:** 21E

**EQUIPMENT DESCRIPTION:**

ONE 42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#1462) EQUIPPED WITH PRESSURE/VACUUM RELIEF VALVE (ANDERSON COMMUNITY)

## PERMIT UNIT REQUIREMENTS

---

1. Formerly S-2803-5-0.
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
3. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall maintain monthly records of average daily crude oil throughput and shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
9. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-430-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** NW30 **TOWNSHIP:** 29S **RANGE:** 21E

**EQUIPMENT DESCRIPTION:**

ONE 42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#2855) EQUIPPED WITH PRESSURE/VACUUM RELIEF VALVE (ANDERSON COMMUNITY)

## PERMIT UNIT REQUIREMENTS

1. Formerly S-2803-6-0.
2. Total tank throughput shall not exceed 150 bbl/day. [District NSR Rule] Federally Enforceable Through Title V Permit
3. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
4. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
9. Permittee shall maintain monthly records of average daily crude oil throughput and shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District NSR Rule and 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-432-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE08 **TOWNSHIP:** 11N **RANGE:** 23W

**EQUIPMENT DESCRIPTION:**

21,000 GALLON FIXED ROOF WASH TANK SERVED BY A SHARED VAPOR RECOVERY COMPRESSOR AND PIPING (SHARED WITH S-1216-5 AND S-1216-6) (SUNSET LEASE)

## PERMIT UNIT REQUIREMENTS

1. Vapor recovery system shall prevent VOC emissions from the storage tanks to the atmosphere at a control efficiency of at least 95% by weight. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Vapor recovery compressor shall be activated and operated at a pressure setting lower than the settings of the individual pressure relief devices installed on tanks being served. [District NSR Rule] Federally Enforceable Through Title V Permit
3. All openings in roof used for sampling or gauging shall be closed and leak-free when not in use. [District NSR Rule] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in leak-free condition. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Permittee shall maintain accurate records of liquids stored, storage temperature, and Reid Vapor Pressure of such liquids. [District NSR Rule] Federally Enforceable Through Title V Permit
6. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit
7. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, as methane, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is the dripping of organic liquid at a rate of more than 3 drops per minute. An instrument reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute are violations of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.17 and 6.4.8] Federally Enforceable Through Title V Permit
8. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-432-1 Jan 28 2010 10:00AM - SIONGCOJ

9. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
10. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
14. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
17. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1738-433-1

EXPIRATION DATE: 02/28/2009

SECTION: SE08 TOWNSHIP: 11N RANGE: 23W

## EQUIPMENT DESCRIPTION:

21,000 GALLON FIXED ROOF STORAGE TANK (TANK #10618) SERVED BY A SHARED VAPOR RECOVERY COMPRESSOR AND PIPING (SHARED WITH S-1216-4) (SUNSET LEASE)

## PERMIT UNIT REQUIREMENTS

1. Vapor recovery system shall prevent VOC emissions from the storage tanks to the atmosphere at a control efficiency of at least 95% by weight. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Vapor recovery compressor shall be activated and operated at a pressure setting lower than the settings of the individual pressure relief devices installed on tanks being served. [District NSR Rule] Federally Enforceable Through Title V Permit
3. All openings in roof used for sampling or gauging shall be closed and leak-free when not in use. [District NSR Rule] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in leak-free condition. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Permittee shall maintain accurate records of liquids stored, storage temperature, and Reid Vapor Pressure of such liquids. [District NSR Rule] Federally Enforceable Through Title V Permit
6. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, as methane, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is the dripping of organic liquid at a rate of more than 3 drops per minute. An instrument reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute are violations of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.17 and 6.4.8] Federally Enforceable Through Title V Permit
7. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit
8. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-433-1; Jan 28 2010 10:00AM -- SINGCO

9. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
10. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
14. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
17. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-434-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** SE08 **TOWNSHIP:** 11N **RANGE:** 23W

**EQUIPMENT DESCRIPTION:**

21,000 GALLON FIXED ROOF STORAGE TANK (TANK #10617) SERVED BY A SHARED VAPOR RECOVERY COMPRESSOR AND PIPING (SHARED WITH S-1216-4) (SUNSET LEASE)

## PERMIT UNIT REQUIREMENTS

1. Vapor recovery system shall prevent VOC emissions from the storage tanks to the atmosphere at a control efficiency of at least 95% by weight. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Vapor recovery compressor shall be activated and operated at a pressure setting lower than the settings of the individual pressure relief devices installed on tanks being served. [District NSR Rule] Federally Enforceable Through Title V Permit
3. All openings in roof used for sampling or gauging shall be closed and leak-free when not in use. [District NSR Rule] Federally Enforceable Through Title V Permit
4. All piping, valves, and fittings shall be constructed and maintained in leak-free condition. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Permittee shall maintain accurate records of liquids stored, storage temperature, and Reid Vapor Pressure of such liquids. [District NSR Rule] Federally Enforceable Through Title V Permit
6. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, as methane, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is the dripping of organic liquid at a rate of more than 3 drops per minute. An instrument reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute are violations of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.17 and 6.4.8] Federally Enforceable Through Title V Permit
7. The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported. Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990." [District Rule 4623, 6.4.6 and 6.4.7] Federally Enforceable Through Title V Permit
8. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-434-1; Jan 28 2010 10:00AM -- SIONGCOJ

9. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
10. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
14. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
17. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-435-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 06 **TOWNSHIP:** 11N **RANGE:** 23W

**EQUIPMENT DESCRIPTION:**

ONE 21,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK SERVED BY A PRESSURE RELIEF DEVICE#10652 (BARBARA LEASE)

## PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 1.5 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
3. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
4. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit
5. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
7. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-435-1 Jan 28 2010 10:00AM -- SIOGCOJ

8. Upon detection of a gas leak, defined as a VOC concentration of greater than 10,000 ppmv measured in accordance with EPA Method 21, operator shall take one of the following actions: 1) eliminate the leak within 8 hours after detection; or 2) if the leak cannot be eliminated, then minimize the leak to the lowest possible level within 8 hours after detection by using best maintenance practices, and eliminate the leak within 48 hours after minimization. In no event shall the total time to minimize and eliminate a leak exceed 56 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
9. Components found to be leaking either liquids or gases shall be immediately affixed with a tag showing the component to be leaking. Operator shall maintain records of the liquid or gas leak detection readings, date/time the leak was discovered, and date/time the component was repaired to a leak-free condition. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
10. Leaking components that have been discovered by the operator that have been immediately tagged and repaired within the timeframes specified in District Rule 4623, Table 3 shall not constitute a violation of this rule. Leaking components as defined by District Rule 4623 discovered by District staff that were not previously identified and/or tagged by the operator, and/or any leaks that were not repaired within the timeframes specified in District Rule 4623, Table 3 shall constitute a violation of this rule. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
11. If a component type for a given tank is found to leak during an annual inspection, operator shall conduct quarterly inspections of that component type on the tank or tank system for four consecutive quarters. If no components are found to leak after four consecutive quarters, the operator may revert to annual inspections. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
12. Any component found to be leaking on two consecutive annual inspections is in violation of this rule, even if covered under the voluntary inspection and maintenance program. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
13. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
14. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
15. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit
16. Facilities S-1216, S-382, and S-1738 constitute one stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1738-436-1

**EXPIRATION DATE:** 02/28/2009

**SECTION:** 06 **TOWNSHIP:** 11N **RANGE:** 23W

**EQUIPMENT DESCRIPTION:**

6,300 GALLON FIXED ROOF PETROLEUM WASH TANK SERVED BY A PRESSURE RELIEF DEVICE (BARBARA LEASE)

## PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 11 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
2. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
3. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
4. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit
5. This tank shall be in a leak-free condition. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A reading in excess of 10,000 ppmv above background or the dripping of organic liquid at a rate of more than 3 drops per minute is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623] Federally Enforceable Through Title V Permit
6. Operator shall visually inspect tank shell, hatches, seals, seams, cable seals, valves, flanges, connectors, and any other piping components directly affixed to the tank and within five feet of the tank at least once per year for liquid leaks, and with a portable hydrocarbon detection instrument conducted in accordance with EPA Method 21 for gas leaks. Operator shall also visually or ultrasonically inspect as appropriate, the external shells and roofs of uninsulated tanks for structural integrity annually. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit
7. Upon detection of a liquid leak, defined as a leak rate of greater than or equal to 30 drops per minute, operator shall repair the leak within 8 hours. For leaks with a liquid leak rate of between 3 and 30 drops per minute, the leaking component shall be repaired within 24 hours after detection. [District Rule 4623 (Table 3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: VINTAGE PRODUCTION CALIFORNIA LLC

Location: LIGHT OIL WESTERN STATIONARY SOURCE, WESTERN KERN COUNTY, KERN COUNTY, CA

S-1738-436-1; Jan 28 2010 10:00AM - SIONGCOJ