



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

April 4, 2013  
*via electronic submittal*

Mr. Gerardo Rios  
U. S. EPA, Region IX  
Mail Stop A-5-2  
75 Hawthorne Street  
San Francisco, California 94105

Dear Mr. Rios:

**RE: Proposed Minor Revision to Title V/RECLAIM Permit  
SFPP, L.P. (Colton Terminal)  
(ID# 800129)**

Enclosed for your 45-day review is the proposed revision to the Title V/RECLAIM Permit for SFPP, L.P. (Colton Terminal), 2359 South Riverside Ave., Bloomington, CA. This revision is considered a "minor permit revision", and a public notice is not required.

We are enclosing the engineering evaluation and the proposed permit(s) to be included in Section D as shown below.

## SECTION D: PERMITS TO OPERATE

<i>New Appl. No.</i>	<i>Previous Appl. No.</i>	<i>Description/Modification</i>
458547	444960	STORAGE TANK FX RF W/INT FLT GASOLINE (C-23) <ul style="list-style-type: none"><li>• Add rim mounted secondary seal</li><li>• Increase vapor pressure and throughput</li><li>• Remove recirculation line and connect line</li><li>• Correct nominal capacity</li></ul>
458551	444961	STORAGE TANK FX RF W/INT FLT GASOLINE (C-25) <ul style="list-style-type: none"><li>• Add secondary seal</li><li>• Increase vapor pressure and throughput</li></ul>
458552	444963	STORAGE TANK FX RF W/INT FLT GASOLINE (C-27) <ul style="list-style-type: none"><li>• Add rim mounted secondary seal</li><li>• Increase vapor pressure and throughput</li></ul>
458553	444976	STORAGE TANK FX RF W/INT FLT GASOLINE (C-33) <ul style="list-style-type: none"><li>• Add rim mounted secondary seal</li><li>• Increase vapor pressure and throughput</li></ul>

*Cleaning the air that we breathe...*


458554	444965	STORAGE TANK FX RF W/INT FLT GASOLINE (C-34) <ul style="list-style-type: none"><li>• Correct from wiper to rim mounted secondary seal</li><li>• Increase vapor pressure and throughput</li><li>• Remove conditions that reference drain dry tanks (this was imposed on previous permit in error since this is not a drain dry tank)</li></ul>
458557	444973	STORAGE TANK FX RF W/INT FLT GASOLINE (C-36) <ul style="list-style-type: none"><li>• Add secondary seal</li><li>• Increase vapor pressure and throughput</li></ul>

This revision is covered under A/N 509021.

This request is being made via electronic submittal in order to facilitate your review.

If you have any questions or wish to provide comments regarding this project, please contact the processing engineer, Ms. Linda Dejbakhsh, at (909) 396-2614, or by email at [LDejbakhsh@aqmd.gov](mailto:LDejbakhsh@aqmd.gov).

Very truly yours,

  
Danny Luong, P.E.  
Senior Manager  
Refinery and Waste Management Permitting

DL:CDT:LLD  
Enclosures  
(epacoverminorrev Tank increase TP VP Addseal 458547-57)

cc: Yijin Wang (no enclosure)  
A/N's 458547, 509021