



DEC 07 2011

Gerardo C. Rios, Chief  
Permits Office (AIR-3)  
U.S. EPA - Region IX  
75 Hawthorne St  
San Francisco, CA 94105

**Re: Notice of Final Action - Minor Title V Permit Modification  
District Facility # S-88  
Project # 1104224**

Dear Mr. Rios:

The Air Pollution Control Officer has modified the Title V permit for Kern River Cogeneration Company by incorporating ATC S-88-2-16. The ATC authorizes the installation of a GE enhanced dry low NOx DLN + combustor technology and individual NOx, CO, and diluent (CO2 or O2) CEMS analyzers on an existing gas turbine combustor.

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on September 21, 2010. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

  
David Warner  
Director of Permit Services

DW:rue

Enclosures

**Seyad Sadredin**  
Executive Director/Air Pollution Control Officer

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



DEC 07 2011

Neil Burgess  
Kern River Cogeneration Company  
PO Box 80478  
Bakersfield, CA 93380

**Re: Notice of Final Action - Minor Title V Permit Modification  
District Facility # S-88  
Project # 1104224**

Dear Mr. Burgess:

The Air Pollution Control Officer has modified the Title V permit for Kern River Cogeneration Company by incorporating ATC S-88-2-16. The ATC authorizes the installation of a GE enhanced dry low NOx DLN + combustor technology and individual NOx, CO, and diluent (CO2 or O2) CEMS analyzers on an existing gas turbine combustor.

Enclosed is the modified Title V permit. The application and proposal were sent to US EPA Region IX on September 21, 2010. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

David Warner  
Director of Permit Services

DW:rue

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-88-2-18

**EXPIRATION DATE:** 08/31/2014

**SECTION:** 32 **TOWNSHIP:** 28S **RANGE:** 28E

## **EQUIPMENT DESCRIPTION:**

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE GENERATOR (CTG) WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (KRCC UNIT #2)

## **PERMIT UNIT REQUIREMENTS**

---

1. Combustion turbine generator (CTG) shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; 40 CFR 60.333(a); Kern County Rule 407] Federally Enforceable Through Title V Permit
2. Operator shall not exceed a NOx emission rate of 3 ppmvd @ 15% O<sub>2</sub>, under load conditions, excluding thermal stabilization and reduced load periods [40 CFR 60.332(a)(1) & 60.332 (a)(2) and District Rule 4703, 5.1.2] Federally Enforceable Through Title V Permit
3. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Rule 110 (Madera); District Rule 1081] Federally Enforceable Through Title V Permit
4. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072-80, D 3031-81, D 4084-82 or D 3246-81. [40 CFR 60.335(d)] Federally Enforceable Through Title V Permit
5. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)] Federally Enforceable Through Title V Permit
6. The HHV and LHV of the fuel shall be determined using ASTM D3588-91, ASTM 1826-88, OR ASTM 1945-81. [40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
7. Nitrogen oxides (NOx) concentrations shall be determined using EPA Method 7E or 20, and oxygen (O<sub>2</sub>) concentrations shall be determined using EPA Method 3, 3A, or 20. [40 CFR 60.335(b) and District Rule 4703, 6.4] Federally Enforceable Through Title V Permit
8. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O<sub>2</sub> (dry). [40 CFR 60.332(a),(b) and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit
9. The operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703, 5.1.1. [40 CFR 60.332(a),(b) and 4703, 5.1.1] Federally Enforceable Through Title V Permit
10. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
12. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [District Rule 1080, 7.3 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
13. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
14. The operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
15. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(b),(c) and District Rule 4703, 5.0] Federally Enforceable Through Title V Permit
16. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.4; PSD SJ 84-01, X.D.1] Federally Enforceable Through Title V Permit
17. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: Rules 404 (Madera), 406 (Fresno), 407 (Kings, Merced, San Joaquin, Stanislaus, Tulare, Kern); District Rule 1081, 4201, 1080, Section 6.5, 7.2, 8.0, 9.0, and 10.0; 40 CFR 60.332(c) and (d); 60.334 (b), (c)(2); 60.335(d). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
18. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: District Rule 4703, sections 5.0, 5.1.1, 6.2.1, 6.2.4, 6.3, 6.4.1, 6.4.3, 6.4.5, and 6.4.6. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
19. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following subsumed requirements: 40 CFR 60.332 (b); 60.335(a), (b), (c), and (e). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
20. Operator shall install, operate, and maintain in calibration a system which continuously measures and records control system operating parameters, elapsed time of operation, and exhaust gas NOx concentration and O2 or CO2 concentration. [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703] Federally Enforceable Through Title V Permit
21. The NOx and CO2 CEMS shall meet the requirements in 40CFR60, Appendix B Performance Specifications 2 and 3 and Appendix F Procedure 1. [40 CFR 60.334(b)(1) and District Rules 1080, 6.3, 6.5, 6.6, & 7.2, and 4703, 6.2.3]
22. Operator shall submit a semiannual report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(c)(2)] Federally Enforceable Through Title V Permit
23. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
24. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rule 1080, 10.0; PSD SJ 84-01, X.D.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [District Rule 1080, 8.0 and PSD SJ 84-01, X.D.3] Federally Enforceable Through Title V Permit
26. The written report for each calendar quarter shall also include: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 84-01, X.E. [District Rule 1080, 8.0; PSD SJ 84-01, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
27. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [District Rule 4703 and PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
28. Each CTG shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
29. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
30. When operating in cogeneration mode, exhaust gas ducting from CTG through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule]
31. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule]
32. Each CTG shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 84-01, X.D.1] Federally Enforceable Through Title V Permit
33. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit
34. HRSG exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081]
35. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Kern River Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit
36. Accurate records of NOx (as NO2) and carbon monoxide (CO) flue gas concentrations corrected to 15% O2, dry and CTG fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
37. Emission rates from CTG shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 12.0 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
38. Emission rates from CTG shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 288.0 lb/day, or CO - 1056.0 lb/day. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
39. Emission rates from CTG, except during startup and/or shutdown and reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

40. During startup and shutdown, emissions shall not exceed any of the following: 140.0 lb/hr of NO<sub>x</sub> on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201]
41. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
42. Daily Emissions for the unit may be determined from the arithmetic mean of three, 40-minute test runs for NO<sub>x</sub> and CO, multiplied by the appropriate factor. [District Rule 2520, 9.4.2 and District Rule 4703] Federally Enforceable Through Title V Permit
43. Source testing to determine NO<sub>x</sub> and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
44. Performance testing shall be conducted annually to measure NO<sub>x</sub> and CO emission concentrations using the following methods: EPA Methods 7E or 20 for NO<sub>x</sub> emissions, EPA Methods 10 or 10B for CO emissions, EPA Methods 3, 3A or 20 for Oxygen content of the exhaust gas. The performance tests shall be performed between 90 and 100 percent of peak (or the highest physically achievable) load. [40 CFR 60.335(a), (b)(7) and District Rule 4703, 6.3.1, 6.4.1, 6.4.2, & 6.4.3] Federally Enforceable Through Title V Permit
45. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
46. Continuous emission monitoring system for NO<sub>x</sub> as NO<sub>2</sub> and continuous monitoring system for CO & CO<sub>2</sub> shall serve each CTG flue gas stream during both simple cycle and cogeneration modes, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 84-01, X.D.1 and .2] Federally Enforceable Through Title V Permit
47. All continuous emissions monitoring systems shall be calibrated and operated during both simple cycle and cogeneration modes according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 84-01 X.D.2] Federally Enforceable Through Title V Permit
48. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 84-01, X.D.5] Federally Enforceable Through Title V Permit
49. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 84-01, X.D.3] Federally Enforceable Through Title V Permit
50. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 84-01, X.D.3] Federally Enforceable Through Title V Permit
51. Startup and shutdown of CTG, as defined in 40 CFR, Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [40 CFR 60.8] Federally Enforceable Through Title V Permit
52. NO<sub>2</sub> and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
53. Daily records of NO<sub>2</sub> and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
54. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 84-01] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

55. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in CO emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 84-01] Federally Enforceable Through Title V Permit
56. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 84-01] Federally Enforceable Through Title V Permit
57. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 84-01] Federally Enforceable Through Title V Permit
58. Any requirements established by this permit for the gathering and reporting of information are not subject to review by the Office of Management and Budget (OMB) under the Paperwork Reduction Act (PRA) because this permit is not an "information collection request" within the meaning of 44 U.S.C. Subsections 3502(4) & (11), 3507, 3512, and 3518. Furthermore, this permit and any information gathering and reporting requirements established by this permit are exempt from OMB review under the PRA because it is directed to fewer than ten persons. [44 U.S.C. Section 3502(4), (11) and 5 CFR Section 1320.5(a) and PSD SJ 84- 01] Federally Enforceable Through Title V Permit
59. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 84-01] Federally Enforceable Through Title V Permit
60. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10 [PSD SJ 84- 01] Federally Enforceable Through Title V Permit
61. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 84-01] Federally Enforceable Through Title V Permit
62. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 84-01] Federally Enforceable Through Title V Permit
63. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 84-01] Federally Enforceable Through Title V Permit
64. This facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 84-01] Federally Enforceable Through Title V Permit
65. All correspondence as required by the PSD permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; and c) Compliance Division, SJVUAPCD. [PSD SJ 84-01] Federally Enforceable Through Title V Permit
66. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

67. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (12/17/92), by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.