

**YOLO-SOLANO AIR QUALITY MANAGEMENT DISTRICT**  
**1947 Galileo Court, Suite 103, Davis, CA 95618**  
**(530)757-3650**

DRAFT TITLE V OPERATING PERMIT

Permit Number: F-00454-25

**ISSUED TO:**

University of California, Davis  
Environmental, Health & Safety  
One Shields Avenue  
Davis, CA 95616-8586

**PLANT SITE LOCATION:**

Davis, CA 95616-8586

**ISSUED BY:**

---

Mat Ehrhardt, P.E., Air Pollution Control Officer

Date

PROPOSED August 9, 2013

EFFECTIVE Proposed

EXPIRATION February 2, 2016

---

Nature of Business:  
SIC Code:

Institute of Higher Education  
8221

**Responsible Official:**

Name: Jill Parker  
Title: Associate Vice Chancellor -Safety Services  
Phone: (530) 752-2599

**Site Contact Person:**

Name: Aimee Pfohl  
Title: Environmental Protection Specialist  
Phone: (530) 754-5267

**TABLE OF CONTENTS**

**I. FACILITY EMISSION UNITS AND EQUIPMENT LISTS: ..... 1**

A. Insignificant Emissions Units ..... 1

B. Significant Emissions Units ..... 3

B1. Emergency Diesel Fired Internal Combustion Engines ..... 3

B2. Emergency Natural Gas Fired Internal Combustion Engines ..... 16

B3. Portable Internal Combustion Engines..... 18

B4. Boilers and Water Heaters ..... 19

B5. Coating Operation ..... 23

B6. Landfill Gas Collection and Soil Vapor Extraction System ..... 23

B7. Incinerator ..... 24

B8. Woodworking Operations ..... 24

B9. Wastewater Treatment Plant ..... 25~~4~~

B10. Cooling Towers..... 25

B11. Gasoline and Aviation Gasoline Storage and Dispensing..... 25

**II. SPECIFIC UNIT REQUIREMENTS ..... 25**

A. Emission Limitations ..... 26~~5~~

A1. Emergency Diesel Fired Internal Combustion Engines ..... 26~~5~~

A2. Emergency Natural Gas Fired Internal Combustion Engines ..... 53

A3. Portable Internal Combustion Engines..... 60

A4. Boilers and Water Heaters ..... 62~~1~~

A5. Coating Operation ..... 74

A6. Landfill Gas Collection and Soil Vapor Extraction System ..... 74

A7. Incinerator ..... 74

A8. Woodworking Operations ..... 75

A9. Wastewater Treatment Plant ..... 75

A10. Cooling Towers..... 76~~5~~

A11. Gasoline and Aviation Gasoline Storage and Dispensing..... 76~~5~~

B. Throughput Limitations ..... 76

B1. Emergency Diesel Internal Combustion Engines..... 76

B2. Emergency Natural Gas Internal Combustion Engines..... 83~~2~~

B3. Portable Internal Combustion Engines..... 84

B4. Boilers and Water Heaters ..... 85~~4~~

B5. Coating Operation ..... 88~~7~~

B6. Landfill Gas Collection and Soil Vapor Extraction System ..... 89

B7. Incinerator ..... 89

B8. Woodworking Operations ..... 90~~89~~

B9. Wastewater Treatment Plant ..... 90~~89~~

B10. Cooling Towers..... 90

B11. Gasoline and Aviation Gasoline Storage and Dispensing..... 90

C. Applicable Requirements ..... 91~~0~~

C1. Emergency Diesel Fired Internal Combustion Engines ..... 91~~0~~

C2. Natural Gas Fired Internal Combustion Engines ..... 96~~5~~

C3.	Portable Internal Combustion Engines.....	98 <del>7</del>
C4.	Boilers and Water Heaters .....	98
C5.	Coating Operation .....	103 <del>2</del>
C6.	Landfill Gas Collection and Soil Vapor Extraction System .....	105
C7.	Incinerator .....	106 <del>5</del>
C8.	Woodworking Operations .....	106
C9.	Cooling Towers.....	107
C10.	Gasoline Storage and Dispensing.....	108 <del>7</del>
C11.	Aviation Gasoline Storage and Dispensing.....	111 <del>0</del>
D.	Monitoring and Testing Requirements.....	111
D1.	Boilers and Water Heaters .....	111
D2.	Landfill Gas Collection and Soil Vapor Extraction System .....	114
D3.	Gasoline Storage and Dispensing.....	114
D4.	Aviation Gasoline Storage and Dispensing.....	116 <del>5</del>
E.	Recordkeeping Requirements .....	116
E1.	Diesel Fired Internal Combustion Engines .....	116
E2.	Natural Gas Fired Internal Combustion Engines .....	118
E3.	Portable Internal Combustion Engines.....	119 <del>8</del>
E4.	Boilers and Water Heaters .....	119
E5.	Coating Operation .....	122 <del>+</del>
E6.	Landfill Gas Collection and Soil Vapor Extraction System .....	122
E7.	Incinerator .....	123 <del>2</del>
E8.	Woodworking Operations .....	123 <del>2</del>
E9.	Wastewater Treatment Plant .....	123
E10.	Gasoline Storage and Dispensing.....	123
E11.	Aviation Gasoline Storage and Dispensing.....	125 <del>4</del>
<b>III.</b>	<b>FACILITY WIDE REQUIREMENTS .....</b>	<b>125<del>4</del></b>
A.	Opacity .....	125 <del>4</del>
B.	Nuisance.....	125
C.	Open Burning .....	125
D.	Open Burning, Certain Materials .....	126
E.	Architectural Coating .....	126
F.	Circumvention.....	126
G.	Orchard Heaters .....	127 <del>6</del>
H.	Graphic Arts Printing .....	126 <del>6</del>
I.	Surface Preparation and Cleanup .....	126 <del>6</del>
J.	Adhesive Operation.....	128
K.	Natural Gas Fired Residential Water Heaters .....	129
L.	Agricultural Burning .....	130 <del>29</del>
M.	General Permit Requirements .....	131 <del>0</del>
N.	Federal Requirements -General.....	131
<b>IV.</b>	<b>TITLE V GENERAL REQUIREMENTS .....</b>	<b>132</b>
A.	Right of Entry.....	132
B.	Compliance with Permit Conditions .....	132

C.	Emergency Provisions.....	133 <del>2</del>
D.	Severability .....	133
E.	Compliance Certification .....	133
F.	Permit Life .....	134 <del>3</del>
G.	Payment of Fees .....	134 <del>3</del>
H.	Permit Revision Exemption .....	134 <del>3</del>
I.	Application Requirements.....	134
J.	Permit Reopening for Cause .....	135 <del>4</del>
K.	Recordkeeping .....	135 <del>4</del>
L.	Reporting Requirements.....	135

**I. FACILITY EMISSION UNITS AND EQUIPMENT LISTS:**

**A. Insignificant Emissions Units**

Insignificant emissions units or exempted equipment may be supplemented, replaced or modified with non-identical equipment without notice provided exemption status has not changed as defined in current district or federal rules. The equipment listed in Table 1 is a partial listing of equipment currently identified as exempt or insignificant and not required to obtain an operating permit pursuant to Rule 3.2 of the Yolo-Solano Air Quality Management District.

Table 1. Exempted And Insignificant Emissions Units (partial listing)

Insignificant Equipment Description	Basis for Exemption
Motor vehicles	District Rule 3.2 Section 101
Air conditioning, refrigeration, ventilating, or vacuum cleaning systems, not designed to remove air contaminants generated by equipment requiring a permit	District Rule 3.2 Section 103
Equipment used in eating establishments for the purpose of preparing food for human consumption	District Rule 3.2 Section 104.1
Internal combustion engines with a maximum continuous rating of 50 bhp or less and gas turbine engines with a maximum heat input rate of 3,000,000 Btu/hr or less	District Rule 3.2 Section 105.1
Combustion equipment with a maximum heat input rating of 1,000,000 Btu/hr or less and fired exclusively with natural gas, liquefied petroleum gas, or any combination thereof	District Rule 3.2 Section 105.2
Ovens, kilns or furnaces fired by electricity and used for the heating, curing, softening, or annealing of plastics or ceramics	District Rule 3.2 Section 106.1
Equipment used for extruding rubber products or plastic where no plasticizer or blowing agent is present	District Rule 3.2 Section 106.2
Equipment used exclusively in the growing of agricultural crops or for the raising of fowl or other animals. Agricultural operations may include but are not limited to items such as solvent dip tanks, sandblasters, beadblasters, solvent or organic liquid storage and usage, orchard heaters, open burning, tractors, forklifts, other mobile sources, fuel storage, and refueling operations.	District Rule 3.2 Section 107
Repairs and maintenance not involving structural changes to any permitted equipment.	District Rule 3.2 Section 108

<p>Tanks and associated dispensing systems containing liquefied or compressed gasses such as oxygen, acetylene, nitrogen, carbon dioxide, air, or inert gasses</p>	<p>District Rule 3.2 Section 109.1</p>
<p>Tanks, vessels, or containers and their associated dispensing systems used for the storage or transfer of unheated organic materials provided that the throughput of these materials is less than 20,000 gal/day, and the compound has an initial boiling point of 302 degrees F or greater, or has a vapor pressure of 0.1 psia or less (examples include compounds such as kerosene, diesel, other fuel oils, and various acids or bases)</p>	<p>District Rule 3.2 Section 109.2</p>
<p>Underground storage tanks and their associated dispensing systems used for the storage or transfer of unheated organic materials provided that tank volume is 6076 gal or less, and the compound has a vapor pressure of 1.5 psia or less.</p>	<p>District Rule 3.2 Section 109.3</p>
<p>Tanks, vessels, or containers and their associated dispensing systems used for the storage and transfer of any unheated solvent with a capacity of 100 gallons or less.</p>	<p>District Rule 3.2 Section 109.4</p>
<p>Water solution for the surface coating preparation, cleaning, stripping, etching, (other than chemical milling) or the electrolytic plating, electrolytic polishing, or electrolytic stripping of brass, bronze, cadmium, copper, iron, lead, nickel, tin, zinc, and precious metals.</p>	<p>District Rule 3.2 Section 110.1</p>
<p>Surface coating or wipe cleaning operations using a combined total of 1 gal/day or less of coating material and solvent.</p>	<p>District Rule 3.2 Section 110.2</p>
<p>Use of unheated and non-conveyorized solvent rinse containers or unheated non-conveyorized coating dip tanks provided that the container volume is 100 gallons or less, has an open surface area of 11 sq. ft. or less, and no more than 25 gal/yr of solvent are evaporated.</p>	<p>District Rule 3.2 Section 110.3</p>
<p>Laboratory equipment used for chemical or physical analysis. Examples of equipment types include chemistry apparatus, laboratory fume hoods and vents (controlled or uncontrolled), and associated vacuum producing equipment.</p>	<p>District Rule 3.2 Section 111</p>
<p>Water cooling towers having a circulation rate of 10,000 gal/min or less and which are not used for the cooling of process water, water from barometric jets, or water from barometric condensers.</p>	<p>District Rule 3.2 Section 112</p>

<p>Other equipment with an uncontrolled air emission rate of less than 2 lb in any 24 hour period. Examples include operations at the Hazardous Materials Handling Facility, Fish Hatchery water degassing, Primate Center ozone generator, Meyer Hall soxhlet extractors, and slaughter house.</p>	<p>District Rule 3.2 Section 113</p>
<p>Portable emissions units which by themselves or in or on a piece of equipment are designed to be and capable of being carried or moved for which a written permit is otherwise required provided that the emissions unit has a valid registration (in accordance with District Rule 3.3, Portable Equipment) and the emissions unit is not subject to District Rule 3.8, Federal Operating Permits (Title V).</p>	<p>District Rule 3.2 Section 114</p>
<p>Consumer use of office equipment and products such as reprographic copiers and computer printers.</p>	<p>USEPA White Paper for Streamlined Development of Part 70 Permit Applications dated July 10, 1995, Attachment A, List of Activities That May Be Considered Trivial</p>
<p>Facility maintenance activities such as groundskeeping, general repairs, architectural coating, welding, plumbing, re-tarring roofs, installing insulation, and paving parking lots.</p>	<p>USEPA White Paper for Streamlined Development of Part 70 Permit Applications dated July 10, 1995, Attachment A, List of Activities That May Be Considered Trivial</p>
<p>Repair or maintenance shop activities not related to a facility's primary business activity, not including emissions from surface coating or degreasing.</p>	<p>USEPA White Paper for Streamlined Development of Part 70 Permit Applications dated July 10, 1995, Attachment A, List of Activities That May Be Considered Trivial</p>
<p>Storage tanks, reservoirs, and pumping and handling equipment containing soaps, vegetable oil, grease, animal fat (such as that at the Animal Science Feed Lot), or non-volatile aqueous salt solutions provided that appropriate lids and covers are utilized.</p>	<p>USEPA White Paper for Streamlined Development of Part 70 Permit Applications dated July 10, 1995, Attachment A, List of Activities That May Be Considered Trivial</p>
<p>Hand-held equipment used for buffing, polishing, cutting, drilling, sawing, grinding, turning, or machining of wood, metal, or plastic.</p>	<p>USEPA White Paper for Streamlined Development of Part 70 Permit Applications dated July 10, 1995, Attachment A, List of Activities That May Be Considered Trivial</p>

**B. Significant Emissions Unit Information**

Each of the sources has been constructed pursuant to issuance of an authority to construct in accordance with District Rules 3.1 and 3.4.

**B1. Emergency Diesel Fired Internal Combustion Engines**

**Identification Number: P-89-94(a)**

- Equipment Description: An internal combustion engine, Caterpillar Model No. 3306, 277 Brake Horsepower, to power an emergency generator.
- Control Equipment: Aftercooler
- Identification Number: P-90-94(a)**
- Equipment Description: An internal combustion engine, Cummins Model No. NTC 290, 290 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-91-94(a)**
- Equipment Description: An internal combustion engine, Cummins Model No. NT855C, 289 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-92-94(a)**
- Equipment Description: An internal combustion engine, Caterpillar Model No. D343, 415 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger
- Identification Number: P-94-94(a)**
- Equipment Description: An internal combustion engine, John Deere Model No. 6059TF001, 150 Brake Horsepower, to power an emergency generator.
- Control Equipment: None
- Identification Number: P-95-94(a)**
- Equipment Description: An internal combustion engine, Waukesha Model No. F1197DSU, 244 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger
- Identification Number: P-96-94(a)**
- Equipment Description: An internal combustion engine, Detroit Diesel Model No. 12V92T, 740 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger
- Identification Number: P-99-94(a)**

Equipment Description:	An internal combustion engine, Cummins Model No. 6CT8.3-G, 207 Brake Horsepower, to power an emergency generator.
Control Equipment:	Turbocharger
<b>Identification Number:</b>	<b>P-100-94(a)</b>
Equipment Description:	An internal combustion engine, Cummins Model No. KTA1150-G, 560 Brake Horsepower, to power an emergency generator.
Control Equipment:	Turbocharger
<b>Identification Number:</b>	<b>P-101-94(a)</b>
Equipment Description:	An internal combustion engine, Cummins Model No. KTTA19G2, 750 Brake Horsepower, to power an emergency generator.
Control Equipment:	Turbocharger
<b>Identification Number:</b>	<b>P-102-94(a)</b>
Equipment Description:	An internal combustion engine, Detroit Diesel Model No. 80837416, 643 Brake Horsepower, to power an emergency generator.
Control Equipment:	Turbocharger
<b>Identification Number:</b>	<b>P-103-94(a)</b>
Equipment Description:	An internal combustion engine, Detroit Diesel Model No. 6-71, 228 Brake Horsepower, to power an emergency pump.
Control Equipment:	None
<b>Identification Number:</b>	<b>P-107-95(a)</b>
Equipment Description:	An internal combustion engine, Cummins Model No. 6CTA8.3-G, 227 Brake Horsepower, to power an emergency generator.
Control Equipment:	Turbocharger and Aftercooler
<b>Identification Number:</b>	<b>P-126-95(a)</b>
Equipment Description:	An internal combustion engine, Cummins Model No. LTA.10G1, 380 Brake Horsepower, to power an emergency generator.
Control Equipment:	Turbocharger and Aftercooler
<b>Identification Number:</b>	<b>P-209-95(a)</b>

- Equipment Description: An internal combustion engine, Cummins Model No. 6CT8.3G, 207 Brake Horsepower, to power an emergency generator.
- Control Equipment: None
- Identification Number: P-29-96(a)**
- Equipment Description: An internal combustion engine, Cummins Model No. NTA-855-G, 390 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger
- Identification Number: P-69-96(a)**
- Equipment Description: An internal combustion engine, Cummins Model No. 6BT5.9-G2, 166 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-42-97**
- Equipment Description: An internal combustion engine, Cummins Model No. 6CT8.3G, 207 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-54-97**
- Equipment Description: An internal combustion engine, Detroit Diesel Model No. 8163-7416, 1,252 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-15-98**
- Equipment Description: An internal combustion engine, Cummins Model No. LTA 10-G1, 380 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger, Aftercooler, and 4 degrees Fuel Injection Timing Retard
- Identification Number: P-16-98**
- Equipment Description: An internal combustion engine, Cummins Model No. MTA 11-G2, 345 Brake Horsepower, to power an emergency generator
- Control Equipment: Turbocharger, Aftercooler, and 4 degrees Fuel Injection Timing Retard

- Identification Number:** **P-17-98**
- Equipment Description: An internal combustion engine, Perkins Model No. T4.236, 82 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and 4 Degree Fuel Injection Timing Retard
- Identification Number:** **P-31-98**
- Equipment Description: An internal combustion engine, Cummins Model No. NTA-855-G3, 535 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger, Aftercooler and 4 Degree Fuel Injection Timing Retard
- Identification Number:** **P-32-98**
- Equipment Description: An internal combustion engine, Cummins Model No. NTA-855-G2, 465 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger, Aftercooler and 4 Degree Fuel Injection Timing Retard
- Identification Number:** **P-32-99**
- Equipment Description: An internal combustion engine, Cummins Model No. NTA855-G3, 535 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number:** **P-88-99**
- Equipment Description: An emergency internal combustion engine, Detroit Diesel Model No. 7243-7406, 1,550 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger, Aftercooler and 4 Degree Fuel Injection Timing Retard
- Identification Number:** **P-1-00**
- Equipment Description: An emergency internal combustion engine, Generac Model No. 133DTA, 440 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger, Aftercooler and 4 Degree Fuel Injection Timing Retard
- Identification Number:** **P-2-00**

Equipment Description: An emergency internal combustion engine, Detroit Diesel Model No. 6V-92TA (8063-7405), 423 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger, Aftercooler and Timing Retard

**Identification Number: P-71-00**

Equipment Description: An emergency internal combustion engine, Cummins Model No. NTA-855-G2, 465 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger and Aftercooler

**Identification Number: P-7-01**

Equipment Description: An emergency internal combustion engine, Cummins Model No. NTA855-G2, 465 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger and Aftercooler

**Identification Number: P-8-01(a)**

Equipment Description: An emergency internal combustion engine, Cummins Model No. KTTA19-G2, 750 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger and Aftercooler

**Identification Number: P-9-01(a)**

Equipment Description: An emergency internal combustion engine, Caterpillar Model No. 3306, 227 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger

**Identification Number: P-108-01**

Equipment Description: An emergency internal combustion engine, Cummins Model No. 4B3.9-G2, 68 Brake Horsepower, to power an emergency generator.

Control Equipment: None

**Identification Number: P-109-01**

Equipment Description: An emergency internal combustion engine, Cummins Model No. 4B3.9-G2, 68 Brake Horsepower, to power an emergency generator.

- Control Equipment: None
- Identification Number: P-111-01**
- Equipment Description: An emergency internal combustion engine, Cummins Model No. QST30-G1, 1,135 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-120-01**
- Equipment Description: An emergency internal combustion engine, Detroit Diesel Model No. R123-7K36, 1,120 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-17-02**
- Equipment Description: An emergency internal combustion engine, Cummins Model No. 6BT5.9-G6, 170 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger
- Identification Number: P-82-02**
- Equipment Description: An emergency internal combustion engine, Detroit Diesel Model No. 6063-MK35, 490 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-83-02**
- Equipment Description: An emergency internal combustion engine, Cummins Model No. 6CT8.3-G2, 207 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger
- Identification Number: P-84-02**
- Equipment Description: An emergency internal combustion engine, Detroit Diesel Model No. 6063HK35, 635 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler

- Identification Number:** **P-114-02**
- Equipment Description: An emergency internal combustion engine, Cummins Model No. 6BT5.9-G6, 170 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger
- Identification Number:** **P-63-03**
- Equipment Description: An emergency internal combustion engine, Cummins Model No. LTA 10-G1, 380 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number:** **P-102-03**
- Equipment Description: An emergency internal combustion engine, Spectrum Detroit Diesel Model No. R163-K735, 1200 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number:** **P-115-03**
- Equipment Description: An emergency internal combustion engine, Cummins Model No. QSX15-G9, 755 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number:** **P-117-03**
- Equipment Description: An emergency internal combustion engine, Cummins Model No. 6BTA5.9-G3, 207 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger
- Identification Number:** **P-118-03**
- Equipment Description: An emergency internal combustion engine, Caterpillar Model No. 3456 ATAAC, 764 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler

**Identification Number: P-119-03**

Equipment Description: An emergency internal combustion engine, Cummins Model No. 6BTA5.9-G3, 207 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger

**Identification Number: P-120-03**

Equipment Description: An emergency internal combustion engine, Detroit Diesel Model No. T163-7K36, 2,935 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger and Aftercooler

**Identification Number: P-121-03**

Equipment Description: An emergency internal combustion engine, Detroit Diesel Model No. R123-7K36, 1,120 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger and Aftercooler

**Identification Number: P-15-04**

Equipment Description: An emergency internal combustion engine, Detroit Diesel Model No. 12V-2000 G81, 1,120 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger

**Identification Number: P-74-05**

Equipment Description: An emergency internal combustion engine, Cummins Model No. QSM11-G2, 470 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger and Aftercooler

**Identification Number: P-38-05**

Equipment Description: An emergency internal combustion engine, Cummins Model No. 6CTAA8.3G3, 317 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger and Aftercooler

**Identification Number: P-59-05**

- Equipment Description: An emergency internal combustion engine, John Deere Model No. 4045HF275G, 145 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-49-07**
- Equipment Description: An emergency internal combustion engine, Caterpillar Model No. C18, 900 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-50-07**
- Equipment Description: An emergency internal combustion engine, Cummins Model No. QST30-G5, 1,490 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-51-07**
- Equipment Description: An emergency internal combustion engine, John Deere Model No. 3029TF270D, 64 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger
- Identification Number: P-52-07**
- Equipment Description: An emergency internal combustion engine, Mitsubishi Model No. S12A2-Y1PTA-1, 1,207 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger, Aftercooler, and Oxidation Catalyst
- Identification Number: P-53-07**
- Equipment Description: An emergency internal combustion engine, Mitsubishi Model No. S12A2-Y1PTA-1, 1,207 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger, Aftercooler, and Oxidation Catalyst
- Identification Number: P-59-07**

- Equipment Description: An emergency internal combustion engine, Cummins Model No. QSL9-G2, 364 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-2-09**
- Equipment Description: An emergency internal combustion engine, John Deere Model No. 4024HF285B 80 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-4-09**
- Equipment Description: An emergency internal combustion engine, John Deere Model No. 6090HF484, 402.3 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-16-09**
- Equipment Description: An emergency internal combustion engine, Caterpillar Model No. C27, 998 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-17-09**
- Equipment Description: An emergency internal combustion engine, John Deere Model No. 6068HF485T,U, 297 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-54-09**
- Equipment Description: An emergency internal combustion engine, Caterpillar Model No. C18, 923 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-66-09**
- Equipment Description: An emergency internal combustion engine, John Deere Model No. 4045HF285H 126 Brake Horsepower, to power an emergency generator.

- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-67-09**
- Equipment Description: An emergency internal combustion engine, John Deere Model No. 4045HF2851, 158 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-68-09**
- Equipment Description: An emergency internal combustion engine, John Deere Model No. 6090HF484A, 453.8 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-69-09**
- Equipment Description: An emergency internal combustion engine, Volvo Model No. TWD1643GE, 904 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-42-10**
- Equipment Description: An emergency internal combustion engine, John Deere Model No. 6068HF485, 315 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-44-10**
- Equipment Description: An emergency internal combustion engine, MTU Detroit Diesel Model No. 12V1600G80S, 896 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number: P-7-11**
- Equipment Description: An emergency internal combustion engine, John Deere IC engine, Model No. 6135HF485T, 617 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler

- Identification Number:** P-72-11
- Equipment Description: An emergency internal combustion engine, Detroit Diesel IC engine, Model No. 12V2000 G85, 1,194 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number:** P-39-12
- Equipment Description: An emergency internal combustion engine, Detroit Diesel IC engine, Model No. 6063HV35, 550 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number:** P-51-12
- Equipment Description: An emergency internal combustion engine, MTU IC engine, Model No. 10V1600G70S, 685 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number:** P-52-12
- Equipment Description: An emergency internal combustion engine, John Deere IC engine, Model No. 4045HF285, 158 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number:** P-55-12
- Equipment Description: An emergency internal combustion engine, John Deere IC engine, Model No. 6090HFG86, 463 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler
- Identification Number:** P-56-12
- Equipment Description: An emergency internal combustion engine, John Deere IC engine, Model No. 6090HFG484, 385 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger and Aftercooler

**Identification Number:** P-4-13

Equipment Description: An emergency internal combustion engine, Caterpillar IC engine, Model No. C27, 1,214 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger and Aftercooler

**B2. Emergency Natural Gas Fired Internal Combustion Engines**

**Identification Number:** P-108-95(a)

Equipment Description: An internal combustion engine, Waukesha Model No. F2895GSIU, 636 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger and Aftercooler

**Identification Number:** P-109-95(a)

Equipment Description: An internal combustion engine, Ford Model No. LSG-8751-6005-A, 111 Brake Horsepower, to power an emergency generator.

Control Equipment: None

**Identification Number:** P-110-95(a)

Equipment Description: An internal combustion engine, Waukesha Model No. L1616GU, 400 Brake Horsepower, to power an emergency generator.

Control Equipment: None

**Identification Number:** P-112-95(a)

Equipment Description: An internal combustion engine, Hercules Model No. G2300, 52 Brake Horsepower, to power an emergency generator.

Control Equipment: None

**Identification Number:** P-113-95(a)

Equipment Description: An internal combustion engine, Ford Model No. C5PF6005A, 124 Brake Horsepower, to power an emergency generator.

Control Equipment: None

**Identification Number:** P-114-95(a)

Equipment Description: An internal combustion engine, Ford Model No. LSG-8751-6005, 111 Brake Horsepower, to power an emergency generator.

Control Equipment:	None
<b>Identification Number:</b>	<b>P-117-95(a)</b>
Equipment Description:	An internal combustion engine, General Motors Model No. 75872, 64 Brake Horsepower, to power an emergency generator.
Control Equipment:	None
<b>Identification Number:</b>	<b>P-118-95(a)</b>
Equipment Description:	An internal combustion engine, Ford Model No. C5PF-6005A, 82 Brake Horsepower, to power an emergency generator.
Control Equipment:	None
<b>Identification Number:</b>	<b>P-119-95(a)</b>
Equipment Description:	An internal combustion engine, Ford Model No. CSG6491-6005A, 82 Brake Horsepower, to power an emergency generator.
Control Equipment:	None
<b>Identification Number:</b>	<b>P-120-95(a)</b>
Equipment Description:	An internal combustion engine, Ford Model No. LSG4231-6005F, 52 Brake Horsepower, to power an emergency generator.
Control Equipment:	Turbocharger
<b>Identification Number:</b>	<b>P-121-95(a)</b>
Equipment Description:	An internal combustion engine, Ford Model No. C5PF-6005A, 124 Brake Horsepower, to power an emergency generator.
Control Equipment:	None
<b>Identification Number:</b>	<b>P-122-95(a)</b>
Equipment Description:	An internal combustion engine, General Motors Model No. 506N, 64 Brake Horsepower, to power an emergency generator.
Control Equipment:	None
<b>Identification Number:</b>	<b>P-123-95(a)</b>
Equipment Description:	An internal combustion engine, General Motors Model No. 74G.N., 160 Brake Horsepower, to power an emergency generator

- Control Equipment: None
- Identification Number: P-124-95(a)**
- Equipment Description: An internal combustion engine, Cummins Model No. G-743, 189 Brake Horsepower, to power an emergency generator.
- Control Equipment: None
- Identification Number: P-125-95(a)**
- Equipment Description: An internal combustion engine, Caterpillar Model No. G333, 166 Brake Horsepower, to power an emergency generator.
- Control Equipment: None
- Identification Number: P-18-98**
- Equipment Description: An internal combustion engine, Cummins Model No. CSG 6941-6005-A, 53 Brake Horsepower, to power an emergency generator.
- Control Equipment: None
- Identification Number: P-61-00**
- Equipment Description: An emergency internal combustion engine, Detroit Diesel Model No. S60G, 415 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger, aftercooler, and a three-way Miratech catalytic converter
- Identification Number: P-3-09**
- Equipment Description: An emergency internal combustion engine, Cummins Model No. GTA28, 770 Brake Horsepower, to power an emergency generator.
- Control Equipment: Turbocharger, aftercooler, and catalytic convertor
- Identification Number: P-43-10**
- Equipment Description: An emergency internal combustion engine, Ford Model No. WSG-1068, 97.5 Brake Horsepower, to power an emergency generator.
- Control Equipment: Catalytic convertor

**B3. Portable Internal Combustion Engines**

**Identification Number:** P-50-99(a)  
Equipment Description: Portable diesel emergency internal combustion engine, Komatsu Model No. 0649T, 118 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger

**Identification Number:** P-51-99(a)  
Equipment Description: Portable diesel emergency internal combustion engine, Komatsu Model No. 0649T, 118 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger

**Identification Number:** P-52-99(a)  
Equipment Description: Portable diesel emergency internal combustion engine, Komatsu Model No. 0649T, 118 Brake Horsepower, to power an emergency generator.

Control Equipment: Turbocharger

**Identification Number:** P-86-01  
Equipment Description: Portable emergency Internal Combustion (IC) engine #7, Volvo diesel Model No. TWD 740 GE, 311 Brake Horsepower

Control Equipment: Turbocharger and Intercooler

**Identification Number:** P-87-01  
Equipment Description: Portable emergency Internal Combustion (IC) engine #8, Volvo diesel Model No. TWD 740 GE, 311 Brake Horsepower

Control Equipment: Turbocharger and Intercooler

**B4. Boilers and Water Heaters**

**Identification Number:** P-44-96  
Equipment Description: 3.2 MMBTU/hr hot water heater, Bryan Model No. L-48, for greenhouses

Control Equipment: None

**Identification Number:** P-45-96

Equipment Description: 1.375 MMBTU/hr hot water heater, Crane Model No. 60W12NA  
Control Equipment: None

**Identification Number: P-47-96**

Equipment Description: 3.75 MMBTU/hr boiler, Ajax Model No. WGXB-3750

Control Equipment: None

**Identification Number: P-48-96**

Equipment Description: 1.2 MMBTU/hr boiler, Bryan Model No. CL-120

Control Equipment: None

**Identification Number: P-54-96**

Equipment Description: 1.5 MMBTU/hr boiler, Bryan Model No. CL-150-W-WT-GT, Serial No. 66671

Control Equipment: None

**Identification Number: P-62-96**

Equipment Description: 2.22 MMBTU/hr boiler, Bryan Model No. L-32-W-WT

Control Equipment: None

**Identification Number: P-67-98**

Equipment Description: 12.6 MMBTU/hr boiler, Hurst Boiler & Welding Company Model No. S4-X-300-150, co-fired with landfill gas and natural gas

Control Equipment: Low NO<sub>x</sub> burner and Flue Gas Recirculation

**Identification Number: P-3-00**

Equipment Description: Ten (10) 0.398 MMBTU/hr, natural gas fired Fulton Boilers, Model No. ICS-95-LE

Control Equipment: None

**Identification Number: P-5-00**

Equipment Description: 1.5 MMBTU/hr boiler, Ajax Model No. 90282 with a Power Flame Burner

Control Equipment: None

**Identification Number: P-52-00**

Equipment Description: Five (5) 0.398 MMBTU/hr natural gas fired boilers, Fulton boiler Model No. FB-010-A, burner Model No. ICS-9.5-LE

Control Equipment: None

**Identification Number: P-54-00(a)**

Equipment Description: One (1) 3.0 MMBtu/hr AERCO International natural gas fired boiler, Model Number BMK 3.0

Control Equipment: Low NOx Burner

**Identification Number: P-55-00**

Equipment Description: Two (2) 0.765 MMBTU/hr boilers, Ajax Model No. WEG900

Control Equipment: None

**Identification Number: P-67-00(a)**

Equipment Description: Six (6) 0.398 MMBtu/hr natural gas fired Fulton Boilers, Model No. ICS-9.5-LE

Control Equipment: None

**Identification Number: P-89-00**

Equipment Description: 12.51 MMBTU/hr boiler, Hurst Model No. S4-X-300-150

Control Equipment: Combustion ~~Specialties~~ [Specialties](#) low NO<sub>x</sub> burner Model No. 300-N304 and a Flue Gas Recirculation (FGR) system

**Identification Number: P-90-00**

Equipment Description: 126.1 MMBTU/hr boiler, Babcock and Wilcox Model No. FM-1487

Control Equipment: COEN low NO<sub>x</sub> burner Model No. QLN 3.8 and induced flue gas recirculation (FGR) system

**Identification Number: P-91-00**

Equipment Description: 126.1 MMBTU/hr boiler, Babcock and Wilcox Model No. FM-1487

Control Equipment: COEN low NO<sub>x</sub> burner Model No. QLN 3.8 and induced flue gas recirculation (FGR) system

**Identification Number: P-96-00**

Equipment Description: 90.3 MMBTU/hr boiler, English Boiler and Tube Company Model No. 75-E-250

Control Equipment: COEN low NO<sub>x</sub> burner Model No. QLN 3.6

**Identification Number: P-90-02**

Equipment Description: 2.0 MMBTU/hr boiler, Bryan Model No. AB-200-W-FDG-LX

Control Equipment: Low NO<sub>x</sub> burner

**Identification Number: P-91-02**

Equipment Description: 2.0 MMBTU/hr boiler, Bryan Model No. AB-200-W-FDG-LW

Control Equipment: Low NO<sub>x</sub> burner

**Identification Number: P-28-03**

Equipment Description: 3.9 MMBTU/hr boiler, Parker Model No. T-3900

Control Equipment: None

**Identification Number: P-64-03(a)**

Equipment Description: Four (4) boilers with combined rating of 1.592 MMBTU/hr boiler, Parker Model No. 103.9.5LA

Control Equipment: Low NO<sub>x</sub> burners

**Identification Number: P-65-03**

Equipment Description: Two (2) 1.14 MMBTU/hr boiler, Parker Model No. T-1140L

Control Equipment: Gas/Air premix with metal fiber burners

**Identification Number: P-101-03**

Equipment Description: Two (2) 1.075 MMBTU/hr boiler, RECO USA Model No. R25-1338 FG

Control Equipment: None

**Identification Number: P-63-06(a)**

Equipment Description: One (1) 301,000 Btu/hr natural gas fired Parker boiler; Boiler #3: Model No. 103-7; three (3) 398,000 Btu/hr, natural gas fired Parker

boilers; Boiler #4: Model No. 103-9.5; Boiler #5: Model No. 103-9.5; Boiler #6: Model No. 9.5L

Control Equipment: Boiler #3, #4 and #5: None; Boiler #6: Low-NOx burner

**Identification Number: P-83-06**

Equipment Description: 180 MMBtu/hr, natural gas fired boiler with diesel back-up fuel, Rentech Model D

Control Equipment: Low NOx burner, selective catalytic reduction (SCR), and oxidation catalyst

**Identification Number: P-16-08**

Equipment Description: 2.1 MMBtu/hr, natural gas fired A.O. Smith boiler, Model No. GW-2100

Control Equipment: Low NOx burners

**Identification Number: P-44-11**

Equipment Description: Five (5) 0.45 MMBtu/hr, natural gas fired HARSCO Industrial/Patterson-Kelley boilers totaling 2.25 MMBtu/hr, Model No. MACH C-450

Control Equipment: Low NOx burners

**B5. Coating Operation**

**Identification Number: P-96-80(a1)**

Equipment Description: Metal and wood parts and products coating operation; 11'8" H x 16'4" W x 24' D paint spray booth with an exempt (<1.0 MMBtu/hr) natural gas fired air make-up unit, spray equipment, enclosed gun washer, and solvent recovery system

Control Equipment: Exhaust fan with dry filter system

**B6. Landfill Gas Collection and Soil Vapor Extraction System**

**Identification Number: P-14-98**

Equipment and Control Equipment Description:

Landfill gas (LFG) collection and soil vapor extraction system; LFG extraction wells with below grade header pipes; soil vapor extraction wells; extraction blowers, Lamson model no. 263-GB, 5 HP; LFG condensate knockout

**B7. Incinerator**

**Identification Number:** P-81-89(a)

Equipment Description: Multiple Chamber Incinerator and Ash Collection System; Incinerator: Advanced Combustion Systems Model No. CA-1100P; Ash Removal System: Kice Model No. FH5; Ash Storage Bin

Control Equipment: Secondary Combustion Chamber and Ash Collection System, Kice Model No. HR-12-6

**B8. Woodworking Operations**

**Identification Number:** P-95-80(a1)

Equipment Description: Miscellaneous woodworking equipment (total cumulative electric motor horsepower not to exceed 174 HP).

Control Equipment: One (1) dust collection floor duct; One (1) U.S. Motors cyclone, Model SC, with a 15 HP blower motor (5,000 CFM) in series with one (1) Murphy-Rodgers, Inc. baghouse, Model MRO-810, with a 3 HP shaker motor; One (1) custom made dust collector, with a 3 HP blower motor (500 CFM).

**Identification Number:** P-54-90(a)

Equipment Description: Miscellaneous woodworking equipment. Total electric horsepower not to exceed 39 HP.

Control Equipment: Dust collection system not to exceed 4,600 CFM

**Identification Number:** **P-43-13**

**Equipment Description:** **Equipment controlled by dust collectors: two (2) band saws, one (1) gliding compound, one (1) table saw, one (1) spindle sander, one (1) disk sander, one (1) belt sander and one (1) miter saw; Uncontrolled equipment: one (1) drill press, one (1) panel saw, and one (1) belt grinder; total electrical horsepower not to exceed 49.9 HP.**

**Control Equipment:** **Donaldson Torit Unimaster Dust Collector, Model No. 450 (5,000 CFM)**

**B9. Wastewater Treatment Plant**

**Identification Number:** P-22-00(a)

**Equipment Description:** Waste Water Treatment Plant; Channels, Mechanically Aerated Oxidation Ditch, Clarifiers, Return and Waste Sludge Pumping, Effluent Filter Cells, UV Disinfection Channels, Effluent Pumps, and Bio-Solids Handling

**Control Equipment:** None

**B10. Cooling Towers**

**Identification Number:** P-101-02

**Equipment Description:** Two 6,000 gpm Cooling Towers, Marley Model No. NC8311F-3BS

**Control Equipment:** None

**B11. Gasoline, and Aviation Gasoline Storage and Dispensing**

**Identification Number:** P-42-76(a3)

**Equipment Description:** Non-Retail Gasoline Storage and Dispensing Facility; One 12,000 gallon underground gasoline storage tank; Four gasoline dispensers (1 nozzle each); One pressure/vacuum vent valve

**Control Equipment:** Balance Vapor Recovery System, Executive Order: Phase VR-102-D, Phase II - VR-203-D

**Identification Number:** P-1-81(a3)

**Equipment Description:** Non-Retail Aviation Gasoline Storage and Dispensing Facility; One 12,000 gallon aboveground aviation gasoline storage tank; One aviation gasoline dispenser (1 nozzle), and one pressure/vacuum valve

**Control Equipment:** Balance Vapor Recovery System, Executive Order: Phase I - G-70-142-B

**Identification Number:** P-84-93(a1)

**Equipment Description:** One 500 gallon aboveground gasoline storage tank; One gasoline dispenser (1 nozzle); One gasoline pressure/vacuum vent valve

**Control Equipment:** Balance vapor recovery system; Executive Orders: Phase I-G-70-142-B, Phase II - G-707-52-AM

**II. SPECIFIC UNIT REQUIREMENTS**

**A. Emission Limitations**

**A1. Emergency Internal Combustion Engines**

1. For the engine operating under P-89-94(a):
  - a. VOC emissions shall not exceed 16.7 lb/day, 139 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-02-309]
  - b. CO emissions shall not exceed 44.4 lb/day, 370 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.19 tons/year. [District Rule 3.4/C-02-309]
  - c. NOx emissions shall not exceed 206.1 lb/day, 1,717 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.86 tons/year. [District Rule 3.4/C-02-309]
  - d. SOx emissions shall not exceed 2.7 lb/day, 22 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-309]
  - e. PM10 emissions shall not exceed 14.6 lb/day, 122 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-02-309]
2. For the engine operating under P-90-94(a):
  - a. VOC emissions shall not exceed 17.5 lb/day, 146 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-02-286]
  - b. CO emissions shall not exceed 46.5 lb/day, 387 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.19 tons/year. [District Rule 3.4/C-02-286]
  - c. NOx emissions shall not exceed 215.8 lb/day, 1,798 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.90 tons/year. [District Rule 3.4/C-02-286]
  - d. SOx emissions shall not exceed 2.8 lb/day, 23 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-286]
  - e. PM10 emissions shall not exceed 15.3 lb/day, 128 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-02-286]
3. For the engine operating under P-91-94(a):
  - a. VOC emissions shall not exceed 17.4 lb/day, 145 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-02-304]
  - b. CO emissions shall not exceed 46.3 lb/day, 386 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.19 tons/year. [District Rule 3.4/C-02-304]
  - c. NOx emissions shall not exceed 215.0 lb/day, 1,792 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.90 tons/year. [District Rule 3.4/C-02-304]

- d. SOx emissions shall not exceed 2.8 lb/day, 23 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-304]
  - e. PM10 emissions shall not exceed 15.3 lb/day, 127 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-02-304]
4. For the engine operating under P-92-94(a):
- a. VOC emissions shall not exceed 25.0 lb/day, 209 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.10 tons/year. [District Rule 3.4/C-02-299]
  - b. CO emissions shall not exceed 66.5 lb/day, 554 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.28 tons/year. [District Rule 3.4/C-02-299]
  - c. NOx emissions shall not exceed 308.8 lb/day, 2,573 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.29 tons/year. [District Rule 3.4/C-02-299]
  - d. SOx emissions shall not exceed 4.0 lb/day, 34 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-02-299]
  - e. PM10 emissions shall not exceed 21.9 lb/day, 183 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-02-299]
5. For the engine operating under P-94-94(a):
- a. VOC emissions shall not exceed 1.8 lb/day, 15 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-285]
  - b. CO emissions shall not exceed 21.2 lb/day, 177 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-02-285]
  - c. NOx emissions shall not exceed 92.6 lb/day, 772 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.39 tons/year. [District Rule 3.4/C-02-285]
  - d. SOx emissions shall not exceed 1.5 lb/day, 12 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-285]
  - e. PM10 emissions shall not exceed 7.9 lb/day, 66 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-02-285]
6. For the engine operating under P-95-94(a):
- a. VOC emissions shall not exceed 14.7 lb/day, 123 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-02-300]
  - b. CO emissions shall not exceed 39.1 lb/day, 326 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.16 tons/year. [District Rule 3.4/C-02-300]

- c. NOx emissions shall not exceed 181.5 lb/day, 1,513 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.76 tons/year. [District Rule 3.4/C-02-300]
  - d. SOx emissions shall not exceed 2.4 lb/day, 20 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-300]
  - e. PM10 emissions shall not exceed 12.9 lb/day, 107 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-02-300]
7. For the engine operating under P-96-94(a):
- a. VOC emissions shall not exceed 12.9 lb/day, 108 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-02-301]
  - b. CO emissions shall not exceed 94.0 lb/day, 783 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.39 tons/year. [District Rule 3.4/C-02-301]
  - c. NOx emissions shall not exceed 426.2 lb/day, 3,552 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.78 tons/year. [District Rule 3.4/C-02-301]
  - d. SOx emissions shall not exceed 7.2 lb/day, 60 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-02-301]
  - e. PM10 emissions shall not exceed 39.1 lb/day, 326 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.16 tons/year. [District Rule 3.4/C-02-301]
8. For the engine operating under P-99-94(a):
- a. VOC emissions shall not exceed 7.7 lb/day, 64 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-02-319]
  - b. CO emissions shall not exceed 21.9 lb/day, 183 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-02-319]
  - c. NOx emissions shall not exceed 120.5 lb/day, 1,004 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.50 tons/year. [District Rule 3.4/C-02-319]
  - d. SOx emissions shall not exceed 2.0 lb/day, 17 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-319]
  - e. PM10 emissions shall not exceed 2.7 lb/day, 23 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-319]
9. For the engine operating under P-100-94(a):
- a. VOC emissions shall not exceed 33.8 lb/day, 282 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.14 tons/year. [District Rule 3.4/C-02-295]

- b. CO emissions shall not exceed 89.8 lb/day, 748 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.37 tons/year. [District Rule 3.4/C-02-295]
  - c. NOx emissions shall not exceed 416.6 lb/day, 3,472 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.74 tons/year. [District Rule 3.4/C-02-295]
  - d. SOx emissions shall not exceed 5.4 lb/day, 45 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-02-295]
  - e. PM10 emissions shall not exceed 29.6 lb/day, 246 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.12 tons/year. [District Rule 3.4/C-02-295]
10. For the engine operating under P-101-94(a):
- a. VOC emissions shall not exceed 14.3 lb/day, 119 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-02-312]
  - b. CO emissions shall not exceed 50.0 lb/day, 417 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.21 tons/year. [District Rule 3.4/C-02-312]
  - c. NOx emissions shall not exceed 452.0 lb/day, 3,767 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.88 tons/year. [District Rule 3.4/C-02-312]
  - d. SOx emissions shall not exceed 7.3 lb/day, 61 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-02-312]
  - e. PM10 emissions shall not exceed 4.8 lb/day, 40 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-02-312]
11. For the engine operating under P-102-94(a):
- a. VOC emissions shall not exceed 11.2 lb/day, 94 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-02-297]
  - b. CO emissions shall not exceed 81.6 lb/day, 680 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.34 tons/year. [District Rule 3.4/C-02-297]
  - c. NOx emissions shall not exceed 370.4 lb/day, 3,086 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.54 tons/year. [District Rule 3.4/C-02-297]
  - d. SOx emissions shall not exceed 6.2 lb/day, 52 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-02-297]
  - e. PM10 emissions shall not exceed 34.0 lb/day, 283 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.14 tons/year. [District Rule 3.4/C-02-297]
12. For the engine operating under P-103-94(a):

- a. VOC emissions shall not exceed 13.8 lb/day, 115 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-02-305]
  - b. CO emissions shall not exceed 36.6 lb/day, 305 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.15 tons/year. [District Rule 3.4/C-02-305]
  - c. NOx emissions shall not exceed 169.6 lb/day, 1,414 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.71 tons/year. [District Rule 3.4/C-02-305]
  - d. SOx emissions shall not exceed 2.2 lb/day, 18 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-305]
  - e. PM10 emissions shall not exceed 12.0 lb/day, 100 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-02-305]
13. For the engine operating under P-107-95(a):
- a. VOC emissions shall not exceed 2.0 lb/day, 17 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-289]
  - b. CO emissions shall not exceed 20.1 lb/day, 167 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/C-02-289]
  - c. NOx emissions shall not exceed 76.3 lb/day, 636 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.32 tons/year. [District Rule 3.4/C-02-289]
  - d. SOx emissions shall not exceed 2.2 lb/day, 18 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-289]
  - e. PM10 emissions shall not exceed 3.0 lb/day, 25 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-289]
14. For the engine operating under P-126-95(a):
- a. VOC emissions shall not exceed 9.7 lb/day, 80 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-02-316]
  - b. CO emissions shall not exceed 20.1 lb/day, 168 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/C-02-316]
  - c. NOx emissions shall not exceed 187.0 lb/day, 1,558 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.78 tons/year. [District Rule 3.4/C-02-316]
  - d. SOx emissions shall not exceed 3.7 lb/day, 31 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-02-316]
  - e. PM10 emissions shall not exceed 10.1 lb/day, 84 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-02-316]

15. For the engine operating under P-209-95(a):
  - a. VOC emissions shall not exceed 7.7 lb/day, 64 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-02-313]
  - b. CO emissions shall not exceed 21.9 lb/day, 183 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-02-313]
  - c. NOx emissions shall not exceed 120.5 lb/day, 1,004 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.50 tons/year. [District Rule 3.4/C-02-313]
  - d. SOx emissions shall not exceed 2.0 lb/day, 17 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-313]
  - e. PM10 emissions shall not exceed 2.7 lb/day, 23 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-313]
  
16. For the engine operating under P-29-96(a):
  - a. VOC emissions shall not exceed 23.5 lb/day, 196 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.10 tons/year. [District Rule 3.4/C-02-282]
  - b. CO emissions shall not exceed 62.5 lb/day, 521 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.26 tons/year. [District Rule 3.4/C-02-282]
  - c. NOx emissions shall not exceed 290.2 lb/day, 2,418 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.21 tons/year. [District Rule 3.4/C-02-282]
  - d. SOx emissions shall not exceed 3.8 lb/day, 32 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-02-282]
  - e. PM10 emissions shall not exceed 10.3 lb/day, 86 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-02-282]
  
17. For the engine operating under P-69-96(a):
  - a. VOC emissions shall not exceed 2.6 lb/day, 22 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-290]
  - b. CO emissions shall not exceed 28.9 lb/day, 241 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.12 tons/year. [District Rule 3.4/C-02-290]
  - c. NOx emissions shall not exceed 93.5 lb/day, 779 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.39 tons/year. [District Rule 3.4/C-02-290]
  - d. SOx emissions shall not exceed 1.6 lb/day, 13 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-290]

- e. PM10 emissions shall not exceed 2.2 lb/day, 18 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-290]
18. For the engine operating under P-42-97:
- a. VOC emissions shall not exceed 3.3 lb/day, 27 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/P-42-97]
  - b. CO emissions shall not exceed 6.6 lb/day, 55 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/P-42-97]
  - c. NOx emissions shall not exceed 54.8 lb/day, 456 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.23 tons/year. [District Rule 3.4/P-42-97]
  - d. SOx emissions shall not exceed 6.1 lb/day, 51 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/P-42-97]
  - e. PM10 emissions shall not exceed 2.9 lb/day, 234 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/P-42-97]
19. For the engine operating under P-54-97:
- a. VOC emissions shall not exceed 8.8 lb/day, 73 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/A-88-97c]
  - b. CO emissions shall not exceed 188.7 lb/day, 1,573 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.79 tons/year. [District Rule 3.4/A-88-97c]
  - c. NOx emissions shall not exceed 672.4 lb/day, 5,604 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2.80 tons/year. [District Rule 3.4/A-88-97c]
  - d. SOx emissions shall not exceed 104.5 lb/day, 871 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.44 tons/year. [District Rule 3.4/A-88-97c]
  - e. PM10 emissions shall not exceed 50.2 lb/day, 418 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.21 tons/year. [District Rule 3.4/A-88-97c]
20. For the engine operating under P-15-98:
- a. VOC emissions shall not exceed 10.0 lb/day, 84 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/A-35-97c]
  - b. CO emissions shall not exceed 32.7 lb/day, 275 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.14 tons/year. [District Rule 3.4/A-35-97c]
  - c. NOx emissions shall not exceed 185.4 lb/day, 1,558 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.78 tons/year. [District Rule 3.4/A-35-97c]

- d. SOx emissions shall not exceed 11.2 lb/day, 94 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/A-35-97c]
  - e. PM10 emissions shall not exceed 10.0 lb/day, 84 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/A-35-97c]
21. For the engine operating under P-16-98:
- a. VOC emissions shall not exceed 5.7 lb/day, 47 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/A-34-97c]
  - b. CO emissions shall not exceed 8.8 lb/day, 73 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/A-34-97c]
  - c. NOx emissions shall not exceed 106.6 lb/day, 888 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.44 tons/year. [District Rule 3.4/A-34-97c]
  - d. SOx emissions shall not exceed 10.2 lb/day, 85 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/A-34-97c]
  - e. PM10 emissions shall not exceed 9.1 lb/day, 76 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/A-34-97c]
22. For the engine operating under P-17-98:
- a. VOC emissions shall not exceed 4.4lb/day, 40 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/A-157-97c]
  - b. CO emissions shall not exceed 10.0 lb/day, 80 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/A-157-97c]
  - c. NOx emissions shall not exceed 46.2 lb/day, 380 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.19 tons/year. [District Rule 3.4/A-157-97c]
  - d. SOx emissions shall not exceed 0.7 lb/day, 583 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/A-157-97c]
  - e. PM10 emissions shall not exceed 3.2 lb/day, 20 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/A-157-97c]
23. For the engine operating under P-31-98:
- a. VOC emissions shall not exceed 8.8 lb/day, 73 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/A-78-97c]
  - b. CO emissions shall not exceed 42.4 lb/day, 353 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.18 tons/year. [District Rule 3.4/A-78-97c]

- c. NOx emissions shall not exceed 158.7 lb/day, 1323 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.66 tons/year. [District Rule 3.4/A-78-97c]
  - d. SOx emissions shall not exceed 16.7 lb/day, 139 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/A-78-97c]
  - e. PM10 emissions shall not exceed 5.4 lb/day, 45 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/A-78-97c]
24. For the engine operating under P-32-98:
- a. VOC emissions shall not exceed 7.6 lb/day, 64 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/A-79-97c]
  - b. CO emissions shall not exceed 36.9 lb/day, 307 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.15 tons/year. [District Rule 3.4/A-79-97c]
  - c. NOx emissions shall not exceed 138.0 lb/day, 1,550 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.58 tons/year. [District Rule 3.4/A-79-97c]
  - d. SOx emissions shall not exceed 14.5 lb/day, 121 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/A-79-97c]
  - e. PM10 emissions shall not exceed 4.7 lb/day, 39 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/A-79-97c]
25. For the engine operating under P-32-99:
- a. VOC emissions shall not exceed 8.8 lb/day, 73 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/A-7-97c]
  - b. CO emissions shall not exceed 42.4 lb/day, 354 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.18 tons/year. [District Rule 3.4/A-7-97c]
  - c. NOx emissions shall not exceed 158.7 lb/day, 1,322 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.66 tons/year. [District Rule 3.4/A-7-97c]
  - d. SOx emissions shall not exceed 16.7 lb/day, 139 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/A-7-97c]
  - e. PM10 emissions shall not exceed 5.4 lb/day, 45 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/A-7-97c]
26. For the engine operating under P-88-99:
- a. VOC emissions shall not exceed 5.3 lb/day, 44 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-99-114]

- b. CO emissions shall not exceed 343.9 lb/day, 2,866 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.43 tons/year. [District Rule 3.4/C-99-114]
  - c. NOx emissions shall not exceed 978.8 lb/day, 8,157 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4.08 tons/year. [District Rule 3.4/C-99-114]
  - d. SOx emissions shall not exceed 137.4 lb/day, 1,145 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.57 tons/year. [District Rule 3.4/C-99-114]
  - e. PM10 emissions shall not exceed 26.0 lb/day, 217 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-99-114]
27. For the engine operating under P-1-00:
- a. VOC emissions shall not exceed 0.2 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-99-70]
  - b. CO emissions shall not exceed 19.6 lb/day, 163 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/C-99-70]
  - c. NOx emissions shall not exceed 153.0 lb/day, 1,275 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.64 tons/year. [District Rule 3.4/C-99-70]
  - d. SOx emissions shall not exceed 4.3 lb/day, 36 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-99-70]
  - e. PM10 emissions shall not exceed 7.4 lb/day, 62 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-99-70]
28. For the engine operating under P-2-00:
- a. VOC emissions shall not exceed 2.0 lb/day, 16 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-98-90]
  - b. CO emissions shall not exceed 74.1 lb/day, 617 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.31 tons/year. [District Rule 3.4/C-98-90]
  - c. NOx emissions shall not exceed 240.2 lb/day, 2,002 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.00 tons/year. [District Rule 3.4/C-98-90]
  - d. SOx emissions shall not exceed 34.6 lb/day, 288 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.14 tons/year. [District Rule 3.4/C-98-90]
  - e. PM10 emissions shall not exceed 22.3 lb/day, 186 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-98-90]
29. For the engine operating under P-71-00:

- a. VOC emissions shall not exceed 1.7 lb/day, 14 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-99-121]
  - b. CO emissions shall not exceed 29.5 lb/day, 246 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.12 tons/year. [District Rule 3.4/C-99-121]
  - c. NOx emissions shall not exceed 218.2 lb/day, 1,819 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.91 tons/year. [District Rule 3.4/C-99-121]
  - d. SOx emissions shall not exceed 15.5 lb/day, 129 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-99-121]
  - e. PM10 emissions shall not exceed 7.4 lb/day, 62 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-99-121]
30. For the engine operating under P-7-01:
- a. VOC emissions shall not exceed 1.7 lb/day, 14 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-99-120]
  - b. CO emissions shall not exceed 29.5 lb/day, 246 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.12 tons/year. [District Rule 3.4/C-99-120]
  - c. NOx emissions shall not exceed 218.2 lb/day, 1,819 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.91 tons/year. [District Rule 3.4/C-99-120]
  - d. SOx emissions shall not exceed 15.5 lb/day, 129 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-99-120]
  - e. PM10 emissions shall not exceed 7.4 lb/day, 62 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-99-120]
31. For the engine operating under P-8-01(a):
- a. VOC emissions shall not exceed 14.3 lb/day, 119 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-06-16]
  - b. CO emissions shall not exceed 50.0 lb/day, 417 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.21 tons/year. [District Rule 3.4/C-06-16]
  - c. NOx emissions shall not exceed 452.0 lb/day, 3,767 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.88 tons/year. [District Rule 3.4/C-06-16]
  - d. SOx emissions shall not exceed 7.3 lb/day, 61 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-06-16]
  - e. PM10 emissions shall not exceed 4.8 lb/day, 40 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-06-16]

32. For the engine operating under P-9-01(a):
- a. VOC emissions shall not exceed 2.6 lb/day, 22 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-06-15]
  - b. CO emissions shall not exceed 24.2 lb/day, 201 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.10 tons/year. [District Rule 3.4/C-06-15]
  - c. NOx emissions shall not exceed 70.3 lb/day, 586 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.29 tons/year. [District Rule 3.4/C-06-15]
  - d. SOx emissions shall not exceed 2.2 lb/day, 18 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-06-15]
  - e. PM10 emissions shall not exceed 3.4 lb/day, 28 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-06-15]
33. For the engine operating under P-108-01:
- a. VOC emissions shall not exceed 4.1 lb/day, 34 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-01-73]
  - b. CO emissions shall not exceed 10.9 lb/day, 91 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-01-73]
  - c. NOx emissions shall not exceed 24.8 lb/day, 207 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.10 tons/year. [District Rule 3.4/C-01-73]
  - d. SOx emissions shall not exceed 0.7 lb/day, 6 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-01-73]
  - e. PM10 emissions shall not exceed 3.6 lb/day, 30 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-01-73]
34. For the engine operating under P-109-01:
- a. VOC emissions shall not exceed 4.1 lb/day, 34 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-01-74]
  - b. CO emissions shall not exceed 10.9 lb/day, 91 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-01-74]
  - c. NOx emissions shall not exceed 24.8 lb/day, 207 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.10 tons/year. [District Rule 3.4/C-01-74]
  - d. SOx emissions shall not exceed 0.7 lb/day, 6 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-01-74]

- e. PM10 emissions shall not exceed 3.6 lb/day, 30 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-01-74]
35. For the engine operating under P-111-01:
- a. VOC emissions shall not exceed 8.4 lb/day, 70 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-01-12]
  - b. CO emissions shall not exceed 30.0 lb/day, 250 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.13 tons/year. [District Rule 3.4/C-01-12]
  - c. NOx emissions shall not exceed 318.3 lb/day, 2,652 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.33 tons/year. [District Rule 3.4/C-01-12]
  - d. SOx emissions shall not exceed 11.0 lb/day, 92 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-01-12]
  - e. PM10 emissions shall not exceed 7.2 lb/day, 60 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-01-12]
36. For the engine operating under P-120-01:
- a. VOC emissions shall not exceed 8.9 lb/day, 74 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-01-170]
  - b. CO emissions shall not exceed 25.5 lb/day, 212 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-01-170]
  - c. NOx emissions shall not exceed 245.3 lb/day, 2,044 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.02 tons/year. [District Rule 3.4/C-01-170]
  - d. SOx emissions shall not exceed 10.9 lb/day, 91 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-01-170]
  - e. PM10 emissions shall not exceed 5.3 lb/day, 44 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-01-170]
37. For the engine operating under P-17-02:
- a. VOC emissions shall not exceed 9.0 lb/day, 75 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-00-86]
  - b. CO emissions shall not exceed 76.4 lb/day, 637 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.32 tons/year. [District Rule 3.4/C-00-86]
  - c. NOx emissions shall not exceed 62.0 lb/day, 517 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.26 tons/year. [District Rule 3.4/C-00-86]

- d. SOx emissions shall not exceed 0.1 lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-00-86]
  - e. PM10 emissions shall not exceed 3.6 lb/day, 30 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-00-86]
38. For the engine operating under P-82-02:
- a. VOC emissions shall not exceed 1.8 lb/day, 15 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-00-173]
  - b. CO emissions shall not exceed 10.1 lb/day, 84 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-00-173]
  - c. NOx emissions shall not exceed 170.1 lb/day, 1,417 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.71 tons/year. [District Rule 3.4/C-00-173]
  - d. SOx emissions shall not exceed 4.8 lb/day, 40 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-00-173]
  - e. PM10 emissions shall not exceed 9.3 lb/day, 78 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-00-173]
39. For the engine operating under P-83-02:
- a. VOC emissions shall not exceed 1.6 lb/day, 14 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-93]
  - b. CO emissions shall not exceed 9.3 lb/day, 78 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-02-93]
  - c. NOx emissions shall not exceed 71.7 lb/day, 598 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.30 tons/year. [District Rule 3.4/C-02-93]
  - d. SOx emissions shall not exceed 6.6 lb/day, 55 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-02-93]
  - e. PM10 emissions shall not exceed 3.0 lb/day, 25 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-93]
40. For the engine operating under P-84-02:
- a. VOC emissions shall not exceed 0.8 lb/day, 7 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-01-201]
  - b. CO emissions shall not exceed 87.4 lb/day, 728 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.36 tons/year. [District Rule 3.4/C-01-201]

- c. NOx emissions shall not exceed 211.0 lb/day, 1,758 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.88 tons/year. [District Rule 3.4/C-01-201]
  - d. SOx emissions shall not exceed 31.2 lb/day, 260 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.13 tons/year. [District Rule 3.4/C-01-201]
  - e. PM10 emissions shall not exceed 3.8 lb/day, 32 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-01-201]
41. For the engine operating under P-114-02:
- a. VOC emissions shall not exceed 3.6 lb/day, 30 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-158]
  - b. CO emissions shall not exceed 12.1 lb/day, 100 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-02-158]
  - c. NOx emissions shall not exceed 54.0 lb/day, 450 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.22 tons/year. [District Rule 3.4/C-02-158]
  - d. SOx emissions shall not exceed 1.7 lb/day, 14 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-158]
  - e. PM10 emissions shall not exceed 2.9 lb/day, 24 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-158]
42. For the engine operating under P-63-03:
- a. VOC emissions shall not exceed 5.4 lb/day, 45 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-02-184]
  - b. CO emissions shall not exceed 12.7 lb/day, 106 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-02-184]
  - c. NOx emissions shall not exceed 123.9 lb/day, 1,032 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.52 tons/year. [District Rule 3.4/C-02-184]
  - d. SOx emissions shall not exceed 3.7 lb/day, 31 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-02-184]
  - e. PM10 emissions shall not exceed 3.2 lb/day, 27 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-184]
43. For the engine operating under P-102-03:
- a. VOC emissions shall not exceed 13.0 lb/day, 108 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-02-322]

- b. CO emissions shall not exceed 21.5 lb/day, 179 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-02-322]
  - c. NOx emissions shall not exceed 421.0 lb/day, 3,508 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.75 tons/year. [District Rule 3.4/C-02-322]
  - d. SOx emissions shall not exceed 11.6 lb/day, 97 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-02-322]
  - e. PM10 emissions shall not exceed 3.0 lb/day, 25 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-322]
44. For the engine operating under P-15-04:
- a. VOC emissions shall not exceed 15.4 lb/day, 128 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-03-251]
  - b. CO emissions shall not exceed 37.9 lb/day, 316 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.16 tons/year. [District Rule 3.4/C-03-251]
  - c. NOx emissions shall not exceed 377.5 lb/day, 3,146 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.57 tons/year. [District Rule 3.4/C-03-251]
  - d. SOx emissions shall not exceed 10.9 lb/day, 91 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-03-251]
  - e. PM10 emissions shall not exceed 3.0 lb/day, 25 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-03-251]
45. For the engine operating under P-74-05:
- a. VOC emissions shall not exceed 2.5 lb/day, 21 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-05-49]
  - b. CO emissions shall not exceed 13.2 lb/day, 110 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-05-49]
  - c. NOx emissions shall not exceed 81.8 lb/day, 682 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.34 tons/year. [District Rule 3.4/C-05-49]
  - d. SOx emissions shall not exceed 4.6 lb/day, 38 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-05-49]
  - e. PM10 emissions shall not exceed 2.5 lb/day, 21 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-05-49]
46. For the engine operating under P-38-05:

- a. VOC emissions shall not exceed 2.3 lb/day, 20 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-05-164]
  - b. CO emissions shall not exceed 7.9 lb/day, 66 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-05-164]
  - c. NOx emissions shall not exceed 61.4 lb/day, 512 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.26 tons/year. [District Rule 3.4/C-05-164]
  - d. SOx emissions shall not exceed 3.1 lb/day, 26 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-05-164]
  - e. PM10 emissions shall not exceed 2.3 lb/day, 20 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-05-164]
47. For the engine operating under P-115-03:
- a. VOC emissions shall not exceed 5.6 lb/day, 47 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-03-98]
  - b. CO emissions shall not exceed 16.0 lb/day, 133 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-03-98]
  - c. NOx emissions shall not exceed 227.7 lb/day, 1,897 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.95 tons/year. [District Rule 3.4/C-03-98]
  - d. SOx emissions shall not exceed 7.3 lb/day, 61 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-03-98]
  - e. PM10 emissions shall not exceed 3.2 lb/day, 27 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-03-98]
48. For the engine operating under P-117-03:
- a. VOC emissions shall not exceed 1.9 lb/day, 16 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-373]
  - b. CO emissions shall not exceed 36.7 lb/day, 306 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.15 tons/year. [District Rule 3.4/C-02-373]
  - c. NOx emissions shall not exceed 75.4 lb/day, 628 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.31 tons/year. [District Rule 3.4/C-02-373]
  - d. SOx emissions shall not exceed 2.0 lb/day, 17 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-373]
  - e. PM10 emissions shall not exceed 9.7 lb/day, 81 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-02-373]

49. For the engine operating under P-118-03:
- a. VOC emissions shall not exceed 1.2 lb/day, 10 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-03-164]
  - b. CO emissions shall not exceed 10.5 lb/day, 88 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-03-164]
  - c. NOx emissions shall not exceed 202.9 lb/day, 1,691 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.85 tons/year. [District Rule 3.4/C-03-164]
  - d. SOx emissions shall not exceed 7.4 lb/day, 62 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-03-164]
  - e. PM10 emissions shall not exceed 0.9 lb/day, 8 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-03-164]
50. For the engine operating under P-119-03:
- a. VOC emissions shall not exceed 1.9 lb/day, 16 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-372]
  - b. CO emissions shall not exceed 36.7 lb/day, 306 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.15 tons/year. [District Rule 3.4/C-02-372]
  - c. NOx emissions shall not exceed 75.4 lb/day, 628 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.31 tons/year. [District Rule 3.4/C-02-372]
  - d. SOx emissions shall not exceed 2.0 lb/day, 17 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-372]
  - e. PM10 emissions shall not exceed 9.7 lb/day, 81 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-02-372]
51. For the engine operating under P-120-03:
- a. VOC emissions shall not exceed 38.8 lb/day, 324 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.16 tons/year. [District Rule 3.4/C-03-99]
  - b. CO emissions shall not exceed 77.7 lb/day, 647 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.32 tons/year. [District Rule 3.4/C-03-99]
  - c. NOx emissions shall not exceed 931.7 lb/day, 7,765 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3.88 tons/year. [District Rule 3.4/C-03-99]
  - d. SOx emissions shall not exceed 28.5 lb/day, 237 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.12 tons/year. [District Rule 3.4/C-03-99]

- e. PM10 emissions shall not exceed 15.6 lb/day, 130 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-03-99]
52. For the engine operating under P-121-03:
- a. VOC emissions shall not exceed 9.0 lb/day, 75 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-03-100]
  - b. CO emissions shall not exceed 25.4 lb/day, 212 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-03-100]
  - c. NOx emissions shall not exceed 245.5 lb/day, 2,046 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.02 tons/year. [District Rule 3.4/C-03-100]
  - d. SOx emissions shall not exceed 10.9 lb/day, 91 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-03-100]
  - e. PM10 emissions shall not exceed 5.3 lb/day, 45 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-03-100]
53. For the engine operating under P-59-05:
- a. VOC emissions shall not exceed 1.5 lb/day, 12 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-05-175]
  - b. CO emissions shall not exceed 5.8 lb/day, 48 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-05-175]
  - c. NOx emissions shall not exceed 33.0 lb/day, 275 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.14 tons/year. [District Rule 3.4/C-05-175]
  - d. SOx emissions shall not exceed 1.4 lb/day, 12 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-05-175]
  - e. PM10 emissions shall not exceed 0.2 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-05-175]
54. For the engine operating under P-49-07:
- a. VOC emissions shall not exceed 2.4 lb/day, 20 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-07-62]
  - b. CO emissions shall not exceed 20.6 lb/day, 171 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-07-62]
  - c. NOx emissions shall not exceed 198.7 lb/day, 1,656 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.83 tons/year. [District Rule 3.4/C-07-62]

- d. SOx emissions shall not exceed 0.3 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-07-62]
  - e. PM10 emissions shall not exceed 2.6 lb/day, 21 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-07-62]
55. For the engine operating under P-50-07:
- a. VOC emissions shall not exceed 10.2 lb/day, 85 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-07-78]
  - b. CO emissions shall not exceed 41.2 lb/day, 343 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.17 tons/year. [District Rule 3.4/C-07-78]
  - c. NOx emissions shall not exceed 354.0 lb/day, 2,950 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.47 tons/year. [District Rule 3.4/C-07-78]
  - d. SOx emissions shall not exceed 0.4 lb/day, 4 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-07-78]
  - e. PM10 emissions shall not exceed 6.5 lb/day, 54 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-07-78]
56. For the engine operating under P-51-07:
- a. VOC emissions shall not exceed 1.2 lb/day, 10 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-07-80]
  - b. CO emissions shall not exceed 3.7 lb/day, 31 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-07-80]
  - c. NOx emissions shall not exceed 15.8 lb/day, 131 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-07-80]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-07-80]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-07-80]
57. For the engine operating under P-52-07:
- a. VOC emissions shall not exceed 25.5 lb/day, 213 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-07-84]
  - b. CO emissions shall not exceed 38.3 lb/day, 319 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.16 tons/year. [District Rule 3.4/C-07-84]

- c. NOx emissions shall not exceed 325.7 lb/day, 2,714 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.36 tons/year. [District Rule 3.4/C-07-84]
  - d. SOx emissions shall not exceed 0.4 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-07-84]
  - e. PM10 emissions shall not exceed 9.6 lb/day, 80 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-07-84]
58. For the engine operating under P-53-07:
- a. VOC emissions shall not exceed 25.5 lb/day, 213 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-07-85]
  - b. CO emissions shall not exceed 38.3 lb/day, 319 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.16 tons/year. [District Rule 3.4/C-07-85]
  - c. NOx emissions shall not exceed 325.7 lb/day, 2,714 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.36 tons/year. [District Rule 3.4/C-07-85]
  - d. SOx emissions shall not exceed 0.4 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-07-85]
  - e. PM10 emissions shall not exceed 9.6 lb/day, 80 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-07-85]
59. For the engine operating under P-59-07:
- a. VOC emissions shall not exceed 3.1 lb/day, 26 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-07-107]
  - b. CO emissions shall not exceed 46.0 lb/day, 384 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.19 tons/year. [District Rule 3.4/C-07-107]
  - c. NOx emissions shall not exceed 51.4 lb/day, 429 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.21 tons/year. [District Rule 3.4/C-07-107]
  - d. SOx emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-07-107]
  - e. PM10 emissions shall not exceed 2.3 lb/day, 19 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-07-107]
60. For the engine operating under P-2-09:
- a. VOC emissions shall not exceed 0.3 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and Neg. tons/year. [District Rule 3.4/C-08-110]

- b. CO emissions shall not exceed 3.7 lb/day, 31 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-08-110]
  - c. NOx emissions shall not exceed 14.5 lb/day, 121 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-08-110]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-08-110]
  - e. PM10 emissions shall not exceed 0.5 lb/day, 4 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-08-110]
61. For the engine operating under P-4-09:
- a. VOC emissions shall not exceed 1.9 lb/day, 16 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-08-232]
  - b. CO emissions shall not exceed 15.8 lb/day, 131 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-08-232]
  - c. NOx emissions shall not exceed 51.7 lb/day, 431 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.22 tons/year. [District Rule 3.4/C-08-232]
  - d. SOx emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-08-232]
  - e. PM10 emissions shall not exceed 1.6 lb/day, 13 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-08-232]
62. For the engine operating under P-16-09:
- a. VOC emissions shall not exceed 6.3 lb/day, 53 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-08-254]
  - b. CO emissions shall not exceed 39.6 lb/day, 330 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.17 tons/year. [District Rule 3.4/C-08-254]
  - c. NOx emissions shall not exceed 210.7 lb/day, 1,756 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.88 tons/year. [District Rule 3.4/C-08-254]
  - d. SOx emissions shall not exceed 0.3 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-08-254]
  - e. PM10 emissions shall not exceed 3.2 lb/day, 26 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-08-254]
63. For the engine operating under P-17-09:

- a. VOC emissions shall not exceed 0.7 lb/day, 6 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-16]
  - b. CO emissions shall not exceed 5.8 lb/day, 48 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-09-16]
  - c. NOx emissions shall not exceed 42.7 lb/day, 356 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.18 tons/year. [District Rule 3.4/C-09-16]
  - d. SOx emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-16]
  - e. PM10 emissions shall not exceed 0.6 lb/day, 5 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-16]
64. For the engine operating under P-54-09:
- a. VOC emissions shall not exceed 2.5 lb/day, 21 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-09-139]
  - b. CO emissions shall not exceed 19.8 lb/day, 165 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/C-09-139]
  - c. NOx emissions shall not exceed 197.4 lb/day, 1,645 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.82 tons/year. [District Rule 3.4/C-09-139]
  - d. SOx emissions shall not exceed 0.3 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-139]
  - e. PM10 emissions shall not exceed 2.5 lb/day, 21 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-09-139]
65. For the engine operating under P-66-09:
- a. VOC emissions shall not exceed 0.7 lb/day, 6 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-127]
  - b. CO emissions shall not exceed 10.7 lb/day, 89 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-09-127]
  - c. NOx emissions shall not exceed 18.0 lb/day, 150 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/C-09-127]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-127]
  - e. PM10 emissions shall not exceed 1.0 lb/day, 8 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-127]

66. For the engine operating under P-67-09:
- a. VOC emissions shall not exceed 0.8 lb/day, 7 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-128]
  - b. CO emissions shall not exceed 10.9 lb/day, 91 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-09-128]
  - c. NOx emissions shall not exceed 23.4 lb/day, 195 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.10 tons/year. [District Rule 3.4/C-09-128]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-128]
  - e. PM10 emissions shall not exceed 1.2 lb/day, 10 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-128]
67. For the engine operating under P-68-09:
- a. VOC emissions shall not exceed 2.4 lb/day, 20 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-09-129]
  - b. CO emissions shall not exceed 16.8 lb/day, 140 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-09-129]
  - c. NOx emissions shall not exceed 57.6 lb/day, 480 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.24 tons/year. [District Rule 3.4/C-09-129]
  - d. SOx emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-129]
  - e. PM10 emissions shall not exceed 1.9 lb/day, 16 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-09-129]
68. For the engine operating under P-69-09:
- a. VOC emissions shall not exceed 3.9 lb/day, 33 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-09-161]
  - b. CO emissions shall not exceed 14.6 lb/day, 122 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-09-161]
  - c. NOx emissions shall not exceed 201.0 lb/day, 1,675 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.84 tons/year. [District Rule 3.4/C-09-161]
  - d. SOx emissions shall not exceed 0.3 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-161]

- e. PM10 emissions shall not exceed 2.7 lb/day, 23 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-09-161]
69. For the engine operating under P-42-10:
- a. VOC emissions shall not exceed 0.8 lb/day, 7 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-10-17]
  - b. CO emissions shall not exceed 7.2 lb/day, 60 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-10-17]
  - c. NOx emissions shall not exceed 45.2 lb/day, 376 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.19 tons/year. [District Rule 3.4/C-10-17]
  - d. SOx emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-10-17]
  - e. PM10 emissions shall not exceed 1.0 lb/day, 8 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-10-17]
70. For the engine operating under P-44-10:
- a. VOC emissions shall not exceed 10.4 lb/day, 87 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-10-45]
  - b. CO emissions shall not exceed 43.6 lb/day, 363 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.18 tons/year. [District Rule 3.4/C-10-45]
  - c. NOx emissions shall not exceed 207.6 lb/day, 1,730 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.87 tons/year. [District Rule 3.4/C-10-45]
  - d. SOx emissions shall not exceed 0.3 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-10-45]
  - e. PM10 emissions shall not exceed 6.6 lb/day, 55 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-10-45]
71. For the engine operating under P-7-11:
- a. VOC emissions shall not exceed 3.2/day, 27 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01tons/year. [District Rule 3.4/C-10-105]
  - b. CO emissions shall not exceed 19.5 day, 162 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/C-10-105]
  - c. NOx emissions shall not exceed 84.3 lb/day, 703 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.35 tons/year. [District Rule 3.4/C-10-105]

- d. SOx emissions shall not exceed 0.2 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-10-105]
- e. PM10 emissions shall not exceed 2.9 lb/day, 24 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-10-105]

72. For the engine operating under P-72-11:

- a. VOC emissions shall not exceed 8.0 lb/day, 67 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-11-89]
- b. CO emissions shall not exceed 75.4 lb/day, 628 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.31 tons/year. [District Rule 3.4/C-11-89]
- c. NOx emissions shall not exceed 259.1 lb/day, 2,159 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.08 tons/year. [District Rule 3.4/C-11-89]
- d. SOx emissions shall not exceed 0.3 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-11-89]
- e. PM10 emissions shall not exceed 7.5 lb/day, 63 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-11-89]

73. For the engine operating under P-39-12:

- a. VOC emissions shall not exceed 3.8 lb/day, 32 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-12-89]
- b. CO emissions shall not exceed 25.3 lb/day, 211 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-12-89]
- c. NOx emissions shall not exceed 72.5 lb/day, 604 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.30 tons/year. [District Rule 3.4/C-12-89]
- d. SOx emissions shall not exceed 0.3 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-11-89]
- e. PM10 emissions shall not exceed 4.1 lb/day, 63 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-11-89]

74. For the engine operating under P-51-12:

- a. VOC emissions shall not exceed 9.7 lb/day, 81 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-12-125]
- b. CO emissions shall not exceed 13.4 lb/day, 112 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-12-125]

- c. NOx emissions shall not exceed 98.4 lb/day, 820 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.41 tons/year. [District Rule 3.4/C-12-125]
- d. SOx emissions shall not exceed 0.2 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-12-125]
- e. PM10 emissions shall not exceed 1.1 lb/day, 9 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-12-125]

75. For the engine operating under P-52-12:

- a. VOC emissions shall not exceed 0.8 lb/day, 7 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-12-126]
- b. CO emissions shall not exceed 10.9 lb/day, 91 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-12-126]
- c. NOx emissions shall not exceed 23.4 lb/day, 195 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.10 tons/year. [District Rule 3.4/C-12-126]
- d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-12-126]
- e. PM10 emissions shall not exceed 1.2 lb/day, 10 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-12-126]

76. For the engine operating under P-55-12:

- a. VOC emissions shall not exceed 2.0 lb/day, 16 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-12-129]
- b. CO emissions shall not exceed 11.0 lb/day, 92 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-12-129]
- c. NOx emissions shall not exceed 67.6 lb/day, 563 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.28 tons/year. [District Rule 3.4/C-12-129]
- d. SOx emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-12-129]
- e. PM10 emissions shall not exceed 2.0 lb/day, 16 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-12-129]

77. For the engine operating under P-56-12:

- a. VOC emissions shall not exceed 1.8 lb/day, 15 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-12-130]

- b. CO emissions shall not exceed 14.3 lb/day, 119 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-12-130]
- c. NOx emissions shall not exceed 53.0 lb/day, 441 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.22 tons/year. [District Rule 3.4/C-12-130]
- d. SOx emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-12-130]
- e. PM10 emissions shall not exceed 2.2 lb/day, 19 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-12-130]

78. For the engine operating under P-4-13:

- a. VOC emissions shall not exceed 5.8 lb/day, 48 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-13-06]
- b. CO emissions shall not exceed 48.2 lb/day, 401 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.20 tons/year. [District Rule 3.4/C-13-06]
- c. NOx emissions shall not exceed 25.6 lb/day, 2,146 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.07 tons/year. [District Rule 3.4/C-13-06]
- d. SOx emissions shall not exceed 0.4 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-13-06]
- e. PM10 emissions shall not exceed 3.9 lb/day, 32 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-13-06]

**A2. Emergency Natural Gas Fired Internal Combustion Engines**

1. For the engine operating under P-108-95(a):

- a. VOC emissions shall not exceed 3.0 lb/day, 25 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-311]
- b. CO emissions shall not exceed 375.9 lb/day, 3,132 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.57 tons/year. [District Rule 3.4/C-02-311]
- c. NOx emissions shall not exceed 223.3 lb/day, 1,861 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.93 tons/year. [District Rule 3.4/C-02-311]
- d. SOx emissions shall not exceed 0.1 lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-311]
- e. PM10 emissions shall not exceed 1.0 lb/day, 8 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-311]

2. For the engine operating under P-109-95(a):

- a. VOC emissions shall not exceed 0.6 lb/day, 5 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-314]
  - b. CO emissions shall not exceed 79.5 lb/day, 662 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.33 tons/year. [District Rule 3.4/C-02-314]
  - c. NOx emissions shall not exceed 47.2 lb/day, 393 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.20tons/year. [District Rule 3.4/C-02-314]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-314]
  - e. PM10 emissions shall not exceed 0.2 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-314]
3. For the engine operating under P-110-95(a):
- a. VOC emissions shall not exceed 1.9 lb/day, 16 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-303]
  - b. CO emissions shall not exceed 241.9 lb/day, 2,016 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.01 tons/year. [District Rule 3.4/C-02-303]
  - c. NOx emissions shall not exceed 143.7 lb/day, 1,198 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.60 tons/year. [District Rule 3.4/C-02-303]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-303]
  - e. PM10 emissions shall not exceed 0.6 lb/day, 5 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-303]
4. For the engine operating under P-112-95(a):
- a. VOC emissions shall not exceed 0.3 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-296]
  - b. CO emissions shall not exceed 35.3 lb/day, 294 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.15 tons/year. [District Rule 3.4/C-02-296]
  - c. NOx emissions shall not exceed 21.0 lb/day, 175 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-02-296]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-296]
  - e. PM10 emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-296]

5. For the engine operating under P-113-95(a):
  - a. VOC emissions shall not exceed 0.4 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-306]
  - b. CO emissions shall not exceed 46.0 lb/day, 383 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.19 tons/year. [District Rule 3.4/C-02-306]
  - c. NOx emissions shall not exceed 27.3 lb/day, 228 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-02-306]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-306]
  - e. PM10 emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-306]
6. For the engine operating under P-114-95(a):
  - a. VOC emissions shall not exceed 0.6 lb/day, 5 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-307]
  - b. CO emissions shall not exceed 71.4 lb/day, 595 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.30 tons/year. [District Rule 3.4/C-02-307]
  - c. NOx emissions shall not exceed 42.4 lb/day, 354 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.18 tons/year. [District Rule 3.4/C-02-307]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-307]
  - e. PM10 emissions shall not exceed 0.2 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-307]
7. For the engine operating under P-117-95(a):
  - a. VOC emissions shall not exceed 0.4 lb/day, 4 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-318]
  - b. CO emissions shall not exceed 53.6 lb/day, 446 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.22 tons/year. [District Rule 3.4/C-02-318]
  - c. NOx emissions shall not exceed 31.8 lb/day, 265 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.13 tons/year. [District Rule 3.4/C-02-318]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-318]

- e. PM10 emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-318]
8. For the engine operating under P-118-95(a):
- a. VOC emissions shall not exceed 0.4 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-308]
  - b. CO emissions shall not exceed 46.0 lb/day, 383 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.19 tons/year. [District Rule 3.4/C-02-308]
  - c. NOx emissions shall not exceed 27.3 lb/day, 228 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-02-308]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-308]
  - e. PM10 emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-308]
9. For the engine operating under P-119-95(a):
- a. VOC emissions shall not exceed 0.4 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-302]
  - b. CO emissions shall not exceed 52.2 lb/day, 435 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.22 tons/year. [District Rule 3.4/C-02-302]
  - c. NOx emissions shall not exceed 31.0 lb/day, 259 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.13 tons/year. [District Rule 3.4/C-02-302]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-302]
  - e. PM10 emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-302]
10. For the engine operating under P-120-95(a):
- a. VOC emissions shall not exceed 0.3 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-317]
  - b. CO emissions shall not exceed 35.3 lb/day, 294 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.15 tons/year. [District Rule 3.4/C-02-317]
  - c. NOx emissions shall not exceed 21.0 lb/day, 175 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-02-317]

- d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-317]
  - e. PM10 emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-317]
11. For the engine operating under P-121-95(a):
- a. VOC emissions shall not exceed 0.4 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-283]
  - b. CO emissions shall not exceed 46.0 lb/day, 383 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.19 tons/year. [District Rule 3.4/C-02-283]
  - c. NOx emissions shall not exceed 27.3 lb/day, 228 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-02-283]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-283]
  - e. PM10 emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-283]
12. For the engine operating under P-122-95(a):
- a. VOC emissions shall not exceed 0.4 lb/day, 4 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-288]
  - b. CO emissions shall not exceed 54.0 lb/day, 450 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.23 tons/year. [District Rule 3.4/C-02-288]
  - c. NOx emissions shall not exceed 32.1 lb/day, 267 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.13 tons/year. [District Rule 3.4/C-02-288]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-288]
  - e. PM10 emissions shall not exceed 0.1 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-288]
13. For the engine operating under P-123-95(a):
- a. VOC emissions shall not exceed 1.2 lb/day, 10 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-292]
  - b. CO emissions shall not exceed 146.9 lb/day, 1,224 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.61 tons/year. [District Rule 3.4/C-02-292]

- c. NOx emissions shall not exceed 87.3 lb/day, 727 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.36 tons/year. [District Rule 3.4/C-02-292]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-292]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-292]
14. For the engine operating under P-124-95(a):
- a. VOC emissions shall not exceed 1.0 lb/day, 8 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-321]
  - b. CO emissions shall not exceed 125.9 lb/day, 1,049 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.52 tons/year. [District Rule 3.4/C-02-321]
  - c. NOx emissions shall not exceed 74.8 lb/day, 623 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.31 tons/year. [District Rule 3.4/C-02-321]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-321]
  - e. PM10 emissions shall not exceed 0.3 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-321]
15. For the engine operating under P-125-95(a):
- a. VOC emissions shall not exceed 0.8 lb/day, 7 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-287]
  - b. CO emissions shall not exceed 106.2 lb/day, 885 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.44 tons/year. [District Rule 3.4/C-02-287]
  - c. NOx emissions shall not exceed 63.1 lb/day, 526 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.26 tons/year. [District Rule 3.4/C-02-287]
  - d. SOx emissions shall not exceed negligible lb/day, negligible lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-287]
  - e. PM10 emissions shall not exceed 0.3 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-287]
16. For the engine operating under P-18-98:
- a. VOC emissions shall not exceed 3.1 lb/day, 20 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/A-133-97c]

- b. CO emissions shall not exceed 7.0 lb/day, 60 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/A-133-97c]
  - c. NOx emissions shall not exceed 28.9 lb/day, 240 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.12 tons/year. [District Rule 3.4/A-133-97c]
  - d. SOx emissions shall not exceed 0.2 lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/A-133-97c]
  - e. PM10 emissions shall not exceed 0.2 lb/day, 11lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/A-133-97c]
17. For the engine operating under P-61-00:
- a. VOC emissions shall not exceed 6.6 lb/day, 55 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-00-105]
  - b. CO emissions shall not exceed 163.9 lb/day, 1,366 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.68 tons/year. [District Rule 3.4/C-00-105]
  - c. NOx emissions shall not exceed 9.4 lb/day, 79 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-00-105]
  - d. SOx emissions shall not exceed 1.3 lb/day, 11 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-00-105]
  - e. PM10 emissions shall not exceed 0.9 lb/day, 8 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-00-105]
18. For the engine operating under P-3-09:
- a. VOC emissions shall not exceed 29.7 lb/day, 248 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.12 tons/year. [District Rule 3.4/C-08-193]
  - b. CO emissions shall not exceed 81.5 lb/day, 679 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.34 tons/year. [District Rule 3.4/C-08-193]
  - c. NOx emissions shall not exceed 17.9 lb/day, 149 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-08-193]
  - d. SOx emissions shall not exceed 2.4 lb/day, 20 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-08-193]
  - e. PM10 emissions shall not exceed 1.8 lb/day, 15 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-08-193]
19. For the engine operating under P-43-10

- a. VOC emissions shall not exceed 0.2 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-10-38]
- b. CO emissions shall not exceed 5.2 lb/day, 43 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-10-38]
- c. NOx emissions shall not exceed 0.7 lb/day, 6 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-10-38]
- d. SOx emissions shall not exceed 0.3 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-10-38]
- e. PM10 emissions shall not exceed 0.2 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-10-38]

**A3. Portable Internal Combustion Engines**

1. For the engine operating under P-50-99(a):

- a. VOC emissions shall not exceed 7.1 lb/day, 59 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-06-17]
- b. CO emissions shall not exceed 18.9 lb/day, 158 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/C-06-17]
- c. NOx emissions shall not exceed 87.8 lb/day, 732 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.37 tons/year. [District Rule 3.4/C-06-17]
- d. SOx emissions shall not exceed 1.1 lb/day, 10 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-06-17]
- e. PM10 emissions shall not exceed 6.2 lb/day, 52 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-06-17]

2. For the engine operating under P-51-99(a):

- a. VOC emissions shall not exceed 7.1 lb/day, 59 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-06-18]
- b. CO emissions shall not exceed 18.9 lb/day, 158 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/C-06-18]
- c. NOx emissions shall not exceed 87.8 lb/day, 732 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.37 tons/year. [District Rule 3.4/C-06-18]
- d. SOx emissions shall not exceed 1.1 lb/day, 10 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-06-18]

- e. PM10 emissions shall not exceed 6.2 lb/day, 52 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-06-18]
3. For the engine operating under P-52-99(a):
- a. VOC emissions shall not exceed 7.1 lb/day, 59 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-06-19]
  - b. CO emissions shall not exceed 18.9 lb/day, 158 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/C-06-19]
  - c. NOx emissions shall not exceed 87.8 lb/day, 732 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.37 tons/year. [District Rule 3.4/C-06-19]
  - d. SOx emissions shall not exceed 1.1 lb/day, 10 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-06-19]
  - e. PM10 emissions shall not exceed 6.2 lb/day, 52 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-06-19]
4. For the engine operating under P-86-01:
- a. VOC emissions shall not exceed 6.6 lb/day, 55 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-00-145]
  - b. CO emissions shall not exceed 13.2 lb/day, 110 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-00-145]
  - c. NOx emissions shall not exceed 87.2 lb/day, 727 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.36 tons/year. [District Rule 3.4/C-00-145]
  - d. SOx emissions shall not exceed 3.0 lb/day, 25 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-00-145]
  - e. PM10 emissions shall not exceed 1.6 lb/day, 14 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-00-145]
5. For the engine operating under P-87-01:
- a. VOC emissions shall not exceed 6.6 lb/day, 55 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-00-146]
  - b. CO emissions shall not exceed 13.2 lb/day, 110 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-00-146]
  - c. NOx emissions shall not exceed 87.2 lb/day, 727 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.36 tons/year. [District Rule 3.4/C-00-146]
  - d. SOx emissions shall not exceed 3.0 lb/day, 25 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-00-146]

- e. PM10 emissions shall not exceed 1.6 lb/day, 14 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-00-146]

**A4. Boilers and Water Heaters**

- 1. For the boiler operating under P-44-96:
  - a. VOC emissions shall not exceed 0.4 lb/day, 33 lb/1<sup>st</sup> calendar quarter, 34 lb/2<sup>nd</sup> calendar quarter, 34 lb/3<sup>rd</sup> calendar quarter, 34 lb/4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/A-43-96]
  - b. CO emissions shall not exceed 1.6 lb/day, 145 lb/1<sup>st</sup> calendar quarter, 147 lb/2<sup>nd</sup> calendar quarter, 148 lb/3<sup>rd</sup> calendar quarter, 148 lb/4<sup>th</sup> calendar quarter, and 0.29 tons/year. [District Rule 3.4/A-43-96]
  - c. NOx emissions shall not exceed 7.7 lb/day, 691 lb/1<sup>st</sup> calendar quarter, 699 lb/2<sup>nd</sup> calendar quarter, 707 lb/3<sup>rd</sup> calendar quarter, 707 lb/4<sup>th</sup> calendar quarter, and 1.40 tons/year. [District Rule 3.4/A-43-96]
  - d. SOx emissions shall not exceed 0.1 lb/day, 5 lb/1<sup>st</sup> calendar quarter, 5 lb/2<sup>nd</sup> calendar quarter, 5 lb/3<sup>rd</sup> calendar quarter, 5 lb/4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/A-43-96]
  - e. PM10 emissions shall not exceed 0.9 lb/day, 83 lb/1<sup>st</sup> calendar quarter, 84 lb/2<sup>nd</sup> calendar quarter, 85 lb/3<sup>rd</sup> calendar quarter, 85 lb/4<sup>th</sup> calendar quarter, and 0.17 tons/year. [District Rule 3.4/A-43-96o]
- 2. For the boiler operating under P-45-96:
  - a. VOC emissions shall not exceed 0.2 lb/day, 14 lb/1<sup>st</sup> calendar quarter, 15 lb/2<sup>nd</sup> calendar quarter, 15 lb/3<sup>rd</sup> calendar quarter, 15 lb/4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/A-44-96]
  - b. CO emissions shall not exceed 0.7 lb/day, 62 lb/1<sup>st</sup> calendar quarter, 63 lb/2<sup>nd</sup> calendar quarter, 63 lb/3<sup>rd</sup> calendar quarter, 63 lb/4<sup>th</sup> calendar quarter, and 0.13 tons/year. [District Rule 3.4/A-44-96]
  - c. NOx emissions shall not exceed 3.3 lb/day, 297 lb/1<sup>st</sup> calendar quarter, 300 lb/2<sup>nd</sup> calendar quarter, 304 lb/3<sup>rd</sup> calendar quarter, 304 lb/4<sup>th</sup> calendar quarter, and 0.60 tons/year. [District Rule 3.4/A-44-96]
  - d. SOx emissions shall not exceed negligible lb/day, 2 lb/1<sup>st</sup> calendar quarter, 2 lb/2<sup>nd</sup> calendar quarter, 2 lb/3<sup>rd</sup> calendar quarter, 2 lb/4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/A-44-96]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 36 lb/1<sup>st</sup> calendar quarter, 36 lb/2<sup>nd</sup> calendar quarter, 37 lb/3<sup>rd</sup> calendar quarter, 37 lb/4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/A-44-96]

3. For the boiler operating under P-47-96:
  - a. VOC emissions shall not exceed 0.4 lb/day, 39 lb/1<sup>st</sup> calendar quarter, 39 lb/2<sup>nd</sup> calendar quarter, 40 lb/3<sup>rd</sup> calendar quarter, 40 lb/4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/A-46-96]
  - b. CO emissions shall not exceed 1.9 lb/day, 170 lb/1<sup>st</sup> calendar quarter, 172 lb/2<sup>nd</sup> calendar quarter, 174 lb/3<sup>rd</sup> calendar quarter, 174 lb/4<sup>th</sup> calendar quarter, and 0.34 tons/year. [District Rule 3.4/A-46-96]
  - c. NOx emissions shall not exceed 9.0 lb/day, 810 lb/1<sup>st</sup> calendar quarter, 819 lb/2<sup>nd</sup> calendar quarter, 828 lb/3<sup>rd</sup> calendar quarter, 828 lb/4<sup>th</sup> calendar quarter, and 1.64 tons/year. [District Rule 3.4/A-46-96]
  - d. SOx emissions shall not exceed 0.1 lb/day, 5 lb/1<sup>st</sup> calendar quarter, 5 lb/2<sup>nd</sup> calendar quarter, 5 lb/3<sup>rd</sup> calendar quarter, 5 lb/4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/A-46-96]
  - e. PM10 emissions shall not exceed 1.1 lb/day, 97 lb/1<sup>st</sup> calendar quarter, 98 lb/2<sup>nd</sup> calendar quarter, 99 lb/3<sup>rd</sup> calendar quarter, 99 lb/4<sup>th</sup> calendar quarter, and 0.20 tons/year. [District Rule 3.4/A-46-96]
4. For the boiler operating under P-48-96:
  - a. VOC emissions shall not exceed 0.1 lb/day, 13 lb/1<sup>st</sup> calendar quarter, 13 lb/2<sup>nd</sup> calendar quarter, 13 lb/3<sup>rd</sup> calendar quarter, 13 lb/4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/A-47-96]
  - b. CO emissions shall not exceed 0.6 lb/day, 54 lb/1<sup>st</sup> calendar quarter, 55 lb/2<sup>nd</sup> calendar quarter, 55 lb/3<sup>rd</sup> calendar quarter, 55 lb/4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/A-47-96]
  - c. NOx emissions shall not exceed 2.9 lb/day, 259 lb/1<sup>st</sup> calendar quarter, 262 lb/2<sup>nd</sup> calendar quarter, 265 lb/3<sup>rd</sup> calendar quarter, 265 lb/4<sup>th</sup> calendar quarter, and 0.52 tons/year. [District Rule 3.4/A-47-96]
  - d. SOx emissions shall not exceed negligible lb/day, 2 lb/1<sup>st</sup> calendar quarter, 2 lb/2<sup>nd</sup> calendar quarter, 2 lb/3<sup>rd</sup> calendar quarter, 2 lb/4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/A-47-96]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 32 lb/1<sup>st</sup> calendar quarter, 32 lb/2<sup>nd</sup> calendar quarter, 32 lb/3<sup>rd</sup> calendar quarter, 32 lb/4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/A-47-96]
5. For the boiler operating under P-54-96:

- a. VOC emissions shall not exceed 0.2 lb/day, 17 lb/1<sup>st</sup> calendar quarter, 17 lb/2<sup>nd</sup> calendar quarter, 17 lb/3<sup>rd</sup> calendar quarter, 17 lb/4<sup>th</sup> calendar quarter, and 0.03 tons/year. [Rule 3.4/A-53-96]
  - b. CO emissions shall not exceed 0.8 lb/day, 68 lb/1<sup>st</sup> calendar quarter, 69 lb/2<sup>nd</sup> calendar quarter, 70 lb/3<sup>rd</sup> calendar quarter, 71 lb/4<sup>th</sup> calendar quarter, and 0.14 tons/year. [Rule 3.4/A-53-96]
  - c. NOx emissions shall not exceed 3.6 lb/day, 324 lb/1<sup>st</sup> calendar quarter, 328 lb/2<sup>nd</sup> calendar quarter, 331 lb/3<sup>rd</sup> calendar quarter, 331 lb/4<sup>th</sup> calendar quarter, and 0.66 tons/year. [Rule 3.4/A-53-96]
  - d. SOx emissions shall not exceed negligible lb/day, 2 lb/1<sup>st</sup> calendar quarter, 2 lb/2<sup>nd</sup> calendar quarter, 2 lb/3<sup>rd</sup> calendar quarter, 2 lb/4<sup>th</sup> calendar quarter, and negligible tons/year. [Rule 3.4/A-53-96]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 39 lb/1<sup>st</sup> calendar quarter, 39 lb/2<sup>nd</sup> calendar quarter, 40 lb/3<sup>rd</sup> calendar quarter, 40 lb/4<sup>th</sup> calendar quarter, and 0.08 tons/year. [Rule 3.4/A-53-96]
6. For the boiler operating under P-62-96:
- a. VOC emissions shall not exceed 0.3 lb/day, 23 lb/1<sup>st</sup> calendar quarter, 24 lb/2<sup>nd</sup> calendar quarter, 24 lb/3<sup>rd</sup> calendar quarter, 24 lb/4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/A-61-96]
  - b. CO emissions shall not exceed 1.1 lb/day, 101 lb/1<sup>st</sup> calendar quarter, 102 lb/2<sup>nd</sup> calendar quarter, 103 lb/3<sup>rd</sup> calendar quarter, 103 lb/4<sup>th</sup> calendar quarter, and 0.20 tons/year. [District Rule 3.4/A-61-96]
  - c. NOx emissions shall not exceed 5.3 lb/day, 480 lb/1<sup>st</sup> calendar quarter, 485 lb/2<sup>nd</sup> calendar quarter, 490 lb/3<sup>rd</sup> calendar quarter, 490 lb/4<sup>th</sup> calendar quarter, and 0.97 tons/year. [District Rule 3.4/A-61-96]
  - d. SOx emissions shall not exceed negligible lb/day, 3 lb/1<sup>st</sup> calendar quarter, 3 lb/2<sup>nd</sup> calendar quarter, 3 lb/3<sup>rd</sup> calendar quarter, 3 lb/4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/A-61-96]
  - e. PM10 emissions shall not exceed 0.6 lb/day, 58 lb/1<sup>st</sup> calendar quarter, 58 lb/2<sup>nd</sup> calendar quarter, 59 lb/3<sup>rd</sup> calendar quarter, 59 lb/4<sup>th</sup> calendar quarter, and 0.12 tons/year. [District Rule 3.4/A-61-96]
7. For the boiler operating under P-67-98:
- a. VOC emissions shall not exceed 0.9 lb/day, 81 lb/1<sup>st</sup> calendar quarter, 82 lb/2<sup>nd</sup> calendar quarter, 83 lb/3<sup>rd</sup> calendar quarter, 83 lb/4<sup>th</sup> calendar quarter, and 0.2 tons/year. [District Rule 3.4/C-98-14]

- b. CO emissions shall not exceed 92.1 lb/day, 8,292 lb/1<sup>st</sup> calendar quarter, 8,384 lb/2<sup>nd</sup> calendar quarter, 8,476 lb/3<sup>rd</sup> calendar quarter, 8,476 lb/4<sup>th</sup> calendar quarter, and 16.80 tons/year. [District Rule 3.4/C-98-14]
  - c. NOx emissions shall not exceed 11.4 lb/day, 1,022 lb/1<sup>st</sup> calendar quarter, 1,033 lb/2<sup>nd</sup> calendar quarter, 1,044 lb/3<sup>rd</sup> calendar quarter, 1,044 lb/4<sup>th</sup> calendar quarter, and 2.1 tons/year. [District Rule 3.4/C-98-14]
  - d. SOx emissions shall not exceed 0.4 lb/day, 38 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.1 tons/year. [District Rule 3.4/C-98-14]
  - e. PM10 emissions shall not exceed 4.3 lb/day, 388 lb/1<sup>st</sup> calendar quarter, 393 lb/2<sup>nd</sup> calendar quarter, 397 lb/3<sup>rd</sup> calendar quarter, 397 lb/4<sup>th</sup> calendar quarter, and 0.8 tons/year. [District Rule 3.4/C-98-14]
8. For the boiler operating under P-3-00:
- a. VOC emissions shall not exceed 0.5 lb/day, 43 lb/1<sup>st</sup> calendar quarter, 44 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-99-107]
  - b. CO emissions shall not exceed 8.0 lb/day, 664 lb/1<sup>st</sup> calendar quarter, 672 lb/2<sup>nd</sup> calendar quarter, 679 lb/3<sup>rd</sup> calendar quarter, 679 lb/4<sup>th</sup> calendar quarter and 1.35 tons/year. [District Rule 3.4/C-98-107]
  - c. NOx emissions shall not exceed 9.6 lb/day, 791 lb/1<sup>st</sup> calendar quarter, 800 lb/2<sup>nd</sup> calendar quarter, 808 lb/3<sup>rd</sup> calendar quarter, 808 lb/4<sup>th</sup> calendar quarter, and 1.6 tons/year. [District Rule 3.4/C-98-107]
  - d. SOx emissions shall not exceed 0.1 lb/day, 5 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-98-107]
  - e. PM10 emissions shall not exceed 0.7 lb/day, 60 lb/1<sup>st</sup> calendar quarter, 61 lb/2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter and 0.12 tons/year. [District Rule 3.4/C-98-107]
9. For the boiler operating under P-5-00:
- a. VOC emissions shall not exceed 0.1 lb/day, 12 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-98-188]
  - b. CO emissions shall not exceed 0.8 lb/day, 69 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter and 0.14 tons/year. [District Rule 3.4/C-98-188]
  - c. NOx emissions shall not exceed 3.6 lb/day, 328 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.66 tons/year. [District Rule 3.4/C-98-188]
  - d. SOx emissions shall not exceed negligible lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-98-188]

- e. PM10 emissions shall not exceed 0.4 lb/day, 39 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter and 0.08 tons/year. [District Rule 3.4/C-98-188]
10. For the boiler operating under P-52-00:
- a. VOC emissions shall not exceed 0.3 lb/day, 24 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-00-176]
  - b. CO emissions shall not exceed 1.7 lb/day, 150 lb/1<sup>st</sup> calendar quarter, 152 lb/2<sup>nd</sup> calendar quarter, 154 lb/3<sup>rd</sup> calendar quarter, 154 lb/4<sup>th</sup> calendar quarter and 0.31 tons/year. [District Rule 3.4/C-00-176]
  - c. NOx emissions shall not exceed 6.7 lb/day, 602 lb/1<sup>st</sup> calendar quarter, 608 lb/2<sup>nd</sup> calendar quarter, 615 lb/3<sup>rd</sup> calendar quarter, 615 lb/4<sup>th</sup> calendar quarter, and 1.22 tons/year. [District Rule 3.4/C-00-176]
  - d. SOx emissions shall not exceed negligible lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-00-176]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 33 lb/1<sup>st</sup> calendar quarter, 33 lb/2<sup>nd</sup> calendar quarter, 34 lb/3<sup>rd</sup> calendar quarter, 34 lb/4<sup>th</sup> calendar quarter and 0.07 tons/year. [District Rule 3.4/C-00-176]
11. For the boiler operating under P-54-00(a):
- a. VOC emissions shall not exceed 0.4 lb/day, 36 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-10-93]
  - b. CO emissions shall not exceed 3.2 lb/day, 287 lb/1<sup>st</sup> calendar quarter, 290 lb/2<sup>nd</sup> calendar quarter, 293 lb/3<sup>rd</sup> calendar quarter, 293 lb/4<sup>th</sup> calendar quarter and 0.58 tons/year. [District Rule 3.4/C-10-93]
  - c. NOx emissions shall not exceed 2.6 lb/day, 236 lb/1<sup>st</sup> calendar quarter, 238 lb/2<sup>nd</sup> calendar quarter, 241 lb/3<sup>rd</sup> calendar quarter, 241 lb/4<sup>th</sup> calendar quarter, and 0.48 tons/year. [District Rule 3.4/C-10-93]
  - d. SOx emissions shall not exceed negligible lb/day, 4 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-10-93]
  - e. PM10 emissions shall not exceed 0.5 lb/day, 49 lb/1<sup>st</sup> calendar quarter, 50 lb/2<sup>nd</sup> calendar quarter, 50 lb/3<sup>rd</sup> calendar quarter, 50 lb/4<sup>th</sup> calendar quarter and 0.10 tons/year. [District Rule 3.4/C-10-93]
  - f. The Permit Holder shall not release or discharge into the atmosphere particulate matter in excess of 0.01 grains per cubic foot of exhaust as calculated at standard conditions. [District Rule 2.11, 2.12 and 3.4/C-10-93]
12. For the boiler operating under P-55-00:

- a. VOC emissions shall not exceed 0.1 lb/day, 13 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.03 tons/year. [District Rule 3.4/C-98-75]
  - b. CO emissions shall not exceed 0.8 lb/day, 69 lb/1<sup>st</sup> calendar quarter, 70 lb/2<sup>nd</sup> calendar quarter, 71 lb/3<sup>rd</sup> calendar quarter, 71 lb/4<sup>th</sup> calendar quarter and 0.14 tons/year. [District Rule 3.4/C-98-75]
  - c. NOx emissions shall not exceed 3.7 lb/day, 330 lb/1<sup>st</sup> calendar quarter, 334 lb/2<sup>nd</sup> calendar quarter, 338 lb/3<sup>rd</sup> calendar quarter, 338 lb/4<sup>th</sup> calendar quarter, and 0.67 tons/year. [District Rule 3.4/C-98-75]
  - d. SOx emissions shall not exceed 0.02 lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-98-75]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 40 lb/1<sup>st</sup> calendar quarter, 40 lb/2<sup>nd</sup> calendar quarter, 41 lb/3<sup>rd</sup> calendar quarter, 41 lb/4<sup>th</sup> calendar quarter and 0.08 tons/year. [District Rule 3.4/C-98-75]
13. For the boiler operating under P-67-00(a):
- a. VOC emissions shall not exceed 0.3 lb/day, 28 lb/1<sup>st</sup> calendar quarter, 29 lb/2<sup>nd</sup> calendar quarter, 29 lb/3<sup>rd</sup> calendar quarter, 29 lb/4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-08-61]
  - b. CO emissions shall not exceed 4.8 lb/day, 433 lb/1<sup>st</sup> calendar quarter, 438 lb/2<sup>nd</sup> calendar quarter, 443 lb/3<sup>rd</sup> calendar quarter, 443 lb/4<sup>th</sup> calendar quarter and 0.88 tons/year. [District Rule 3.4/C-08-61]
  - c. NOx emissions shall not exceed 5.7 lb/day, 516 lb/1<sup>st</sup> calendar quarter, 522 lb/2<sup>nd</sup> calendar quarter, 527 lb/3<sup>rd</sup> calendar quarter, 527 lb/4<sup>th</sup> calendar quarter, and 1.05 tons/year. [District Rule 3.4/C-08-61]
  - d. SOx emissions shall not exceed negligible lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-08-61]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 39 lb/1<sup>st</sup> calendar quarter, 40 lb/2<sup>nd</sup> calendar quarter, 40 lb/3<sup>rd</sup> calendar quarter, 40 lb/4<sup>th</sup> calendar quarter and 0.08 tons/year. [District Rule 3.4/C-08-61]
14. For the boiler operating under P-89-00:
- a. VOC emissions shall not exceed 1.7 lb/day, 154 lb/1<sup>st</sup> calendar quarter, 156 lb/2<sup>nd</sup> calendar quarter, 158 lb/3<sup>rd</sup> calendar quarter, 158 lb/4<sup>th</sup> calendar quarter, and 0.31 tons/year. [District Rule 3.4/C-00-41]
  - b. CO emissions shall not exceed 98.2 lb/day, 8,380 lb/1<sup>st</sup> calendar quarter, 8,473 lb/2<sup>nd</sup> calendar quarter, 8,565 lb/3<sup>rd</sup> calendar quarter, 8,565 lb/4<sup>th</sup> calendar quarter, and 16.86 tons/year. [District Rule 3.4/C-00-41]

- c. NOx emissions shall not exceed 36.3 lb/day, 1,384 lb/1<sup>st</sup> calendar quarter, 1,396 lb/2<sup>nd</sup> calendar quarter, 1,407 lb/3<sup>rd</sup> calendar quarter, 1,407 lb/4<sup>th</sup> calendar quarter, and 2.25 tons/year. [District Rule 3.4/C-00-41]
  - d. SOx emissions shall not exceed 17.0 lb/day, 261 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.16 tons/year. [District Rule 3.4/C-00-41]
  - e. PM10 emissions shall not exceed 4.3 lb/day, 242 lb/1<sup>st</sup> calendar quarter, 244 lb/2<sup>nd</sup> calendar quarter, 246 lb/3<sup>rd</sup> calendar quarter, 246 lb/4<sup>th</sup> calendar quarter, and 0.45 tons/year. [District Rule 3.4/C-00-41]
15. For the boiler operating under P-90-00:
- a. VOC emissions shall not exceed 16.4 lb/day, 558 lb/1<sup>st</sup> calendar quarter, 563 lb/2<sup>nd</sup> calendar quarter, 567 lb/3<sup>rd</sup> calendar quarter, 567 lb/4<sup>th</sup> calendar quarter, and 0.86 tons/year. [District Rule 3.4/C-98-184]
  - b. CO emissions shall not exceed 982.6 lb/day, 81,719 lb/1<sup>st</sup> calendar quarter, 82,613 lb/2<sup>nd</sup> calendar quarter, 83,506 lb/3<sup>rd</sup> calendar quarter, 83,506 lb/4<sup>th</sup> calendar quarter, and 163.74 tons/year. [District Rule 3.4/C-98-184]
  - c. NOx emissions shall not exceed 363.1 lb/day, 13,587 lb/1<sup>st</sup> calendar quarter, 13,697 lb/2<sup>nd</sup> calendar quarter, 13,807 lb/3<sup>rd</sup> calendar quarter, 13,807 lb/4<sup>th</sup> calendar quarter, and 21.93 tons/year. [District Rule 3.4/C-98-184]
  - d. SOx emissions shall not exceed 169.6 lb/day, 2,601 lb/1<sup>st</sup> calendar quarter, 2,603 lb/2<sup>nd</sup> calendar quarter, 2,605 lb/3<sup>rd</sup> calendar quarter, 2,605 lb/4<sup>th</sup> calendar quarter, and 1.55 tons/year. [District Rule 3.4/C-98-184]
  - e. PM10 emissions shall not exceed 71.3 lb/day, 1,721 lb/1<sup>st</sup> calendar quarter, 1,730 lb/2<sup>nd</sup> calendar quarter, 1,739 lb/3<sup>rd</sup> calendar quarter, 1,739 lb/4<sup>th</sup> calendar quarter, and 2.11 tons/year. [District Rule 3.4/C-98-184]
16. For the boiler operating under P-91-00:
- a. VOC emissions shall not exceed 16.4 lb/day, 558 lb/1<sup>st</sup> calendar quarter, 563 lb/2<sup>nd</sup> calendar quarter, 567 lb/3<sup>rd</sup> calendar quarter, 567 lb/4<sup>th</sup> calendar quarter, and 0.86 tons/year. [District Rule 3.4/C-98-185]
  - b. CO emissions shall not exceed 982.6 lb/day, 81,719 lb/1<sup>st</sup> calendar quarter, 82,613 lb/2<sup>nd</sup> calendar quarter, 83,506 lb/3<sup>rd</sup> calendar quarter, 83,506 lb/4<sup>th</sup> calendar quarter, and 163.74 tons/year. [District Rule 3.4/C-98-185]
  - c. NOx emissions shall not exceed 363.1 lb/day, 13,587 lb/1<sup>st</sup> calendar quarter, 13,697 lb/2<sup>nd</sup> calendar quarter, 13,807 lb/3<sup>rd</sup> calendar quarter, 13,807 lb/4<sup>th</sup> calendar quarter, and 21.93 tons/year. [District Rule 3.4/C-98-185]

- d. SOx emissions shall not exceed 169.6 lb/day, 2,601 lb/1<sup>st</sup> calendar quarter, 2,603 lb/2<sup>nd</sup> calendar quarter, 2,605 lb/3<sup>rd</sup> calendar quarter, 2,605 lb/4<sup>th</sup> calendar quarter, and 1.55 tons/year. [District Rule 3.4/C-98-185]
  - e. PM10 emissions shall not exceed 71.3 lb/day, 1,721 lb/1<sup>st</sup> calendar quarter, 1,730 lb/2<sup>nd</sup> calendar quarter, 1,739 lb/3<sup>rd</sup> calendar quarter, 1,739 lb/4<sup>th</sup> calendar quarter, and 2.11 tons/year. [District Rule 3.4/C-98-185]
17. For the boiler operating under P-96-00:
- a. VOC emissions shall not exceed 12.3 lb/day, 1,077 lb/1<sup>st</sup> calendar quarter, 1,089 lb/2<sup>nd</sup> calendar quarter, 1,101 lb/3<sup>rd</sup> calendar quarter, 1,101 lb/4<sup>th</sup> calendar quarter, and 2.18 tons/year. [District Rule 3.4/C-01-39]
  - b. CO emissions shall not exceed 733.5 lb/day, 20,285 lb/1<sup>st</sup> calendar quarter, 20,418 lb/2<sup>nd</sup> calendar quarter, 20,551 lb/3<sup>rd</sup> calendar quarter, 20,551 lb/4<sup>th</sup> calendar quarter, and 28.40 tons/year. [District Rule 3.4/C-01-39]
  - c. NOx emissions shall not exceed 286.2 lb/day, 9,973 lb/1<sup>st</sup> calendar quarter, 10,052 lb/2<sup>nd</sup> calendar quarter, 10,131 lb/3<sup>rd</sup> calendar quarter, 10,131 lb/4<sup>th</sup> calendar quarter, and 15.83 tons/year. [District Rule 3.4/C-01-39]
  - d. SOx emissions shall not exceed 114.5 lb/day, 1,688 lb/1<sup>st</sup> calendar quarter, 1,689 lb/2<sup>nd</sup> calendar quarter, 1,690 lb/3<sup>rd</sup> calendar quarter, 1,690 lb/4<sup>th</sup> calendar quarter, and 1.02 tons/year. [District Rule 3.4/C-01-39]
  - e. PM10 emissions shall not exceed 53.2 lb/day, 1,992 lb/1<sup>st</sup> calendar quarter, 2,009 lb/2<sup>nd</sup> calendar quarter, 2,025 lb/3<sup>rd</sup> calendar quarter, 2,025 lb/4<sup>th</sup> calendar quarter, and 3.26 tons/year. [District Rule 3.4/C-01-39]
18. For the boiler operating under P-90-02:
- a. VOC emissions shall not exceed 0.2 lb/day, 11 lb/1<sup>st</sup> calendar quarter, 12 lb/2<sup>nd</sup> calendar quarter, 12 lb/3<sup>rd</sup> calendar quarter, 12 lb/4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-00-191]
  - b. CO emissions shall not exceed 3.5 lb/day, 199 lb/1<sup>st</sup> calendar quarter, 202 lb/2<sup>nd</sup> calendar quarter, 204 lb/3<sup>rd</sup> calendar quarter, 204 lb/4<sup>th</sup> calendar quarter, and 0.40 tons/year. [District Rule 3.4/C-00-191]
  - c. NOx emissions shall not exceed 1.7 lb/day, 98 lb/1<sup>st</sup> calendar quarter, 99 lb/2<sup>nd</sup> calendar quarter, 100 lb/3<sup>rd</sup> calendar quarter, 100 lb/4<sup>th</sup> calendar quarter, and 0.20 tons/year. [District Rule 3.4/C-00-191]
  - d. SOx emissions shall not exceed negligible lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-00-191]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 21 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-00-191]

19. For the boiler operating under P-91-02:
  - a. VOC emissions shall not exceed 0.2 lb/day, 11 lb/1<sup>st</sup> calendar quarter, 12 lb/2<sup>nd</sup> calendar quarter, 12 lb/3<sup>rd</sup> calendar quarter, 12 lb/4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-00-196]
  - b. CO emissions shall not exceed 3.5 lb/day, 199 lb/1<sup>st</sup> calendar quarter, 202 lb/2<sup>nd</sup> calendar quarter, 204 lb/3<sup>rd</sup> calendar quarter, 204 lb/4<sup>th</sup> calendar quarter, and 0.40 tons/year. [District Rule 3.4/C-00-196]
  - c. NOx emissions shall not exceed 1.7 lb/day, 98 lb/1<sup>st</sup> calendar quarter, 99 lb/2<sup>nd</sup> calendar quarter, 100 lb/3<sup>rd</sup> calendar quarter, 100 lb/4<sup>th</sup> calendar quarter, and 0.20 tons/year. [District Rule 3.4/C-00-196]
  - d. SOx emissions shall not exceed negligible lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-00-196]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 21 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-00-196]
  
20. For the boiler operating under P-28-03:
  - a. VOC emissions shall not exceed 1.4 lb/day, 124 lb/1<sup>st</sup> calendar quarter, 63 lb/2<sup>nd</sup> calendar quarter, 64 lb/3<sup>rd</sup> calendar quarter, 127 lb/4<sup>th</sup> calendar quarter, and 0.19 tons/year. [District Rule 3.4/C-02-353]
  - b. CO emissions shall not exceed 5.2 lb/day, 466 lb/1<sup>st</sup> calendar quarter, 236 lb/2<sup>nd</sup> calendar quarter, 238 lb/3<sup>rd</sup> calendar quarter, 477 lb/4<sup>th</sup> calendar quarter, and 0.71 tons/year. [District Rule 3.4/C-02-353]
  - c. NOx emissions shall not exceed 5.7 lb/day, 511 lb/1<sup>st</sup> calendar quarter, 258 lb/2<sup>nd</sup> calendar quarter, 261 lb/3<sup>rd</sup> calendar quarter, 522 lb/4<sup>th</sup> calendar quarter, and 0.78 tons/year. [District Rule 3.4/C-02-353]
  - d. SOx emissions shall not exceed negligible lb/day, 3 lb/1<sup>st</sup> calendar quarter, 1 lb/2<sup>nd</sup> calendar quarter, 1 lb/3<sup>rd</sup> calendar quarter, 3 lb/4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-353]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 32 lb/1<sup>st</sup> calendar quarter, 16 lb/2<sup>nd</sup> calendar quarter, 16 lb/3<sup>rd</sup> calendar quarter, 33 lb/4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-02-353]
  
21. For the boiler operating under P-64-03(a):
  - a. VOC emissions shall not exceed 0.2 lb/day, 19 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-04-22]

- b. CO emissions shall not exceed 11.3 lb/day, 1,015 lb/1<sup>st</sup> calendar quarter, 1,027 lb/2<sup>nd</sup> calendar quarter, 1,038 lb/3<sup>rd</sup> calendar quarter, 1,038 lb/4<sup>th</sup> calendar quarter, and 2.06 tons/year. [District Rule 3.4/C-04-22]
  - c. NOx emissions shall not exceed 1.2 lb/day, 104 lb/1<sup>st</sup> calendar quarter, 105 lb/2<sup>nd</sup> calendar quarter, 107 lb/3<sup>rd</sup> calendar quarter, 107 lb/4<sup>th</sup> calendar quarter, and 0.21 tons/year. [District Rule 3.4/C-04-22]
  - d. SOx emissions shall not exceed negligible lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-04-22]
  - e. PM10 emissions shall not exceed 0.3 lb/day, 26 lb/1<sup>st</sup> calendar quarter, 26 lb/2<sup>nd</sup> calendar quarter, 27 lb/3<sup>rd</sup> calendar quarter, and 27 lb/4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-04-22]
22. For the boiler operating under P-65-03:
- a. VOC emissions shall not exceed 0.3 lb/day, 27 lb/1<sup>st</sup> calendar quarter, 27 lb/2<sup>nd</sup> calendar quarter, 28 lb/3<sup>rd</sup> calendar quarter, 28 lb/4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-02-331]
  - b. CO emissions shall not exceed 2.4 lb/day, 218 lb/1<sup>st</sup> calendar quarter, 221 lb/2<sup>nd</sup> calendar quarter, 223 lb/3<sup>rd</sup> calendar quarter, 223 lb/4<sup>th</sup> calendar quarter, and 0.44 tons/year. [District Rule 3.4/C-02-331]
  - c. NOx emissions shall not exceed 1.3 lb/day, 119 lb/1<sup>st</sup> calendar quarter, 121 lb/2<sup>nd</sup> calendar quarter, 122 lb/3<sup>rd</sup> calendar quarter, 122 lb/4<sup>th</sup> calendar quarter, and 0.24 tons/year. [District Rule 3.4/C-02-331]
  - d. SOx emissions shall not exceed negligible lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-331]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 37 lb/1<sup>st</sup> calendar quarter, 38 lb/2<sup>nd</sup> calendar quarter, 38 lb/3<sup>rd</sup> calendar quarter, 38 lb/4<sup>th</sup> calendar quarter, and 0.08 tons/year. [District Rule 3.4/C-02-331]
23. For the boiler operating under P-101-03:
- a. VOC emissions shall not exceed 0.3 lb/day, 5 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, 4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-335]
  - b. CO emissions shall not exceed 1.5 lb/day, 29 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.06 tons/year. [District Rule 3.4/C-02-335]
  - c. NOx emissions shall not exceed 2.8 lb/day, 53 lb/1<sup>st</sup> calendar quarter, 53 lb/2<sup>nd</sup> calendar quarter, 54 lb/3<sup>rd</sup> calendar quarter, 54 lb/4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-02-335]

- d. SOx emissions shall not exceed negligible lb/day, 1 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-02-335]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 7 lb/1<sup>st</sup> calendar quarter, 7 lb/2<sup>nd</sup> calendar quarter, 8 lb/3<sup>rd</sup> calendar quarter, 8 lb/4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-02-335]
24. For the boiler operating under P-63-06(a):
- a. VOC emissions shall not exceed 1.0 lb/day, 78 lb/1<sup>st</sup> calendar quarter, 79 lb/2<sup>nd</sup> calendar quarter, 79 lb/3<sup>rd</sup> calendar quarter, 79 lb/4<sup>th</sup> calendar quarter, and 0.16 tons/year. [District Rule 3.4/C-09-210]
  - b. CO emissions shall not exceed 3.3 lb/day, 248 lb/1<sup>st</sup> calendar quarter, 251 lb/2<sup>nd</sup> calendar quarter, 254 lb/3<sup>rd</sup> calendar quarter, 254 lb/4<sup>th</sup> calendar quarter, and 0.50 tons/year. [District Rule 3.4/C-09-210]
  - c. NOx emissions shall not exceed 3.4 lb/day, 251 lb/1<sup>st</sup> calendar quarter, 254 lb/2<sup>nd</sup> calendar quarter, 256 lb/3<sup>rd</sup> calendar quarter, 256 lb/4<sup>th</sup> calendar quarter, and 0.51 tons/year. [District Rule 3.4/C-09-210]
  - d. SOx emissions shall not exceed negligible lb/day, 2 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-09-210]
  - e. PM10 emissions shall not exceed 0.3 lb/day, 21 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.04 tons/year. [District Rule 3.4/C-09-210]
  - f. The Permit Holder shall not release or discharge into the atmosphere particulate matter in excess of 0.01 grains per cubic foot of exhaust as calculated at standard conditions. [District Rule 3.4/C-09-210]
25. For the boiler operating under P-83-06:
- a. VOC emissions shall not exceed 25.0 lb/day, 1,667 lb/1<sup>st</sup> calendar quarter, 1,686 lb/2<sup>nd</sup> calendar quarter, 1,704 lb/3<sup>rd</sup> calendar quarter, 1,704 lb/4<sup>th</sup> calendar quarter, and 3.38 tons/year. [District Rule 3.4/C-05-237]
  - b. CO emissions shall not exceed 36.5 lb/day, 1,517 lb/1<sup>st</sup> calendar quarter, 1,533 lb/2<sup>nd</sup> calendar quarter, 1,549 lb/3<sup>rd</sup> calendar quarter, 1,549 lb/4<sup>th</sup> calendar quarter, and 3.07 tons/year. [District Rule 3.4/C-05-237]
  - c. NOx emissions shall not exceed 78.0 lb/day, 2,565 lb/1<sup>st</sup> calendar quarter, 2,591 lb/2<sup>nd</sup> calendar quarter, 2,617 lb/3<sup>rd</sup> calendar quarter, 2,617 lb/4<sup>th</sup> calendar quarter, and 5.20 tons/year. [District Rule 3.4/C-05-237]
  - d. SOx emissions shall not exceed 7.6 lb/day, 253 lb/1<sup>st</sup> calendar quarter, 256 lb/2<sup>nd</sup> calendar quarter, 258 lb/3<sup>rd</sup> calendar quarter, 258 lb/4<sup>th</sup> calendar quarter, and 0.51 tons/year. [District Rule 3.4/C-05-237]

- e. PM10 emissions shall not exceed 179.8 lb/day, 2,948 lb/1<sup>st</sup> calendar quarter, 2,974 lb/2<sup>nd</sup> calendar quarter, 3,000 lb/3<sup>rd</sup> calendar quarter, 3,000 lb/4<sup>th</sup> calendar quarter, and 5.96 tons/year. [District Rule 3.4/C-05-237]
  - f. The Permit Holder shall not release or discharge into the atmosphere particulate matter in excess of 0.033 grains per cubic foot of exhaust as calculated at standard conditions. [District Rule 3.4/C-05-237]
26. For the boiler operating under P-16-08:
- a. VOC emissions shall not exceed 0.3 lb/day, 25 lb/1<sup>st</sup> calendar quarter, 25 lb/2<sup>nd</sup> calendar quarter, 26 lb/3<sup>rd</sup> calendar quarter, 26 lb/4<sup>th</sup> calendar quarter, and 0.05 tons/year. [District Rule 3.4/C-07-150]
  - b. CO emissions shall not exceed 1.0 lb/day, 90 lb/1<sup>st</sup> calendar quarter, 91 lb/2<sup>nd</sup> calendar quarter, 92 lb/3<sup>rd</sup> calendar quarter, 92 lb/4<sup>th</sup> calendar quarter, and 0.18 tons/year. [District Rule 3.4/C-07-150]
  - c. NOx emissions shall not exceed 1.5 lb/day, 132 lb/1<sup>st</sup> calendar quarter, 133 lb/2<sup>nd</sup> calendar quarter, 135 lb/3<sup>rd</sup> calendar quarter, 135 lb/4<sup>th</sup> calendar quarter, and 0.27 tons/year. [District Rule 3.4/C-07-150]
  - d. SOx emissions shall not exceed negligible lb/day, 3 lb/1<sup>st</sup> calendar quarter, 3 lb/2<sup>nd</sup> calendar quarter, 3 lb/3<sup>rd</sup> calendar quarter, 3 lb/4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/C-07-150]
  - e. PM10 emissions shall not exceed 0.4 lb/day, 34 lb/1<sup>st</sup> calendar quarter, 35 lb/2<sup>nd</sup> calendar quarter, 35 lb/3<sup>rd</sup> calendar quarter, 35 lb/4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-07-150]
  - f. The Permit Holder shall not release or discharge into the atmosphere particulate matter in excess of 0.01 grains per cubic foot of exhaust as calculated at standard conditions. [District Rule 3.4/C-07-150]
27. For the boiler operating under P-44-11:
- a. VOC emissions shall not exceed 0.3 lb/day, 11 lb/1<sup>st</sup> calendar quarter, 6 lb/2<sup>nd</sup> calendar quarter, 6 lb/3<sup>rd</sup> calendar quarter, 11 lb/4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-11-62]
  - b. CO emissions shall not exceed 2.7 lb/day, 99 lb/1<sup>st</sup> calendar quarter, 49 lb/2<sup>nd</sup> calendar quarter, 49 lb/3<sup>rd</sup> calendar quarter, 99 lb/4<sup>th</sup> calendar quarter, and 0.15 tons/year. [District Rule 3.4/C-11-62]
  - c. NOx emissions shall not exceed 1.3 lb/day, 49 lb/1<sup>st</sup> calendar quarter, 24 lb/2<sup>nd</sup> calendar quarter, 24 lb/3<sup>rd</sup> calendar quarter, 49 lb/4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/C-11-62]

- d. SOx emissions shall not exceed negligible lb/day, 1 lb/1<sup>st</sup> calendar quarter, 1 lb/2<sup>nd</sup> calendar quarter, 1 lb/3<sup>rd</sup> calendar quarter, 1 lb/4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-11-62]
- e. PM10 emissions shall not exceed 0.4 lb/day, 15 lb/1<sup>st</sup> calendar quarter, 8 lb/2<sup>nd</sup> calendar quarter, 8 lb/3<sup>rd</sup> calendar quarter, 15 lb/4<sup>th</sup> calendar quarter, and 0.02 tons/year. [District Rule 3.4/C-11-62]
- f. The Permit Holder shall not release or discharge into the atmosphere particulate matter in excess of 0.1 grains per cubic foot of exhaust as calculated at standard conditions. [District Rule 2.11, 2.12 and 3.4/C-11-62]

**A5. Coating Operation**

- 1. For the coating process operating under P-96-80(a1):
  - a. VOC emissions shall not exceed 291.8 lb/day, 1,715 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3.37 tons/year. [District Rule 3.4/C-00-88]
  - b. PM10 emissions shall not exceed 8.2 lb/day, 54 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.11 tons/year. [District Rule 3.4/C-00-88]

**A6. Landfill Gas Collection and Soil Vapor Extraction System**

- 1. For the landfill gas collection and soil vapor extraction system operating under P-14-98:
  - a. VOC emissions shall not exceed 67.7 lb/day, 6,089 lb/1<sup>st</sup> calendar quarter, 6,157 lb/2<sup>nd</sup> calendar quarter, 6,225 lb/3<sup>rd</sup> calendar quarter, 6,225 lb/4<sup>th</sup> calendar quarter, and 12.31 tons/year. [District Rule 3.4/C-95-67]
  - b. CO emissions shall not exceed 10.0 lb/day, 902 lb/1<sup>st</sup> calendar quarter, 912 lb/2<sup>nd</sup> calendar quarter, 922 lb/3<sup>rd</sup> calendar quarter, 922 lb/4<sup>th</sup> calendar quarter, and 1.82 tons/year. [District Rule 3.4/C-95-67]
  - c. NOx emissions shall not exceed 10.1 lb/day, 907 lb/1<sup>st</sup> calendar quarter, 917 lb/2<sup>nd</sup> calendar quarter, 927 lb/3<sup>rd</sup> calendar quarter, 927 lb/4<sup>th</sup> calendar quarter, and 1.83 tons/year. [District Rule 3.4/C-95-67]
  - d. SOx emissions shall not exceed 0.5 lb/day, 47 lb/1<sup>st</sup> calendar quarter, 47 lb/2<sup>nd</sup> calendar quarter, 48 lb/3<sup>rd</sup> calendar quarter, 48 lb/4<sup>th</sup> calendar quarter, and 0.09 tons/year. [District Rule 3.4/C-95-67]

**A7. Incinerator**

- 1. For the incinerator operating under P-81-89(a):
  - a. VOC emissions shall not exceed 0.4 lb/day, 34 lb/1<sup>st</sup> calendar quarter, 34 lb/2<sup>nd</sup> calendar quarter, 34 lb/3<sup>rd</sup> calendar quarter, 34 lb/4<sup>th</sup> calendar quarter, and 0.07 tons/year. [District Rule 3.4/A-41-88]

- b. CO emissions shall not exceed 1.1 lb/day, 84 lb/1<sup>st</sup> calendar quarter, 84 lb/2<sup>nd</sup> calendar quarter, 84 lb/3<sup>rd</sup> calendar quarter, 84 lb/4<sup>th</sup> calendar quarter, and 0.17 tons/year. [District Rule 3.4/A-41-88]
- c. NOx emissions shall not exceed 13.5 lb/day, 1,053 lb/1<sup>st</sup> calendar quarter, 1,053 lb/2<sup>nd</sup> calendar quarter, 1,053 lb/3<sup>rd</sup> calendar quarter, 1,053 lb/4<sup>th</sup> calendar quarter, and 2.10 tons/year. [District Rule 3.4/A-41-88]
- d. SOx emissions shall not exceed negligible lb/day, 3 lb/1<sup>st</sup> calendar quarter, 3 lb/2<sup>nd</sup> calendar quarter, 3 lb/3<sup>rd</sup> calendar quarter, 3 lb/4<sup>th</sup> calendar quarter, and 0.01 tons/year. [District Rule 3.4/A-41-88]
- e. PM10 emissions shall not exceed 1.1 lb/day, 87 lb/1<sup>st</sup> calendar quarter, 87 lb/2<sup>nd</sup> calendar quarter, 87 lb/3<sup>rd</sup> calendar quarter, 87 lb/4<sup>th</sup> calendar quarter, and 0.18 tons/year. [District Rule 3.4/A-41-88]

**A8. Woodworking**

- 1. For the woodworking facility operating under P-95-80(a1):
  - a. PM10 emissions shall not exceed 4.5 lb/day, 407 lb/1<sup>st</sup> calendar quarter, 412 lb/2<sup>nd</sup> calendar quarter, 416 lb/3<sup>rd</sup> calendar quarter, 416 lb/4<sup>th</sup> calendar quarter, and 0.83 tons/year. [District Rule 3.4/C-07-25]
  - b. The Permit Holder shall not release or discharge into the atmosphere, from the dust collection system, particulate matter in excess of 0.01 grains per cubic foot of exhaust as calculated at standard conditions. [District Rule 3.4/C-07-25]
- 2. For the wood working facility operating under P-54-90(a):
  - a. PM10 emissions shall not exceed 0.4 lb/day, 34 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, 4<sup>th</sup> calendar quarter and 0.07 tons/year. [District Rule 3.4/P-54-90(a)]
  - b. The Permit Holder shall not release or discharge into the atmosphere, from the dust collection system, particulate matter in excess of 0.001 grains per cubic foot of exhaust as calculated at standard conditions. [District Rule 3.4]
- 3. For the wood working facility operating under P-43-13:
  - a. PM10 emissions shall not exceed 13.5 lb/day, 1,215 lb/1<sup>st</sup> calendar quarter, 1,229 2<sup>nd</sup> calendar quarter, 1,242 3<sup>rd</sup> calendar quarter, 1,242 4<sup>th</sup> calendar quarter and 2.46tons/year. [District Rule 3.4/C-13-84]
  - b. The Permit Holder shall not release or discharge into the atmosphere, from the dust collection system, particulate matter in excess of 0.1 grains per cubic foot of exhaust as calculated at standard conditions. [District Rule 2.11]

**A9. Wastewater Treatment Plant**

1. For the wastewater treatment plant operating under P-22-00(a), VOC emissions shall not exceed 1.4 lb/day, 78 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, 4<sup>th</sup> calendar quarter and 0.16 tons/year. [District Rule 3.4/C-06-142]

**A10. Cooling Towers**

1. For the cooling towers operating under P-101-02, PM10 emissions shall not exceed 1.7 lb/day, 154 lb/1<sup>st</sup> calendar quarter, 156 lb/2<sup>nd</sup> calendar quarter, 158 lb/3<sup>rd</sup> calendar quarter, 158 lb/4<sup>th</sup> calendar quarter, and 0.30 tons/year. [District Rule 3.4/C-01-62]

**A11. Gasoline and Aviation Gasoline Storage and Dispensing**

1. For the gasoline storage and dispensing facility operating under P-42-76(a3), VOC emissions shall not exceed 5.5 lb/day, 220 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.44 tons/year. [District Rule 3.4/C-09-57]
2. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), VOC emissions shall not exceed 15.8 lb/day, 475 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.95 tons/year. [District Rule 3.4/C-11-80]
3. For the gasoline storage and dispensing facility operating under P-84-93(a1), VOC emissions shall not exceed 0.4 lb/day, 3 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and negligible tons/year. [District Rule 3.4/C-08-97]

**B. Throughput Limitations**

**B1. Emergency Diesel Fired Internal Combustion Engines**

1. For the internal combustion engine operating under P-89-94(a), the maximum amount of diesel consumption shall not exceed 300 gallons/day, 2,500 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,500 gallons/year. [District Rule 3.4/C-02-309]
2. For the internal combustion engine operating under P-90-94(a), the maximum amount of diesel consumption shall not exceed 348 gallons/day, 2,900 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,900 gallons/year. [District Rule 3.4/C-02-286]
3. For the internal combustion engine operating under P-91-94(a), the maximum amount of diesel consumption shall not exceed 288 gallons/day, 2,400 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,400 gallons/year. [District Rule 3.4/C-02-304]
4. For the internal combustion engine operating under P-92-94(a), the maximum amount of diesel consumption shall not exceed 600 gallons/day, 5,000 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 5,000 gallons/year. [District Rule 3.4/C-02-299]
5. For the internal combustion engine operating under P-94-94(a), the maximum amount of diesel consumption shall not exceed 163 gallons/day, 1,360 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,360 gallons/year. [District Rule 3.4/C-02-285]

6. For the internal combustion engine operating under P-95-94(a), the maximum amount of diesel consumption shall not exceed 360 gallons/day, 3,000 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3,000 gallons/year. [District Rule 3.4/C-02-300]
7. For the internal combustion engine operating under P-96-94(a), the maximum amount of diesel consumption shall not exceed 912 gallons/day, 7,600 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 7,600 gallons/year. [District Rule 3.4/C-02-301]
8. For the internal combustion engine operating under P-99-94(a), the maximum amount of diesel consumption shall not exceed 218 gallons/day, 1,820 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,820 gallons/year. [District Rule 3.4/C-02-319]
9. For the internal combustion engine operating under P-100-94(a), the maximum amount of diesel consumption shall not exceed 624 gallons/day, 5,200 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 5,200 gallons/year. [District Rule 3.4/C-02-295]
10. For the internal combustion engine operating under P-101-94(a), the maximum amount of diesel consumption shall not exceed 814 gallons/day, 6,780 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 6,780 gallons/year. [District Rule 3.4/C-02-312]
11. For the internal combustion engine operating under P-102-94(a), the maximum amount of diesel consumption shall not exceed 797 gallons/day, 6,640 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 6,640 gallons/year. [District Rule 3.4/C-02-297]
12. For the internal combustion engine operating under P-103-94(a), the maximum amount of diesel consumption shall not exceed 312 gallons/day, 2,600 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,600 gallons/year. [District Rule 3.4/C-02-305]
13. For the internal combustion engine operating under P-107-95(a), the maximum amount of diesel consumption shall not exceed 252 gallons/day, 2,100 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,100 gallons/year. [District Rule 3.4/C-02-289]
14. For the internal combustion engine operating under P-126-95(a), the maximum amount of diesel consumption shall not exceed 410 gallons/day, 3,420 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3,420 gallons/year. [District Rule 3.4/C-02-316]
15. For the internal combustion engine operating under P-209-95(a), the maximum amount of diesel consumption shall not exceed 214 gallons/day, 1,780 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,780 gallons/year. [District Rule 3.4/C-02-313]
16. For the internal combustion engine operating under P-29-96(a), the maximum amount of diesel consumption shall not exceed 504 gallons/day, 4,200 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4,200 gallons/year. [District Rule 3.4/C-02-282]
17. For the internal combustion engine operating under P-69-96(a), the maximum amount of diesel consumption shall not exceed 154 gallons/day, 1,280 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,280 gallons/year. [District Rule 3.4/C-02-290]

18. For the internal combustion engine operating under P-42-97, the maximum amount of diesel consumption shall not exceed 214 gallons/day, 1,780 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,780 gallons/year. [District Rule 3.4/P-42-97]
19. For the internal combustion engine operating under P-54-97, the maximum amount of diesel consumption shall not exceed 1,560 gallons/day, 13,000 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 13,000 gallons/year. [District Rule 3.4/A-88-97c]
20. For the internal combustion engine operating under P-15-98, the maximum amount of diesel consumption shall not exceed 410 gallons/day, 3,420 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3,420 gallons/year. [District Rule 3.4/A-35-97c]
21. For the internal combustion engine operating under P-16-98, the maximum amount of diesel consumption shall not exceed 334 gallons/day, 2,780 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,780 gallons/year. [District Rule 3.4/A-34-97c]
22. For the internal combustion engine operating under P-17-98, the maximum amount of diesel consumption shall not exceed 98.4 gallons/day, 820 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 820 gallons/year. [District Rule 3.4/A-157-97c]
23. For the internal combustion engine operating under P-31-98, the maximum amount of diesel consumption shall not exceed 607 gallons/day, 5,0060 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 5,060 gallons/year. [District Rule 3.4/A-78-97c]
24. For the internal combustion engine operating under P-32-98, the maximum amount of diesel consumption shall not exceed 564 gallons/day, 4,700 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4,700 gallons/year. [District Rule 3.4/A-79-97c]
25. For the internal combustion engine operating under P-32-99, the maximum amount of diesel consumption shall not exceed 607.2 gallons/day, 5,060 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 5,060 gallons/year. [District Rule 3.4/A-7-97c]
26. For the internal combustion engine operating under P-88-99, the maximum amount of diesel consumption shall not exceed 1,932 gallons/day, 16,100 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 16,100 gallons/year. [District Rule 3.4/C-99-114]
27. For the internal combustion engine operating under P-1-00, the maximum amount of diesel consumption shall not exceed 562 gallons/day, 4,680 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4,680 gallons/year. [District Rule 3.4/C-99-70]
28. For the internal combustion engine operating under P-2-00, the maximum amount of diesel consumption shall not exceed 461 gallons/day, 3,840 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3,840 gallons/year. [District Rule 3.4/C-98-90]
29. For the internal combustion engine operating under P-71-00, the maximum amount of diesel consumption shall not exceed 564 gallons/day, 4,700 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4,700 gallons/year. [District Rule 3.4/C-99-121]

30. For the internal combustion engine operating under P-7-01, the maximum amount of diesel consumption shall not exceed 564 gallons/day, 4,700 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4,700 gallons/year. [District Rule 3.4/C-99-120]
31. For the internal combustion engine operating under P-8-01(a), the maximum amount of diesel consumption shall not exceed 838 gallons /day, 6,980 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 6,980 gallons/year. [District Rule 3.4/C-06-16]
32. For the internal combustion engine operating under P-9-01(a), the maximum amount of diesel consumption shall not exceed 379 gallons/day, 3,160 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3,160 gallons/year. [District Rule 3.4/C-06-15]
33. For the internal combustion engine operating under P-108-01, the maximum amount of diesel consumption shall not exceed 70 gallons/day, 580 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 580 gallons/year. [District Rule 3.4/C-01-73]
34. For the internal combustion engine operating under P-109-01, the maximum amount of diesel consumption shall not exceed 70 gallons/day, 580 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 580 gallons/year. [District Rule 3.4/C-01-74]
35. For the internal combustion engine operating under P-111-01, the maximum amount of diesel consumption shall not exceed 1,344 gallons/day, 11,200 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 11,200 gallons/year. [District Rule 3.4/C-01-12]
36. For the internal combustion engine operating under P-120-01, the maximum amount of diesel consumption shall not exceed 1,313 gallons/day, 10,940 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 10,940 gallons/year. [District Rule 3.4/C-01-170]
37. For the internal combustion engine operating under P-17-02, the maximum amount of diesel consumption shall not exceed 180 gallons/day, 1,500 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,500 gallons/year. [District Rule 3.4/C-00-86]
38. For the internal combustion engine operating under P-82-02, the maximum amount of diesel consumption shall not exceed 523 gallons/day, 4,360 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4,360 gallons/year. [District Rule 3.4/C-00-173]
39. For the internal combustion engine operating under P-83-02, the maximum amount of diesel consumption shall not exceed 264 gallons/day, 2,200 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,200 gallons/year. [District Rule 3.4/C-02-93]
40. For the internal combustion engine operating under P-84-02, the maximum amount of diesel consumption shall not exceed 727 gallons/day, 6,060 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 6,060 gallons/year. [District Rule 3.4/C-01-201]
41. For the internal combustion engine operating under P-114-02, the maximum amount of diesel consumption shall not exceed 382 gallons/day, 3,180 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3,180 gallons/year. [District Rule 3.4/C-02-158]

42. For the internal combustion engine operating under P-63-03, the maximum amount of diesel consumption shall not exceed 410 gallons/day, 3,420 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3,420 gallons/year. [District Rule 3.4/C-02-184]
43. For the internal combustion engine operating under P-102-03, the maximum amount of diesel consumption shall not exceed 1,368 gallons/day, 11,400 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 11,400 gallons/year. [District Rule 3.4/C-02-322]
44. For the internal combustion engine operating under P-15-04, the maximum amount of diesel consumption shall not exceed 1,313 gallons/day, 10,940 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 10,940 gallons/year. [District Rule 3.4/C-03-251]
45. For the internal combustion engine operating under P-74-05, the maximum amount of diesel consumption shall not exceed 415 gallons/day, 3,460 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3,460 gallons/year. [District Rule 3.4/C-05-49]
46. For the internal combustion engine operating under P-38-05, the maximum amount of diesel consumption shall not exceed 283 gallons/day, 2,360 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,360 gallons/year. [District Rule 3.4/C-05-164]
47. For the internal combustion engine operating under P-115-03, the maximum amount of diesel consumption shall not exceed 590 gallons/day, 4,920 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4,920 gallons/year. [District Rule 3.4/C-03-98]
48. For the internal combustion engine operating under P-117-03, the maximum amount of diesel consumption shall not exceed 228 gallons/day, 1,900 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,900 gallons/year. [District Rule 3.4/C-02-373]
49. For the internal combustion engine operating under P-118-03, the maximum amount of diesel consumption shall not exceed 871 gallons/day, 7,260 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 7,260 gallons/year. [District Rule 3.4/C-03-164]
50. For the internal combustion engine operating under P-119-03, the maximum amount of diesel consumption shall not exceed 228 gallons/day, 1,900 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,900 gallons/year. [District Rule 3.4/C-02-372]
51. For the internal combustion engine operating under P-120-03, the maximum amount of diesel consumption shall not exceed 3,228 gallons/day, 26,900 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 26,900 gallons/year. [District Rule 3.4/C-03-99]
52. For the internal combustion engine operating under P-121-03, the maximum amount of diesel consumption shall not exceed 1,313 gallons/day, 10,940 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 10,940 gallons/year. [District Rule 3.4/C-03-100]
53. For the internal combustion engine operating under P-59-05, the maximum amount of diesel consumption shall not exceed 182 gallons/day, 1,520 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,520 gallons/year. [District Rule 3.4/C-05-175]

54. For the internal combustion engine operating under P-49-07, the maximum amount of diesel consumption shall not exceed 1,025 gallons/day, 8,540 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 8,540 gallons/year. [District Rule 3.4/C-07-62]
55. For the internal combustion engine operating under P-50-07, the maximum amount of diesel consumption shall not exceed 1,265 gallons/day, 10,540 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 10,540 gallons/year. [District Rule 3.4/C-07-78]
56. For the internal combustion engine operating under P-51-07, the maximum amount of diesel consumption shall not exceed 58 gallons/day, 480 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 480 gallons/year. [District Rule 3.4/C-07-80]
57. For the internal combustion engine operating under P-52-07, the maximum amount of diesel consumption shall not exceed 1,390 gallons/day, 11,580 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 11,580 gallons/year. [District Rule 3.4/C-07-84]
58. For the internal combustion engine operating under P-53-07, the maximum amount of diesel consumption shall not exceed 1,390 gallons/day, 11,580 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 11,580 gallons/year. [District Rule 3.4/C-07-85]
59. For the internal combustion engine operating under P-59-07, the maximum amount of diesel consumption shall not exceed 331 gallons/day, 2,760 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,760 gallons/year. [District Rule 3.4/C-07-107]
60. For the internal combustion engine operating under P-2-09, the maximum amount of diesel consumption shall not exceed 103 gallons/day, 860 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 860 gallons/year. [District Rule 3.4/C-08-110]
61. For the internal combustion engine operating under P-4-09, the maximum amount of diesel consumption shall not exceed 526 gallons/day, 4,380 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4,380 gallons/year. [District Rule 3.4/C-08-232]
62. For the internal combustion engine operating under P-16-09, the maximum amount of diesel consumption shall not exceed 1,130 gallons/day, 9,420 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 9,420 gallons/year. [District Rule 3.4/C-08-254]
63. For the internal combustion engine operating under P-17-09, the maximum amount of diesel consumption shall not exceed 341 gallons/day, 2,840 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,840 gallons/year. [District Rule 3.4/C-09-16]
64. For the internal combustion engine operating under P-54-09, the maximum amount of diesel consumption shall not exceed 1,025 gallons/day, 8,540 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 8,540 gallons/year. [District Rule 3.4/C-09-139]
65. For the internal combustion engine operating under P-66-09, the maximum amount of diesel consumption shall not exceed 151 gallons/day, 1,260 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,260 gallons/year. [District Rule 3.4/C-09-127]

66. For the internal combustion engine operating under P-67-09, the maximum amount of diesel consumption shall not exceed 185 gallons/day, 1,540 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,540 gallons/year. [District Rule 3.4/C-09-128]
67. For the internal combustion engine operating under P-68-09, the maximum amount of diesel consumption shall not exceed 526 gallons/day, 4,380 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4,380 gallons/year. [District Rule 3.4/C-09-129]
68. For the internal combustion engine operating under P-69-09, the maximum amount of diesel consumption shall not exceed 1,332 gallons/day, 11,100 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 11,100 gallons/year. [District Rule 3.4/C-09-161]
69. For the internal combustion engine operating under P-42-10, the maximum amount of diesel consumption shall not exceed 326 gallons/day, 2,720 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,720 gallons/year. [District Rule 3.4/C-10-17]
70. For the internal combustion engine operating under P-44-10, the maximum amount of diesel consumption shall not exceed 960 gallons/day, 8,000 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 8,000 gallons/year. [District Rule 3.4/C-10-45]
71. For the internal combustion engine operating under P-7-11, the maximum amount of diesel consumption shall not exceed 734 gallons/day, 6,113 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 6,113 gallons/year. [District Rule 3.4/C-10-105]
72. For the internal combustion engine operating under P-72-11, the maximum amount of diesel consumption shall not exceed 1,392 gallons/day, 11,600 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 11,600 gallons/year. [District Rule 3.4/C-11-89]
73. For the internal combustion engine operating under P-39-12, the maximum amount of diesel consumption shall not exceed 648 gallons/day, 5,400 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 5,400 gallons/year. [District Rule 3.4/C-12-89]
74. For the internal combustion engine operating under P-51-12, the maximum amount of diesel consumption shall not exceed 710 gallons/day, 5,920 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 5,920 gallons/year. [District Rule 3.4/C-12-125]
75. For the internal combustion engine operating under P-52-12, the maximum amount of diesel consumption shall not exceed 146 gallons/day, 1,220 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,220 gallons/year. [District Rule 3.4/C-12-126]
76. For the internal combustion engine operating under P-55-12, the maximum amount of diesel consumption shall not exceed 533 gallons/day, 4,440 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 4,440 gallons/year. [District Rule 3.4/C-12-129]
77. For the internal combustion engine operating under P-56-12, the maximum amount of diesel consumption shall not exceed 422 gallons/day, 3,520 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3,520 gallons/year. [District Rule 3.4/C-12-130]

78. For the internal combustion engine operating under P-4-13, the maximum amount of diesel consumption shall not exceed 1,375 gallons/day, 11,460 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 11,460 gallons/year. [District Rule 3.4/C-12-130]

**B2. Emergency Natural Gas Internal Combustion Engines**

1. For the internal combustion engine operating under P-108-95(a), the maximum amount of natural gas consumption shall not exceed 101,040 cubic feet /day, 0.842 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.842 million cubic feet/year. [District Rule 3.4/C-02-311]
2. For the internal combustion engine operating under P-109-95(a), the maximum amount of natural gas consumption shall not exceed 21,360 cubic feet/day, 0.178 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.178 million cubic feet/year. [District Rule 3.4/C-02-314]
3. For the internal combustion engine operating under P-110-95(a), the maximum amount of natural gas consumption shall not exceed 65,040 cubic feet/day, 0.542 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.542 million cubic feet/year. [District Rule 3.4/C-02-303]
4. For the internal combustion engine operating under P-112-95(a), the maximum amount of natural gas consumption shall not exceed 9,480 cubic feet/day, 0.079 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.079 million cubic feet/year. [District Rule 3.4/C-02-296]
5. For the internal combustion engine operating under P-113-95(a), the maximum amount of natural gas consumption shall not exceed 12,360 cubic feet/day, 0.103 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.103 million cubic feet/year. [District Rule 3.4/C-02-306]
6. For the internal combustion engine operating under P-114-95(a), the maximum amount of natural gas consumption shall not exceed 19,200 cubic feet/day, 0.160 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.160 million cubic feet/year. [District Rule 3.4/C-02-307]
7. For the internal combustion engine operating under P-117-95(a), the maximum amount of natural gas consumption shall not exceed 14,400 cubic feet/day, 0.120 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.120 million cubic feet/year. [District Rule 3.4/C-02-318]
8. For the internal combustion engine operating under P-118-95(a), the maximum amount of natural gas consumption shall not exceed 12,360 cubic feet/day, 0.103 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.103 million cubic feet/year. [District Rule 3.4/C-02-308]
9. For the internal combustion engine operating under P-119-95(a), the maximum amount of natural gas consumption shall not exceed 14,040 cubic feet/day, 0.117 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.117 million cubic feet/year. [District Rule 3.4/C-02-302]
10. For the internal combustion engine operating under P-120-95(a), the maximum amount of natural gas consumption shall not exceed 9,480 cubic feet/day, 0.079 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.079 million cubic feet/year. [District Rule 3.4/C-02-317]
11. For the internal combustion engine operating under P-121-95(a), the maximum amount of natural gas consumption shall not exceed 12,360 cubic feet/day, 0.103 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.103 million cubic feet/year. [District Rule 3.4/C-02-283]

12. For the internal combustion engine operating under P-122-95(a), the maximum amount of natural gas consumption shall not exceed 14,520 cubic feet/day, 0.121 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.121 million cubic feet/year. [District Rule 3.4/C-02-288]
13. For the internal combustion engine operating under P-123-95(a), the maximum amount of natural gas consumption shall not exceed 39,480 cubic feet/day, 0.329 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.329 million cubic feet/year. [District Rule 3.4/C-02-292]
14. For the internal combustion engine operating under P-124-95(a), the maximum amount of natural gas consumption shall not exceed 33,840 cubic feet/day, 0.282 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.282 million cubic feet/year. [District Rule 3.4/C-02-321]
15. For the internal combustion engine operating under P-125-95(a), the maximum amount of natural gas consumption shall not exceed 28,560 cubic feet/day, 0.238 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.238 million cubic feet/year. [District Rule 3.4/C-02-287]
16. For the internal combustion engine operating under P-18-98, the maximum amount of natural gas consumption shall not exceed 12.17 MMBTU/day, 101.4 MMBTU/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 101.4 MMBTU/year. [District Rule 3.4/A-133-97c]
17. For the internal combustion engine operating under P-61-00, the maximum amount of natural gas consumption shall not exceed 69,600 cubic feet/day, 580,000 cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 580,000 cubic feet/year. [District Rule 3.4/C-00-105]
18. For the internal combustion engine operating under P-3-09, the maximum amount of natural gas consumption shall not exceed 145,800 cubic feet/day, 1.215 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1.215 million cubic feet/year. [District Rule 3.4/C-08-193]
19. For the internal combustion engine operating under P-43-10, the maximum amount of natural gas consumption shall not exceed 20,664 cubic feet/day, 0.172 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 0.172 million cubic feet/year. [District Rule 3.4/C-10-38]

**B3. Portable Internal Combustion Engines**

1. For the portable engine operating under P-50-99(a), the maximum amount of diesel consumption shall not exceed 125 gallons/day, 1,040 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,040 gallons/year. [District Rule 3.4/C-06-17]
2. For the portable engine operating under P-51-99(a), the maximum amount of diesel consumption shall not exceed 125 gallons/day, 1,040 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,040 gallons/year. [District Rule 3.4/C-06-18]
3. For the portable engine operating under P-52-99(a), the maximum amount of diesel consumption shall not exceed 125 gallons/day, 1,040 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,040 gallons/year. [District Rule 3.4/C-06-19]

4. For the portable engine operating under P-86-01, the maximum amount of diesel consumption shall not exceed 326 gallons/day, 2,720 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,720 gallons/year. [District Rule 3.4/C-00-145]
5. For the portable engine operating under P-87-01, the maximum amount of diesel consumption shall not exceed 326 gallons/day, 2,720 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,720 gallons/year. [District Rule 3.4/C-00-146]

**B4. Boilers and Water Heaters**

1. For the boiler operating under P-44-96, the maximum amount of natural gas consumption shall not exceed 0.0768 million cubic feet/day, 6.912 million cubic feet/1<sup>st</sup> calendar quarter, 6.989 million cubic feet/2<sup>nd</sup> calendar quarter, 7.066 million cubic feet/3<sup>rd</sup> calendar quarter, 7.066 million cubic feet/4<sup>th</sup> calendar quarter, and 27.955 million cubic feet/year. [District Rule 3.4/A-71-98]
2. For the boiler operating under P-45-96, the maximum amount of natural gas consumption shall not exceed 0.033 million cubic feet/day, 2.970 million cubic feet/1<sup>st</sup> calendar quarter, 3.003 million cubic feet/2<sup>nd</sup> calendar quarter, 3.036 million cubic feet/3<sup>rd</sup> calendar quarter, 3.036 million cubic feet/4<sup>th</sup> calendar quarter, and 12.01 million cubic feet/year. [District Rule 3.4/A-44-96]
3. For the boiler operating under P-47-96, the maximum amount of natural gas consumption shall not exceed 0.09 million cubic feet/day, 8.100 million cubic feet/1<sup>st</sup> calendar quarter, 8.190 million cubic feet/2<sup>nd</sup> calendar quarter, 8.280 million cubic feet/3<sup>rd</sup> calendar quarter, 8.280 million cubic feet/4<sup>th</sup> calendar quarter, and 32.76 million cubic feet/year. [District Rule 3.4/A-46-96]
4. For the boiler operating under P-48-96, the maximum amount of natural gas consumption shall not exceed 0.0288 million cubic feet/day, 2.592 million cubic feet/1<sup>st</sup> calendar quarter, 2.621 million cubic feet/2<sup>nd</sup> calendar quarter, 2.650 million cubic feet/3<sup>rd</sup> calendar quarter, 2.650 million cubic feet/4<sup>th</sup> calendar quarter, and 10.48 million cubic feet/year. [District Rule 3.4/A-47-96]
5. For the boiler operating under P-54-96, the maximum amount of natural gas consumption shall not exceed 0.036 million cubic feet/day, 3.240 million cubic feet/1<sup>st</sup> calendar quarter, 3.276 million cubic feet/2<sup>nd</sup> calendar quarter, 3.312 million cubic feet/3<sup>rd</sup> calendar quarter, 3.312 million cubic feet/4<sup>th</sup> calendar quarter, and 13.1 million cubic feet/year. [Rule 3.4/A-53-96]
6. For the boiler operating under P-62-96, the maximum amount of natural gas consumption shall not exceed 0.0533 million cubic feet/day, 4.797 million cubic feet/1<sup>st</sup> calendar quarter, 4.850 million cubic feet/2<sup>nd</sup> calendar quarter, 4.904 million cubic feet/3<sup>rd</sup> calendar quarter, 4.904 million cubic feet/4<sup>th</sup> calendar quarter, and 19.4 million cubic feet/year. [District Rule 3.4/A-61-96]
7. For the boiler operating under P-67-98, the maximum amount of natural gas/landfill gas consumption shall not exceed 3,024 therms/day, 272,160 therms/1<sup>st</sup> calendar quarter, 275,184 therms/2<sup>nd</sup> calendar quarter, 278,208 therms/3<sup>rd</sup> calendar quarter, 278,208 therms/4<sup>th</sup> calendar quarter, and 1,103,760 therms/year. [District Rule 3.4/C-98-14]
8. For the boiler operating under P-3-00, the maximum amount of natural gas consumption shall not exceed 0.096 million cubic feet/day, 7.7909 million cubic feet/1<sup>st</sup> calendar quarter, 7.997 million cubic feet/2<sup>nd</sup> calendar quarter, 8.085 million cubic feet/3<sup>rd</sup> calendar quarter, 8.085 million cubic feet/4<sup>th</sup> calendar quarter, and 32.076 million cubic feet/year. [District Rule 3.4/C-99-107]

9. For the boiler operating under P-5-00, the maximum amount of natural gas consumption shall not exceed 0.036 million cubic feet/day, 3.276 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 13.10 million cubic feet/year. [District Rule 3.4/C-98-188]
10. For the boiler operating under P-52-00, the maximum amount of natural gas consumption shall not exceed 0.048 million cubic feet/day, 4.298 million cubic feet/1<sup>st</sup> calendar quarter, 4.346 million cubic feet/2<sup>nd</sup> calendar quarter, 4.394 million cubic feet/3<sup>rd</sup> calendar quarter, 4.394 million cubic feet/4<sup>th</sup> calendar quarter, and 17.432 million cubic feet/year. [District Rule 3.4/C-00-176]
11. For the boiler operating under P-54-00(a), the maximum amount of natural gas consumption shall not exceed 0.072 million cubic feet/day, 6.480 million cubic feet/1<sup>st</sup> calendar quarter, 6.552 million cubic feet/2<sup>nd</sup> calendar quarter, 6.624 million cubic feet/3<sup>rd</sup> calendar quarter, 6.624 million cubic feet/4<sup>th</sup> calendar quarter, and 26.280 million cubic feet/year. [District Rule 3.4/C-10-93]
12. For the boiler operating under P-55-00, the maximum amount of natural gas consumption shall not exceed 0.0367 million cubic feet/day, 3.30 million cubic feet/1<sup>st</sup> calendar quarter, 3.34 million cubic feet/2<sup>nd</sup> calendar quarter, 3.38 million cubic feet/3<sup>rd</sup> calendar quarter, 3.38 million cubic feet/4<sup>th</sup> calendar quarter, and 13.40 million cubic feet/year. [District Rule 3.4/C-98-75]
13. For the boiler operating under P-67-00(a), the maximum amount of natural gas consumption shall not exceed 57,312 cubic feet/day, 5.158 million cubic feet/1<sup>st</sup> calendar quarter, 5.215 million cubic feet/2<sup>nd</sup> calendar quarter, 5.273 million cubic feet/3<sup>rd</sup> calendar quarter, 5.273 million cubic feet/4<sup>th</sup> calendar quarter, and 20.919 million cubic feet/year. [District Rule 3.4/C-08-61]
14. For the boiler operating under P-89-00, the maximum amount of natural gas consumption shall not exceed 0.31 million cubic feet/day, 28.1 million cubic feet/1<sup>st</sup> calendar quarter, 28.4 million cubic feet/2<sup>nd</sup> calendar quarter, 28.7 million cubic feet/3<sup>rd</sup> calendar quarter, 28.7 million cubic feet/4<sup>th</sup> calendar quarter, and 113.9 million cubic feet/year. The maximum amount of fuel oil #2 consumption shall not exceed 2,160 gallons/day, 31,392 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 31,392 gallons/year. [District Rule 3.4/C-00-41]
15. For the boiler operating under P-90-00, the maximum amount of natural gas consumption shall not exceed 3.03 million cubic feet/day, 272.7 million cubic feet/1<sup>st</sup> calendar quarter, 275.7 million cubic feet/2<sup>nd</sup> calendar quarter, 278.8 million cubic feet/3<sup>rd</sup> calendar quarter, 278.8 million cubic feet/4<sup>th</sup> calendar quarter, and 1,106.0 million cubic feet/year. The maximum amount of fuel oil #2 consumption shall not exceed 21,600 gallons/day, 313,916 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 313,916 gallons/year. [District Rule 3.4/C-98-184]
16. For the boiler operating under P-91-00, the maximum amount of natural gas consumption shall not exceed 3.03 million cubic feet/day, 272.7 million cubic feet/1<sup>st</sup> calendar quarter, 275.7 million cubic feet/2<sup>nd</sup> calendar quarter, 278.8 million cubic feet/3<sup>rd</sup> calendar quarter, 278.8 million cubic feet/4<sup>th</sup> calendar quarter, and 1,106.0 million cubic feet/year. The maximum amount of fuel oil #2 consumption shall not exceed 21,600 gallons/day, 313,916 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 313,916 gallons/year. [District Rule 3.4/C-98-185]
17. For the boiler operating under P-96-00, the maximum amount of natural gas consumption shall not exceed 2.167 million cubic feet/day, 195.048 million cubic feet/1<sup>st</sup> calendar quarter, 197.215 million cubic feet/2<sup>nd</sup> calendar quarter, 199.382 million cubic feet/3<sup>rd</sup> calendar quarter, 199.382 million cubic

feet/4<sup>th</sup> calendar quarter, and 791.028 million cubic feet/year. The maximum amount of fuel oil #2 consumption shall not exceed 16,128 gallons/day, 223,752 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 223,752 gallons/year. [District Rule 3.4/C-98-184]

18. For the boiler operating under P-90-02, the maximum amount of natural gas consumption shall not exceed 48,000 cubic feet/day, 2.700 million cubic feet/1<sup>st</sup> calendar quarter, 2.730 million cubic feet/2<sup>nd</sup> calendar quarter, 2.760 million cubic feet/3<sup>rd</sup> calendar quarter, 2.760 million cubic feet/4<sup>th</sup> calendar quarter, and 10.950 million cubic feet/year. [District Rule 3.4/C-00-191]
19. For the boiler operating under P-91-02, the maximum amount of natural gas consumption shall not exceed 48,000 cubic feet/day, 2.700 million cubic feet/1<sup>st</sup> calendar quarter, 2.730 million cubic feet/2<sup>nd</sup> calendar quarter, 2.760 million cubic feet/3<sup>rd</sup> calendar quarter, 2.760 million cubic feet/4<sup>th</sup> calendar quarter, and 10.950 million cubic feet/year. [District Rule 3.4/C-00-196]
20. For the boiler operating under P-28-03, the maximum amount of natural gas consumption shall not exceed 47,000 cubic feet/day, 4.212 million cubic feet/1<sup>st</sup> calendar quarter, 2.129 million cubic feet/2<sup>nd</sup> calendar quarter, 2.153 million cubic feet/3<sup>rd</sup> calendar quarter, 4.306 million cubic feet/4<sup>th</sup> calendar quarter, and 12.800 million cubic feet/year. [District Rule 3.4/C-02-353]
21. For the boilers operating under P-64-03(a), the maximum amount of natural gas consumption for all four boilers shall not exceed 38,000 cubic feet/day, 3.439 million cubic feet/1<sup>st</sup> calendar quarter, 3.477 million cubic feet/2<sup>nd</sup> calendar quarter, 3.515 million cubic feet/3<sup>rd</sup> calendar quarter, 3.515 million cubic feet/4<sup>th</sup> calendar quarter, and 13.946 million cubic feet/year. [District Rule 3.4/C-04-22]
22. For the boiler operating under P-65-03, the maximum amount of natural gas consumption shall not exceed 27,400 cubic feet/day, 2.462 million cubic feet/1<sup>st</sup> calendar quarter, 2.490 million cubic feet/2<sup>nd</sup> calendar quarter, 2.517 million cubic feet/3<sup>rd</sup> calendar quarter, 2.517 million cubic feet/4<sup>th</sup> calendar quarter, and 9.986 million cubic feet/year. [District Rule 3.4/C-02-331]
23. For the boiler operating under P-101-03, the maximum amount of natural gas consumption shall not exceed 51,600 cubic feet/day, 0.968 million cubic feet/1<sup>st</sup> calendar quarter, 0.978 million cubic feet/2<sup>nd</sup> calendar quarter, 0.989 million cubic feet/3<sup>rd</sup> calendar quarter, 0.989 million cubic feet/4<sup>th</sup> calendar quarter, and 3.924 million cubic feet/year. [District Rule 3.4/C-02-335]
24. For the boilers operating under P-63-06(a), the maximum amount of natural gas consumption from boiler #3 shall not exceed 7,224 cubic feet/day, 0.181 million cubic feet/1<sup>st</sup> calendar quarter, 0.181 million cubic feet/2<sup>nd</sup> calendar quarter, 0.181 million cubic feet/3<sup>rd</sup> calendar quarter, 0.181 million cubic feet/4<sup>th</sup> calendar quarter, and 0.722 million cubic feet/year. The maximum amount of natural gas consumption from boilers #4, #5 and #6 combined shall not exceed 28,656 cubic feet/day, 2.579 million cubic feet/1<sup>st</sup> calendar quarter, 2.608 million cubic feet/2<sup>nd</sup> calendar quarter, 2.636 million cubic feet/3<sup>rd</sup> calendar quarter, 2.636 million cubic feet/4<sup>th</sup> calendar quarter, and 10.459 million cubic feet/year. [District Rule 3.4/C-09-210]
25. For the boiler operating under P-83-06:
  - a. The maximum amount of natural gas consumption shall not exceed 4.32 million cubic feet/day, 388.80 million cubic feet/1<sup>st</sup> calendar quarter, 393.12 million cubic feet/2<sup>nd</sup> calendar quarter, 397.44 million cubic feet/3<sup>rd</sup> calendar quarter, 397.44 million cubic feet/4<sup>th</sup> calendar quarter, and 1,576.80 million cubic feet/year. [District Rule 3.4/C-05-237]

- b. The maximum amount of diesel consumption shall not exceed 32,112 gallons/day, 128,448 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 513,792 gallons/year. [District Rule 3.4/C-05-237]
- 26. For the boiler operating under P-16-08, the maximum amount of natural gas consumption shall not exceed 50,400 cubic feet/day, 4.536 million cubic feet/1<sup>st</sup> calendar quarter, 4.586 million cubic feet/2<sup>nd</sup> calendar quarter, 4.637 million cubic feet/3<sup>rd</sup> calendar quarter, 4.637 million cubic feet/4<sup>th</sup> calendar quarter, and 18.396 million cubic feet/year. [District Rule 3.4/C-07-150]
- 27. For the boiler operating under P-44-11, the maximum amount of natural gas consumption shall not exceed 50,400 cubic feet/day, 2.000 million cubic feet/1<sup>st</sup> calendar quarter, 1.000 million cubic feet/2<sup>nd</sup> calendar quarter, 1.000 million cubic feet/3<sup>rd</sup> calendar quarter, 2.000 million cubic feet/4<sup>th</sup> calendar quarter, and 6.000 million cubic feet/year. [District Rule 3.4/C-11-62]

**B5. Coating Operation - Throughput Limitations:**

- 1. For the coating process operating under P-96-80(a1):
  - a. Metal Parts and Products Coating
    - i. The maximum amount of general coatings shall not exceed 10.0 gallons/day, 179 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 715 gallons/year.
    - ii. The maximum amount of etching filler shall not exceed 1.0 gallons/day, 1 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1 gallons/year.
    - iii. The maximum amount of heat resistant coating shall not exceed 1.0 gallons/day, 2 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 5 gallons/year.
    - iv. The maximum amount of high gloss coatings shall not exceed 5.0 gallons/day, 38 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 150 gallons/year.
    - v. The maximum amount of metallic coatings shall not exceed 1.0 gallons/day, 2 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 5 gallons/year.
    - vi. The maximum amount of extreme performance coatings shall not exceed 1.0 gallons/day, 2 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 5 gallons/year.
    - vii. The maximum amount of high performance architectural coatings shall not exceed 5.0 gallons/day, 13 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 50 gallons/year.
    - viii. The maximum amount of clean-up solvent shall not exceed 2.0 gallons/day, 8 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 30 gallons/year. [District Rule 3.4/C-00-88]
  - b. Wood Products Coating Operation

- i. The maximum amount of clear topcoats shall not exceed 8.0 gallons/day, 56 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 225 gallons/year.
  - ii. The maximum amount of conversion varnish shall not exceed 2.0 gallons/day, 25 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 100 gallons/year.
  - iii. The maximum amount of filler shall not exceed 1.0 gallons/day, 1 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1 gallons/year.
  - iv. The maximum amount of high-solid stains shall not exceed 1.0 gallons/day, 3 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 10 gallons/year.
  - v. The maximum amount of low-solid stains shall not exceed 5.0 gallons/day, 25 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 100 gallons/year.
  - vi. The maximum amount of multi-colored coatings shall not exceed 7.0 gallons/day, 10 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 40 gallons/year.
  - vii. The maximum amount of pigmented coatings shall not exceed 8.0 gallons/day, 25 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 100 gallons/year.
  - viii. The maximum amount of sealer shall not exceed 8.0 gallons/day, 57 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 225 gallons/year. [District Rule 3.4/C-00-88]
- c. Miscellaneous Coating Operation
- i. The maximum amount of miscellaneous coatings shall not exceed 5.0 gallons/day, 15 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 60 gallons/year. [District Rule 3.4/C-00-88]

**B6. Landfill Gas Collection and Soil Vapor Extraction System**

1. For the landfill gas collection and soil vapor extraction system operating under P-14-98:
  - a. The maximum amount of landfill gas collected shall not exceed 172,800 cubic feet/day, 16 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 63 million cubic feet/year. [District Rule 3.4/P-14-98]
  - b. The maximum amount of contaminated soil vapors collected shall not exceed 576,000 cubic feet/day, 52 million cubic feet/gallons/1<sup>st</sup> and 2<sup>nd</sup> calendar quarter, and 53 million cubic feet/3<sup>rd</sup> and 4<sup>th</sup> calendar quarter, and 210 million cubic feet/year. [District Rule 3.4/P-14-98]

**B7. Incinerator**

1. For the incinerator operating under P-81-89(a):
  - a. The maximum amount of natural gas burned shall not exceed 54,000 cubic feet/day, 4 million cubic feet/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 17 million cubic/year. [District Rule 3.4/P-81-89(a)]

- b. The maximum amount of pathological refuse burned shall not exceed 9,000 pound/day, 702,000 lb/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 1,400 tons/year. [District Rule 3.4/P-81-89(a)]
- c. The maximum amount of bio-hazard bags burned shall not exceed 0.01% of pathological refuse/batch on a daily and annual basis. [District Rule 3.4/A-41-88o]

**B8. Woodworking Operations**

- 1. For the woodworking facility operating under P-95-80(a1), the maximum operation hours of the dust collection control equipment shall not exceed 24 hours/day, 2,160 hours/1<sup>st</sup> calendar quarter, 2,184 hours/2<sup>nd</sup> calendar quarter, 2,208 hours/3<sup>rd</sup> calendar quarter, 2,208 hours/4<sup>th</sup> calendar quarter, and 8,760 hours/year. [District Rule 3.4/C-07-25]
- 2. For the woodworking facility operating under P-54-90(a), the maximum operation hours shall not exceed 24 hours/day, 2,160 hours/1<sup>st</sup> calendar quarter, 2,184 hours/2<sup>nd</sup> calendar quarter, 2,208 hours/3<sup>rd</sup> calendar quarter, 2,208 hours/4<sup>th</sup> calendar quarter, and 8,760 hours/year. [District Rule 3.4/C-07-105]
- 3. For the woodworking facility operating under P-43-13, the maximum operation hours shall not exceed 24 hours/day, 2,160 hours/1<sup>st</sup> calendar quarter, 2,184 hours/2<sup>nd</sup> calendar quarter, 2,208 hours/3<sup>rd</sup> calendar quarter, 2,208 hours/4<sup>th</sup> calendar quarter, and 8,760 hours/year. [District Rule 3.4/C-07-105]

**B9. Wastewater Treatment Plant**

- 1. For the wastewater treatment plant operating under P-22-00(a), the maximum amount of wastewater influent shall not exceed 9.4 million gallons/day, 530 million gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 2,120 million gallons/year. [District Rule 3.4/C-06-142]

**B10. Cooling Towers**

- 1. For the cooling towers operating under P-101-02, the maximum amount of process water shall not exceed 8.64 million gallons/day, 777.6 million gallons/1<sup>st</sup> calendar quarter, 786.2 million gallons/2<sup>nd</sup> calendar quarter, 794.9 million gallons/3<sup>rd</sup> calendar quarter, 794.9 million gallons/4<sup>th</sup> calendar quarter, and 3,153.6 million gallons/year. [District Rule 3.4/C-01-62]

**B11. Gasoline and Aviation Storage and Dispensing**

- 1. For the gasoline storage and dispensing facility operating under P-42-76(a3), the maximum amount of gasoline shall not exceed 3,125 gallons/day, 125,000 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 500,000 gallons/year. [District Rule 3.4/C-09-57]
- 2. For the gasoline storage and dispensing facility operating under P-84-93(a1), the maximum amount of gasoline shall not exceed 150 gallons/day, 945 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 3,750 gallons/year. [District Rule 3.4/C-08-97]
- 3. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), the maximum amount of aviation gasoline shall not exceed 1,000 gallons/day, 30,000 gallons/1<sup>st</sup>, 2<sup>nd</sup>, 3<sup>rd</sup>, and 4<sup>th</sup> calendar quarter, and 120,000 gallons/year. [District Rule 3.4/C-11-80]

**C. Applicable Requirements**

**C1. Emergency Diesel Fired Internal Combustion Engines**

The following conditions are applicable to the PTOs and ATCs listed in Table 2:

1. The Permit Holder shall only refuel the IC engine with CARB certified diesel fuel. [District Rule 3.4, Title 17 CCR, Section 93115.5 and/or 40 CFR Part 60.4207]
2. The Permit Holder shall not operate the IC engine more than 200 hours per calendar year. [District Rule 3.4, §110.2]
3. The Permit Holder shall not operate the IC engine for the supplying of power to a serving utility for distribution on the grid. [District Rule 3.4, §110.3]
4. The Permit Holder’s operation of this IC engine for reasons other than maintenance and testing purposes shall be limited to actual interruptions of electrical power by the serving utility. [District Rule 3.4, §110.4]
5. The Permit Holder shall install and maintain a non-resettable hour meter with a minimum display capability of 9,999 hours. [District Rule 3.4, Title 17 CCR, Section 93115.10(e)(1)40 and/or CFR Part 60.4209]

Table 2: Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-89-94(a)	C-02-309		P-15-04	C-03-251
P-90-94(a)	C-02-286		P-74-05	C-05-49
P-91-94(a)	C-02-304		P-38-05	C-05-164
P-92-94(a)	C-02-299		P-115-03	C-03-98
P-94-94(a)	C-02-285		P-117-03	C-02-373
P-95-94(a)	C-02-300		P-118-03	C-03-164
P-96-94(a)	C-02-301		P-119-03	C-02-372
P-99-94(a)	C-02-319		P-120-03	C-03-99
P-100-94(a)	C-02-295		P-121-03	C-03-100
P-101-94(a)	C-02-312		P-59-05	C-05-178
P-102-94(a)	C-02-297		P-49-07	C-07-62
P-108-01	C-01-73		P-50-07	C-07-78
P-103-94(a)	C-02-305		P-51-07	C-07-80
P-107-95(a)	C-02-289		P-52-07	C-07-84
P-126-95(a)	C-02-316		P-53-07	C-07-85
P-209-95(a)	C-02-313		P-59-07	C-07-107
P-29-96(a)	C-02-282		P-2-09	C-08-110

P-69-96(a)	C-02-290		P-4-09	C-08-232
P-32-99	A-7-97-c		P-16-09	C-08-254
P-88-99	C-99-114		P-17-09	C-09-16
P-1-00	C-99-70		P-54-09	C-09-139
P-2-00	C-98-90		P-66-09	C-09-127
P-71-00	C-99-121		P-67-09	C-09-128
P-7-01	C-99-120		P-68-09	C-09-129
P-8-01(a)	C-06-16		P-69-09	C-09-161
P-109-01	C-01-74		P-42-10	C-10-17
P-111-01	C-01-12		P-44-10	C-10-45
P-120-01	C-01-170		P-7-11	C-10-105
P-17-02	C-00-86		P-72-11	C-11-89
P-82-02	C-00-173		P-39-12	C-12-89
P-83-02	C-02-93		P-51-12	C-12-125
P-84-02	C-01-201		P-52-12	C-12-126
P-114-02	C-02-158		P-55-12	C-12-129
P-63-03	C-02-184		P-56-12	C-12-130
P-102-03	C-02-322		P-4-13	C-13-06

The following conditions are applicable to the PTOs and ATCs listed in Table 3:

- 6. The Permit Holder shall not discharge into the atmosphere any air contaminant for a period or periods aggregating more than three (3) minutes in any one (1) hour which is:
  - a. As dark or darker in shade than No. 1 on the Ringelmann Chart; or
  - b. Greater than 20% opacity. [District Rule 2.3]

Table 3. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-42-10	C-10-17		P-51-12	C-12-125
P-44-10	C-10-45		P-52-12	C-12-126
P-7-11	C-10-105		P-55-12	C-12-129
P-72-11	C-11-89		P-56-12	C-12-130
P-39-12	C-12-89		P-4-13	C-13-06

The following conditions are applicable to the PTOs and ATCs listed in Table 4:

- 7. The Permit Holder shall not discharge into the atmosphere any air contaminant for a period or periods aggregating more than three (3) minutes in any one (1) hour which is:
  - a. As dark or darker in shade than No. 1 on the Ringelmann Chart; or
  - b. Greater than 20% opacity. [District Rule 3.1 or 3.4]

Table 4. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-89-94(a)	C-02-309		P-111-01	C-01-12
P-90-94(a)	C-02-286		P-120-01	C-01-170
P-91-94(a)	C-02-304		P-17-02	C-00-86
P-92-94(a)	C-02-299		P-82-02	C-00-173
P-94-94(a)	C-02-285		P-83-02	C-02-93
P-95-94(a)	C-02-300		P-84-02	C-01-201
P-96-94(a)	C-02-301		P-114-02	C-02-158
P-99-94(a)	C-02-319		P-63-03	C-02-184
P-100-94(a)	C-02-295		P-102-03	C-02-322
P-101-94(a)	C-02-312		P-115-03	C-03-98
P-102-94(a)	C-02-297		P-117-03	C-02-373
P-103-94(a)	C-02-305		P-118-03	C-03-164
P-107-95(a)	C-02-289		P-119-03	C-02-372
P-126-95(a)	C-02-316		P-120-03	C-02-322
P-209-95(a)	C-02-313		P-121-03	C-03-100
P-29-96(a)	C-02-282		P-15-04	C-03-251
P-69-96(a)	C-02-290		P-74-05	C-05-49
P-42-97	NA		P-38-05	C-05-164
P-54-97	C-97-118		P-59-05	C-05-178
P-15-98	C-97-115		P-49-07	C-07-62
P-16-98	C-97-82		P-50-07	C-07-78
P-17-98	C-97-130		P-51-07	C-07-80
P-31-98	C-97-65		P-52-07	C-07-84
P-32-98	C-97-66		P-53-07	C-07-85
P-32-99	C-96-67		P-59-07	C-07-107
P-88-99	C-99-114		P-2-09	C-08-110
P-1-00	C-99-70		P-4-09	C-08-232
P-2-00	C-98-90		P-16-09	C-08-254
P-71-00	C-99-121		P-17-09	C-09-16
P-7-01	C-99-120		P-54-09	C-09-139
P-8-01(a)	C-06-16		P-66-09	C-09-127
P-9-01(a)	C-06-15		P-67-09	C-09-128
P-108-01	C-01-73		P-68-09	C-09-129
P-109-01	C-01-74		P-69-09	C-09-161

The following condition is applicable to the PTOs and ATCs listed in Table 5:

8. The Permit Holder shall maintain the engine and control device according to the manufacturer's instructions or alternate procedures approved by the manufacturer. [District Rule 3.4 and 40CFR Part 60.4206 and 60.4211]
9. The Permit Holder shall comply with the applicable requirements of 40 CFR Part 60, Subpart III. [40 CFR Part 60, Subpart III and 40 CFR Part 63, Subpart ZZZZ]

Table 5. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-49-07	C-07-80		P-69-09	C-09-161
P-50-07	C-07-78		P-42-10	C-10-17
P-51-07	C-07-80		P-44-10	C-10-45
P-59-07	C-07-107		P-7-11	C-10-105
P-2-09	C-08-110		P-72-11	C-11-89
P-4-09	C-08-232		P-39-12	C-12-89
P-16-09	C-08-254		P-51-12	C-12-125
P-17-09	C-09-16		P-52-12	C-12-126
P-54-09	C-09-139		P-55-12	C-12-129
P-66-09	C-09-127		P-56-12	C-12-130
P-67-09	C-09-128		P-4-13	C-13-06
P-68-09	C-09-129			

The following condition is applicable to the PTOs and ATCs listed in Table 6:

10. The Permit Holder shall not operate the IC engine more than 50 hours per calendar year for maintenance and testing purposes, and such operation shall be scheduled in cooperation with the District so as to limit air quality impact. [District Rule 3.4, §110.1, Title 17 CCR, Section 93115.6(b)(3)(A) and 40 CFR Part 60.4211]

Table 6. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-8-01(a)	C-06-16		P-59-07	C-07-107
P-109-01	C-01-74		P-2-09	C-08-110
P-111-01	C-01-12		P-4-09	C-08-232
P-120-01	C-01-170		P-16-09	C-08-254
P-84-02	C-01-201		P-17-09	C-09-16
P-114-02	C-02-158		P-54-09	C-09-139
P-102-03	C-02-322		P-66-09	C-09-127

P-15-04	C-03-251		P-67-09	C-09-161
P-74-05	C-05-49		P-68-09	C-09-129
P-38-05	C-05-164		P-69-09	C-09-161
P-115-03	C-03-98		P-42-10	C-10-17
P-117-03	C-02-373		P-44-10	C-10-45
P-118-03	C-03-164		P-7-11	C-10-105
P-120-03	C-03-99		P-72-11	C-11-89
P-121-03	C-03-100		P-39-12	C-12-89
P-59-05	C-05-178		P-51-12	C-12-125
P-49-07	C-07-62		P-52-12	C-12-126
P-50-07	C-07-78		P-55-12	C-12-129
P-51-07	C-07-80		P-56-12	C-12-130
P-52-07	C-07-84		P-56-12	C-12-130
P-53-07	C-08-85		P-4-13	C-13-06

The following condition is applicable to the PTOs and ATCs listed in Table 7:

- The Permit Holder shall not operate the IC engine more than 30 hours per calendar year for maintenance and testing purposes, and such operation shall be scheduled in cooperation with the District so as to limit air quality impact. [District Rule 3.4, §110.1, Title 17 CCR, Section 93115.6(b)(3)(A) and 40 CFR Part 60.4211]

Table 7. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-99-94(a)	C-02-300		P-71-00	C-99-121
P-107-95(a)	C-02-289		P-7-01	C-99-120
P-209-95(a)	C-02-313		P-17-02	C-00-86
P-69-96(a)	C-02-290		P-82-02	C-00-173
P-32-99	A-7-97-c		P-83-02	C-02-93
P-88-99	C-99-114		P-63-03	C-02-184
P-1-00	C-99-70			

The following condition is applicable to the PTOs and ATCs listed in Table 8:

- The Permit Holder shall not operate the IC engine more than 20 hours per calendar year for maintenance and testing purposes, and such operation shall be scheduled in cooperation with the District so as to limit air quality impact. [District Rule 3.4, §110.1, Title 17 CCR, Section 93115.6(b)(3)(A) and 40 CFR Part 60.4211]

Table 8. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
-----------------------------	--	--	--	--

PTO Number	ATC Number		PTO Number	ATC Number
P-89-94(a)	C-02-309		P-102-94(a)	C-02-297
P-90-94(a)	C-02-286		P-108-01	C-01-73
P-91-94(a)	C-02-304		P-103-94(a)	C-02-305
P-92-94(a)	C-02-299		P-126-95(a)	C-02-316
P-94-94(a)	C-02-285		P-26-96(a)	C-02-282
P-95-94(a)	C-02-300		P-2-00(a)	C-98-90
P-96-94(a)	C-02-301		P-117-03	C-02-373
P-100-94(a)	C-02-295		P-119-03	C-02-372

**C2. Natural Gas Fired Internal Combustion Engines**

The following conditions are applicable to the PTOs and ATCs listed in Table 9:

1. The IC engine shall be fired only on Public Utility Commission (PUC) grade pipeline natural gas. [District Rule 3.4]
2. The Permit Holder shall not operate the IC engine more than 50 hours per calendar year for maintenance and testing purposes, and such operation shall be scheduled in cooperation with the District so as to limit air quality impact. [District Rule 3.4, §110.1 and 40 CFR Part 60.4243]
3. The Permit Holder shall not operate the IC engine more than 200 hours per calendar year. [District Rule 3.4, §110.2]
4. The Permit Holder shall not operate this IC engine for the supplying of power to a serving utility for distribution on the grid. [District Rule 3.4, §110.3]
5. The Permit Holder's operation of this IC engine for reasons other than maintenance purposes shall be limited to actual interruptions of electrical power by the serving utility. [District Rule 3.4, §110.4]

Table 9. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-108-95(a)	C-02-311		P-121-95(a)	C-02-283
P-109-95(a)	C-02-314		P-122-95(a)	C-02-288
P-110-95(a)	C-02-303		P-123-95(a)	C-02-292
P-112-95(a)	C-02-296		P-124-95(a)	C-02-321
P-113-95(a)	C-02-306		P-125-95(a)	C-02-287
P-114-95(a)	C-02-307		P-18-98	C-97-119
P-117-95(a)	C-02-318		P-61-00	C-00-105
P-118-95(a)	C-02-308		P-3-09	C-08-193
P-119-95(a)	C-02-302		P-43-10	C-10-38
P-120-95(a)	C-02-317			

The following condition is applicable to the PTO and ATC listed in Table 10:

- 6. The Permit Holder shall not discharge into the atmosphere any air contaminant for a period or periods aggregating more than three (3) minutes in any one (1) hour which is:
  - a. As dark or darker in shade than No. 1 on the Ringelmann Chart; or
  - b. Greater than 20% opacity. [District Rule 2.3]

Table 10. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-43-10	C-10-38			

The following conditions are applicable to the PTOs and ATCs listed in Table 10:

- 7. The Permit Holder shall not discharge into the atmosphere any air contaminant for a period or periods aggregating more than three (3) minutes in any one (1) hour which is:
  - a. As dark or darker in shade than No. 1 on the Ringelmann Chart; or
  - b. Greater than 20% opacity. [District Rule 3.4 or 3.1]

Table 11. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-108-95(a)	C-02-311		P-120-95(a)	C-02-317
P-109-95(a)	C-02-314		P-121-95(a)	C-02-283
P-110-95(a)	C-02-303		P-122-95(a)	C-02-288
P-112-95(a)	C-02-296		P-123-95(a)	C-02-292
P-113-95(a)	C-02-306		P-124-95(a)	C-02-321
P-114-95(a)	C-02-307		P-125-95(a)	C-02-287
P-117-95(a)	C-02-318		P-18-98	C-97-119
P-118-95(a)	C-02-308		P-61-00	C-00-105
P-119-95(a)	C-02-302		P-3-09	C-08-193

The following conditions are applicable to the PTOs and ATCs listed in Table 12:

- 8. The Permit Holder shall operate and maintain the engine and control device according to the manufacturer's emission related instructions or alternate procedures approved by the District. [District Rule 3.4 and 40 CFR Part 60.4234 and 60.4243]
- 9. The Permit Holder shall comply with the applicable requirements of 40 CFR Part 60, Subpart JJJJ. [40 CFR Part 60, Subpart JJJJ and 40 CFR Part 63, Subpart ZZZZ]

Table 12. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
-----------------------------	--	--	--	--

PTO Number	ATC Number		PTO Number	ATC Number
P-3-09	C-08-193		P-43-10	C-10-38

**C3. Portable Internal Combustion Engines**

The following conditions are applicable to the PTOs and ATCs listed in Table 13:

1. The Permit Holder shall not operate the IC engine more than 200 hours per calendar year. [District Rule 3.4, §110.2]
2. The Permit Holder shall not operate the IC engine for the supplying of power to a serving utility for distribution on the grid. [District Rule 3.4, §110.3]
3. The Permit Holder’s operation of the IC engine for reasons other than maintenance purposes shall be limited to actual interruptions of electrical power by the serving utility. [District Rule 3.4, §110.4]
4. The Permit Holder shall not discharge into the atmosphere any air contaminant for a period or periods aggregating more than three (3) minutes in any one (1) hour which is:
  - a. As dark or darker in shade than No. 1 on the Ringelmann Chart; or
  - b. Greater than 20% opacity. [District Rule 3.4 or 3.1]
5. Operation for maintenance and testing purposes shall be limited to 50 hours per year, and such operation shall be scheduled in cooperation with the District so as to limit air quality impact. [District Rule 3.4/C-00-145, and C-00-146 respectively]

Table 13. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-86-01	C-00-145		P-51-99(a)	C-06-18
P-87-01	C-00-146		P-52-99(a)	C-06-19
P-50-99(a)	C-06-17			

**C4. Boilers and Water Heaters**

The following condition is applicable to the PTOs and ATCs listed in Table 14:

1. The boiler(s) shall be fired only on Public Utility Commission (PUC) grade pipeline natural gas. [District Rule 3.4 or District Rule 3.1, §402]

Table 14. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-3-00	C-99-107		P-64-03(a)	C-04-22
P-52-00	C-00-176		P-65-03	C-02-331
P-54-00(a)	C-10-93		P-101-03	C-02-335

P-67-00(a)	C-08-61		P-63-06(a)	C-06-80
P-90-00	C-00-176		P-56-96(a)	C-07-123
P-90-02	C-00-191		P-16-08	C-07-150
P-91-02	C-00-196rev		P-44-11	C-11-62
P-28-03	C-02-353			

The following condition is applicable to the PTOs and ATCs listed in Table 15:

2. The Permit Holder shall not discharge into the atmosphere any air contaminant for a period or periods aggregating more than three (3) minutes in any one (1) hour which is:
  - a. As dark or darker in shade than No. 1 on the Ringelmann Chart; or
  - b. Greater than or equal to 20% opacity. [District Rule 2.3, 3.4 or District Rule 3.1, §402]

Table 15. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-63-06(a)	C-06-80		P-67-00(a1)	C-08-61
P-83-06	C-05-237		P-54-00(a)	C-10-93
P-16-08	C-07-150		P-44-11	C-11-62

3. The boiler operating under P-83-06 shall be fired on Public Utility Commission (PUC) grade pipeline natural gas or diesel fuel. [District Rule 3.4/C-05-237]
4. For the boiler operating under P-83-06, diesel fuel shall only be used when natural gas is unavailable for purchase or for equipment testing or emissions testing. [District Rule 3.4/C-05-237]
5. The boiler operating under P-83-06 shall not combust diesel fuel exceeding 0.0015% sulfur content by weight. [District Rule 3.4/C-05-237]
6. For the boilers operating under P-89-00, P-90-00, P-91-00, and P-96-00, the boilers shall be fired only on Public Utility Commission (PUC) grade pipeline natural gas or #2 fuel oil. Sulfur content of #2 fuel oil shall not exceed 0.05% by weight. [District Rule 3.4/P-89-00, C-98-184, C-98-185, and C-01-39]
7. For the boiler operating under P-90-00, fuel oil #2 shall only be used when natural gas is unavailable for purchase or for equipment testing. The use of fuel oil #2 shall not exceed 301 hours in any one year during natural gas curtailment and shall not exceed 48 hours in any one year for equipment or emissions testing. [District Rule 2.27, §110 and Rule 3.4/C-98-184]
8. For the boiler operating under P-89-00, the emission concentration when firing on Fuel oil #2 shall not exceed the following:
  - a. CO - 400 parts per million by volume, dry, corrected to 3% O<sub>2</sub>;
  - b. NO<sub>x</sub> - 90 parts per million by volume, dry, corrected to 3% O<sub>2</sub>, or 0.120 mmBTU. [District Rule 3.4, §409.2/C-00-41]
9. For the boilers operating under P-90-00 and P-91-00, the emission concentration when firing on natural gas shall not exceed the following:
  - a. CO - 400 parts per million by volume dry, corrected to 3% O<sub>2</sub>;

- b. NOx - 30 parts per million by volume, dry, corrected to 3% O<sub>2</sub>, or 0.036 lbs/mmBTU.  
[District Rule 3.4, §409.2/C-98-184, C-98-185]
10. For the boilers operating under P-90-00 and P-91-00, the emission concentration when firing on fuel oil #2 shall not exceed the following:  
a. CO - 400 parts per million by volume dry, corrected to 3% O<sub>2</sub>;  
b. NOx - 90 parts per million by volume, dry, corrected to 3% O<sub>2</sub>, or 0.120 lbs/mmBTU.  
[District Rule 3.4, §409.2/C-98-184, C-98-185]
11. For the boiler operating under P-96-00, the emission concentration when firing on natural gas shall not exceed the following:  
a. CO - 83 parts per million by volume dry, corrected to 3% O<sub>2</sub>;  
b. NOx - 30 parts per million by volume, dry, corrected to 3% O<sub>2</sub>, or 0.036 lbs/mmBTU.  
[District Rule 3.4, §409.2/C-01-39]
12. For the boiler operating under P-96-00, the emission concentration when firing on fuel oil #2 shall not exceed the following:  
a. CO - 400 parts per million by volume dry, corrected to 3% O<sub>2</sub>;  
b. NOx - 95 parts per million by volume, dry, corrected to 3% O<sub>2</sub>, or 0.127 lbs/mmBTU.  
[District Rule 3.4, §409.2/C-01-39]
13. For the boiler operating under P-83-06, the emission concentrations when firing on natural gas shall not exceed the following:  
a. VOC (as methane) - 10 parts per million by volume, dry, corrected to 3% O<sub>2</sub>;  
b. CO - 5 parts per million by volume, dry, corrected to 3% O<sub>2</sub>;  
c. NOx (as NO<sub>2</sub>) - 9 parts per million by volume, dry, corrected to 3% O<sub>2</sub> (3-hour rolling average);  
d. NOx (as NO<sub>2</sub>) - 5 parts per million by volume, dry, corrected to 3% O<sub>2</sub> (calendar quarter average);  
e. NH<sub>3</sub> - 10 parts per million by volume, dry, corrected to 3% O<sub>2</sub>.  
[District Rule 3.4, §409.2/C-05-237]
14. For the boiler operating under P-83-06, the emission concentrations when firing on diesel fuel shall not exceed the following:  
a. VOC (as methane) - 12 parts per million by volume, dry, corrected to 3% O<sub>2</sub>;  
b. CO - 10 parts per million by volume, dry, corrected to 3% O<sub>2</sub>; and  
c. NOx (as NO<sub>2</sub>) - 13 parts per million by volume, dry, corrected to 3% O<sub>2</sub>;  
d. NH<sub>3</sub> - 10 parts per million by volume, dry, corrected to 3% O<sub>2</sub>.  
[District Rule 3.4, §409.2/C-05-237]
15. If gas is unavailable for purchase, units which normally burn only gas and are subject to the requirements of Section 301 of Rule 2.27 shall comply with a NOx emission limit not to exceed 0.6 lb/mmBtu when burning non-gaseous fuel according to the following equation:

$(X) * (Y) < 36.12$ , where:  
X = lb/mmBtu NOx emission rate, and  
Y = hours of operation per calendar year.  
36.12 = Regulatory constant  
[District Rule 2.27, §110]

16. The hours of operation limit in this exemption shall not include equipment testing and emissions testing time of less than 48 hours per calendar year. [District Rule 2.27, §110]
17. For units with rated heat inputs of greater than or equal to 5 million BTU per hour and annual heat inputs of greater than or equal to 90,000 therms for any single calendar year of the three previous calendar years, NO<sub>x</sub> emissions shall not exceed the following levels:
  - a. 30 parts per million by volume (ppmv), or 0.036 pound per million BTU of heat input when operated on gas; or
  - b. 40 parts per million by volume (ppmv), or 0.052 pound per million BTU of heat input, when operated on non-gaseous fuel; or
  - c. The heat-input weighted average of the limits specified in 301.1 and 301.2 of Rule 2.27, when operated on a combination of gas and non-gaseous fuels. [District Rule 2.27, §301]
18. Emissions from units subject to Section 301 of Rule 2.27 shall not exceed a carbon monoxide concentration of 400 parts per million by volume (ppmv). [District Rule 2.27, §301]
19. For the boilers operating under P-67-98, P-89-00 and P-96-00, no owner or operator of an affected facility that combusts oil shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of 215 ng/J (0.50 lb/million Btu) heat input; or, as an alternative, no owner or operator of an affected facility that combusts oil shall combust oil in the affected facility that contains greater than 0.5 weight percent sulfur. [40 CFR Part 60 Subpart Dc §60.42c(d)]
20. For the boilers operating under P-67-98, P-89-00 and P-96-00, no owner or operator of an affected facility that combusts coal, oil, or coal and oil with any other fuel shall cause to be discharge into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of the emissions limit determined according to the following formula:  
$$ES = (K_a + H_a + K_b + H_b + K_c H_c) / (H_a + H_b + H_c)$$

Where:

Es = SO<sub>2</sub> emission limit, expressed in ng/J or lb/million BTU input;  
Ka = 520 ng/J (1.2lb/million Btu);  
Kb = 260 ng/J (0.60 lb/million Btu);  
Kc = 215 ng/J (0.50 lb/million Btu);  
Ha = the heat input from the combustion of coal, except coal combusted in an affected facility subject to paragraph (b)(2) of § 60.42(c), in J (million Btu)  
Hb = the heat input from the combustion of coal in an affected facility subject to paragraph (b)(2) of § 60.42(c), in J (million Btu);  
Hc = the heat input from the combustion of oil, in J (million Btu).  
[40 CFR Part 60 Subpart Dc, §60.42c]
21. For the boilers operating under P-67-98, P-89-00 and P-96-00, compliance with the emission limits or fuel oil sulfur limits under § 60.42c may be determined based on a certification from the fuel supplier, as described under § 60.48c(f)(1), (2), or (3), as applicable. [40 CFR Part 60 Subpart Dc, §60.42c(h)]

22. For the boilers operating under P-67-98, P-89-00 and P-96-00, only the heat input supplied to the affected facility from the combustion of oil is counted under § 60.42c. No credit is provided for the heat input to the affected facility from wood or other fuels or for heat derived from exhaust gases from other sources, such as stationary turbines or internal combustion engines. [40 CFR Part 60 Subpart Dc, §60.42c(j)]
23. For the boiler operating under P-96-00, no owner or operator of an affected facility that combusts oil and has a heat input capacity of 30 million Btu/hr or greater shall cause to be discharged into the atmosphere from that affected facility any gases that exhibit greater than 20 percent opacity (6 minute average), except for one 6-minute period/hour of not more than 27 percent opacity. [40 CFR Part 60 Subpart Dc, §60.43c(c)]
24. For the boiler operating under P-96-00, the PM opacity standards under §60.43c apply at all times, except during periods of startup, shutdown, or malfunction. [40 CFR Part 60 Subpart Dc, §60.43c(d)]
25. For the boiler operating under P-83-06, the Permit Holder shall comply with the applicable requirements of 40 CFR Part 60, Subpart A and Subpart Db. [40 CFR Part 60 Subpart A and Subpart Db/C-05-237]
26. For the boiler operating under P-83-06, the Permit Holder shall calibrate, maintain, and operate a CEMS for NO<sub>x</sub> and O<sub>2</sub> in the exhaust gas stack. [40 CFR Part 60.48b(b)(1)/C-05-237]
27. For the boiler operating under P-83-06, the CEMS shall comply with the requirements of 40 CFR Part 60, Appendix B and Appendix F. [40 CFR Part 60.13(a) & 40 CFR Part 60, Appendix B and Appendix F/C-05-237]
28. For the boiler operating under P-83-06, the CEMS shall be evaluated and operated as specified in 40 CFR Part 60.13. [40 CFR Part 60.13 & 60.48b(e)/C-05-237]
29. The CEMS span value for NO<sub>x</sub> shall be 500 ppm, or an alternative span value as approved by the District. If a District approved alternative span value for NO<sub>x</sub> is exceeded due to emissions from the boiler:
  - a. The CEMS span value for NO<sub>x</sub> shall revert to 500 ppm; or
  - b. The Permit Holder shall propose another alternative span value for District approval. [40 CFR Part 60.48b(e)(2) & District Rule 3.4/C-05-237]
30. For the boiler operating under P-83-06, the CEMS shall be operated, and data recorded, during all periods of operation of the boiler except for CEMS breakdowns and repairs. CEMS data shall be recorded during calibration checks, and zero and span adjustments. [40 CFR Part 60.48b(c)/C-05-237]
31. For the boiler operating under P-83-06, NO<sub>x</sub> emission rates measured by the CEMS shall be expressed in pounds per million British Thermal Unit (BTU), or other measurement unit that can be directly correlated to pounds per million BTU. [40 CFR Part 60.48b(d)/C-05-237]
32. For the boiler operating under P-83-06, when NO<sub>x</sub> emission data is not obtained because of CEMS breakdowns, repairs, calibration checks, and zero and span adjustments, the Permit Holder shall obtain emission data by using a standby monitoring system, EPA Method 7, EPA Method 7A, or other approved reference methods to provide emission data for a minimum of 75 percent of the operating hours each day the boiler is operated, in at least 22 out of 30 successive days the boiler is operated. [40 CFR Part 60.48b(f)/C-05-237]

33. For the boiler operating under P-83-06, the Permit Holder shall notify the District of any violation of the 3-hour rolling average NOx emission concentration limitation, as indicated by the CEMS, within 96 hours after such occurrence. [District Rule 3.4/C-05-237]
34. For the boiler operating under P-83-06, a written quality assurance (QA) program shall be established in accordance with 40 CFR Part 60, Appendix B and 40 CFR Part 60, Appendix F. [40 CFR Part 60, Appendix B and Appendix F/C-05-237]

**C5. Coating Operation**

1. The provisions of Section 301 of Rule 2.25 shall not apply to coatings used in volumes of less than 50 gallons per year. [District Rule 2.25, §110/P-96-80(a1)]
2. The provisions of Section 302 of Rule 2.25 shall not apply to the application of touch-up coatings, repair coatings, textured finish coatings, metallic coatings which have a metallic content of more than 30 grams per liter, mold seal coatings, and to facilities that use less than one (1) gallon of coating per day, as applied, including any VOC-containing material added to the original coating as supplied by the manufacturer. [District Rule 2.25, §112/P-96-80(a1)]
3. The Permit Holder shall not apply to metal parts and products any coating, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified in Table 16: [District Rule 2.25, §301/P-96-80(a1)]

Table 16. Metal Parts and Products Coating Limits

COATING VOC CONTENT* GRAM/LITER (LBS/GAL)		
Coating Category	Baked	Air Dried
<b>General Coatings:</b>	275 (2.3)	340 (2.8)
<b>Specialty Coatings:</b> Etching Filler	420 (3.5)	420 (3.5)
Solar-Absorbent	360 (3.0)	420 (3.5)
Heat-Resistant	360 (3.0)	420 (3.5)
High Gloss	360 (3.0)	420 (3.5)
Metallic	360 (3.0)	420 (3.5)
Extreme Performance	420 (3.5)	420 (3.5)
Silicone Release	420 (3.5)	420 (3.5)
High Performance	420 (3.5)	420 (3.5)
Camouflage	360 (3.0)	420 (3.5)
Vacuum-Metalizing	420 (3.5)	420 (3.5)
Mold-Seal	420 (3.5)	420 (3.5)
High Temperature	420 (3.5)	420 (3.5)
Pan Backing	420 (3.5)	420 (3.5)
Pretreatment Wash Primer**	420 (3.5)	420 (3.5)

\* Units are grams of VOC per liter of coating (pounds per gallon), less water and exempt compounds.  
 \*\* No maximum solids content restriction.

4. The Permit Holder shall not apply coatings to metal parts and products unless the coatings are applied using properly operated equipment, and by using one of the following application methods or other

high transfer efficiency application equipment which has been approved, in writing, by the Air Pollution Control Officer:

- a. Electrostatic attraction operated in accordance with manufacturer's recommendations;
  - b. High-volume, low-pressure (HVLP) spray system operated in accordance with manufacturer's recommendations;
  - c. Flow coat;
  - d. Dip coat;
  - e. Hand coat;
  - f. Roll coat; or
  - g. Any other coating application method demonstrated, in accordance with the provisions of Section 608 to have a transfer efficiency equivalent to or greater than the coating application method listed in Section 302.2, and is approved in writing by the EPA and APCO. [District Rule 2.25, §302 and 3.1/P-96-80(a1)]
5. The maximum as-applied VOC-content of solvents used for product cleaning and general maintenance and repair operations shall not exceed 25 g/L (0.4 lb/gallon). [District Rule 3.1 /P-96-80(a1)]
6. The Permit Holder shall only use the following methods to apply solvents with a VOC-content greater than 25 g/l (0.21 lb/gallon) for surface preparation:
- a. Wipe Cleaning;
  - b. Spray bottles or containers with a maximum capacity of 16 fluid ounces from which solvents are applied without a propellant-induced force.
  - c. Any other method approved by the District [District Rule 3.1 /P-96-80(a1)]
7. The Permit Holder shall store all VOC-containing materials in non-absorbent, non-leaking containers. The containers are to be kept closed at all times except when filling or emptying. [District Rule 2.25, 2.31 and 3.1/P-96-80(a1)]
8. The Permit Holder shall use closed containers for the disposal of cloth, paper, or other VOC laden materials (including solvent and spent solvent used for surface preparation, clean-up, and paint removal). [District Rule 2.25, 2.31 and 3.1/P-96-80(a1)]
9. The Permit Holder shall not use VOC containing materials with a VOC content greater than 25 g/l (0.21 lb/gallon) for the cleanup of coating equipment in the gun washer. [District Rule 2.31 and 3.1]
10. The Permit Holder shall not apply any coating to any wood product unless the following type of application equipment is used [District Rule 3.1 and 2.39, §301/P-96-80(a1)]:
- a. Electrostatic;
  - b. High volume low pressure (HVLP);
  - c. Flow coat;
  - d. Dip coat;
  - e. Hand application;
  - f. Roll coater;
  - g. Low volume low pressure (LVLP);
  - h. Air assisted airless;
  - i. Any other equivalent method which has been approved in writing by the Air Pollution Control Officer and the U.S. Environmental Protection Agency.

11. Except as provided in Sections 110 through 113, 305, and 306, of Rule 2.39 the Permit Holder shall not apply any coating, to a new wood product, which has a volatile organic compound (VOC) content exceeding the applicable limits specified below. The VOC content of coatings, except low-solid stains, toners, and washcoats, shall be determined in accordance with Sections 403 and 503.1 of Rule 2.39. The VOC content of low-solid stains, toners, and washcoats shall be determined in accordance with Section 404 and Section 503.1 of Rule 2.39. VOC limits are listed in Table 17 as grams per liter of coating, less water and exempt solvents. [District Rule 3.1 and 3.39, §302/C-00-88]

Table 17. Limits VOC-Less Water and Exempt Compounds

LIMITS VOC - Less Water and Less Exempt Compounds (Grams per Liter)		
Coating	On or After July 1, 1999	On or After September 1, 2005
Clear Topcoats	550	275
Conversion Varnish	550	550
Filler	500	275
High-solid Stains	550	350
Low-solid Stains	480	120
Multi-colored Coatings	685	275
Pigmented Coatings	550	275
Sealer	550	275

12. The Permit Holder shall store VOC containing materials (as defined in Rule 1.1) in containers which are closed when not in use, and shall dispose of such materials in a manner that the VOC are not emitted into the atmosphere. [District Rule 3.1 and 2.39, §306.3/C-00-88]
13. For the coating operation operating under P-96-80(a1), all painting shall be conducted in booth with filters in place, fan operating, and doors closed. [District Rule 3.4, §409.1/C-00-88]
14. For the metal and wood parts and products coating operation operating under P-96-80-(a1), the Permit Holder shall not coat any other products using any coating with a VOC content in excess of 550 grams/liter, excluding water and exempt compounds. [District Rule 3.1, §402/C-00-88]
15. The Permit Holder shall not apply a coating to metal or plastic components containing the following compounds in the stated amounts:
- a. Cadmium (Cd), Chromium (Cr), lead (Pb), or nickel (Ni) in amounts greater than or equal to 0.1% by mass; or
  - b. Manganese (Mn) in amounts greater than or equal to 1.0% by mass. [District Rule 3.1, §402/P-96-80(a1)]
16. The Permit Holder shall not use any chemical strippers containing methylene chloride (MeCl) to remove dried coatings. [District Rule 3.1, §402/P-96-80(a1)]

**C6. Landfill Gas Collection and Soil Vapor Extraction System**

1. Any MSW Landfill with a design capacity less than 2.5 million megagrams by mass or 2.5 million cubic meters by volume that has accepted waste at any time since November 8, 1987 shall be subject to the requirements of the initial design capacity report in accordance with 40 CFR 60.752. [District Rule 2.38, §102.1]

**C7. Incinerator**

1. No person shall burn any combustible refuse except that which may be burned in an open outdoor fire, in any incinerator within the boundaries of the Yolo-Solano Air Pollution Control District except in a multiple-chamber incinerator or in equipment found by the Air Pollution Control Officer to be equally effective for the purpose of air pollution control. [District Rule 2.10]
2. For the multiple chamber incinerator and ash collection system operating under P-81-89(a), a maximum batch charge rate shall not exceed 2,500 lbs without prior approval from the APCO (This is less than the maximum charge rate listed on the approved application, but is consistent with the source test performed on October 6, 1988). [District Rule 3.4/P-81-89(a)]
3. For the multiple chamber incinerator and ash collection system operating under P-81-89(a), a copy of the operating procedures incorporating limitations shall be submitted to the District. The approved operating instructions are to be posted adjacent to, or on, the equipment. [District Rule 3.4/P-81-89(a)]
4. For the multiple chamber incinerator and ash collection system operating under P-81-89(a), the burner shall be operated within the temperature ranges as stated on the original contract for the equipment: After warmup, the incinerator shall maintain temperatures of at least 1200°F in the primary combustion chamber and 1600°F to 1800°F in the secondary combustion chamber, with momentary and infrequent peaks not to exceed 2000°F. [District Rule 3.4/P-81-89(a)]
5. For the multiple chamber incinerator and ash collection system operating under P-81-89(a), the ash storage bin shall be closed at all times except when ash is transferred in or out of the bin. [District Rule 3.4/P-81-89(a)]

**C8. Woodworking Operations**

1. For the woodworking facilities operating under P-95-80(a1), the Permit Holder shall not discharge into the atmosphere, from the dust collection system, any air contaminant for a period or periods aggregating more than three (3) minutes in any one (1) hour which is:
  - a. As dark or darker in shade than No. 1/4 on the Ringelmann Chart; or
  - b. Greater than 5% opacity. [District Rule 3.4/C-07-25]
2. For the woodworking facilities operating under P-95-80(a1), ~~and P-54-90(a)~~, and P-43-13 the Permit Holder shall not discharge into the atmosphere, from any single source of emission whatsoever, any air contaminant for a period or periods aggregating more than three (3) minutes in any one (1) hour which is:
  - a. As dark or darker in shade than No. 1 on the Ringelmann Chart; or
  - b. Greater than 20% opacity. [District Rule 3.4/ C-07-25 and District Rule 2.3 and District Rule 3.4/C-07-105]

3. For the woodworking facilities operating under P-54-90(a) and P-43-13, the Permit Holder shall not discharge into the atmosphere, from the dust collection system, any air contaminant for a period or periods aggregating more than three (3) minutes in any one (1) hour which is:
  - a. As dark or darker in shade than No. 1/4 on the Ringelmann Chart; or
  - b. Greater than 5% opacity. [District Rule 3.4/C-07-105 and C-13-84]
4. For the woodworking facilities operating under P-95-80(a1) ~~and~~ P-54-90(a), and P-43-13 all control equipment, including ducts, shall be properly maintained, kept in good operating condition per manufacturer's specifications, and be operated at all times in conjunction with its associated process. [District Rule 3.4/C-07-25, ~~and C-07-105~~, and C-13-84]
5. For the woodworking facilities operating under P-95-80(a1), the Permit Holder shall dispose of all material collected by the dust collection system in a manner preventing its entrainment into the atmosphere. [District Rule 3.4/C-07-25]
6. For the woodworking facilities operating under P-54-90(a) and P-43-13, the Permit Holder shall dispose of all material collected in the control equipment in a manner to minimize the release of the collected material into the atmosphere. [District Rule 3.4/C-07-105 and C-13-84]
7. For the woodworking facilities operating under P-95-80(a1), the Permit Holder shall maintain a complete list of all equipment associated with the process, which includes a description and horsepower rating for each piece of woodworking equipment. The electric motors serving the equipment may be changed so long as the total cumulative horsepower of the motors does not exceed the amount listed in the billing schedule. This list shall be maintained with the Permit to Operate and made available to the District upon request. [District Rule 3.4/C-07-25]
8. For the woodworking facilities operating under P-54-90(a) and P-43-13 ~~T~~the Permit Holder shall maintain a complete list of all equipment associated with the process, which includes a description and horsepower rating for each piece of woodworking equipment and the rating of the associated the control equipment in cubic feet per minute (CFM). This list shall be maintained with the Permit to Operate and shall be made available to the District upon request. [District Rule 3.4/C-07-105 and C-13-84]

#### **C9. Cooling Towers**

1. For the cooling towers operating under P-101-02,
  - a. The maximum total dissolved solids for the cooling tower water shall not exceed 700 ppm. [District Rule 3.4/C-01-62]
  - b. The drift loss associated with the cooling towers shall not exceed 0.0017%. [District Rule 3.1, §402/C-01-62]
  - c. The Permit Holder shall use only rust inhibiting products that do not contain VOCs. [District Rule 3.1, §402/C-01-62]
2. The Permit Holder shall not use or allow the use of chromium containing compounds in the treatment of cooling tower circulating water. [District Rule 9.3 §c.1.]

**C10. Gasoline Storage and Dispensing**

1. A person shall not store gasoline in open container(s) of any size or handle gasoline in any manner (spillage, spraying, etc.) that allows gasoline liquid or gasoline vapors to enter the atmosphere, contaminate the ground, or the public sewer system. [District Rule 2.22, §301]
2. A person shall not top off motor vehicle fuel tanks. [District Rule 2.22, §303]
3. A person shall not transfer, allow the transfer or provide equipment for the transfer of gasoline from any transport vessel into any storage tank with a capacity of 251 gallons or more unless all of the following conditions are met:
  - a. Such storage tank is equipped with a California Air Resources Board (CARB) certified vapor recovery system that recovers or processes displaced gasoline vapors by at least 95% by weight, or having a minimum volumetric efficiency of 98% and an emission factor not exceeding 0.15 pounds per 1,000 gallons, as applicable. [District Rule 2.22, §304.1]
  - b. The vapor recovery system shall be maintained and operated according to the manufacturer's specifications and as per the most recent applicable CARB Executive Orders. [District Rule 2.22, §304.2]
  - c. All vapor return lines are connected between the transport vessel and the storage tank while gasoline is transferred, and all associated hoses, fittings, and couplings are maintained in a liquid tight and vapor tight condition. [District Rule 2.22, §304.3]
  - d. Such storage tank is equipped with a CARB certified submerged fill tube. [District Rule 2.22, §304.4]
  - e. The fill tube shall be maintained liquid tight, vapor tight, and free of air ingestion. A fill tube that is free of air ingestion is determined by observing the gasoline stream as clear and free of air bubbles through the sight windows on the fill tube, except during the initial and final 60 seconds of gasoline transfer. [District Rule 2.22, §304.5]
  - f. The following equipment shall be installed, operated and maintained as specified below:
    - i. All fill tubes are equipped with vapor tight caps;
    - ii. All dry breaks are equipped with vapor tight seals and vapor tight caps;
    - iii. All CARB certified coaxial fill tubes are spring-loaded and operated so that the vapor passage from the storage tank back to the transport vessel is not obstructed;
    - iv. The fill tube assembly, including fill tube, fittings and gaskets, is maintained to prevent vapor leakage from any portion of the vapor recovery system;
    - v. All storage tank vapor return lines without dry breaks are equipped with vapor tight caps;
    - vi. Each vapor tight cap is in a closed position except when the fill tube or dry break it serves is actively in use; and
    - vii. Each gasoline delivery elbow is equipped with sight windows. [District Rule 2.22, §304.6]
  - g. Except when otherwise specified in the most recent applicable CARB Executive Orders, the Phase I vapor recovery system shall be of dual-point design and equipped with CARB

certified poppetted dry breaks or spring-loaded vapor check valves on the vapor return coupler. [District Rule 2.22, §304.8]

- h. The hatch on any transport vessel shall be equipped and operated with a vapor tight cover during gasoline transfer and pumping. The hatch shall not be opened except for visual inspection, which may be performed after at least 3 minutes following the completion of the gasoline transfer or pumping. Except otherwise specified by CARB, visual inspection shall be completed in 3 minutes or less. [District Rule 2.22, §304.9]
  - i. All open pipe vents on stationary tanks at gasoline dispensing facilities shall be equipped with a pressure-vacuum relief valve. Unless otherwise specified in the most recent applicable CARB Executive Orders, the pressure relief for an underground storage tank shall be set for pressure relief at  $3 \pm 0.5$  inches water column and vacuum relief at  $8 \pm 0.5$  inches water column. For the purpose of this section, vent pipes of storage tanks may be manifolded according to the most recent applicable CARB Executive Order. [District Rule 2.22, §304.10]
  - j. The vent pipe opening on underground tanks shall be at least 12 feet above the driveway level used for transport vessel filling. [District Rule 2.22, §304.12]
4. A person shall not dispense or allow the dispensing or provide equipment for the dispensing of gasoline to a motor vehicle fuel tank with a capacity of greater than 5 gallons from a gasoline dispensing system unless all of the following requirements are met:
- a. The transfer is made with a dispensing unit that is equipped with a CARB certified Phase II vapor recovery system to recover or process displaced gasoline vapors at an efficiency of at least 95% by weight, or having an emission factor not exceeding 0.38 pounds per 1,000 gallons of gasoline dispensed, as applicable. [District Rule 2.22, §305.1]
  - b. The vapor recovery system and associated components shall be operated and maintained in a manner in accordance with the manufacturer's specifications and as per the most recent applicable CARB Executive Orders. [District Rule 2.22, §305.2]
  - c. The vapor recovery system and associated components shall be operated and maintained free of major defects and in a vapor and liquid tight condition at all times. [District Rule 2.22, §305.3]
  - d. Where District personnel determines that any vapor recovery component contains a minor defect, District personnel shall provide the owner/operator with a notice of correction specifying the basis on which the component is deemed defective. The owner/operator shall repair or replace such component and provide the District with adequate evidence that the component is in good working order within 7 days of receiving the notice. Furthermore, if the Air Pollution Control Officer (APCO) makes a determination that any vapor recovery component may not be in compliance with any provision of this rule, the APCO may require the owner/operator to conduct and successfully pass an applicable test in accordance with the test methods and procedures specified in Section 600 of Rule 2.22 to verify compliance. [District Rule 2.22, §305.4]
  - e. Each balance-system nozzle shall be equipped with a CARB certified insertion interlock mechanism and a CARB certified vapor check valve. [District Rule 2.22, §305.5]

- f. All balance-system nozzle boots shall be replaced at least once per year and tested to verify compliance with the vapor path leak requirements and a record made in the maintenance log prior to continued operation. [District Rule 2.22, §305.6]
- g. Each gasoline-dispensing nozzle shall be equipped with a CARB certified coaxial hose. [District Rule 2.22, §305.7]
- h. Unless otherwise specified in the most recent applicable CARB Executive Orders, all liquid removal devices installed for any gasoline-dispensing nozzle with a dispensing rate of greater than 5 gallons per minute shall be CARB certified with a minimum liquid removal rate of 5 milliliters per gallon dispensed. [District Rule 2.22, §305.8]
- i. Each breakaway coupling shall be CARB certified and shall be equipped with a poppet valve. The poppet valve shall close and maintain both the gasoline vapor and liquid lines vapor tight and liquid tight when the coupling is separated. [District Rule 2.22, §305.9]
- j. In the event of a separation of a hose from the dispenser or a hose from the nozzle (i.e., "driveoff"), the owner/operator shall complete one of the following and document the repair activities as specified in Section 502 of Rule 2.22:
  - i. Conduct a visual inspection of the affected equipment and perform qualified repairs on any damaged components before placing the affected equipment back in service. In addition, the applicable reverification tests as specified in Section 309.1 of Rule 2.22 shall be conducted and successfully passed within 24 hours after the affected equipment is placed back in service, or
  - ii. Conduct a visual inspection of the affected equipment and replace the affected nozzles, coaxial hoses, breakaway couplings, and any other damaged components with new or certified rebuilt components that are CARB certified, before placing any affected equipped back in service.

The owner/operator shall notify the District within 24 hours of completing the requirements specified in Sections 305.10.a or 305.10.b of Rule 2.22. [District Rule 2.22, §305.10]

- 5. The owner/operator shall not operate or resume operation of a gasoline dispensing facility, unless the facility has successfully passed the applicable performance or reverification tests. Notwithstanding the above, when a dispenser associated with any equipment that has failed a reverification test is isolated and shut down, the owner/operator may continue operation or resume operation of the remaining equipment at the facility, provided that test results demonstrate that the remaining equipment is in good operating condition. All test results and the method of isolating the defective equipment shall be documented in the test reports to be submitted to the APCO pursuant Section 502.3 of Rule 2.22. [District Rule 2.22, §309.6]
- 6. Whenever the Air Pollution Control Officer determines that a Phase II vapor recovery system, or any component thereof, contains a defect specified by the California Air Resources Board pursuant to Section 41960.2(c) of the California Health and Safety Code, the Air Pollution Control Officer shall mark such a system or component "Out of Order." No person shall use or permit the use of such marked component or system until it has been repaired, replaced, or adjusted, as necessary, and the APCO has reinspected it or has authorized its use pending reinspection. [District Rule 2.22, §310]

7. Any equipment subject to the provisions of this rule that fails to meet the requirements contained in Section 305 of Rule 2.22 shall be tagged "Out of Order." Such failures shall constitute a violation of this rule. Except during repair activity, the "Out of Order" tag shall not be removed and the tagged equipment shall not be used, permitted to be used, or provided for use unless all of the following conditions are met:
  - a. The tagged equipment has been repaired, replaced, or adjusted, as necessary;
  - b. The District has been notified of the repairs by completing and signing the form supplied by the District; and
  - c. The tagged equipment has been reinspected and/or authorized for use by the APCO.

Failure of any of the test methods specified in Section 600 of Rule 2.22 shall constitute a violation of this rule. [District Rule 2.22, §402]

#### **C11. Aviation Gasoline Storage and Dispensing**

- 1 The vapor recovery system shall be maintained and operated according to the manufacturer's specifications and as per the most recent applicable CARB Executive Order. [District Rule 2.21, §311.3/C-11-80]
- 2 Organic liquids subject to District Rule 2.21 shall not be discarded to public sewers, stored in open containers, or handled in any other manner that would result in evaporation to the atmosphere. [District Rule 2.21, §314/C-11-80]
- 3 For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), all vapor return lines shall be connected between the transport vessel and the storage tank while aviation gasoline is transferred. [District Rule 3.4/C-11-80]
- 4 For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), the vapor recovery system and associated components shall be operated and maintained free of major defects and in a vapor and liquid tight condition at all times. [District Rule 3.4/C-11-80]

#### **D. Monitoring and Testing Requirements**

##### **D1. Boilers and Water Heaters**

1. For the boilers operating under P-67-98 and P-89-00, compliance with NO<sub>x</sub> and CO emissions shall be demonstrated at least triennially via a source test. Source test results shall be submitted to the District within 60 days of the test. [District Rule 3.4/C-98-14 and C-00-41]
2. For the boilers operating under P-67-98 and P-89-00, a source test protocol shall be submitted to the District two (2) weeks prior to a proposed source test date. [District Rule 3.4/C-98-14 and C-00-41]

The following condition is applicable to the PTOs and ATCs listed in Table 18:

3. A non-resettable, totalizing gaseous fuel flow meter shall be installed and utilized to measure the quantity (in cubic feet) of natural gas combusted by the boiler(s). [District Rule 3.4 or District Rule 3.1, §402]

Table 18. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-54-00(a)	C-10-93		P-16-08	C-07-150
P-28-03	C-02-353		P-67-00(a1)	C-08-61
P-63-06(a)	C-06-80		P-44-11	C-11-62
P-56-96(a)	C-07-123			

4. For the boiler operating under P-83-06, a non-resettable, totalizing gaseous fuel flow meter or other District approved fuel tracking technology shall be installed and utilized to measure the quantity (in cubic feet) of natural gas combusted by the boiler(s). [District Rule 3.4 or District Rule 3.1, §402]
5. For the boiler operating under P-83-06, a non-resettable, totalizing liquid fuel flow meter or other District approved fuel tracking technology shall be installed and utilized to measure the quantity (in gallons) of diesel fuel combusted in the boiler. [District Rule 3.4/C-05-237]
6. For the boilers operating under P-64-03(a), P-65-03, and P-101-03 the Permit Holder shall perform a tune-up per manufacturer's specifications on each boiler at least once every 12 months. [District Rule 3.4/C-04-22, C-02-331, and C-02-335]
7. For the boiler operating under P-83-06, the Permit Holder shall perform a source test at least once every twelve (12) months to demonstrate compliance with the following emission limitations:
  - a. VOC concentration (ppmvd @ 3% O<sub>2</sub>);
  - b. CO concentration (ppmvd @ 3% O<sub>2</sub>);
  - c. NO<sub>x</sub> concentration (ppmvd @ 3% O<sub>2</sub>);
  - d. NH<sub>3</sub> concentration (ppmvd @ 3% O<sub>2</sub>). [District Rule 3.4/C-05-237]
8. For the boiler operating under P-83-06, annual source tests shall include emissions testing for each fuel that was combusted by the boiler during the previous one (1) year period. If diesel was only used for testing and maintenance purposes during the previous one (1) year period, the annual source test only needs to be performed for natural gas. [District Rule 3.4/C-05-237]
9. For the boiler operating under P-83-06, source testing shall be conducted using the following test methods (or equivalent methods as approved by the District):
  - a. VOC - EPA method 18 or 25, or CARB method 100;
  - b. CO - EPA method 10, or CARB method 100;
  - c. NO<sub>x</sub> (as NO<sub>2</sub>) - EPA method 7E, or CARB method 100;
  - d. Stack gas oxygen - EPA method 3 or 3a, or CARB Method 100;
  - e. Flow rate - EPA method 19, or CARB Methods 1-4; and
  - f. NH<sub>3</sub> - Bay Area Air Quality Management District (BAAQMD) Method ST-1B. [District Rule 2.27, §502.1 & §502.2, & District Rule 3.4/C-05-237]

10. For the boiler operating under P-83-06, the Permit Holder shall perform a Relative Accuracy Test Audit (RATA) on the CEMS at least once every twelve (12) months. The RATA shall be performed in accordance with 40 CFR Part 60, Appendix B (PERFORMANCE SPECIFICATIONS). [District Rule 3.4/C-05-237]
11. For the boiler operating under P-83-06, the District must be notified prior to any compliance source test and/or RATA, and a source test/RATA protocol must be submitted for approval 30 days prior to testing. The results of the source test/RATA shall be submitted to the District within 60 days of the test date. The protocol and report shall be mailed to the attention of the Supervising Air Quality Engineer. [District Rule 3.4/C-05-237]
12. For the boilers operating under P-63-06(a), the Permit Holder shall perform a tune-up per manufacturer's specifications on the boiler equipped with a low-NOx burner (Boiler #6) at least once every 12 months. [District Rule 3.4/C-09-210]
13. For the boiler operating under P-16-08, the Permit Holder shall perform a tune-up, per manufacturer's specifications, on the boiler at least once every 12 months. [District Rule 3.4/C-07-150]
14. An owner or operator shall have the option of complying with either the pounds-per-million-Btu emission rates or the parts-per-million-by-volume emission limits specified in Section 301. [District Rule 2.27, §402.1]
15. All emission determinations shall be made in the as-found operating condition, except that emission determinations shall include at a minimum at least one source test conducted at the maximum firing rate allowed by the District permit, and no compliance determination shall be established within two hours after a continuous period in which fuel flow to the unit is zero, or shut off, for thirty minutes or longer. [District Rule 2.27, §402.2]
16. All ppmv emission limits specified in Sections 110 and 301 of Rule 2.27 are referenced at dry stack-gas conditions and 3.00 percent by volume stack-gas oxygen. Emission concentrations shall be corrected to 3.00 percent oxygen as follows [District Rule 2.27, §402.3]:

$$[\text{ppm NOx}]_{\text{corrected}} = \frac{20.95\% - 3.00\%}{20.95\% - [\% \text{O}_2]_{\text{measured}}} * [\text{ppm NOx}]_{\text{measured}}$$

$$[\text{ppm CO}]_{\text{corrected}} = \frac{20.95\% - 3.00\%}{20.95\% - [\% \text{O}_2]_{\text{measured}}} * [\text{ppm CO}]_{\text{measured}}$$

17. All pounds-per-million-BTU emission rates shall be calculated as pounds of nitrogen dioxide (NO<sub>2</sub>) per million Btu of heat input. [District Rule 2.27, §402.4]

18. All emission concentrations and emission rates shall be based on 15-consecutive-minute averages. These averages shall be calculated from no less than five data sets, recorded from sampling on intervals of no greater than three minutes. [District Rule 2.27, §402.5]
19. Sources subject to District Rule 2.27, Section 301 shall perform annual source tests in accordance with District Rule 2.27, Section 502 or tune-ups in accordance with District Rule 2.27, Section 600 to demonstrate compliance with this rule. If annual tune-ups are used to certify compliance, then the tune-up data demonstrating the equipment is operating within the parameters established during the initial source test must be submitted to the District. The Air Pollution Control Officer shall require additional source testing if the tune-up data indicates a deviation from the parameters established in the initial source test. [District Rule 2.27, §402.7]
20. Failure to comply with all of the provisions of an approved plan under Section 401.1 of Rule 2.27 shall constitute a violation of this rule. [District Rule 2.27, §402.8]
21. The cumulative annual usage of each fuel shall be monitored from utility service meters, purchase, or tank fill records, or by any other acceptable methods approved by the Air Pollution Control Officer. [District Rule 2.27, §402.9]
22. Compliance with NO<sub>x</sub> emission requirements and the stack-gas carbon monoxide and oxygen requirements of Section 300 of Rule 2.27 shall be determined using the following test methods:
  - a. Oxides of Nitrogen - ARB Method 100;
  - b. Carbon Monoxide - ARB Method 100;
  - c. Stack-gas oxygen - ARB Method 100;
  - d. NO<sub>x</sub> emission rate (Heat Input Basis) - EPA Method 19.[District Rule 2.27, §502.1]
23. Test methods other than those specified in Section 502.1 of Rule 2.27 for oxides of nitrogen, stack-gas oxygen, and stack-gas carbon monoxide, may be used to determine compliance so long as they are functionally equivalent and approved by the Air Pollution Control Officer. [District Rule 2.27, §502.2]
24. Where the owner operator seeks to demonstrate compliance with the SO<sub>2</sub> standards based on fuel supplier certification, the performance test shall consist of the certification from the fuel supplier, as described under § 60.48c(f)(1), (2), or (3), as applicable. [40 CFR Part 60 Subpart Dc, §60.44c(h)]

**D2. Landfill Gas Collection and Soil Vapor Extraction System**

1. A non-resettable, totalizing gaseous fuel flow meter shall be installed and utilized to measure the quantity (in cubic feet) of gas combusted in the flare. [District Rule 3.4]

**D3. Gasoline Storage and Dispensing**

1. The Permit Holder shall not transfer or permit the transfer of organic liquid into any storage container with a capacity greater than 250 gallons unless such transfer is made employing a vapor control system that prevents the release to the atmosphere of not less than 95 percent by weight of the organic vapors displaced, excluding methane, and unless stationary storage containers are also equipped with a submerged fill pipe. For gasoline, the vapor control system shall be California Air Resources Board (CARB) certified and maintained and operated as certified. [District Rule 2.21 §303.1]

2. Organic liquids subject to Rule 2.21 shall not be spilled, discarded to sewers, stored in open containers, or handled in any other manner that would result in evaporation to the atmosphere. [District Rule 2.21 §304]
3. The owner/operator shall implement a self-compliance program as follows:
  - a. Inspection and maintenance procedures shall be conducted at least once every 3 months in accordance with the protocol specified in Section 307 of Rule 2.22 to ensure proper operating conditions of all components of the vapor recovery systems.
  - b. Inspections procedures shall be conducted at least once every 12 months in accordance with the protocol specified in Section 308 of Rule 2.22 to verify the compliance with all applicable District rules and regulations, as well as all permit conditions. [District Rule 2.22, §306.2]
4. The owner/operator shall conduct and successfully pass the applicable reverification tests using the most recent applicable CARB Executive Orders, in accordance with the test methods and procedures as specified in Section 600 of Rule 2.22 to verify proper operation of the vapor recovery system as follows:
  - a. Static pressure test (Phase I and II systems).
  - b. Dynamic pressure test for all gasoline dispensing facilities.
  - c. Liquid removal test for systems with a liquid removal device required by the most recent applicable CARB Executive Orders. [District Rule 2.22, §309.1]
5. The owner/operator shall complete the reverification test initially no later than June 12, 2003, and annually thereafter. Each annual test shall be completed within 12 months of the previous successful test. No adjustments to the gasoline dispensing facility shall be made the day of the test and the test shall be conducted in an as-is-condition. [District Rule 2.22, §309.3]
6. All reverification tests shall comply with all of the following:
  - a. Conduct tests in accordance with the applicable test methods specified in Section 600 and other CARB testing procedures. Tests shall be conducted using calibrated equipment meeting the calibration range and calibration intervals specified by the manufacturer.
  - b. Provide notification to the District at least 3 days prior to testing except for reverification tests conducted after a driveoff, provided that the person conducting the tests complies with all other applicable provisions of the rule.
  - c. Conduct the tests any time Monday through Friday from 9:00 a.m. through 4:00 p.m.
  - d. Submit a copy of the test report in District-approved format to the APCO within 48 hours after each test is conducted. The test report shall include all the required records of tests, test data, a statement whether the system or component tested meets or fails to meet the required standards, and the name and signature of the person responsible for conducting the tests. [District Rule 2.22, §309.4]

7. Notwithstanding Section 309.4.b of Rule 2.22, the owner/operator that has failed a reverification test or portions thereof may retest the facility prior to resuming operation provided that the person conducting the tests has complied with one of the following:
  - a. Notify the District at least 12 hours prior to retesting; or
  - b. When all necessary repairs are performed during the same day the facility has failed, the owner/operator may retest the facility on the same day without re-notification, provided that the reasons for the test failure and any repairs performed are properly documented in the test reports and the repair logs pursuant to Sections 502.2 and 502.3 of Rule 2.22. [District Rule 2.22, §309.5]

**D4. Aviation Gasoline Storage and Dispensing**

1. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), a source test shall be conducted and passed every twelve (12) calendar months. [District Rule 2.21, §502.4/C-11-80]
2. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), no adjustments shall be made to the facility on the day of a source test event. Testing shall be conducted in an "as-is" condition. [District Rule 3.4/C-11-80]
3. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), source test procedures to be performed at this facility shall include: Static Pressure Decay (CARB TP-201.3B). [District Rule 2.21, §502.4/C-11-80]
4. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), the Permit Holder shall notify the District of the date and time of all source test events. The notification shall be given at least three (3) days prior to the source test event date. [District Rule 2.21, §502.4/C-11-80]
5. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), the Permit Holder shall submit all test results within forty-five (45) days of conducting the test. [District Rule 2.21, §503.2/C-11-80]
6. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), if a re-verification test is failed, the facility must successfully pass a retest prior to resuming operation. [District Rule 3.4/C-11-80]
7. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), the Permit Holder shall implement a self-compliance program that includes:
  - a. Quarterly self-inspection and maintenance procedures to be completed at least once every three (3) months using a District approved quarterly inspection form; and
  - b. Annual self-inspection procedures to be completed at least once every twelve (12) months using a District approved annual inspection form. [District Rule 3.4/ C-11-80]

**E. Recordkeeping Requirements**

**E1. Diesel Fired Internal Combustion Engines**

The following conditions are applicable to the PTOs and ATCs listed in Table 19:

1. The Permit Holder shall maintain a monthly log of usage that shall list and document the nature of use for each of the following:
  - a. Emergency use hours of operation;
  - b. Maintenance and testing hours of operation;
  - c. Hours of operation for emission testing to show compliance with Title 17 CCR, Section 93115.6(a)(3) and 93115.6(b)(3);
  - d. Initial start-up hours;
  - e. Fuel use through the retention of fuel purchase records which indicate that the fuel used in the IC engine is CARB certified diesel fuel or an approved ATCM compliant alternative fuel. [District Rule 3.4 and Title 17 CCR, Section 93115.10(g)(1)]
  
2. The Permit Holder shall retain the log for a minimum of 60 months (5 years) from the date of entry. Log entries made within 24 months of the most recent entry shall be retained on-site and made immediately available to the District staff upon request. Log entries made from 25 to 60 months from most recent entry shall be made available to District staff within 5 working days from request. [District Rule 3.4, 3.8, §302.6 and Title 17 CCR, Section 93115.10(g)(2)]

Table 19: PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-89-94(a)	C-02-309		P-84-02	C-01-201
P-90-94(a)	C-02-286		P-114-02	C-02-158
P-91-94(a)	C-02-304		P-63-03	C-02-184
P-92-94(a)	C-02-299		P-102-03	C-02-322
P-94-94(a)	C-02-285		P-115-03	C-03-98
P-95-94(a)	C-02-300		P-117-03	C-02-373
P-96-94(a)	C-02-301		P-118-03	C-03-164
P-99-94(a)	C-02-319		P-119-03	C-02-372
P-100-94(a)	C-02-295		P-120-03	C-02-322
P-101-94(a)	C-02-312		P-121-03	C-03-100
P-102-94(a)	C-02-297		P-15-04	C-03-251
P-103-94(a)	C-02-305		P-74-05	C-05-49
P-107-95(a)	C-02-289		P-38-05	C-05-164
P-126-95(a)	C-02-316		P-59-05	C-05-178
P-209-95(a)	C-02-313		P-49-07	C-07-62
P-29-96(a)	C-02-282		P-50-07	C-07-78
P-69-96(a)	C-02-290		P-51-07	C-07-80
P-42-97	NA		P-52-07	C-07-84
P-54-97	C-97-118		P-53-07	C-07-85
P-15-98	C-97-115		P-59-07	C-07-107
P-16-98	C-97-82		P-2-09	C-08-110

P-17-98	C-97-130		P-4-09	C-08-232
P-31-98	C-97-65		P-16-09	C-08-254
P-32-98	C-97-66		P-17-09	C-09-16
P-32-99	C-96-67		P-54-09	C-09-139
P-88-99	C-99-114		P-66-09	C-09-127
P-1-00	C-99-70		P-67-09	C-09-128
P-2-00	C-98-90		P-68-09	C-09-129
P-71-00	C-99-121		P-69-09	C-09-161
P-7-01	C-99-120		P-42-10	C-10-17
P-8-01(a)	C-06-16		P-44-10	C-10-45
P-9-01(a)	C-06-15		P-7-11	C-10-105
P-108-01	C-01-73		P-72-11	C-11-89
P-109-01	C-01-74		P-36-12	C-12-89
P-111-01	C-01-12		P-51-12	C-12-125
P-120-01	C-01-170		P-52-12	C-12-126
P-17-02	C-00-86		P-55-12	C-12-129
P-82-02	C-00-173		P-56-12	C-12-130
P-83-02	C-02-93		P-4-13	C-13-06

**E2. Natural Gas Fired Internal Combustion Engines**

The following conditions is applicable to the PTOs and ATCs listed in Table 20:

1. The Permit Holder shall maintain a log of the operation hours for internal combustion engines identifying the type of usage (either maintenance or emergency), the duration and date of each usage. The log shall be maintained for a period of five (5) years and be made available to the District upon request. [District Rule 3.4, §501]

Table 20. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-108-95(a)	C-02-311		P-121-95(a)	C-02-283
P-109-95(a)	C-02-314		P-122-95(a)	C-02-288
P-110-95(a)	C-02-303		P-123-95(a)	C-02-292
P-112-95(a)	C-02-296		P-124-95(a)	C-02-321
P-113-95(a)	C-02-306		P-125-95(a)	C-02-287
P-114-95(a)	C-02-307		P-18-98	C-97-119
P-117-95(a)	C-02-318		P-61-00	C-00-105
P-118-95(a)	C-02-308		P-3-09	C-08-193
P-119-95(a)	C-02-302		P-43-10	C-10-38

P-120-95(a)	C-02-317			
-------------	----------	--	--	--

The following condition is applicable to the PTOs and ATCs listed in Table 21:

1. The Permit Holder shall maintain the following records:
  - a. All maintenance conducted on the engine; and
  - b. Documentation from the engine manufacturer the engine is certified to meet the emission standards. [District Rule 3.4 and 40 CFR Part 60.4235]

Table 21. Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-3-09	C-08-193		P-43-10	C-10-38

**E3. Portable Internal Combustion Engines**

The following conditions are applicable to the PTOs and ATCs listed in Table 22:

1. The Permit Holder shall maintain a monthly log of usage that shall list and document the nature of use for each of the following:
  - a. Emergency use hours of operation;
  - b. Maintenance and testing hours of operation;
  - c. Hours of operation for emission testing to show compliance with Title 17 CCR, Section 93115.6(a)(3) and 93115.6(b)(3);
  - d. Initial start-up hours;
  - e. Fuel use through the retention of fuel purchase records which indicate that the fuel used in the IC engine is CARB certified diesel fuel or an approved ATCM compliant alternative fuel. [District Rule 3.4 and Title 17 CCR, Section 93115.10(g)(1)m]
2. All required records shall be retained for a period of five (5) years and be made available to District personnel upon request. [District Rule 3.4, §501and 3.8, §302]

Table 22: Table of PTOs and Corresponding ATCs

PTOs and Corresponding ATCs				
PTO Number	ATC Number		PTO Number	ATC Number
P-86-01	C-00-145		P-51-99(a)	C-06-18
P-87-01	C-00-146		P-52-99(a)	C-06-19
P-50-99(a)	C-06-17			

**E4. Boilers and Water Heaters**

1. For the boiler operating under P-64-03(a), the Permit Holder shall maintain quarterly and yearly records of fuel usage for the boilers. The records shall be maintained for a period of five years and shall be made available to the District upon request. [District Rule 3.4/C-04-22]
2. For the boiler operating under P-83-06, the Permit Holder shall monitor and record the cumulative

quarterly and annual natural gas (in cubic feet) and diesel (in gallons) fuel usage from their respective totalizing meter, or by any other acceptable methods approved by the District. The records shall be updated quarterly. [District Rule 3.4/C-05-237]

3. For the boiler(s) operating under P-54-00(a), P-63-06(a), P-16-08, and P-67-00(a) the Permit Holder shall monitor and record the cumulative quarterly and annual natural gas fuel usage (in cubic feet) for the boiler(s). The records shall be updated quarterly and made available to the District upon request. Historic annual data for the five (5) previous calendar years shall be kept and made available to the District upon request. [District Rule 3.4/C-10-93, C-09-210, C-07-150, C-08-61 and District Rule 3.1, §402/C-07-123]
4. For the boilers operating under P-90-02 and P-91-02, the Permit Holder shall maintain quarterly and yearly records of fuel usage. The records shall be retained for a period of five years and made available to the District upon request. [District Rule 3.4/C-00-191, C-00-196rev]
5. For the boiler operating under P-28-03, the Permit Holder shall maintain records of fuel usage on a daily and quarterly basis. The Permit Holder shall retain the records for a period of five years. These records shall be made available to the District upon request. [District Rule 3.4/C-02-353]
6. For the boilers operating under P-64-03(a), P-65-03, and P-101-03 the Permit Holder shall keep records of tune-ups for each boiler. The records shall be retained for a period of five years and shall be made available to the District upon request. [District Rule 3.4/C-04-22, C-02-331, and C-02-335]
7. For the boilers operating under P-63-06(a), the Permit Holder shall maintain records of tune-ups for the boiler equipped with a low-NOx burner (Boiler #6). The records shall be retained for the five (5) previous calendar years and made available to the District upon request. [District Rule 3.4/C-09-210]
8. For the boiler operating under P-16-08, the Permit Holder shall maintain records of tune-ups for the boiler. The records shall be retained for the five (5) previous calendar years and made available to the District upon request. [District Rule 3.4/C-07-150]
9. For boiler, steam generators, and process heaters with rated heat inputs of greater than or equal to five (5) million BTU per hour, the owner or operator shall, at least every twelve months, submit either source or tune-up test reports on each unit for each fuel burned, including any fuels which may be burned in accordance with Section 110 of Rule 2.27. For units complying with Section 302.2, of Rule 2.27, tune-up verification reports shall also be submitted not less than once every twelve months. Test reports shall include the operational characteristics of all flue-gas NOx reduction equipment that were monitored as required by Section 303.2 of Rule 2.27. [District Rule 2.27, §403]
10. For boiler, steam generators, and process heaters with rated heat inputs of greater than or equal to five (5) million BTU per hour, fuel usage and operating hours shall be kept according to District Rule 2.27, §501. [District Rule 2.27, §501]
11. The owner or operator subject to the fuel oil sulfur limits shall keep records and submit the reports to the Administrator. If fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification as described under paragraph (f)(1), (2), or (3) of § 60.48c shall be submitted to the Administrator. [40 CFR Part 60 Subpart Dc, §60.48c(d) and (e)(11)]
12. Fuel supplier certification shall include the name of the oil supplier and a statement from the oil

supplier that the oil complies with specifications for fuel oil #2, as defined by the American Society for Testing and Materials in ASTM D396-78, 89, 90, 92, 96, or 98, "Standard Specification for Fuel Oils". [40 CFR Part 60 Subpart Dc, §60.48c(f)(1)(I) and (ii)]

13. For the boiler operating under P-83-06, the Permit Holder shall demonstrate compliance with the diesel fuel sulfur content limitation by obtaining, and maintaining at the facility, fuel receipts from the diesel fuel supplier certifying the sulfur content of the diesel fuel delivered and combusted by the boiler. [40 CFR Part 60.45b(k), 60.46b(i), 60.47b(g), 60.48b(j), & District Rule 3.4/C-05-237]
14. For the boiler operating under P-83-06, the Permit Holder shall maintain records of the following information for each day the boiler is operated:
  - a. Calendar date;
  - b. The average hourly nitrogen oxides (expressed as NO<sub>2</sub>) emission rates (lb/MMBtu heat input) measured;
  - c. The 30-day average nitrogen oxides emission rates (lb/MMBtu heat input) calculated at the end of each boiler operating day from the measured hourly nitrogen oxide emission rates for the preceding 30 boiler operating days;
  - d. Identification of the boiler operating days when the calculated 30-day average nitrogen oxides emission rates are in excess of the nitrogen oxides emission limitations of this permit, with the reasons for such excess emissions as well as a description of corrective actions taken;
  - e. Identification of the boiler operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken;
  - f. Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data;
  - g. Identification of "F" factor used for calculations, method of determination, and type of fuel combusted;
  - h. Identification of the times when the pollutant concentration exceeded full span of the CEMS;
  - i. Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with 40 CFR Part 60 Appendix B, PERFORMANCE SPECIFICATIONS 2 or 3;
  - j. Results of daily CEMS drift tests and quarterly accuracy assessments as required under 40 CFR Part 60 appendix F, Procedure 1;
  - k. Time and duration of boiler start-up and shutdown events;
  - l. Time and duration of equipment and/or control equipment malfunction. [40 CFR Part 60.49b(g) & 40 CFR Part 60.7(b)/C-05-237]
15. For the boiler operating under P-83-06, the Permit Holder shall submit to the District the records required by 40 CFR 60.49b(g) of this permit for each calendar year within 60 days of the end of the calendar year. [40 CFR Part 60.49b(i)/C-05-237]
16. For the boiler operating under P-83-06, the Permit Holder shall submit to the District a written report for each calendar quarter, within 30 days of the end of the calendar quarter, which includes the following:
  - a. The date, time intervals, and magnitude of excess emissions computed in accordance with 40 CFR Part 60.13(h);
  - b. The nature and cause of the excess emissions, and corrective actions taken;
  - c. The time and date of each period during which the CEMS was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; and
  - d. A negative declaration when no excess emissions occurred, if applicable. [40 CFR Part

60.7(c) & 40 CFR Part 60.49b(h)/C-05-237]

17. The Permit Holder shall comply with the Compliance Assurance Monitoring record-keeping and reporting requirements of 40 CFR Part 64.9. [40 CFR Part 64.9/C-05-237]
18. For the boiler operating under P-44-11, the Permit Holder shall monitor and record the quarterly and annual natural gas fuel usage (in cubic feet) for the boiler. The records shall be updated quarterly and made available to the District upon request. Historic annual data for the five (5) previous calendar years shall be kept and made available to the District upon request. [District Rule 3.4/C-11-62]

#### **E5. Coating Operation**

1. The Permit Holder shall maintain a list of each coating, stripper and solvent used at each process, including the following information: [District Rule 2.25, 3.1 and 3.4]
  - a. The name of the solvent;
  - b. The name of the solvent manufacturer;
  - c. The applicable coating category;
  - d. Mix ratio (if any catalyst, reducer, or other components used);
  - e. The VOC content of the material applied expressed in grams/liter or pound/gallon;
  - f. Weight percent water;
  - g. Weight percent exempt solvent; and
  - h. Thinning solvent composition and density.
2. The permit holder shall maintain a record of the amounts of coatings and solvents used and the resulting VOCs emitted on a monthly basis, except for the following: [District Rule 2.25, 3.4 and 3.1]
  - a. records of usage for coatings that do not comply with the applicable VOC limitation shall be maintained on a daily basis,
  - b. records of usage for coatings that are exempt from the applicable requirements of Rule 2.25 based on the annual usage being less than 50 gallons per year may be maintained on a quarterly basis.
3. Records shall be maintained for a period of five years, and shall be made available for District inspection upon request. [District Rule 3.1 and 3.8]

#### **E6. Landfill Gas Collection and Soil Vapor Extraction System**

1. The Permit Holder shall monitor and record the cumulative quarterly and annual gas fuel usage (in cubic feet) from the totalizing meter. The records shall be updated quarterly and made available to the District upon request. Historic annual data for the five (5) previous calendar years shall be kept and made available to the District upon request. [District Rule 3.4]
2. Each owner or operator of an MSW landfill having a design capacity less than 2.5 million megagrams by mass or 2.5 million cubic meters by volume shall submit an initial design capacity report to the Administrator as provided in § 60.757(a)(2) of subpart WWW by the date specified in § 60.35c of subpart Cc. The landfill may calculate design capacity in either megagrams or cubic meters for comparison with the exemption values. Any density conversions shall be documented and submitted with the report. Submittal of the initial design capacity report shall fulfill the requirements of this subpart except as provided below:
  - a. The owner or operator shall submit an amended design capacity report as provided in §

60.757(a)(3) of Subpart WWW. (Guidance: Note that if the design capacity increase is the result of a modification, as defined in § 60.751 of Subpart WWW, that was commenced on or after May 30, 1991, the landfill will become subject to Subpart WWW instead of Subpart Cc. If the design capacity increase is the result of a change in operating practices, density, or some other change that is not a modification, the landfill remains subject to Subpart Cc.)

- b. When an increase in the maximum design capacity of a landfill with an initial design capacity less than 2.5 million megagrams or 2.5 million cubic meters results in a revised maximum design capacity equal to or greater than 2.5 million megagrams and 2.5 million cubic meters, the owner or operator shall comply with paragraph (e) of 40 CFR Part 60, Subpart Cc § 60.33c. [District Rule 2.38, §102.1]

#### **E7. Incinerator**

1. For the multiple chamber incinerator and ash collection system operating under P-81-89(a), for each day the incinerator is operated, records shall be kept on the weight of each type of waste (animal remains or biohazard bags) charged to the incinerator per batch and per day total. All records shall be retained for a period of five years and shall be made available to the District upon request. [District Rule 3.4/P-81-89(a)]

#### **E8. Woodworking Operations**

1. For the woodworking facilities operating under P-95-80(a1), the Permit Holder shall maintain a record-keeping log of the quarterly operational hours for the dust collection system. Historic data shall be retained for the five (5) previous calendar years and made available to the District upon request. [District Rule 3.4/C-07-25]
2. For the woodworking facilities operating under P-54-90(a), The Permit Holder shall maintain quarterly and yearly records of the operational hours for the dust collection system. Historic data shall be retained for the five (5) previous calendar years and made available to the District upon request. [District Rule 3.4/C-07-105]
3. The Permit Holder shall maintain quarterly and yearly records of the operational hours for the dust collection system. Historic data shall be retained for the five (5) previous calendar years and made available to the District upon request. [District Rule 3.4/C-13-84]

#### **E9. Wastewater Treatment Plant**

1. For the wastewater treatment plant operating under P-22-00(a), the Permit Holder shall maintain quarterly and yearly records of wastewater influent flow (in gallons). These records shall be retained for at least five (5) years from the date of entry and made available to the District upon request. [District Rule 3.4/C-06-142]

#### **E10. Gasoline Storage and Dispensing**

1. The owner/operator shall implement a maintenance program and document the program in a preventative maintenance (PM) manual for the Phase II vapor recovery system. The PM manual shall be kept at the facility and made available to any person who operates, inspects, maintains, repairs, or tests any part of the vapor recovery system. The PM manual shall be made available to District

personnel upon request. The PM manual shall contain detailed instructions to assure proper operation and maintenance of the vapor recovery system and its components. The PM manual shall include the following current information:

- a. A copy of all applicable CARB Executive Orders, Approval Letters, and valid District Permits. [District Rule 2.22, §501.1]
  - b. A copy of the manufacturer's specifications and instructions for installation, operation, repair and maintenance required pursuant to CARB Certification Procedure CP-201, Certification Procedure for Vapor Recovery Systems at Gasoline Dispensing Facilities, and any additional instructions provided by the manufacturer. [District Rule 2.22, §501.2]
  - c. System and/or component testing requirements, including test schedules and passing criteria for each of the standard tests specified in Section 600 of Rule 2.22. The owner/operator may include any non-CARB required diagnostic and other tests as part of the testing requirements. [District Rule 2.22, §501.3]
  - d. Additional O&M instructions, if any, that are designed to ensure compliance with the applicable rules, regulations, CARB Executive Orders and District Permit to Operate conditions, including replacement schedules for failure or wear prone components. [District Rule 2.22, §501.4]
2. Records for non-retail gasoline dispensing facilities that are unmanned may be kept off site provided that the records are made available to District personnel within 72 hours. All records required by this section shall be made available to the District personnel upon request both on site during inspections and offsite as specified:
- a. Records of all defective components identified or repaired during self-compliance inspections. [District Rule 2.22, §502.1]
  - b. Repair logs shall include at a minimum:
    - i. Date and time of repair.
    - ii. The name of the person(s) who performed the repair, and if applicable, the name, address and phone number of the person's employer.
    - iii. Description of service performed.
    - iv. Each component that was repaired, serviced, or removed, including the required component identification information.
    - v. Each component that was installed as replacement, if applicable, including the required component identification information.
    - vi. Receipts for parts used in the repair and, if applicable, work orders, which shall include the name and signature of the person responsible for performing the repairs. [District Rule 2.22, §502.2]
  - c. Records of tests, which shall include:
    - i. Date and time of each test.
    - ii. Name, affiliation, address and phone number of the person(s) who performed the test.
    - iii. Test data and calibration data for all equipment used.
    - iv. Date and time each test is completed and the facility owner/operator is notified of the results. For a test that fails, a description of the reasons for the test failure shall also be

- included.
- v. For a retest following a failed performance or reverification test, description of repairs performed.
- vi. Copies of the test reports in District-approved format. [District Rule 2.22, §502.3]

**E11. Aviation Gasoline Storage and Dispensing**

1. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), the Permit Holder shall implement a preventive maintenance program with a manual that documents inspections, maintenance, repairs, applicable executive orders, District permits, manufacturer's operating and maintenance instructions, and testing requirements/procedures. [District Rule 3.4/C-11-80]
2. For the aviation gasoline storage and dispensing facility operating under P-1-81(a3), the Permit Holder shall maintain records of all self-compliance inspections, source tests, repairs, and quarterly throughput. These records shall be retained for a period of five (5) years and made available to District personnel upon request. [District Rule 3.4/C-11-80]

**III. FACILITY WIDE REQUIREMENTS**

**A. Opacity**

1. The permit holder shall not discharge into the atmosphere from any single source of emission whatsoever, any air contaminant for a period or periods aggregating more than three (3) minutes in any one (1) hour which is:
  - a. As dark or darker in shade as that designated as No. 1 on the Ringlemann Chart as published by the United States Bureau of Mines; or
  - b. Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subsection a. of this condition. [District Rule 2.3/District Rule 3.1]

**B. Nuisance**

1. The permit holder shall not discharge from any source whatsoever such quantities of air contaminants or other material which cause injury, detriment, nuisance, or annoyance to any considerable number of persons or to the public or which endanger the comfort, repose, health, or safety of any such persons or the public or which cause to have a natural tendency to cause injury or damage to business or property. [This permit condition is federally enforceable because it derives from District Rule 2.5 - Nuisance that is currently part of the California State Implementation Plan (SIP). The District is taking steps to remove Rule 2.5 from the SIP. Once the U.S. EPA has taken final action to remove District Rule 2.5 from the SIP, this permit condition will become state-enforceable only]

**C. Open Burning**

1. Except as set forth in Rule 2.8, no person shall set or permit an open outdoor fire within the boundaries of the District. [District Rule 2.8, § a.]
2. On permissive burn days only the provisions of Rule 2.8, § a. does not apply to the following fires:

- a. For a fire set or for which permission for such fire is given in performance of the official duty of any public officer, and such fire in the opinion of such officer is necessary:
  - I. For the purpose of the prevention of a fire or health hazard which cannot be abated by any other means;
  - ii. Set pursuant to permit on property used for industrial purposes for the purpose of instruction of employees in the method of fighting fires;
  - iii. For right-of-way clearing by a public entity or utility, or for levee, reservoir, and ditch maintenance when the material has been prepared by stacking, drying, or other methods to promote combustion as specified by the Air Pollution Control Officer. Any such burning near populated areas shall be done in accordance with the requirements given in District Regulation VI, Agricultural Burning.;
  - iv. For agricultural burning permitted by law;  
For burning of vegetative material from residential yards in rural areas. [District Rule 2.8, § b.]
3. On all days the provisions of Rule 2.8, § a. do not apply to the following fires:
  - a. For a fire set or for which permission for such fire is given in the performance of the official duty of any public officer and such fire in the opinion of the officer is necessary:
    - i. For the instruction of public or industrial employees in methods of fighting fire where a permit has been issued by the Air Pollution Control Officer;
    - ii. To set or cause to be set backfires necessary to save life or valuable property pursuant to Section 4426 of the Public Resources Code;
    - iii. To abate fires pursuant to Chapter 2 (commencing with Section 13055) of Part 1 of Division 12 of the California Health and Safety Code;
    - iv. Fires for recreational use and cooking of foods;
    - v. Fires not used for purposes of disposal of materials and which the Air Pollution Control Officer determines necessary and not to have significant air pollution effects and for which specific permission is given by the Air Pollution Control Officer;
    - vi. For fires to burn empty sacks or containers which contained pesticides or other toxic substances in accordance with procedures approved by fire agencies and the Air Pollution Control Officer providing the sacks or containers are within the definition of "open burning in agricultural operation in the growing of crops or raising of fowls or animals". [District Rule 2.8, § c.]

**D. Open Burning, Certain Materials**

1. Notwithstanding any other provisions of the Yolo-Solano Air Quality Management District Rules and Regulations, no person shall use open outdoor fires for the purpose of disposal of petroleum waste, demolition debris, construction debris, tires or other rubber materials, materials containing tar, or for metal salvage or burning of vehicle bodies. [District Rule 2.9]

**E. Architectural Coating**

1. The permit holder shall not apply any architectural coating which contains more than 250 grams of volatile organic material per liter of coating as applied, excluding water. [District Rule 2.14]

**F. Circumvention**

1. The Permit Holder shall not build, erect, install or use any article, machine, equipment, or other contrivance, the use of which, without resulting in a reduction in the total release of air contaminants to the atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Division 26, Part 3 and Part 4 of the Health and Safety Code of the State of California or District Rules or Regulations. [District Rule 2.17 and 40 CFR Part 60.12 and 63.4]

**G. Orchard Heaters**

1. No person shall use any orchard or citrus heater unless it has been approved by the State Air Resources Board or does not produce more than one gram per minute of unconsumed carbonaceous material. [District Rule 2.20]

**H. Graphic Arts Printing**

1. Any person claiming to emit less than 400 pounds of volatile organic compounds in any month from graphic arts operations shall have information available, such as purchase order or hazardous waste manifests, that would allow the Air Pollution Control Officer to verify the facility usage. [District Rule 2.29, §111]

**I. Surface Preparation and Cleanup**

1. A person shall not perform solvent cleaning operations unless one of the following cleaning devices or methods is used:
  - a. Wipe cleaning;
  - b. Spray bottles or containers with a maximum capacity of 16 fluid ounces from which solvents are applied without a propellant-induced force;
  - c. Cleaning equipment which has a solvent container that can be, and is, closed during cleaning operations, except when depositing and removing objects to be cleaned, and is closed during non-operation with the exception of maintenance and repair to the cleaning equipment itself;
  - d. Cleaning device or mechanism which has been determined by the Air Pollution Control Officer to result in equivalent or lower emissions;
  - e. Remote reservoir cold cleaner used pursuant to Section 303 of Rule 2.31;
  - f. Non-atomized solvent flow method where the cleaning solvent is collected in a container or a collection system which is closed except for solvent application openings and , if necessary, openings to avoid excessive pressure build-up inside the container; or
  - g. Solvent flushing method where the cleaning solvent is discharged into a container which is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container. The discharged solvent from the equipment must be collected into containers without atomizing into the air. The solvent may be flushed through the system by air or hydraulic pressure, or by pumping. [District Rule 2.31, §302]
2. A person shall not atomize any solvent into open air. [District Rule 2.31, §306.1]

3. Records shall be maintained pursuant to Section 501 of Rule 2.31, for all applications subject to Rule 2.31, including those exempted under Section 110 through 118 of Rule 2.31, except for cleaning operations performed with a solvent which has a water content of 98% or more, by weight, or a VOC composite partial pressure of 0.1 mm Hg or less at 20°C (68°F). Each owner or operator of a facility subject to the provisions of Rule 2.31 shall collect and record all information necessary to demonstrate daily compliance with the requirements of Section 300 of Rule 2.31 or with the exemption conditions of Section 110 through 118 of Rule 2.31. The information shall be collected monthly, and shall be made available to the Air Pollution Control Officer upon request. The information shall include, but not limited to, the following:
  - a. Identification of each solvent cleaning operation and other process at the facility subject to Rule 2.31. The identification shall include location, permit number (if applicable), description of activity, and substrate type;
  - b. The amount and type of each VOC-containing material used at each operation and process, including exempt compounds. Use of amounts one pint per week or less may be recorded on a monthly basis;
  - c. The VOC content of each VOC-containing material;
  - d. Where applicable, the vapor pressure of each VOC-containing material; and
  - e. Records demonstrating compliance with Section 305 of Rule 2.31. [District Rule 2.31, §501]

**J. Adhesive Operations**

1. The VOC content of adhesives used for specific applications, except as provided in Sections 301.3 and 301.4 of Rule 2.33, shall not exceed the limits set forth in Table 23, expressed as grams of VOC per liter less water and exempt compounds, as applied [District Rule 2.33, §301]:

Table 23. Limits VOC-Less Water and Exempt Compounds

LIMITS VOC - Less Water and Less Exempt Compounds (Grams per Liter)		
Applications	Effective September 14, 1995	Effective January 1, 1997
Multipurpose Construction	200	
Indoor Floor Covering Installation	150	
Ceramic Tile Installation	150	130
Single-ply Roof Material Installation	650	250
Structural Glazing	100	
Plastic Cement Welding Adhesive/Primer	650	450
Solvent Welding Adhesive/Primer	650	450
Adhesive and Wash Primers	250	

Staple and Nail Manufacturing	640	
-------------------------------	-----	--

- The VOC content of adhesives, except as provided in Sections 301.1, 301.3, and 301.4 of Rule 2.33 shall not exceed the limits set forth in Table 24, expressed as grams of VOC per liter less water and exempt compounds, as applied [District Rule 2.33, §301]:

Table 24. VOC Content of Adhesives By Substrate

Material Bonded	Grams VOC per Liter
Metal to Metal	30
Porous Materials	150
Plastic Foam	120
All Other Substrates	250

- The higher of the two limits from the above table applies to the bonding of two dissimilar substrates. [District Rule 2.33, §301.2]
- Spray application of adhesives shall only be performed using airless, air assisted airless, high volume low pressure, disposable aerosol containers, or electrostatic spray equipment. [District Rule 2.33, §301.3]
- Closed containers shall be used to store adhesive products, cleaning materials, or other VOC-containing materials except when accessed for use. [District Rule 2.33, §303.1]
- Self-closing containers shall be used for the disposal of all adhesive products, cleaning materials, or other unused VOC-containing materials in such a manner as to effectively control VOC emissions. [District Rule 2.33, §303.2]
- A person shall not use any aerosol spray adhesive that exceeds 25% VOC by weight. [District Rule 2.33, §304.2]

**K. Natural Gas-Fired Residential Water Heaters**

- No person shall manufacture, offer for sale, sell, or install any natural gas fired water heater with oxides of nitrogen (NOx) emissions in excess of the limits set forth in the compliance schedule indicated in Table 25: [District Rule 2.37, §301]

Table 25. Water Heater NOx Limitations

Category	Rated Heat Input Capacity (Btu/hour)	NOx Emission Limit	NOx Emission Limit	NOx Emission Limit
		Effective 5/31/1995 - 12/31/2009	Effective 1/1/2010 - 12/31/2013	Effective 1/1/2014
Small water heater	< 75,000	40ng/J	10ng/J or 15 ppm NOx @ 3% O <sub>2</sub> dry	10ng/J or 15 ppm NOx @ 3% O <sub>2</sub> dry

Large water heater	75,000 - 400,000	No present standard	40ng/J or 55 ppm NOx @ 3% O <sub>2</sub> dry	14ng/J or 20 ppm NOx @ 3% O <sub>2</sub> dry
Small boiler	> 400,000 - < 1,000,000	No present standard	20ng/J or 30 ppm NOx @ 3% O <sub>2</sub> dry	14ng/J or 20 ppm NOx @ 3% O <sub>2</sub> dry
Mobile home water heater	All	No present standard	40ng/J or 55 ppm NOx @ 3% O <sub>2</sub> dry	40ng/J or 55 ppm NOx @ 3% O <sub>2</sub> dry
Pool/spa heater	> 400,000 - < 1,000,000	No present standard	40ng/J or 55 ppm NOx @ 3% O <sub>2</sub> dry	14ng/J or 20 ppm NOx @ 3% O <sub>2</sub> dry

**L. Agricultural Burning**

1. Agricultural burning as defined in Rule 1.1, Section 201, shall be permitted only on permissive burn days and in accordance with Sections 41508 and 41854 of the California Health and Safety Code under provisions of this regulation as authorized by the Air Pollution Control Officer pursuant to the authority granted to him by these regulations. [District Rule 6.1, §120.1]
2. During the period between January 1 and May 31, range improvement burning may be conducted by special permit of the Air Pollution Control Officer, as provided in Section 405 of Rule 6.1, on a no-burn day, providing that no more than 50 percent of the land has been brush-treated and that the California Air Resources Board has not prohibited such range improvement burning in order to maintain suitable air quality. [District Rule 6.1, §120.2]
3. No-burn days declared by the District can be declared for specific areas within the District. A District-declared no-burn day will be based on whether there has been poor meteorological dispersion of pollutants on previous days such that visibility and federal oxidant standard might be violated and agricultural burning could exacerbate poor ambient air quality conditions for the day. [District Rule 6.1, §120.3]
4. Material listed in Rule 2.9 shall not be disposed of as provided in Rule 6.1. [District Rule 6.1, §120.4]
5. No agricultural burning permit shall be valid on a no-burn day, and no person shall knowingly set or permit agricultural burning on a no-burn day without permission granted under Section 405 of Rule 6.1. [District Rule 6.1, §120.5]
6. No person shall set or allow an open outdoor fire for agricultural burning except in a manner as to produce a minimum of smoke. [District Rule 6.1, §301]
7. No person shall knowingly ignite or permit to be ignited any field crop stubble from agricultural operations before 10:00 a.m. or after 5:00 p.m. of any day. From September 15 through April 1, no field crops are to be ignited before 10:00 a.m. or after 3:00 p.m. [District Rule 6.1, §304.1]
8. All other agricultural burning shall not be ignited before 8:00 a.m. or after 5:00 p.m. or one hour before sunset, whichever is earlier. [District Rule 6.1, §304.2]

9. Except as authorized by the Air Pollution Control Officer no person shall knowingly set or permit an open fire outdoor fire for agricultural burning within 3 miles of a populated area. The Air Pollution Control Officer and the local fire agency may set additional burning conditions which will minimize adverse effects on populated areas. [District Rule 6.1, §306]

**M. General Permit Requirements**

1. No person shall build, erect, alter, or replace any facility, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants, or the use of which may eliminate or reduce or control the issuance of air contaminants, without first obtaining an authorization to construct from the Air Pollution Control Officer as specified in Section 401 of District Rule 3.1. [District Rule 3.1, §301.1]
2. No person shall operate any facility, article, machine, equipment, or other contrivance, for which an authorization to construct is required by District Rules and Regulations without first obtaining a written permit from the Air Pollution Control Officer. [District Rule 3.1, §302.1]
3. No person shall operate any facility, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate or reduce or control the issuance of air contaminants, without obtaining a permit from the Air Pollution Control Officer or the Hearing Board. [District Rule 3.1, §302.2]
4. The owner or operator shall install and maintain such facilities as are necessary for sampling and testing purposes. The number, size, and location of sampling ports shall be in accordance with Air Resources Board Test Method 1. The location and access to the sampling platform shall be in accordance with the General Industry Safety Orders of the State of California. [District Rule 3.1, §303.2]
5. The owner or operator of any facility, article, machine, equipment, or other contrivance for which a permit to operate is in effect shall notify the District office whenever a breakdown, malfunction, or operational upset condition exists which would tend to increase emissions of air pollutants or whenever any operating condition contrary to any provision of the permit to operate exists. Such notice shall be given to the District no later than four hours after occurrence during regular workday hours or no later than two hours of the District workday following an occurrence not during regular District workday hours. The notice shall provide the District information as to causes and corrective action being taken, with a schedule for return to required operating conditions. [District Rule 3.1, §405.3]

**N. Federal Requirements -General**

1. The Permit Holder shall comply with the following General Provisions of 40 CFR 60, Subpart A:
  - a. 60.1 - General applicability of the general provisions
  - b. 60.4 - Address
  - c. 60.5 - Determination of construction of modification
  - d. 60.6 - Review of plans
  - e. 60.7 - Notification and recordkeeping
  - f. 60.8 - Performance tests
  - g. 60.9 - Availability of information
  - h. 60.10 - State Authority

- i. 60.11 - Compliance with standards and maintenance requirements
  - j. 60.12 - Circumvention
  - k. 60.13 - Monitoring requirements
  - l. 60.14 - Modification
  - m. 60.15 - Reconstruction
  - n. 60.17 - Incorporation by reference
  - o. 60.18 - General control device requirements
  - p. 60.19 - General notification and reporting requirements
- [District Rule 3.4 and 40 CFR Part 60]

2. The Permit Holder shall comply with the following applicable General Provisions of 40 CFR 63, Subpart A:

- a. 63.1 - General applicability of the general provisions
  - b. 63.4 - Prohibited activities and circumvention
  - c. 63.5 - Construction and reconstruction
  - d. 63.6(a) - Applicability
  - e. 63.6(b) - Compliance dates and notification
  - f. 63.6(c) - Compliance dates
  - g. 63.6(f2) - Methods for determining compliance
  - h. 63.6(f3) - Finding of compliance
  - i. 63.6(g1-3) - Use of alternate standard
  - j. 63.6(i) - Compliance extension procedures
  - k. 63.6(j) - Presidential compliance procedures
  - l. 63.7 - Performance testing requirements
  - m. 63.8 - Monitoring requirements
  - n. 63.9 - Notification Requirements
  - o. 63.10 - Recordkeeping and reporting requirements
  - p. 63.12 - State Authority and delegations
  - q. 63.13 - Addresses
  - r. 63.14 - Incorporation by reference
  - s. 63.15 - Availability of information
- [District Rule 3.4 and 40 CFR Part 63]

#### **IV. TITLE V GENERAL REQUIREMENTS**

##### **A. Right of Entry**

- 1. The permit shall require that the source allow the entry of the District, ARB, or U.S. EPA officials for the purpose of inspection and sampling, including:
  - a. Inspection of the stationary source, including equipment, work practices, operations, and emissions-related activity;
  - b. Inspection and duplication of records required by the permit to operate; and
  - c. Source sampling or other monitoring activities. [District Rule 3.8, §302.10]

##### **B. Compliance with Permit Conditions**

- 1. The permittee shall comply with all Title V permit conditions. [District Rule 3.8, §302.11a]
- 2. The permit does not convey property rights or exclusive privilege of any sort. [District Rule 3.8,

§302.11b]

3. Non-compliance with any permit condition is grounds for permit termination, revocation and reissuance, modification, enforcement action, or denial of permit renewal. [District Rule 3.8, §302.11c]
4. The permittee shall not use the "need to halt or reduce a permitted activity in order to maintain compliance" as a defense for non-compliance with any permit condition. [District Rule 3.8, §302.11d]
5. A pending permit action or notification of anticipated non-compliance does not stay any permit condition. [District Rule 3.8, §302.11e]
6. Within a reasonable time period, the permittee shall furnish any information requested by the APCO, in writing, for the purpose of determining:
  - a. Compliance with the permit; or
  - b. Whether or not cause exists for a permit or enforcement action. [District Rule 3.8, §302.11f]

**C. Emergency Provisions**

1. Within two weeks of an emergency event, the owner or operator shall submit to the District a properly signed contemporaneous log or other relevant evidence demonstrating that:
  - a. An emergency occurred;
  - b. The permittee can identify the cause(s) of the emergency;
  - c. The facility was being properly operated at the time of the emergency;
  - d. All steps were taken to minimize the emissions resulting from the emergency; and
  - e. Within two working days of the emergency event, the permittee provided the District with a description of the emergency and any mitigating or corrective actions taken [District Rule 3.8, §302.12]
2. In any enforcement proceeding, the permittee has the burden of proof for establishing that an emergency occurred. [District Rule 3.8, §302.12]

**D. Severability**

1. If any provision, clause, sentence, paragraph, section or part of these conditions for any reason is judged to be unconstitutional or invalid, such judgement shall not affect or invalidate the remainder of these conditions. [District Rule 3.8, §302.13]

**E. Compliance Certification**

1. The Responsible Official shall submit a compliance certification to the U.S. EPA and the APCO every twelve (12) months unless required more frequently by an applicable requirement. The twelve (12) month period will begin on January 1 and end on December 31, and will be due by January 31 for the previous reporting year, unless otherwise approved in writing by the District. All compliance reports and other documents required to be submitted to the District by the responsible official shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
2. The compliance certification shall identify the basis for each permit term or condition (e.g., specify the

emissions limitation, standard, or work practice) and a means of monitoring compliance with the term or condition consistent with Sections 302.5, 302.6, and 302.7 of Rule 3.8. [District Rule 3.8, §302.14b]

3. The compliance certification shall include a statement of the compliance status, whether compliance was continuous or intermittent, and method(s) used to determine compliance for the current time period and over the entire reporting period. [District Rule 3.8, §302.14c]
44. The compliance certification shall include any additional inspection, monitoring, or entry requirement that may be promulgated pursuant to Sections 114(a) and 504(b) of the Federal Clean Air Act. [District Rule 3.8, §302.14d]

**F. Permit Life**

1. The Title V permit shall expire five years from the date of issuance. Title V permit expiration terminates the stationary source's right to operate unless a timely and complete Title V permit application for renewal has been submitted. [District Rule 3.8, §302.15]

**G. Payment of Fees**

1. An owner or operator shall pay the appropriate Title V permit fees on schedule. If fees are not paid on schedule, the permit is forfeited. Operation without a permit subjects the source to potential enforcement action by the District and the U.S. EPA pursuant to Section 502(a) of the CAA. [District Rule 3.8, §302.16]

**H. Permit Revision Exemption**

1. No permit revision shall be required under any approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in the permit. [District Rule 3.8, §302.22]

**I. Application Requirements**

1. An owner or operator shall submit a standard District application for renewal of the Title V permit, no earlier than 18 months and no later than six months before the expiration date of the current permit to operate. [District Rule 3.8, §402.2]
2. An owner or operator shall submit a standard District application for each emissions unit affected by a proposed permit revision that qualifies as a significant Title V permit modification. The application shall be submitted after obtaining any required preconstruction permits. Upon request by the APCO, the owner or operator shall submit copies of the latest preconstruction permit for each affected emissions unit. The emissions unit(s) shall not commence operation until the APCO approves the permit revision. [District Rule 3.8, §402.3]
3. An owner or operator shall submit a standard District application for each emissions unit affected by the proposed permit revision that qualifies as a minor permit modification. The application shall be submitted after obtaining any required preconstruction permits. The emissions unit(s) shall not commence operation until the APCO approves the permit revision. In the application, the owner or operator shall include the following:

- a. A description of the proposed permit revision, any change in emissions, and additional applicable federal requirements that will apply;
- b. Proposed permit terms and conditions; and
- c. A certification by a responsible official that the permit revision meets criteria for use of minor permit modification procedures and a request that such procedures be used. [District Rule 3.8, §402.4]

**J. Permit Reopening for Cause**

1. Circumstances that are cause for reopening and revision of a permit include, but are not limited to, the following:
  - a. The need to correct a material mistake or inaccurate statement;
  - b. The need to revise or revoke a permit to operate to assure compliance with applicable federal requirements;
  - c. The need to incorporate any new, revised, or additional applicable federal requirements, if the remaining authorized life of the permit is 3 years or greater, no later than 18 months after the promulgation of such requirement (where less than 3 years remain in the authorized life of the permit, the APCO shall incorporate the requirements into the permit to operate upon renewal); or
  - d. Additional requirements promulgated pursuant to Title IV as they become applicable to any acid rain unit governed by the permit. [District Rule 3.8, §413.1]

**K. Recordkeeping**

1. The permit holder shall record maintenance of all monitoring and support information required by any applicable federal requirement, including:
  - a. Date, place, and time of sampling;
  - b. Operating conditions at the time of sampling;
  - c. Date, place, and method of analysis; and
  - d. Results of the analysis. [District Rule 3.8, §302.6a]
2. The permit holder shall retain records of all required monitoring data and support information for a period of at least five years from the date of sample collection, measurement, report, or application. [District Rule 3.8 §302.6b]

**L. Reporting Requirements**

1. Any deviation from permit requirements, including that attributable to upset conditions (as defined in the permit), shall be promptly reported to the APCO. For the purpose of this condition prompt means as soon as reasonably possible, but no later than 10 days after detection.[District Rule 3.8, §302.7a]
2. A semi-annual monitoring report shall be submitted at least once every six (6) consecutive calendar months and shall identify any deviation from permit requirements, including that previously reported to the APCO pursuant to Section 302.7(a) of Rule 3.8. Unless otherwise approved in writing by the District, the following shall apply:
  - a. The first six (6) month monitoring period will begin on January 1 and end on June 30, and the report will be due by July 31 of the reporting year; and
  - b. The second six (6) month period will begin on July 1 and end on December 31, and

Permit No. F-00454-25  
University of California, Davis

Effective: Proposed  
Expiration: February 2, 2016

the report will be due on January 31 of the following calendar year.

3. All reports of deviation from permit requirements shall include the probable cause of the deviation and any preventive or corrective action taken. [District Rule 3.8, §302.7c]
4. Each monitoring report shall be accompanied by a written statement from the responsible official that certifies the truth, accuracy, and completeness of the report. [District Rule 3.8, §302.7e]