



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

October 28, 2009
via electronic submittal

Mr. Gerardo Rios
USEPA – Region IX
Mail Stop A-5-2
75 Hawthorne Blvd.
San Francisco, CA 94105

Dear Mr. Rios:

Proposed De Minimus Significant Revision to Title V Permit for Eastern Municipal Water District, San Jacinto Facility (ID#19159)

Enclosed for your review is the proposed revisions to the Title V Permit for EMWD San Jacinto Facility located at 770 N. Sanderson Avenue, San Jacinto, CA. This revision is considered to be a de minimus significant permit revision, and a public notice is not required. We are enclosing proposed Sections H, which includes the revised permit as shown below, and the engineering evaluation.

SECTION H, PERMIT TO CONSTRUCT

Appl. No.	Equipment	Description
475845	Biofilter	New
475846	Sewage Treatment (>5 MGD) Anaerobic	Modification to increase capacity to 14 MGD from 11 MGD.

The initial Title V permit for this facility was issued on January 19, 2009, and a subsequent revision was issued on September 11, 2009.

The proposed changes will result in an increase of 8.5 lb/day of VOC emissions from the increase in capacity to 14 MGD from 11 MGD.

This request is being made via electronic submittal in order to facilitate your review. If you have any questions or need additional information, please contact Mr. Ken Matsuda at (909) 396-2656 or by email at kmatsuda@aqmd.gov.

Sincerely,

Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery and Waste Management Permitting

Enclosure

cc Appl.No. 475844
Ed Filadelfa, EMWD w/ proposed permit