

FACILITY PERMIT TO OPERATE OC WASTE & RECYCLING, SANTIAGO

PERMIT TO OPERATE

Permit No. TBD
A/N 494357

Equipment Description:

LANDFILL GAS FLARING SYSTEM CONSISTING OF:

1. ONE (1) CONDENSATE SEPARATOR WITH FILTER, ENDUSTRA, 3750 SCFM CAPACITY, 6'-8" HIGH BY 4'-6" DIAM.
2. ONE (1) FLOW METER WITH RECORDER, FOR TOTAL INLET LANDFILL GAS.
3. THREE (3) BLOWERS, LOCATED IN PARALLEL, EACH 40 HP, EACH 1250 SCFM.
4. THREE (3) SHUT-OFF VALVES, EACH 12-INCH CONNECTIONS, PNEUMATIC, LOCATED IN PARALLEL.
5. THREE (3) FLAME ARRESTORS, 12-INCH CONNECTIONS.
6. TWO (2) PUMPS (P-102A & P-102B), CONDENSATE/GROUNDWATER INJECTION, EACH 7.5 GPM MAX CAPACITY, PNEUMATIC, ALTERNATING OPERATION.
7. TWO (2) FILTERS (F-102A & F-102B).
8. THREE (3) SPRAY NOZZLES, CONDENSATE/GROUNDWATER INJECTION, ONE TO EACH FLARE, LOCATED IN MIDDLE OF BURNERS.
9. THREE (3) FLARES, EACH 8'-4.5" W. BY 8'-4" D. BY 30'-0" H., WITH PROPANE PILOT, PERRENIAL BURNERS, TEN 4-INCH SOURCE TEST PORTS, 41.25 MMBTU/HR, 1250 SCFM, SIX AUTOMATIC AIR LOUVERS, ELECTRIC IGNITER, UV FLAME SCANNER, AND THERMOCOUPLE WITH TEMPERATURE INDICATOR AND RECORDER, FLARES OPERATED IN PARALLEL.
10. TWO (2) TANKS, EACH 5 GALLON CAPACITY CONTAINING PROPANE GAS FOR FLARE PILOTS.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]

FACILITY PERMIT TO OPERATE OC WASTE & RECYCLING, SANTIAGO

3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. TEN (10) SAMPLING PORTS SHALL BE PROVIDED IN EACH FLARE STACK AT LEAST FIVE (5) FEET UPSTREAM OF THE FLARE OUTLET. FIVE OF THE PORTS SHALL BE LOCATED IN A LINEAR, HORIZONTAL POSITION ACROSS ONE SIDE OF THE FLARE STACK, AND THE REMAINING FIVE SHALL BE LOCATED IN A LINEAR, HORIZONTAL POSITION DIRECTLY OPPOSITE THE FIRST FIVE. EACH SAMPLING PORT SHALL CONSIST OF A FOUR-INCH COUPLING WITH PLUG. ALL PORTS SHALL BE PROPERLY CENTERED. AN EQUIVALENT METHOD OF EMISSION SAMPLING MAY BE USED UPON APPROVAL BY THE EXECUTIVE OFFICER. ADEQUATE AND SAFE ACCESS TO ALL SOURCE TEST PORTS SHALL BE PROVIDED.
[RULE 217]
5. A SAMPLING PORT SHALL BE INSTALLED AND MAINTAINED AT THE INLET GAS LINE TO THE FLARES TO ALLOW THE COLLECTION OF A LANDFILL GAS SAMPLE.
[RULE 217, 431.1, 1150.1, 1303(b)(2)-OFFSET]
6. EACH FLARE SHALL BE EQUIPPED WITH A TEMPERATURE INDICATOR AND RECORDER WHICH MEASURES AND RECORDS THE GAS TEMPERATURE IN THE FLARE STACK. THE TEMPERATURE INDICATOR AND RECORDER SHALL OPERATE WHENEVER ITS CORRESPONDING FLARE IS IN OPERATION. THE TEMPERATURE SHALL BE MEASURED AT A LOCATION ABOVE THE FLAME ZONE, AT LEAST 0.6 SECOND DOWNSTREAM OF THE BURNER AND NOT LESS THAN FIVE (5) FEET FROM THE TOP OF THE STACK.
[RULE 1303(a)(1)-BACT]
7. WHENEVER A FLARE IS IN OPERATION, A TEMPERATURE OF NOT LESS THAN 1500 DEGREES F, AS MEASURED BY THE TEMPERATURE INDICATOR AND RECORDER, SHALL BE MAINTAINED IN ITS FLARE STACK.
[RULE 1303(a)(1)-BACT]
8. EACH FLARE SHALL BE EQUIPPED WITH AN AUTOMATIC SHUT-DOWN SYSTEM WITH A FAILURE ALARM, WHICH HAS BEEN APPROVED BY THE EXECUTIVE OFFICER, TO AUTOMATICALLY ISOLATE THE FLARE FROM THE LANDFILL GAS SUPPLY LINE, SHUT OFF THE BLOWERS AND IMMEDIATELY NOTIFY A RESPONSIBLE PARTY OF THE SHUT-DOWN.
[RULE 1303(a)(1)-BACT]
9. THE AUTOMATIC SHUT-DOWN SAFETY SYSTEM SHALL BE TESTED MONTHLY FOR PROPER OPERATION AND THE RESULTS RECORDED.
[RULE 1303(a)(1)-BACT]
10. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE LANDFILL GAS SUPPLY LINE TO THE FLARE STATION TO MEASURE AND RECORD THE TOTAL QUANTITY OF LANDFILL GAS (IN SCFM) BEING BURNED IN THE FLARE STATION. THE FLOW INDICATING AND RECORDING DEVICE SHALL OPERATE CONTINUOUSLY WHENEVER THE FLARE(S) IS(ARE) IN OPERATION.
[RULE 1303(b)(2)-OFFSET]
11. THE PRESSURE DROP ACROSS EACH FLAME ARRESTOR SHALL BE MEASURED AND RECORDED MONTHLY.

- 23. EACH FLARE SHALL BE DESIGNED AND OPERATED SO THAT THE FLAME IN THE FLARE REMAINS BELOW THE HEIGHT OF THE FLARE'S OPERATING THERMOCOUPLE AT ALL TIMES. [RULE 1303(a)(1)-BACT]
- 22. EACH FLARE SHALL BE EQUIPPED WITH AT LEAST ONE VIEW PORT TO ALLOW VISUAL INSPECTION OF THE FLAME WITHIN THE FLARE AT ALL TIMES. SAFE AND ADEQUATE ACCESS SHALL BE PROVIDED FOR ALL VIEW PORTS UPON REQUEST BY SCAQMD PERSONNEL. [RULE 217, 1303(a)(1)-BACT]
- 21. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF DAY. [RULE 1303(b)(2)-OFFSET]
- 20. ALL LANDFILL GAS COLLECTED SHALL BE DIRECTED EITHER TO THE FLARE(S) FOR COMBUSTION OR TO A TREATMENT FACILITY WHICH HAS A VALID PERMIT FROM THE SCAQMD. [RULE 1150.1, 1303(a)(1)-BACT]
- 19. WEEKLY READINGS OF THE COMPOSITION OF THE LANDFILL GAS AT THE INLET TO THE FLARE(S) SHALL BE RECORDED USING AN INSTRUMENT APPROVED BY THE SCAQMD. [RULE 1303(b)(2)-OFFSET]
- 18. THE TOTAL VOLUME OF LIQUID INJECTED INTO THE FLARE STATION SHALL NOT EXCEED 2.46 GALLONS PER MINUTE (GPM). [RULE 1303(b)(2)-OFFSET, 1401]
- 17. THE VOLUME OF LIQUID INJECTED INTO EACH FLARE SHALL NOT EXCEED 1.9 GALLONS PER MINUTE (GPM). [RULE 1303(b)(2)-OFFSET, 1401]
- 16. THE TOTAL HEAT INPUT THROUGH THE FLARE STATION SHALL NOT EXCEED 112.5 MILLION BTU'S PER HOUR. [RULE 1303(b)(2)-OFFSET]
- 15. THE HEAT INPUT THROUGH EACH FLARE SHALL NOT EXCEED 41.25 MILLION BTU'S PER HOUR. [RULE 1303(b)(2)-OFFSET]
- 14. THE TOTAL COMBINED VOLUME OF LANDFILL GAS BURNED IN THE FLARE STATION SHALL NOT EXCEED 3672 STANDARD CUBIC FEET PER MINUTE. [RULE 1303(b)(2)-OFFSET]
- 13. THE VOLUME OF LANDFILL GAS BURNED IN EACH FLARE SHALL NOT EXCEED 1224 STANDARD CUBIC FEET PER MINUTE. [RULE 1303(b)(2)-OFFSET]
- 12. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE CONDENSATE LINE TO MEASURE AND RECORD THE CONDENSATE INJECTION RATE INTO THE FLARE. [RULE 1303(b)(2)-OFFSET]

**FACILITY PERMIT TO OPERATE
OC WASTE & RECYCLING, SANTIAGO**

FACILITY PERMIT TO OPERATE OC WASTE & RECYCLING, SANTIAGO

24. THE MAXIMUM FLARE SKIN TEMPERATURE AT ANY LOCATION SHALL NOT EXCEED 250 DEGREES F.
[RULE 217]
25. OPERATION OF THIS EQUIPMENT SHALL NOT RESULT IN THE RELEASE OF RAW LANDFILL GAS INTO THE ATMOSPHERE. ANY BREAKDOWN OR MALFUNCTION WHICH RESULTS IN EMISSIONS OF RAW LANDFILL GAS SHALL BE REPORTED TO THE SCAQMD MANAGER OF TOXICS AND WASTE MANAGEMENT TEAM WITHIN ONE HOUR AFTER OCCURRENCE, OR WITHIN ONE HOUR OF THE TIME ORANGE COUNTY PERSONNEL KNEW OR REASONABLY SHOULD HAVE KNOWN OF ITS OCCURRENCE, AND IMMEDIATE REMEDIAL MEASURES SHALL BE UNDERTAKEN TO CORRECT THE PROBLEM AND PREVENT FURTHER EMISSIONS INTO THE ATMOSPHERE.
[RULE 402, 430, 1150.1]
26. THE APPLICANT SHALL CONDUCT ANNUAL SOURCE TESTS AND SUBMIT WRITTEN RESULTS OF PERFORMANCE TESTS PERFORMED IN ACCORDANCE WITH SCAQMD RULE 1150.1. WRITTEN NOTICE OF THE PERFORMANCE TESTS SHALL BE PROVIDED TO THE SCAQMD 10 DAYS PRIOR TO THE TESTING SO THAT AN OBSERVER MAY BE PRESENT. ALL SOURCE TESTING AND ANALYTICAL METHODS SHALL BE SUBMITTED TO THE SCAQMD FOR APPROVAL AT LEAST 30 DAYS PRIOR TO START OF TESTS. THE TESTS SHALL INCLUDE, BUT MAY NOT BE LIMITED TO, A TEST OF THE INLET GAS TO THE FLARE AND THE FLARE EXHAUST FOR:
- A. METHANE
 - B. TOTAL NON-METHANE ORGANICS (WITH AND WITHOUT INJECTION)
 - C. OXIDES OF NITROGEN (EXHAUST ONLY)(WITH AND WITHOUT INJECTION)
 - D. CARBON MONOXIDE (EXHAUST ONLY)(WITH AND WITHOUT INJECTION)
 - E. TOTAL PARTICULATES (EXHAUST ONLY)(WITH AND WITHOUT INJECTION)
 - F. HYDROGEN SULFIDE (INLET ONLY)
 - G. C1 THROUGH C3 SULFUR COMPOUNDS (SPECIATED)(INLET ONLY)
 - H. CARBON DIOXIDE
 - I. RULE 1150.1 TABLE 1 COMPOUNDS
 - J. OXYGEN
 - K. NITROGEN
 - L. MOISTURE CONTENT
 - M. TEMPERATURE
 - N. FLOW RATE
 - O. NMOC DESTRUCTION EFFICIENCY
- [RULE 1150.1, 1303(a)(1)-BACT, 1303(b)(2)-OFFSET, 1401, 40 CFR 63 SUBPART AAAA]
27. APPLICANT SHALL SUBMIT ANALYSES OF CONDENSATE AND GROUNDWATER WITH ANNUAL SOURCE TEST RESULTS.
[RULE 1303(b)(2)-OFFSET, 1401]

**FACILITY PERMIT TO OPERATE
OC WASTE & RECYCLING, SANTIAGO**

28. EMISSIONS RESULTING FROM EACH FLARE SHALL NOT EXCEED THE FOLLOWING:

POLLUTANT	LBS./HOUR
NOX, AS NO2	2.50
SOX, AS SO2	0.50 0.56
CO	12.0
PM	1.4
NMHC, AS METHANE	0.65

[RULE 1303(b)(2)-OFFSET]

29. TOTAL EMISSIONS RESULTING FROM THE FLARE STATION SHALL NOT EXCEED THE FOLLOWING:

POLLUTANT	LBS./HOUR	LBS./DAY
NOX, AS NO2	6.8	162
SOX, AS SO2	1.12	27
CO	32.6	783
PM	4.1	99
NMHC, AS METHANE	1.91	46

[RULE 1303(b)(2)-OFFSET]

30. NO MORE THAN TWO FLARES OF THE FLARE STATION SHALL BE OPERATED AT THE SAME TIME.

31. EMISSIONS OF HEXAVALENT CHROME FROM THE FLARE STATION SHALL NOT EXCEED 0.03005 LB/YR. UNLESS OTHERWISE ANALYZED, ALL CHROME EMITTED SHALL BE ASSUMED TO BE HEXAVALENT.
[RULE 1401]

32. APPLICANT SHALL SAMPLE FOR TOTAL CHROME FROM A WELL-MIXED, COMPOSITE GROUNDWATER/CONDENSATE SAMPLE ON A WEEKLY BASIS WHENEVER GROUNDWATER IS BEING COLLECTED AT THE SITE FOR INJECTION INTO THE FLARE(S).
[RULE 1401]

33. OXIDES OF NITROGEN EMISSIONS SHALL NOT EXCEED 0.06 POUNDS PER MILLION BTU'S INLET GAS.
[RULE 1303(a)(1)-BACT]

33. CARBON MONOXIDE EMISSIONS SHALL NOT EXCEED 0.29 POUNDS PER MILLION BTU'S INLET GAS.
[RULE 1303(b)(2)-OFFSET]

34. PARTICULATE EMISSIONS SHALL NOT EXCEED 18.5 POUNDS PER MILLION CUBIC FEET INLET GAS.
[RULE 1303(b)(2)-OFFSET]

FACILITY PERMIT TO OPERATE OC WASTE & RECYCLING, SANTIAGO

Emissions and Requirements:

35. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

NMOC: 20 PPMV OR 98 WEIGHT PERCENT REDUCTION, RULE 1150.1

NMOC: 20 PPMV OR 98 WEIGHT PERCENT REDUCTION, 40 CFR 63 SUBPART AAAAA

CO: 2000 PPM, RULE 407

PM: 0.1 GR/SCF, RULE 409

PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS