



Re: FW: Added recordkeeping conditions for SJVAPCD project S -1100733 
Laura Yannayon to: Kristopher Rickards

10/13/2010 09:58 AM

Hi Richard,

The proposed condition changes look acceptable. Please go ahead and process the final action.

Laura Yannayon

US EPA, Region 9 / Air Division, Permits Office (Air-3) / 75 Hawthorne St. / San Francisco, CA
94105-3901

yannayon.laura@epa.gov / (415) 972-3534 / (415) 947-3579 (fax)

"Kristopher Rickards"

Laura,

10/13/2010 09:47:40 AM

From: "Kristopher Rickards" <kristopher.rickards@valleyair.org>
To: Laura Yannayon/R9/USEPA/US@EPA
Date: 10/13/2010 09:47 AM
Subject: FW: Added recordkeeping conditions for SJVAPCD project S-1100733

Laura,

This project was sent with a request for COC and received no comments from you on September 9, 2010.

It appears that inspection and maintenance conditions were dropped a few years ago around the time of the initial Title V permitting for permit S-1114-74. Since these would take a significant modification to remove I will be modifying and adding the following conditions back onto the ATC that was originally sent to you (S-1114-74-10):

8. Steam generator firebox convection section, scrubber/wet ESP bypass valve, and all flue gas ductwork shall be ~~maintained with no detectable leaks~~ inspected monthly for detectable leaks. Operator shall repair each leak within 15 calendar days of detection. [District NSR Rule and Rule 2520, 9.3.2]
41. Records of steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork monthly inspections shall be maintained. Inspection log shall contain at a minimum the following: 1) date of inspection; 2) name of inspector; 3) identification and location of leak; and 4) date when leak has been repaired. [District Rule 2520, 9.3.2]

Please let me know if you have any comments on this action,

Kris Rickards
Air Quality Engineer



Make one change for clean air!

San Joaquin Valley Air Pollution Control District

34946 Flyover Court | Bakersfield, CA 93308

www.valleyair.org | **Email:** Kristopher.Rickards@valleyair.org

Fax: (661) 392-5585 | **Phone:** (661) 392-5611

 *Please consider the environment before printing this email*

This message and any attachments are intended only for the use of the addressee and may contain information that is privileged and confidential. If the reader of the message is not the intended recipient or an authorized representative of the intended recipient, you are hereby notified that any dissemination of this communication is strictly prohibited. If you have received this communication in error, notify the sender immediately by return e-mail and delete the message and any attachments from your system.