



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

October 13, 2011

Mr. Ian Cuthbertson  
Plant Manger  
Southern California Edison, Mountainview Power  
2492 W. San Bernardino Ave  
Redlands, CA 92374

**SUBJECT:** RECLAIM/Title V Facility Permit Revision (Facility ID: 160437)

Dear Mr. Cuthbertson:

Please find attached the RECLAIM/Title V Facility Permit for your facility located at 2492 W. San Bernardino Ave, Redlands, CA 92374. This RECLAIM/Title V Facility Permit reflects the approval of the administrative permit revision requested in your Application No. 501263 for change of operator from Mountainview Power, LLC (ID 121737) to Southern California Edison (ID 160437) for the equipment listed in Attachment 1.

Please review the attached Title V Facility Permit carefully. Questions concerning changes to your permit should be directed to Mr. Chris Perri at (909) 396-2696.

Sincerely,

Brian L. Yeh  
Senior Manager  
Mechanical, Chemical, and Public Services

BLY:approval  
Attachments

cc: Gerardo Rios, EPA Region IX

**Attachment 1**

<i>Equipment</i>	<i>New A/N ID 160437</i>	<i>Previous A/N ID 121737</i>	<i>Device No.</i>	<i>Process /System</i>
Turbine/duct burner/stack 3A	500208	453966	18/21/26	1/1
CO/SCR catalyst 3-1	500214	366151	23/24	1/1
Turbine/duct burner/stack 3B	500211	453967	27/30/35	1/1
CO/SCR Catalyst 3-2	500217	366152	32/33	1/1
Turbine/duct burner/stack 4A	500212	453968	36/39/44	1/1
CO/SCR Catalyst 4-1	500218	366153	41/42	1/1
Turbine/duct burner/stack 4B	500213	453970	45/48/53	1/1
CO/SCR Catalyst 4-2	500219	366154	50/51	1/1
ICE	500220	399729	58	1/2
ICE	500222	454902	61	1/2
Tank	500221	446886	60	2/0
R219 Exempt Abrasive Blast	none	none	14	3/0
R219 Exempt Arch Coating	none	none	16	3/0

---

## FACILITY PERMIT TO OPERATE

---

**SOUTHERN CALIFORNIA EDISON  
2492 W SAN BERNARDINO AVE  
REDLANDS, CA 92374**

### NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.  
EXECUTIVE OFFICER

By   
Mohsen Nazemi, P.E.  
Deputy Executive Officer  
Engineering & Compliance

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	0	10/13/2011
B	RECLAIM Annual Emission Allocation	0	10/13/2011
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	0	10/13/2011
E	Administrative Conditions	0	10/13/2011
F	RECLAIM Monitoring and Source Testing Requirements	0	10/13/2011
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	0	10/13/2011
H	Permit To Construct and Temporary Permit to Operate	0	10/13/2011
I	Compliance Plans & Schedules	0	10/13/2011
J	Air Toxics	0	10/13/2011
K	Title V Administration	0	10/13/2011
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	0	10/13/2011
B	Rule Emission Limits	0	10/13/2011

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION A: FACILITY INFORMATION

**LEGAL OWNER &/OR OPERATOR:** SOUTHERN CALIFORNIA EDISON

**LEGAL OPERATOR (if different than owner):**

**EQUIPMENT LOCATION:** 2492 W SAN BERNARDINO AVE  
REDLANDS, CA 92374-5016

**MAILING ADDRESS:** 2492 W SAN BERNARDINO AVE  
REDLANDS, CA 92374

**RESPONSIBLE OFFICIAL:** RUSS KRIEGER

**TITLE:** VP POWER PRODUCTION

**TELEPHONE NUMBER:** (909) 394-8667

**CONTACT PERSON:** IAN CUTHBERTSON

**TITLE:** PLANT MANAGER

**TELEPHONE NUMBER:** (909) 478-1713

**INITIAL TITLE V PERMIT ISSUED:** April 09, 2010

**TITLE V PERMIT EXPIRATION DATE:** April 08, 2015

TITLE V	RECLAIM
YES	<b>NOx:</b> YES <b>SOx:</b> NO <b>CYCLE:</b> 1 <b>ZONE:</b> INLAND

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

### SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NO<sub>x</sub> RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NO<sub>x</sub> emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

#### RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year Begin End (month/year)	Zone	NO <sub>x</sub> RTC Initially Allocated	NO <sub>x</sub> RTC <sup>1</sup> Holding as of 10/13/2011 (pounds)	Non-Tradable <sup>2</sup> Non-Usable RTCs (pounds)
1/2011 12/2011	Coastal	0	178247	0
7/2011 6/2012	Coastal	0	81849	0
1/2011 12/2011	Inland	12035	13455	0
7/2011 6/2012	Inland	0	16081	0
1/2012 12/2012	Coastal	0	178247	0
7/2012 6/2013	Coastal	0	81849	0
1/2012 12/2012	Inland	12035	13455	0
7/2012 6/2013	Inland	0	16081	0
1/2013 12/2013	Coastal	0	178247	0
7/2013 6/2014	Coastal	0	81849	0
1/2013 12/2013	Inland	12035	13455	0
7/2013 6/2014	Inland	0	16081	0
1/2014 12/2014	Coastal	0	178247	0
7/2014 6/2015	Coastal	0	81849	0
1/2014 12/2014	Inland	12035	13455	0
7/2014 6/2015	Inland	0	16081	0
1/2015 12/2015	Coastal	0	178247	0

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

### SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NO<sub>x</sub> RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NO<sub>x</sub> emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

#### RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year Begin End (month/year)	Zone	NO <sub>x</sub> RTC Initially Allocated	NO <sub>x</sub> RTC <sup>1</sup> Holding as of 10/13/2011 (pounds)	Non-Tradable <sup>2</sup> Non-Usable RTCs (pounds)
7/2015 6/2016	Coastal	0	81849	0
1/2015 12/2015	Inland	12035	13455	0
7/2015 6/2016	Inland	0	16081	0
1/2016 12/2016	Coastal	0	178247	0
7/2016 6/2017	Coastal	0	81849	0
1/2016 12/2016	Inland	12035	13455	0
7/2016 6/2017	Inland	0	16081	0
1/2017 12/2017	Coastal	0	178247	0
7/2017 6/2018	Coastal	0	81849	0
1/2017 12/2017	Inland	12035	13455	0
7/2017 6/2018	Inland	0	16081	0
1/2018 12/2018	Coastal	0	178247	0
7/2018 6/2019	Coastal	0	81849	0
1/2018 12/2018	Inland	12035	13455	0
7/2018 6/2019	Inland	0	16081	0
1/2019 12/2019	Coastal	0	178247	0
7/2019 6/2020	Coastal	0	81849	0

**Footnotes:**

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION**

The annual allocation of NOx RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NOx emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

**RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)**

Year Begin End (month/year)	Zone	NOx RTC Initially Allocated	NOx RTC <sup>1</sup> Holding as of 10/13/2011 (pounds)	Non-Tradable <sup>2</sup> Non-Usable RTCs (pounds)
1/2019 12/2019	Inland	12035	13455	0
7/2019 6/2020	Inland	0	16081	0
1/2020 12/2020	Coastal	0	178247	0
7/2020 6/2021	Coastal	0	81849	0
1/2020 12/2020	Inland	12035	13455	0
7/2020 6/2021	Inland	0	16081	0
1/2021 12/2021	Coastal	0	178247	0
7/2021 6/2022	Coastal	0	81849	0
1/2021 12/2021	Inland	12035	13455	0
7/2021 6/2022	Inland	0	16081	0
1/2022 12/2022	Coastal	0	178247	0
7/2022 6/2023	Coastal	0	81849	0
1/2022 12/2022	Inland	12035	13455	0
7/2022 6/2023	Inland	0	16081	0
1/2023 12/2023	Coastal	0	178247	0
7/2023 6/2024	Coastal	0	81849	0
1/2023 12/2023	Inland	12035	13455	0

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION**

The annual allocation of NOx RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NOx emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

**RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)**

Year Begin End (month/year)	Zone	NOx RTC Initially Allocated	NOx RTC <sup>1</sup> Holding as of 10/13/2011 (pounds)	Non-Tradable <sup>2</sup> Non-Usable RTCs (pounds)
7/2023 6/2024	Inland	0	16081	0
1/2024 12/2024	Coastal	0	178247	0
7/2024 6/2025	Coastal	0	81849	0
1/2024 12/2024	Inland	12035	13455	0
7/2024 6/2025	Inland	0	16081	0
1/2025 12/2025	Coastal	0	178247	0
7/2025 6/2026	Coastal	0	81849	0
1/2025 12/2025	Inland	12035	13455	0
7/2025 6/2026	Inland	0	16081	0
1/2026 12/2026	Coastal	0	178247	0
1/2026 12/2026	Inland	12035	13455	0

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION**

The annual allocation of RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. If the facility submits a permit application to increase in an annual allocation to a level greater than the facility's starting Allocation plus Non-Tradable credits as listed below, the application will be evaluated for compliance with Rule 2005 (c)(4). Rule 2005 (e) - Trading Zone Restrictions applies if an annual allocation is increased to a level greater than the facility's Starting Allocation plus Non-Tradable Credits:

Year		Zone	NOx RTC	Non-Tradable Credits(NTC) (pounds)
Begin (month/year)	End		Starting Allocation (pounds)	
1/1994	12/1994	Inland	30727	49187

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION C: FACILITY PLOT PLAN**

(TO BE DEVELOPED)

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION</b>					
<b>System 1: POWER GENERATION</b>					

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION</b>					
STEAM TURBINE, STEAM, COMMON WITH GAS TURBINE 3-2, 209.2 MW (MAXIMUM GROSS OUTPUT)					
BURNER, DUCT, NATURAL GAS, 135 MMBTU/HR A/N: 500208	D21		NOX: MAJOR SOURCE**		
OXIDIZER, CARBON MONOXIDE, NO. 3-1, WITH 240 CUBIC FEET OF TOTAL CATALYST VOLUME A/N: 500214	C23	D18			
SELECTIVE CATALYTIC REDUCTION, NO. 3-1, WITH 2750 CUBIC FEET OF TOTAL CATALYST VOLUME, WIDTH: 25 FT 6 IN; HEIGHT: 72 FT ; LENGTH: 1 FT 6 IN WITH AMMONIA INJECTION, INJECTION GRID A/N: 500214	C24	D18		NH3: 5 PPMV (4) [RULE 1303(a) (1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A195.4, D12.3, D12.4, D12.5, D29.3, E179.1, E179.2
STACK, NO. 3-1 A/N: 500208	S26	D18			

- \* (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate  
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit  
(5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit  
(7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
(9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
<b>Process I: INTERNAL COMBUSTION</b>					
GAS TURBINE, NO. 3B (TRAIN 3-2), NATURAL GAS, GENERAL ELECTRIC, MODEL 7241FA, COMBINED CYCLE, WITH DRY LOW NOX COMBUSTORS, 1991 MMBTU/HR WITH A/N: 500211	D27	C32 C33 S35	NOX: MAJOR SOURCE**	CO: 6 PPMV (4) [RULE 1303(a) (1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 2000 PPMV (5) [RULE 407, 4-2-1982]; NOX: 2 PPMV (4) [RULE 2005, 4-20-2001; RULE 2005, 5-6-2005]; NOX: 87.9 PPMV (8) [40CFR 60 Subpart GG, 3-6-1981]; PM: 0.01 GRAINS/SCF (5B) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]; PM: 11 LBS/HR (5A) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; SO <sub>2</sub> : (9) [40CFR 72 - Acid Rain Provisions, 11-24-1997]; SOX: 150 PPMV (8) [40CFR 60 Subpart GG, 3-6-1981]; VOC: 2 PPMV (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a) (1)-BACT, 12-6-2002]	A63.2, A63.3, A63.4, A99.2, A99.3, A195.1, A195.2, A327.1, A433.1, A433.2, D29.2, D82.1, D82.2, D182.1, D372.1, E57.1, E193.1, E193.3, E193.4, H23.4, I296.1, K40.1, K67.4, K171.1, K171.2, K171.3
GENERATOR, ELECTRICAL, 175.7 MW (MAXIMUM GROSS OUTPUT)					
GENERATOR, HEAT RECOVERY STEAM					
STEAM TURBINE, STEAM, COMMON WITH GAS TURBINE 3-1, 209.2 MW (MAXIMUM GROSS OUTPUT)					

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
(3) Denotes RECLAIM concentration limit  
(5) (5A) (5B) Denotes command and control emission limit  
(7) Denotes NSR applicability limit  
(9) See App B for Emission Limits  
(2) (2A) (2B) Denotes RECLAIM emission rate  
(4) Denotes BACT emission limit  
(6) Denotes air toxic control rule limit  
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
(10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION</b>					
BURNER, DUCT, NATURAL GAS, 135 MMBTU/HR A/N: 500211	D30		NOX: MAJOR SOURCE**		
OXIDIZER, CARBON MONOXIDE, NO. 3-2, WITH 240 CUBIC FEET OF TOTAL CATALYST VOLUME A/N: 500217	C32	D27			
SELECTIVE CATALYTIC REDUCTION, NO. 3-2, WITH 2750 CUBIC FEET OF TOTAL CATALYST VOLUME, WIDTH: 25 FT 6 IN; HEIGHT: 72 FT ; LENGTH: 1 FT 6 IN WITH A/N: 500217  AMMONIA INJECTION, INJECTION GRID	C33	D27		NI13: 5 PPMV (4) [RULE 1303(a) (1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A195.4, D12.3, D12.4, D12.5, D29.3, E179.1, E179.2
STACK, NO. 3-2 A/N: 500211	S35	D27			

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION</b>					
GAS TURBINE, NO. 4A (TRAIN 4-1), NATURAL GAS, GENERAL ELECTRIC, MODEL 7241FA, COMBINED CYCLE, WITH LOW NOX COMBUSTORS, 1991 MMBTU/HR WITH A/N: 500212	D36	C41 C42 S44	NOX: MAJOR SOURCE**	CO: 6 PPMV (4) [RULE 1303(a) (1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 2000 PPMV (5) [RULE 407, 4-2-1982]; NOX: 2 PPMV (4) [RULE 2005, 4-20-2001; RULE 2005, 5-6-2005]; NOX: 87.9 PPMV (8) [40CFR 60 Subpart GG, 3-6-1981]; PM: 0.01 GRAINS/SCF (5B) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981; RULE 429, 12-21-1990]; PM: 11 LBS/HR (5A) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; SO2: (9) [40CFR 72 - Acid Rain Provisions, 11-24-1997]; SOX: 150 PPMV (8) [40CFR 60 Subpart GG, 3-6-1981]; VOC: 2 PPMV (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a) (1)-BACT, 12-6-2002]	A63.2, A63.3, A63.4, A99.2, A99.3, A195.1, A195.2, A327.1, A433.1, A433.2, D29.2, D82.1, D82.2, D182.1, D372.1, E57.1, E193.1, E193.3, E193.4, H23.4, I296.1, K40.1, K67.4, K171.1, K171.2, K171.3
GENERATOR, ELECTRICAL, 175.7 MW (MAXIMUM GROSS OUTPUT)					
GENERATOR, HEAT RECOVERY STEAM					
STEAM TURBINE, STEAM, COMMON WITH GAS TURBINE 4-2, 209.2 MW (MAXIMUM GROSS OUTPUT)					

\* (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate  
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit  
(5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit  
(7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
(9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION</b>					
BURNER, DUCT, NATURAL GAS, 135 MMBTU/HR A/N: 500212	D39		NOX: MAJOR SOURCE**		
OXIDIZER, CARBON MONOXIDE, NO. 4-1, WITH 240 CUBIC FEET OF TOTAL CATALYST VOLUME A/N: 500218	C41	D36			
SELECTIVE CATALYTIC REDUCTION, NO. 4-1, WITH 2750 CUBIC FEET OF TOTAL CATALYST VOLUME, WIDTH: 25 FT 6 IN; HEIGHT: 72 FT ; LENGTH: 1 FT 6 IN WITH A/N: 500218  AMMONIA INJECTION, INJECTION GRID	C42	D36		NI13: 5 PPMV (4) [RULE 1303(a) (1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(1)-Modeling, 5-10-1996]	A195.4, D12.3, D12.4, D12.5, D29.3, E179.1, E179.2
STACK, NO. 4-1 A/N: 500212	S44	D36			

\* (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements  
 \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION</b>					
GAS TURBINE, NO. 4B (TRAIN 4-2), NATURAL GAS, GENERAL ELECTRIC, MODEL 7241FA, COMBINED CYCLE, WITH DRY LOW NOX COMBUSTORS, 1991 MMBTU/HR WITH A/N: 500213	D45	C50 C51 S53	NOX: MAJOR SOURCE**	CO: 6 PPMV (4) [RULE 1303(a) (1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 2000 PPMV (5) [RULE 407, 4-2-1982]; NOX: 2 PPMV (4) [RULE 2005, 4-20-2001; RULE 2005, 5-6-2005]; NOX: 87.9 PPMV (8) [40CFR 60 Subpart GG, 3-6-1981]; PM: 0.01 GRAINS/SCF (5B) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]; PM: 11 LBS/HR (5A) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; SO2: (9) [40CFR 72 - Acid Rain Provisions, 11-24-1997]; SOX: 150 PPMV (8) [40CFR 60 Subpart GG, 3-6-1981]; VOC: 2 PPMV (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a) (1)-BACT, 12-6-2002]	A63.2, A63.3, A63.4, A99.2, A99.3, A193.1, A195.2, A327.1, A433.1, A433.2, D29.2, D82.1, D82.2, D182.1, D372.1, E57.1, E193.1, E193.3, E193.4, H23.4, I296.1, K40.1, K67.4, K171.1, K171.2, K171.3
GENERATOR, ELECTRICAL, 175.7 MW (MAXIMUM GROSS OUTPUT)					
GENERATOR, HEAT RECOVERY STEAM					
STEAM TURBINE, STEAM, COMMON WITH GAS TURBINE 4-1, 209.2 MW (MAXIMUM GROSS OUTPUT)					

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION</b>					
BURNER, DUCT, NATURAL GAS, 135 MMBTU/HR A/N: 500213	D48		NOX: MAJOR SOURCE**		
OXIDIZER, CARBON MONOXIDE, NO. 4-2, WITH 240 CUBIC FEET OF TOTAL CATALYST VOLUME A/N: 500219	C50	D45			
SELECTIVE CATALYTIC REDUCTION, NO. 4-2, WITH 2750 CUBIC FEET OF TOTAL CATALYST VOLUME, WIDTH: 25 FT 6 IN; HEIGHT: 72 FT; LENGTH: 1 FT 6 IN WITH A/N: 500219  AMMONIA INJECTION, INJECTION GRID	C51	D45		NI13: 5 PPMV (4) [RULE 1303(a) (1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A195.A, D12.3, D12.4, D12.5, D29.3, E179.1, E179.2
STACK, NO. 4-2 A/N: 500213	S53	D45			
<b>System 2: DIESEL ENGINES</b>					

- \* (1) (1A) (1B) Denotes RECLAIM emission factor  
(3) Denotes RECLAIM concentration limit  
(5) (5A) (5B) Denotes command and control emission limit  
(7) Denotes NSR applicability limit  
(9) See App B for Emission Limits
- (2) (2A) (2B) Denotes RECLAIM emission rate  
(4) Denotes BACT emission limit  
(6) Denotes air toxic control rule limit  
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
(10) See section J for NESHAP/MACT requirements
- \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, LEAN BURN, DIESEL FUEL, CLARKE, MODEL JW6H-UF60, FUEL INJECTION TIMING RETARD, WITH AFTERCOOLER, TURBOCHARGER, 375 BHP A/N: 500220	D58		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a) (1)-BACT, 12-6-2002]; NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 2005, 4-20-2001; RULE 2005, 5-6-2005]; NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-11-2001; RULE 2012, 12-5-2003]; PM: (9) [RULE 404, 2-7-1986]; PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1) -BACT, 12-6-2002]; VOC: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1) -BACT, 12-6-2002]	B61.1, C1.1, C177.2, I296.1, K67.3

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
(3) Denotes RECLAIM concentration limit  
(5) (5A) (5B) Denotes command and control emission limit  
(7) Denotes NSR applicability limit  
(9) See App B for Emission Limits  
(2) (2A) (2B) Denotes RECLAIM emission rate  
(4) Denotes BACT emission limit  
(6) Denotes air toxic control rule limit  
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
(10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, LEAN BURN, DIESEL FUEL, CATERPILLAR, MODEL 3512B, AUTOMATIC FUEL INJECTION TIMING RETARD, WITH AFTERCOOLER, TURBOCHARGER, 2155 BHP WITH A/N: 500222  FILTER, DIESEL PARTICULATES, CLEANAIR SYSTEMS "PERMIT", WITH SIX 15" X 15" PARALLEL OXIDIZING FILTER ELEMENTS	D61		NOX: PROCESS UNIT**	CO: 0.072 GRAM/13HP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.53 GRAM/BHP-HR DIESEL (4) [RULE 2005, 4-9-1999]; NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 12-5-2003]; PM: (9); PM10: 0.024 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; VOC: 0.026 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	B61.1, C1.2, E193.2, I296.1, K67.5
<b>Process 2: STORAGE TANKS</b>					
STORAGE TANK, TK-3, 19%W AQUEOUS AMMONIA, SERVING SCR 3-1, 3-2, 4-1, AND 4-2 WITH A VAPOR RETURN LINE, 36000 GALS; DIAMETER: 15 FT ; LENGTH: 27 FT A/N: 500221	D60				C157.1, E144.1
<b>Process 3: R219 EQUIPMENT SUBJECT TO SOURCE-SPECIFIC RULE</b>					
RULE 219 EXEMPT EQUIPMENT, ABRASIVE BLASTING EQUIPMENT, GLOVE-BOX, <= 53 FT3, WITH DUST FILTER	E14			PM: (9) [RULE 1140, 8-2-1985; RULE 404, 2-7-1986; RULE 405, 2-7-1986]	D322.1, D381.1, K67.1

\* (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate  
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit  
(5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit  
(7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
(9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
<b>Process 3: R219 EQUIPMENT SUBJECT TO SOURCE-SPECIFIC RULE</b>					
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS	E16			ROG: (9) [RULE 1113, 11-8-1996; RULE 1113, 7-9-2004; RULE 1171, 11-7-2003; RULE 1171, 5-6-2005]	K67.2

\* (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION D: DEVICE ID INDEX**

**The following sub-section provides an index  
to the devices that make up the facility  
description sorted by device ID.**

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION D: DEVICE ID INDEX**

Device Index For Section D			
Device ID	Section D Page No.	Process	System
E14	11	3	0
E16	12	3	0
D18	3	1	1
D21	3	1	1
C23	3	1	1
C24	3	1	1
S26	3	1	1
D27	4	1	1
D30	5	1	1
C32	5	1	1
C33	5	1	1
S35	5	1	1
D36	6	1	1
D39	7	1	1
C41	7	1	1
C42	7	1	1
S44	7	1	1
D45	8	1	1
D48	9	1	1
C50	9	1	1
C51	9	1	1
S53	9	1	1
D58	10	1	2
D60	11	2	0
D61	11	1	2

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

#### FACILITY CONDITIONS

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

F14.1 The operator shall not use diesel fuel containing sulfur compounds in excess of 0.05 percent by weight.

F14.2 The operator shall not purchase diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

F18.1 Acid Rain SO<sub>2</sub> Allowance Allocation for affected units are as follows:

Device ID	Boiler ID	Contaminant	Tons in any year
1	Boiler No. 1	SO <sub>2</sub>	117
2	Boiler No. 2	SO <sub>2</sub>	17

#### DEVICE CONDITIONS

##### A. Emission Limits

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

A63.2 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
CO	Less than or equal to 8610 LBS IN ANY ONE MONTH
VOC	Less than or equal to 3569 LBS IN ANY ONE MONTH
PM10	Less than or equal to 7725 LBS IN ANY ONE MONTH
SOX	Less than or equal to 1005 LBS IN ANY ONE MONTH

The operator shall calculate the monthly emissions for VOC, PM10 and SOx using the equation below and the following emission factors: VOC - 2.51 lbs/mmescf; PM10 - 5.57 lbs/mmescf; and SOx - 0.71 lbs/mmescf.

Monthly Emissions, lbs/mon = X (E.F.)

where X = monthly fuel usage, mmscf/mon and E.F = emission factor indicated above.

Compliance with the CO emission limit shall be verified through valid CEMS data.

The operator shall calculate the emission limit(s) for the purpose of determining compliance with the monthly CO limit in the absence of valid CEMS data by using the above equation and the following emission factor(s):

(C) After CO CEMS certification testing - 13.10 lbs CO/mmescf. After CO CEMS certification test is approved by the AQMD, the emissions monitored by the CEMS and calculated in accordance with Condition 82.1 shall be used to calculate emissions.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D18, D27, D36, D45]

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

A63.3 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
CO	Less than or equal to 694 LBS IN ANY ONE DAY

The operator shall calculate the emission limit(s) from valid CEMS data. In the absence of valid CEMS data, the daily CO emissions shall be calculated by using daily fuel use data and the following emission factor: 13.10 lbs/mmcf.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D18, D27, D36, D45]

A63.4 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
NOX	Less than 3419 LBS IN ANY ONE DAY

The limit shall be based on the emissions of all 4 turbines combined

[40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : D18, D27, D36, D45]

A99.2 The 2.0 PPM NOX emission limit(s) shall not apply during a startup. Startup time shall not exceed 4 hours per day, except for a cold startup or combustor tuning activities, which shall not exceed 6 hours per day. A shutdown event shall not exceed 30 minutes.

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

A cold start up shall be defined as a start up of the gas turbine after the steam turbine has been shut down for a period of 72 hours or more

A gas turbine shutdown event shall be defined as the period beginning with the inability to comply with the 2.0 ppmv limit after initiation of the combustion turbine shutdown sequence and ending either with 1) the cessation of firing of the combustion turbine, or 2) when the unit ramps back up after an aborted shutdown, to the attainment of minimum load

Total start up and shutdown time for all four gas turbines shall not exceed 3008 hours per year

**[RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; 40CFR 52.21 - PSD, 6-19-1978]**

[Devices subject to this condition : D18, D27, D36, D45]

A99.3 The 6.0 PPM CO emission limit(s) shall not apply during a startup. Startup time shall not exceed 4 hours per day, except for a cold startup or combustor tuning activities, which shall not exceed 6 hours per day. A shutdown event shall not exceed 30 minutes.

A cold startup shall be defined as a start up of the gas turbine after the steam turbine has been shutdown for a period of 72 hours or more

A gas turbine shutdown event shall be defined as the period beginning with the inability to comply with the 2.0 ppmv NOx limit after initiation of the combustion turbine shutdown sequence and ending either with 1) the cessation of firing of the combustion turbine, or 2) when the unit ramps back up after an aborted shutdown, to the attainment of minimum load

Total start up and shutdown time for all four gas turbines shall not exceed 3008 hours per year

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; 40CFR 52.21 - PSD, 6-19-1978]**

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D18, D27, D36, D45]

A195.1 The 2.0 PPM NOX emission limit(s) is averaged over 60 minutes at 15 percent oxygen, dry. The limit shall not apply to the first fifteen 1-hour average NOx emissions above 2.0 ppmv, dry basis at 15% O2, in any rolling 12-month period for each combustion gas turbine provided that it meets all of the following requirements in subsections A, B, C, and D below.

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

A. This equipment operates under any one of the following qualified conditions listed under a, b, c, or d.

a) Rapid combustion turbine load changes due to the following conditions: 1) Load changes initiated by the California ISO or a successor entity when the plant is operating under Automatic Generation Control; or 2) Activation of a plant automatic safety or equipment protection system which rapidly decreases turbine load.

b) The first two 1-hour reporting periods following the initiation/shutdown of an evaporative cooler, c) The first two 1-hour reporting periods following the initiation/shutdown of HRSG duct burners, d) events as the result of technological limitation identified by the operator and approved in writing by the EPA and AQMD EO or his designees.

B. The 1-hour average NO<sub>x</sub> emissions above 2.0 ppmv, dry basis at 15 percent O<sub>2</sub>, did not occur as a result of operator neglect, improper operation or maintenance, or qualified breakdown under Rule 2004(i).

C. The qualified operating conditions described in (A) above are recorded in the plant's operating log within 24 hours of the event, and in the CEMS by 5 p.m. the next business day following the qualified operating condition. The notations in the log and CEMS must describe the data and time of entry into the log/CEMS and the plant operating conditions responsible for NO<sub>x</sub> emissions exceeding the 2.0 ppmv 1-hour average limit.

D. The 1-hour average NO<sub>x</sub> concentration for periods that result from a qualified operating condition does not exceed 25 ppmv, dry basis at 15 percent O<sub>2</sub>.

All NO<sub>x</sub> emissions during these events shall be included in all calculations of hourly, daily, and annual mass emission rates as required by this permit.

[RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; 40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : D18, D27, D36, D45]

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

A195.2 The 6.0 PPMV CO emission limit(s) is averaged over 60 minutes at 15 percent oxygen, dry.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D18, D27, D36, D45]

A195.4 The 5.0 PPM NH3 emission limit(s) is averaged over 60 minutes at 15 percent O2, dry. The operator shall calculate and continuously record the NH3 slip concentration using the following:  $NH_3(ppmv)=[a-b*(c*1.2)/1E6]*1E6/b$ , where a=NH3 injection rate (lb/hr)/17(lb/lbmol), b=dry exhaust flow rate (scf/hr)/(385.5 scf/lbmol), c=change in measured NOx across the SCR, ppmvd at 15 percent O2. The operator shall install a NOx analyzer to measure the SCR inlet NOx ppm accurate to within +/- 5 percent calibrated at least once every 12 months.

The operator shall use the method described above or another alternative method approved by the Executive Officer.

The ammonia slip calculation procedures described above shall not be used for compliance determination or emission information determination without corroborative data using an approved reference method for the determination of ammonia.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C24, C33, C42, C51]

A327.1 For the purpose of determining compliance with District Rule 475, combustion contaminant emissions may exceed the concentration limit or the mass emission limit listed, but not both limits at the same time.

[RULE 475, 10-8-1976; RULE 475, 8-7-1978]

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D18, D27, D36, D45]

A433.1 The operator shall comply with the 2.0 ppmvd NOx BACT emission concentration limit at all times, except as specified in Condition A195.1 and under the following conditions:

Emission Limit	Averaging Time	Operation Requirements
600 lbs/startup	6 Hour	The 600 lbs/startup emission limit shall apply to a single turbine during a cold startup which shall not exceed 6 hours per day.
400 lbs/startup	4 Hour	The 400 lbs/startup emission limit shall apply to a single turbine during a startup other than a cold startup. Startup time shall not exceed 4 hours/day.
320 lbs/hr	1 Hour	The 320 lbs/hr limit shall only apply when a turbine is in any startup mode. The limit shall be based on the total emissions from the 4 turbines (D18, D27, D36, D45) and the duct burners (D21, D30, D39, and D48)

For purposes of this entire condition, a cold startup shall be defined as a start up of a gas turbine after the steam turbine has been shutdown for a period of 72 hours or more

[RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; 40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : D18, D27, D36, D45]

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

**The operator shall comply with the terms and conditions set forth below:**

A433.2 The operator shall comply with the 2.0 ppmvd NOx BACT emission concentration limit at all times, except as specified in Condition A195.1 and under the following conditions:

Emission Limit	Averaging Time	Operation Requirements
80 lbs/hr	1 Hour	The 80 lbs/hr emission limit shall apply to combustor tuning. Combustor tuning activity shall not exceed 6 hrs/day. The operator shall notify the AQMD via email at REFINERYENERGY@AQMD.GOV within 2 weeks of combustor tuning activity.
160 lbs/hr	3 Hour	The 160 lbs/hr emission limit shall apply to a single turbine during startups. Startup time shall not exceed 4 hours/day, except for a cold startup which shall not exceed 6 hours per day.
70 lbs/shutdown	30 minutes	The 70 lbs/shutdown emission limit shall apply to a single gas turbine during a shutdown event which shall not exceed 30 minutes per event

For purposes of this entire condition, a cold startup shall be defined as a start up of a gas turbine after the steam turbine has been shutdown for a period of 72 hours or more

[RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; 40CFR 52.21 - PSD, 6-19-1978]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D18, D27, D36, D45]

#### B. Material/Fuel Type Limits

B61.1 The operator shall only use Diesel fuel containing the following specified compounds:

Compound	Limit	ppm by weight
Sulfur	less than or equal to	15

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470, 3-4-2005]

[Devices subject to this condition : D58, D61]

#### C. Throughput or Operating Parameter Limits

C1.1 The operator shall limit the operating time to no more than 199 hour(s) in any one year.

To comply with this condition, the operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

The 199 hours per year shall include no more than 34 hours in any one year for maintenance and testing purposes..

[RULE 1110.2, 11-14-1997; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 1401, 5-3-2002; RULE 1470, 6-1-2007; RULE 2012, 5-11-2001; RULE 2012, 12-5-2003; 40CFR 52.21 - PSD, 6-19-1978]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D58]

C1.2 The operator shall limit the operating time to no more than 200 hour(s) in any one year.

To comply with this condition, the operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

The total operating time allowed under this condition includes no more than 50 hours in any one year for maintenance and testing.

Operation of the engine beyond the 50 hr/yr allotted for engine maintenance and testing shall be allowed only in the event of a loss of grid power, emergency operation as defined in R 1470, or up to 30 min prior to a rotating outage, if the grid operator or utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time, and the engine is located in a utility service block that is subject to the rotating outage.

Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

[RULE 1110.2, 11-14-1997; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996**; RULE 1401, 5-3-2002; RULE 1470, 6-1-2007; **RULE 2012, 12-5-2003**; **RULE 2012, 1-7-2005**]

[Devices subject to this condition : D61]

C157.1 The operator shall install and maintain a pressure relief valve with a minimum pressure set at 25 psig.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; **RULE 1303(a)(1)-BACT, 12-6-2002**]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D60]

C177.2 The operator shall set and maintain the fuel injection timing of the engine at 9.7 degrees retarded relative to standard timing.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; 40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : D58]

#### D. Monitoring/Testing Requirements

D12.3 The operator shall install and maintain a(n) continuous monitoring system to accurately indicate the ammonia injection rate of the ammonia injection system.

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; 40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : C24, C33, C42, C51]

D12.4 The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature in the SCR catalyst.

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

**The operator shall comply with the terms and conditions set forth below:**

[RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; 40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : C24, C33, C42, C51]

D12.5 The operator shall install and maintain a(n) pressure gauge to accurately indicate the pressure across the SCR catalyst bed in inches water column.

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; 40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : C24, C33, C42, C51]

D29.2 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
SOX emissions	Approved District method	District-approved averaging time	Fuel Sample
VOC	Approved District method	1 hour	Outlet of the SCR serving this equipment
PM10 emissions	Approved District method	District-approved averaging time	Outlet of the SCR serving this equipment

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

The test(s) shall be conducted at least once every three years. In the case where 3 consecutive annual PM tests (required under condition D372.1) show compliance, the once every 3 year frequency of this condition shall take precedence over the once every 5 year time frame specified in condition D372.1.

The test shall be conducted and the results submitted to the District within 60 days after the test date. The AQMD shall be notified of the date and time of the test at least 7 days prior to the test.

The test shall be conducted in accordance with a District approved source test protocol. The protocol shall be submitted to the District permitting engineer no later than 45 days before the proposed test date and shall be approved by the District before the test commences. The protocol shall include the proposed operating conditions of the turbine during the tests, the identity of the testing lab, a statement from the lab certifying that it meets the criteria of R304, and a description of all sampling and analytical procedures.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration and emissions limit.

The test shall be conducted to determine the oxygen levels in the exhaust. In addition, the tests shall measure the fuel flow rate (CFH), the flue gas flow rate, and the turbine generating output (MW).

The test shall be conducted for compliance verification of the BACT VOC 2.0 ppmv limit.

For natural gas fired turbines only, VOC compliance shall be demonstrated as follows: a) Stack gas samples are extracted into Summa canisters, maintaining a final canister pressure between 400 - 500 mm Hg absolute, b) Pressurization of canisters are done with zero gas analyzed/certified to contain less than 0.05 ppmv total hydrocarbon as carbon, and c) Analysis of canisters are per EPA Method TO-12 (with pre-concentration) and temperature of canisters when extracting samples for analysis is not below 70 degF

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

**The operator shall comply with the terms and conditions set forth below:**

The use of this alternative method for VOC compliance determination does not mean that it is more accurate than AQMD Method 25.3, nor does it mean that it may be used in lieu of AQMD method 25.3 without prior approval, except for the determination of compliance with the VOC BACT level of 2.0 ppmv calculated as carbon for natural gas fired turbines.

Because the VOC BACT level was set using data derived from various source test methods, this alternate VOC compliance method provides a fair comparison and represents the best sampling and analysis technique for this purpose at this time. The test results shall be reported with two significant digits.

The test shall be conducted when this equipment is operating at loads of 100, 75, and 50 percent of maximum load.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D18, D27, D36, D45]

D29.3 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NH3 emissions	District method 207.1 and 5.3 or EPA method	1 hour	Outlet of the SCR serving this equipment

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

The test shall be conducted once each calendar quarter during the first 12 months of operation and at least annually thereafter. The NO<sub>x</sub> concentration, as determined by the CEMS, shall be simultaneously recorded during the ammonia slip test. If the CEMS is inoperable, a test shall be conducted to determine the NO<sub>x</sub> emissions using District Method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit.

The test shall be conducted when the equipment is operating at 80 percent load or greater.

The test shall be conducted and the results submitted to the AQMD permitting engineer within 45 days after the test date.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C24, C33, C42, C51]

D82.1 The operator shall install and maintain a CEMS to measure the following parameters:

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

CO concentration in ppmv

Concentrations shall be corrected to 15 percent oxygen on a dry basis.

The CEMS shall be installed and operated to measure CO concentrations over a 15 minute averaging time period

The CEMS would convert the actual CO concentrations to mass emission rates (lbs/hr) using the equation below and record the hourly emission rates on a continuous basis.

CO Emission Rate, lbs/hr =  $K C_{co} F_d [20.9/(20.9\% - \%O_2 d)] [(Q_g \times HHV)/1.0E+06]$ , where:

1.  $K = 7.267E-08$  (lb/scf)/ppm
2.  $C_{co}$  = Average of four consecutive 15-min. ave. CO concentration, ppm
3.  $F_d = 8710$  dscf/mmBTU natural gas
4.  $\%O_2 d$  = Hourly ave. % by vol.  $O_2$  dry, corresponding to  $C_{co}$ .
5.  $Q_g$  = Fuel gas usage during the hour, scf/hr
6.  $HHV$  = Gross high heating value of fuel gas, BTU/scf

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 218, 8-7-1981; RULE 218, 5-14-1999]

[Devices subject to this condition : D18, D27, D36, D45]

D82.2 The operator shall install and maintain a CEMS to measure the following parameters:

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

NOX concentration in ppmv

The CEMS shall meet EPA monitoring performance and quality assurance specifications of 40 CFR Part 60, Appendix B and Appendix F, and 40 CFR Part 75.

Concentrations shall be corrected to 15% oxygen on a dry basis

The CEMS shall be operated during start ups and shutdowns

[RULE 2012, 5-11-2001; RULE 2012, 12-5-2003; 40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : D18, D27, D36, D45]

D182.1 The operator shall test this equipment in accordance with the following specifications:

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

the test shall be constructed to determine the NOx emissions using EPA methods 1-4 and 7E measured over a 60 minute averaging period. In lieu of the above mentioned test methods, equivelant methods may be used with prior written approval from EPA

The test shall be conducted within 60 days after achieving the maximum production rate, but no later than 180 days after initial start up (as defined in 40 CFR 60.2), and annually thereafter (within 30 days of the anniversary of the initial performance test). Upon written request from the permittee (Attn: Air 5), and adequate justification, EPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity

The EPA shall be notified of the date and time of the test at least 30 days prior to the test

The test shall be conducted to determine the oxygen levels in the exhaust. In addition, the test shall measure the fuel flow rate (CFH), the flue gas flow rate, and the turbine generating output (MW)

For the initial source test, the test shall be conducted when the equipment is operating at or near loads of 100 percent, 75 percent, and 50 percent of maximum load. For the annual source tests, the test shall be conducted when the equipment is operating at or near maximum load

The test shall be conducted in accordance with an EPA approved source test protocol. The protocol shall be submitted to the EPA no later than 45 days prior to the proposed test date and shall be approved by the EPA before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the test, the identity of the testing lab, and a description of all sampling and analytical procedures

[40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : D18, D27, D36, D45]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

D322.1 The operator shall perform annual inspection of the equipment and filter media for leaks, broken or torn filter media, and improperly installed filter media.

**[RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : E14]

D372.1 The operator shall determine compliance with the particulate matter (PM) emission limit by conducting a source test at the outlet of the exhaust stack annually using AQMD Method 5.1. Each test shall include:

(a) One test using natural gas operating at minimum load under normal operating conditions, if natural gas is burned more than 120 consecutive hours or 200 hours accumulated over any 12 consecutive months. The test shall be conducted no later than six months after the time limit has been exceeded;

(b) One test using natural gas operating at maximum load under normal operating conditions, if natural gas is burned more than 120 consecutive hours or 200 hours accumulated over any 12 consecutive months. The test shall be conducted no later than six months after the time limit has been exceeded;

(c) One test using fuel oil operating at maximum load under normal operating conditions, if fuel oil is burned more than 120 consecutive hours or 200 hours accumulated over any twelve consecutive months. However, this condition does not apply if fuel oil is not burned. The test shall be conducted no later than six months after the time limit has been exceeded.

The annual source test frequency will be reduced to at least once every five years for each fuel type under the highest emitting load if three consecutive annual tests show compliance with either the concentration limit or the mass emission limit.

No test shall be required in any one year for which the equipment is not in operation.

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : D18, D27, D36, D45]

D381.1 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on an annual basis, at least, unless the equipment did not operate during the entire annual period. The routine annual inspection shall be conducted while the equipment is in operation and during daylight hours. If any visible emissions (not including condensed water vapor) are detected, the operator shall take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

- 1). Stack or emission point identification;
- 2). Description of any corrective actions taken to abate visible emissions; and
- 3). Date and time visible emission was abated.

**[RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : E14]

### **E. Equipment Operation/Construction Requirements**

E57.1 The operator shall vent this equipment to the SCR and oxidation catalyst whenever the turbines are in operation.

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

During a turbine start up, ammonia injection must be initiated as soon as the SCR catalyst temperature exceed 480 degrees F and the ammonia vaporizer outlet temperature has been at least 495 degrees F for a period of 30 minutes.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; 40CFR 52.21 - PSD, 6-19-1978]**

[Devices subject to this condition : D18, D27, D36, D45]

E144.1 The operator shall vent this equipment, during filling, only to the vessel from which it is being filled.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : D60]

E179.1 For the purpose of the following condition number(s), continuous monitoring shall be defined as measuring at least once every 15 minutes, except as allowed by Rule 2000.

Condition Number D 12- 3

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; 40CFR 52.21 - PSD, 6-19-1978]**

[Devices subject to this condition : C24, C33, C42, C51]

E179.2 For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour.

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

Condition Number D 12- 3

Condition Number D 12- 4

Condition Number D 12- 5

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : C24, C33, C42, C51]

E193.1 The operator shall operate and maintain this equipment according to the following specifications:

A data acquisition system shall be installed and maintained to monitor and record the combined NO<sub>x</sub> emissions in pounds per hour from all gas turbines, Devices D18, D27, D36, and D45 and their respective Duct Burners, Devices D21, D30, D39 and D48, whenever at least one gas turbine is in startup mode. This data shall be used to determine compliance with permit condition A433.1

**[RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; 40CFR 52.21 - PSD, 6-19-1978]**

[Devices subject to this condition : D18, D27, D36, D45]

E193.2 The operator shall operate and maintain this equipment according to the following specifications:

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

The Cleanair Systems "PERMIT" filter system installed for the equipment shall be operated according to the following criteria: (1) The maximum consecutive minutes at idle shall not exceed 240 minutes; (2) The number of 10-minute idle sessions before regeneration is required shall be after 24 consecutive sessions; (3) The minimum temperature/load/time for regeneration shall not be less than 40% load or 300 deg. C for 30% of operating time or 2 hrs, whichever is longer.

The Cleanair Systems "PERMIT" filter system installed for the equipment shall be provided with a data logging and alarm system to record and monitor the equipment's exhaust backpressure and temperature during operation.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470, 3-4-2005]

[Devices subject to this condition : D61]

E193.3 The operator shall construct, operate, and maintain this equipment according to the following specifications:

In compliance with all applicable provisions of all other applicable Federal, State, and local air quality regulations, including, but not limited to 40 CFR Parts 52, 60, and 61

[40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : D18, D27, D36, D45]

E193.4 The operator shall operate and maintain this equipment according to the following specifications:

All equipment, facilities and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollution emissions

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : D18, D27, D36, D45]

#### H. Applicable Rules

H23.4 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
NOX	40CFR60, SUBPART	KKKK
CO	40CFR60, SUBPART	KKKK
PM10	40CFR60, SUBPART	KKKK
SOX	40CFR60, SUBPART	KKKK

[Devices subject to this condition : D18, D27, D36, D45]

#### I. Administrative

I296.1 This equipment shall not be operated unless the operator demonstrates to the Executive Officer that the facility holds sufficient RTCs to offset the annual emissions increase for the first 12 months of operation. In addition, this equipment shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the start of operation, the facility holds sufficient RTCs in an amount equal to the annual emissions increase.

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

To comply with this condition, the operator shall limit the 1st year cumulative facilitywide NOx emissions from all equipment to no more than 492,897 lbs/yr. The purpose of this condition is to insure the facility does not exceed the 1st year RTCs provided for the project. This condition shall apply during the 1st 12 months of operation, commencing with the initial operation of the first gas turbine (Devices D18, D27, D36, or D45).

To comply with this condition, the operator shall, prior to the beginning of all years subsequent to the 1st compliance year, hold a minimum of 464,338 lbs of NOx RTCs for operation of all equipment at the facility. In accordance with Rule 2005(f), unused RTCs may be sold only during the reconciliation period for the fourth quarter of the applicable compliance year inclusive of the 1st compliance year.

[RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; RULE 2012, 5-11-2001; RULE 2012, 12-5-2003]

[Devices subject to this condition : D18, D27, D36, D45, D58, D61]

#### **K. Record Keeping/Reporting**

K40.1 The operator shall provide to the District a source test report in accordance with the following specifications:

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

Source test results shall also include turbine and generator output under which the test was conducted.

Source test results shall also include turbine fuel flow rate under which the test was conducted.

All exhaust flow rate shall be expressed in terms of dry standard cubic feet per minute (DSCFM) and dry actual cubic feet per minute (DACFM).

Emission data shall be expressed in terms of lbs/MM cubic feet.

Source test results shall be submitted to the District no later than 60 days after the source test was conducted.

Emission data shall be expressed in terms of concentration (ppmv), corrected to 15 percent oxygen, dry basis.

Emission data shall be expressed in terms of mass rate (lbs/hr). In addition, solid PM emissions, if required to be tested, shall also be reported in terms of grains per DSCF.

Source test results shall also include exhaust gas moisture content under which the test was conducted.

Source test results shall be submitted to the EPA no later than 60 days after the source test was conducted. Written correspondence shall be forwarded to EPA at the following address: Director, Air Division (Attn: Air-1), US EPA Region 9, 75 Hawthorne St, San Francisco, CA 94105

[**RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; 40CFR 52.21 - PSD, 6-19-1978**]

[Devices subject to this condition : D18, D27, D36, D45]

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

**The operator shall comply with the terms and conditions set forth below:**

K67.1 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the dust collector

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection

**[RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : E14]

K67.2 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

For architectural applications where no thinners, reducers, or other VOC containing materials are added, maintain semi-annual records for all coating consisting of (a) coating type, (b) VOC content as supplied in grams per liter (g/l) of materials for low-solids coatings, (c) VOC content as supplied in g/l of coating, less water and exempt solvent, for other coatings.

For architectural applications where thinners, reducers, or other VOC containing materials are added, maintain daily records for each coating consisting of (a) coating type, (b) VOC content as applied in grams per liter (g/l) of materials used for low-solids coatings, (c) VOC content as applied in g/l of coating, less water and exempt solvent, for other coatings.

**[RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : E16]

K67.3 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

An engine operating log listing on a monthly basis the emergency use hours of operation, maintenance and testing hours of operation, and any other hours of use with a description of the reasons for operation. Additionally, each time the engine is started manually, the log shall include the date of operation and the timer reading in hours at the beginning and end of operation

The log shall be kept for a minimum of five calendar years prior to the current year and be made available to EPA and District personnel upon request. The total hours of operation for the previous calendar year shall be recorded sometime during the first 15 days of January of each year

[RULE 1110.2, 11-14-1997; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996**; RULE 1401, 5-3-2002; RULE 1470, 6-1-2007; **40CFR 52.21 - PSD, 6-19-1978**]

[Devices subject to this condition : D58]

K67.4 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

Facility log documenting all start-ups, shutdowns, and combustor tuning events. The log shall indicate the date, type, time and duration of each event

Data acquired as specified in condition E193.1 for turbine startups.

The permittee must maintain a file of all measurements, including continuous monitoring system evaluations; all continuous monitoring systems or monitoring device calibration checks; adjustments and maintenance performed on these systems or device; and all other information required by this permit and 40CFR 60 Appendices A-B and 40CFR 75, recorded in a permanent form suitable for inspection. The file must be retained for 5 years following the date of such measurements, maintenance, reports, and records

Records shall be kept and maintained on file for a minimum of five years and made available to EPA and AQMD personnel upon request.

[RULE 2005, 4-20-2001; RULE 2005, 5-6-2005; RULE 2012, 5-11-2001; RULE 2012, 12-5-2003]

[Devices subject to this condition : D18, D27, D36, D45]

K67.5 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

**The operator shall comply with the terms and conditions set forth below:**

Records obtained from a data logger and alarm system provided for use on the equipment's diesel particulate filter.

An engine operating log listing on a monthly basis the emergency use hours of operation, maintenance and testing hours of operation, and any other hours of use with a description of the reasons for operation. Additionally, each time the engine is started manually, the log shall include the date of operation and the timer reading in hours at the beginning and end of operation

The log shall be kept for a minimum of five calendar years prior to the current year and be made available to EPA and District personnel upon request. The total hours of operation for the previous calendar year shall be recorded sometime during the first 15 days of January of each year

[RULE 1110.2, 11-14-1997; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996**; RULE 1401, 5-3-2002; RULE 1470, 3-4-2005; **40CFR 52.21 - PSD, 6-19-1978**]

[Devices subject to this condition : D61]

K171.1 The operator shall notify EPA if any of the following situations occur:

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

Excess emissions: the permittee must submit a written report of all excess emissions to EPA for every calendar quarter. The report must include the following

The magnitude of the excess emissions computed in accordance with 40 CFR 60.13(H), any conversion factors used, the date and time of commencement, and compilation of each time period of excess emissions

Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of any equipment. The nature and cause of any malfunction (if known) and the corrective action taken or preventative measures adopted must also be reported

The date and time indentifying each period during which the continuous monitoring system was inoperative except for zero and span chaecks, and the nature of the system repairs or adjustments

When no exces emissions have occured or the continuous monitoring system has not been inoperative, repaired, or adjusted, such information must be stated in the report

Excess emissions shal be defined as any 1-hour period during which the average emissions of NOx, as measured by the CEMS, exceeds the maximum emission limits set forth in this permit

Written correspondence shall be forwarded to EPA at the following address:  
Director, Air Division (Attn: Air-1), US EPA Region 9, 75 Hawthorne St, San Francisco, CA 94105

[40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : D18, D27, D36, D45]

K171.2 The operator shall notify EPA if any of the following situations occur:

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

Following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner, which results in an increase in emissions above any allowable emission limit stated in this permit. The notice shall be sent to the EPA Regional Administrator by electronic mail transmission at R9.AEO@EPA.GOV within 2 working days of the occurrence. In addition, the regional administrator shall be notified in writing within 15 days of any such failure

The notice shall include a description of the malfunctioning equipment or abnormal operation, date of the initial failure, period of time over which emissions were increased due to the failure, cause of the failure, the estimated and resultant emissions in excess of those allowed in the permit

The notice shall also include the methods utilized to mitigate emissions and restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violation of this permit or of any law or regulation that such malfunction may cause, except as provided for below:

**Definition of malfunction:** A malfunction means a sudden and reasonably unforeseeable breakdown of equipment or of a process beyond the control of the source requiring immediate corrective action to restore normal operation

Emissions in excess of the limits in this permit shall constitute a violation and may be the subject of enforcement proceedings

All emissions including those associated with a malfunction which may be eligible for an affirmative defense, must be included in all emissions calculations and demonstrations of compliance with mass emissions limits in this permit

This provision is in addition to any emergency or malfunction provision contained in any applicable requirement or elsewhere in this permit

Written correspondence shall be forwarded to EPA at the following address:  
Director, Air Division (Attn: Air-1), US EPA Region 9, 75 Hawthorne St, San Francisco, CA 94105

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[40CFR 52.21 - PSD, 6-19-1978]

[Devices subject to this condition : D18, D27, D36, D45]

K171.3 The operator shall notify EPA if any of the following situations occur:

In the event of any changes in control of ownership of the facilities to be constructed the applicant shall notify the succeeding owner and operator of this existence of this permit and its conditions by letter, a copy of which shall be forwarded to the EPA Regional Administrator and the State and local air pollution control agency within 30 days of change in ownership. The permit shall be binding on all subsequent owners and operators

Written correspondence shall be forwarded to EPA at the following address: Director, Air Division (Attn: Air-1), US EPA Region 9, 75 Hawthorne St, San Francisco, CA 94105. And to CARB at the following address: Chief, Stationary Source Division, California Air Resources Board, 1001 "I" St, P.O. Box 2815, Sacramento, CA 95812

[Devices subject to this condition : D18, D27, D36, D45]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
  - a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
  - b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
  - c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statutes of other governmental agencies. [204]
4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION E: ADMINISTRATIVE CONDITIONS

5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]
6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least: [204]
  - a. Three years for a facility not subject to Title V; or
  - b. Five years for a facility subject to Title V.
7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]
  - a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134, 204]
  - b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
  - c. For a large NO<sub>x</sub> source, compliance with a RECLAIM concentration limit shall be measured over a continuous 60 minutes for that source; [2012]
  - d. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION E: ADMINISTRATIVE CONDITIONS

- e. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO<sub>2</sub>) and be averaged over 15 consecutive minutes; [407]
  - f. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO<sub>2</sub>) at standard conditions and averaged over 15 consecutive minutes. [409]
  - g. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O<sub>2</sub>) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]
8. All equipment operating under the RECLAIM program shall comply concurrently with all provisions of AQMD Rules and Regulations, except those listed in Table 1 of Rule 2001 for NO<sub>x</sub> RECLAIM sources and Table 2 of Rule 2001 for SO<sub>x</sub> RECLAIM sources. Those provisions listed in Tables 1 or 2 shall not apply to NO<sub>x</sub> or SO<sub>x</sub> emissions after the date the facility has demonstrated compliance with all monitoring and reporting requirements of Rules 2011 or 2012, as applicable. Provisions of the listed AQMD rules in Tables 1 or 2 which have initial implementation dates in 1994 shall not apply to a RECLAIM NO<sub>x</sub> or SO<sub>x</sub> source, respectively. [2001]
9. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]
- a. Brief description of the equipment tested.

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION E: ADMINISTRATIVE CONDITIONS

- b. Brief process description, including maximum and normal operating temperatures, pressures, through-put, etc.
  - c. Operating conditions under which the test will be performed.
  - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
  - e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
  - f. Description of calibration and quality assurance procedures.
  - g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (no conflict of interest).
10. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD Rules or equipment-specific conditions. The report shall contain the following information: [204]
- a. The results of the source test.
  - b. Brief description of the equipment tested.
  - c. Operating conditions under which test will be performed.
  - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
  - e. Field and laboratory data forms, strip charts and analyses.

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION E: ADMINISTRATIVE CONDITIONS**

- f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.
- 11. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]
- 12. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

The Facility shall comply with all applicable monitoring and source testing requirements in Regulation XX. These requirements may include but are not limited to the following:

I. NO<sub>x</sub> Monitoring Conditions

A. The Operator of a NO<sub>x</sub> Major Source, as defined in Rule 2012, shall, as applicable:

1. Install, maintain, and operate an AQMD certified direct or time-shared monitoring device or an approved alternative monitoring device for each major NO<sub>x</sub> source to continuously measure the concentration of NO<sub>x</sub> emissions and all other applicable variables specified in Rule 2012, Table 2012-1 and Rule 2012, Appendix A, Table 2-A to determine the NO<sub>x</sub> emissions rate from each source. The time-sharing of CEMS among NO<sub>x</sub> sources may be allowed by the Executive Officer in accordance with the requirements for time sharing specified in Appendix A. [2012]
2. Install, maintain, and operate a totalizing fuel meter approved by the Executive Officer for each major source. [2012]
3. If the facility is operating existing CEMS and fuel meters, continue to follow recording and reporting procedures required by AQMD Rules and Regulations in effect prior to October 15, 1993 until the CEMS is certified pursuant to Rule 2012. [2012]
4. Use valid data collected by an AQMD certified or provisionally certified CEMS in proper operation that meets all the requirements of Appendix A of Rule 2012, unless final certification of the CEMS is denied, to determine mass emissions for all purposes, including, but not limited to, determining: [2012]
  - a. compliance with the annual Allocation;
  - b. excess emissions;
  - c. the amount of penalties; and
  - d. fees.

---

**FACILITY PERMIT TO OPERATE**  
**SOUTHERN CALIFORNIA EDISON**

---

**SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS**

5. Follow missing data procedures as specified in Rule 2012 Appendix A whenever valid data is not available or collected to determine mass emissions for all purposes, including, but not limited to, determining: [2012]
  - a. compliance with the annual Allocation;
  - b. excess emissions;
  - c. the amount of penalties; and
  - d. fees.

B. The Operator of a NO<sub>x</sub> large Source, as defined in Rule 2012, shall, as applicable:

Not Applicable

C. The Operator of a NO<sub>x</sub> Process Unit, as defined in Rule 2012, shall, as applicable:

1. Install, maintain, and operate a totalizing fuel meter or any device approved by the Executive Officer to measure quarterly fuel usage or other applicable variables specified in Rule 2012, Table 2012-1, and Rule 2012, Appendix A, Table 4-A. The sharing of totalizing fuel meters may be allowed by the Executive Officer if the fuel meter serves process units which have the same emission factor or emission rate. The sharing of totalizing meter shall not be allowed for process units which are required to comply with an annual heat input limit. [2012]

II. NO<sub>x</sub> Source Testing and Tune-up conditions

1. The operator shall conduct all required NO<sub>x</sub> source testing in compliance with an AQMD-approved source test protocol. [2012]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

2. The operator shall, as applicable, conduct source tests for every large NO<sub>x</sub> source no later than December 31, 1996 and every 3 years thereafter. The source test shall include the determination of NO<sub>x</sub> concentration and a relative accuracy audit of the exhaust stack flow determination (e.g. in-stack flow monitor or fuel flow monitor based F-factor calculation). Such source test results shall be submitted per the schedule described by APEP. In lieu of submitting the first source test report, the facility permit holder may submit the results of a source test not more than 3 years old which meets the requirements when conducted. [2012]
  
3. All NO<sub>x</sub> large sources and NO<sub>x</sub> process units shall be tuned-up in accordance with the schedule specified in Rule 2012, Appendix A, Chapter 5, Table 5-B. [2012]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR RECLAIM SOURCES

The Facility shall comply with all applicable reporting and recordkeeping requirements in Regulation XX. These requirements may include but are not limited to the following:

#### I. Recordkeeping Requirements for all RECLAIM Sources

1. The operator shall maintain all monitoring data required to be measured or reported pursuant to Rule 2011 and Rule 2012, whichever is applicable. All records shall be made available to AQMD staff upon request and be maintained for at least:
  - a. Three years after each APEP report is submitted to AQMD for a facility not subject to Title V, unless a different time period is required in Rule 2011 or Rule 2012 [2011 & 2012]; or
  - b. Five years after each APEP report is submitted to AQMD for a facility subject to Title V. [3004(a)(4)(E)]
  - c. Notwithstanding the above, all data gathered or computed for intervals of less than 15 minutes shall only be maintained a minimum of 48 hours. [2011 & 2012]
2. The operator shall store on site and make available to the Executive Officer upon request: records used to determine emissions, maintenance records, sources test reports, relative accuracy test audit reports, relative accuracy audit reports and fuel meter calibration records. [2011 & 2012]

#### II. Reporting Requirements for all RECLAIM Sources

1. The operator shall submit a quarterly certification of emissions including the total facility NO<sub>x</sub> or SO<sub>x</sub> emissions, whichever is applicable, for the quarter within 30 days after the end of the first three quarters and 60 days after the end of the fourth quarter of a compliance year. [2004]

#### NO<sub>x</sub> Reporting Requirements

- A. The Operator of a NO<sub>x</sub> Major Source, as defined in Rule 2012, shall, as applicable:

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR RECLAIM SOURCES

1. No later than 12 months after entry into the RECLAIM program or after the initial operation of a new major source, whichever is later, install, maintain, and operate a reporting device to electronically report everyday to the AQMD central station for each major NOx source, the total daily mass emissions of NOx and daily status codes. Such data shall be transmitted by 5:00 p.m. of the following day. If the facility experiences a power, computer, or other system failure that prevents the submittal of the daily report, the Facility Permit holder shall be granted 24 hours extension to submit the report. [2012]
  2. Calculate NOx emissions pursuant to missing data procedures set forth in Appendix A, Chapter 2 of Rule 2012 if the Facility Permit holder fails to meet the deadline for submitting the daily report. [2012]
  3. Submit an electronic report within 15 days following the end of each month totaling NOx emissions from all major NOx sources during the month. [2012]
  4. For those facilities with existing CEMS and fuel meters as of October 15, 1993, continue to follow recording and reporting procedures required by AQMD Rules and Regulations in effect until the CEMS is certified pursuant to Rule 2011 and/or Rule 2012, as applicable. [2012]
- B. The Operator of a NOx Large Source, as defined in Rule 2012, shall:  
Not Applicable
- C. The Operator of a NOx Process Unit, as defined in Rule 2012, shall:
1. Electronically report the calculated quarterly NOx emissions for each NOx process unit. The Operator shall comply with this requirement within 12 months of the date of entry to the RECLAIM Program. [2012]
-

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE**

NONE

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION I: PLANS AND SCHEDULES**

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

SECTION J: AIR TOXICS

NOT APPLICABLE

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION K: TITLE V Administration

#### GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

#### Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]  
  
(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

#### Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

#### Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION K: TITLE V Administration

#### Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
- (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
  - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
  - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

#### COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
  - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
  - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
  - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
  - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
  - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]
  
10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]
  
11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]
  
12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]
  
13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
15. Nothing in this permit or in any permit shield can alter or affect:
- (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
  - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
  - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
  - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
  - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
  - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION K: TITLE V Administration EMERGENCY PROVISIONS

17. An emergency<sup>1</sup> constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
    - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
    - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
    - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
    - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
  - (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

---

<sup>1</sup> "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION K: TITLE V Administration  
RECORDKEEPING PROVISIONS**

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:

- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
- (B) The date(s) analyses were performed;
- (C) The company or entity that performed the analyses;
- (D) The analytical techniques or methods used;
- (E) The results of such analyses; and
- (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]

20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]

21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

**REPORTING PROVISIONS**

22. The operator shall comply with the following requirements for prompt reporting of deviations:

- (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**SECTION K: TITLE V Administration**

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
- (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### SECTION K: TITLE V Administration

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn:  
Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

### PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

### SECTION K: TITLE V Administration

#### FACILITY RULES

*This facility is subject to the following rules and regulations*

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

<b>RULE SOURCE</b>	<b>Adopted/Amended Date</b>	<b>FEDERAL Enforceability</b>
RULE 1110.2	11-14-1997	Non federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	7-9-2004	Non federally enforceable
RULE 1140	8-2-1985	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 118	12-7-1995	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(1)-Modeling	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and Offset Exemption	6-14-1996	Federally enforceable
RULE 1401	5-3-2002	Non federally enforceable
RULE 1470	3-4-2005	Non federally enforceable
RULE 1470	6-1-2007	Non federally enforceable
RULE 2005	4-20-2001	Federally enforceable
RULE 2005	4-9-1999	Federally enforceable
RULE 2005	5-6-2005	Federally enforceable
RULE 2012	1-7-2005	Federally enforceable
RULE 2012	12-5-2003	Federally enforceable
RULE 2012	5-11-2001	Federally enforceable

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**SECTION K: TITLE V Administration**

<b>RULE SOURCE</b>	<b>Adopted/Amended Date</b>	<b>FEDERAL Enforceability</b>
RULE 2012	5-6-2005	Federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 217	1-5-1990	Federally enforceable
RULE 218	5-14-1999	Federally enforceable
RULE 218	8-7-1981	Federally enforceable
RULE 219	9-4-1981	Federally enforceable
RULE 3002	11-14-1997	Federally enforceable
RULE 3003	11-14-1997	Federally enforceable
RULE 3004(a)(4)-Periodic Monitoring	12-12-1997	Federally enforceable
RULE 3005	11-14-1997	Federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 304	1-14-1982	Non federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 405	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 429	12-21-1990	Non federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 431.1	11-17-1995	Non federally enforceable
RULE 464	12-7-1990	Federally enforceable
RULE 475	10-8-1976	Federally enforceable
RULE 475	8-7-1978	Non federally enforceable
RULE 701	6-13-1997	Federally enforceable
40CFR 52.21 - PSD	6-19-1978	Federally enforceable
40CFR 60 Subpart GG	3-6-1981	Federally enforceable
40CFR 72 - Acid Rain Provisions	11-24-1997	Federally enforceable

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN  
PERMIT PURSUANT TO RULE 219**

1. WATER HEATERS, NATURAL GAS
2. PROCESS HEATER, NATURAL GAS
3. DRYER, NATURAL GAS

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1113 11-08-1996]**

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

**TABLE OF STANDARDS**

**VOC LIMITS**

**Grams of VOC Per Liter of Coating,  
 Less Water And Less Exempt Compounds**

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior Coatings	350	450		350			
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250						
Graphic Arts (Sign) Coatings	500				100		50

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1113 11-08-1996]**

Industrial Maintenance						
Primers and Topcoats						
Alkyds	420					
Catalyzed Epoxy	420					
Bituminous Coatings	420					
Materials						
Inorganic Polymers	420					
Vinyl Chloride Polymers	420					
Chlorinated Rubber	420					
Acrylic Polymers	420					
Urethane Polymers	420					
Silicones	420					
Unique Vehicles	420					
Japans/Faux Finishing	350	700		350		
Coatings						
Magnesite Cement Coatings	600			450		
Mastic Coatings	300					
Metallic Pigmented Coatings	500					
Multi-Color Coatings	420		250			
Pigmented Lacquer	680		550			275
Pre-Treatment Wash Primers	780					
Primers, Sealers, and	350					
Undercoaters						
Quick-Dry Enamels	400					
Roof Coatings	300					
Shellac						
Clear	730					
Pigmented	550					
Stains	350					
Swimming Pool Coatings						
Repair	650					
Other	340					
Traffic Coatings	250		150			
Waterproofing Sealers	400					
Wood Preservatives						
Below-Ground	350					
Other	350					

\* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

**TABLE OF STANDARDS (cont.)**

**VOC LIMITS**

**Grams of VOC Per Liter of Material**

COATING	Limit
Low-Solids Coating	120

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-09-2004]

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1113 07-09-2004]  
 TABLE OF STANDARDS  
 VOC LIMITS**

**Grams of VOC Per Liter of Coating,  
 Less Water and Less Exempt Compounds**

COATING	Limit *	Effective Date								
		1/1/98	1/1/99	7/1/01	1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350									
Clear Wood Finishes										
Varnish	350							275		
Sanding Sealers	350							275		
Lacquer	680	550					275			
Clear Brushing Lacquer	680						275			
Concrete-Curing Compounds	350									
Dry-Fog Coatings	400									
Fire-Proofing Exterior Coatings	450		350							
Fire-Retardant Coatings										
Clear	650									
Pigmented	350									
Flats	250			100						50
Floor Coatings	420				100			50		
Graphic Arts (Sign) Coatings	500									
Industrial Maintenance (IM) Coatings	420					250		100		
High Temperature IM Coatings**					420					
Zinc-Rich IM Primers	420				340			100		
Japans/Faux Finishing Coatings	700		350							
Magnesite Cement Coatings	600		450							
Mastic Coatings	300									
Metallic Pigmented Coatings	500									
Multi-Color Coatings	420	250								
Non-Flat Coatings	250				150			50		
Pigmented Lacquer	680	550					275			
Pre-Treatment Wash Primers	780				420					
Primers, Sealers, and Undercoaters	350				200			100		
Quick-Dry Enamels	400				250			50		

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1113 07-09-2004]**

COATING	Limit *	Effective Date								
		1/1/98	1/1/99	7/1/01	1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Quick-Dry Primers, Sealers, and Undercoaters	350				200			100		
Recycled Coatings					250					
Roof Coatings	300				250		50			
Roof Coatings, Aluminum	500						100			
Roof Primers, Bituminous	350				350					
Rust Preventative Coatings	420				400			100		
Shellac										
Clear	730									
Pigmented	550									
Specialty Primers	350							100		
Stains	350				250				100	
Stains, Interior	250									
Swimming Pool Coatings										
Repair	650				340					
Other	340									
Traffic Coatings	250	150								
Waterproofing Sealers	400				250			100		
Waterproofing Concrete/Masonry Sealers	400							100		
Wood Preservatives										
Below-Ground	350									
Other	350									

\* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

\*\* The National VOC Standard at 650 g/l is applicable until 1/1/2003

**TABLE OF STANDARDS (cont.)  
 VOC LIMITS**

**Grams of VOC Per Liter of Material**

COATING	Limit
Low-Solids Coating	120

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### APPENDIX B: RULE EMISSION LIMITS [RULE 1140 08-02-1985]

- (1) The operator shall not, if he complies with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
  - (A) As dark or darker in shade as that designated as No. 2 on the Ringelmann Chart, as published by the United States Bureau of Mines, or
  - (B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (1)(A).
  
- (2) The operator shall not, if he is not complying with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
  - (A) As dark or darker in shade as that designated as No. 1 on the Ringelmann Chart, as published by the United States Bureau of Mines, or
  - (B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (2)(A).

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1171 11-07-2003]**

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1171 11-07-2003]**

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
[RULE 1171 11-07-2003]**

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Roller Wash -- Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1171 05-06-2005]**

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS*	Effective 7/1/2005*	Effective 7/1/2006
	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application			
(i) General	25 (0.21)		
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)		
(B) Repair and Maintenance Cleaning			
(i) General	25 (0.21)		
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals			

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1171 05-06-2005]**

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS*	Effective 7/1/2005*	Effective 7/1/2006
	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(A) Tools, Equipment, & Machinery	800 (6.7)		
(B) General Work Surfaces	600 (5.0)		
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)	25 (0.21)	
(D) Cleaning of Ink Application Equipment			
(i) General	25 (0.21)		
(ii) Flexographic Printing	25 (0.21)		
(iii) Gravure Printing			
(A) Publication	750 (6.3)	100 (0.83)	
(B) Packaging	25 (0.21)		
(iv) Lithographic or Letter Press Printing			
(A) Roller Wash – Step 1	600 (5.0)	500 (4.2)	100 (0.83)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)	500 (4.2)	100 (0.83)

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 1171 05-06-2005]**

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS*	Effective 7/1/2005*	Effective 7/1/2006
	VOC g/l (lb/gal)	VOC g/l (lb/gal)	VOC g/l (lb/gal)
(C) Removable Press Components	25 (0.21)		
(v) Screen Printing	750 (6.3)	500 (4.2)	100 (0.83)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)	500 (4.2)	100 (0.83)
(vii) Specialty Flexographic Printing	600 (5.0)	100 (0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)		

\* The specified limits remain in effect unless revised limits are listed in subsequent columns.

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 404 02-07-1986]**

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a).

Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

**TABLE 404(a)**

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter <sup>2</sup> Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 404 02-07-1986]**

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 404 02-07-1986]**

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 405 02-07-1986]**

The operator shall not discharge into the atmosphere from this equipment, solid particulate matter including lead and lead compounds in excess of the rate shown in Table 405(a).

Where the process weight per hour is between figures listed in the table, the exact weight of permitted discharge shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

**TABLE 405(a)**

Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All Points of Process)		Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All points of Process)	
Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour
100 or less	220 or less	0.450	0.99	9000	19840	5.308	11.7
150	331	0.585	1.29	10000	22050	5.440	12.0
200	441	0.703	1.55	12500	27560	5.732	12.6
250	551	0.804	1.77	15000	33070	5.982	13.2
300	661	0.897	1.98	17500	38580	6.202	13.7
350	772	0.983	2.17	20000	44090	6.399	14.1
400	882	1.063	2.34	25000	55120	6.743	14.9
450	992	1.138	2.51	30000	66140	7.037	15.5
500	1102	1.209	2.67	35000	77160	7.296	16.1
600	1323	1.340	2.95	40000	88180	7.527	16.6

**FACILITY PERMIT TO OPERATE  
 SOUTHERN CALIFORNIA EDISON**

**APPENDIX B: RULE EMISSION LIMITS  
 [RULE 405 02-07-1986]**

Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All Points of Process		Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All points of Process	
Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour
700	1543	1.461	3.22	45000	99210	7.738	17.1
800	1764	1.573	3.47	50000	110200	7.931	17.5
900	1984	1.678	3.70	60000	132300	8.277	18.2
1000	2205	1.777	3.92	70000	154300	8.582	18.9
1250	2756	2.003	4.42	80000	176400	8.854	19.5
1500	3307	2.206	4.86	90000	198400	9.102	20.1
1750	3858	2.392	5.27	100000	220500	9.329	20.6
2000	4409	2.563	5.65	125000	275600	9.830	21.7
2250	4960	2.723	6.00	150000	330700	10.26	22.6
2500	5512	2.874	6.34	175000	385800	10.64	23.5
2750	6063	3.016	6.65	200000	440900	10.97	24.2
3000	6614	3.151	6.95	225000	496000	11.28	24.9
3250	7165	3.280	7.23	250000	551200	11.56	25.5
3600	7716	3.404	7.50	275000	606300	11.82	26.1
4000	8818	3.637	8.02	300000	661400	12.07	26.6
4500	9921	3.855	8.50	325000	716500	12.30	27.1
5000	11020	4.059	8.95	350000	771600	12.51	27.6
6000	13230	4.434	9.78	400000	881800	12.91	28.5
7000	15430	4.775	10.5	450000	992100	13.27	29.3
8000	17640	5.089	11.2	500000 or more	1102000 or more	13.60	30.0

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]

1. A Title V permit revision is not required for emission increases that are authorized by allowances acquired under the Acid Rain Program, provided that the increases do not trigger a Title V permit revision under any other applicable requirement. [70.6 (a)(4)(ii)]

#### Monitoring Requirements

2. The owners and operators and, to the extent applicable, the designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR Parts 74, 75, and 76. [40 CFR 72.50, 72.31, 72.9(b)(1)]
3. The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the acid rain emissions limitations and emissions reduction requirements for sulfur dioxide (SO<sub>2</sub>) under the Acid Rain Program. [40 CFR 72.9(b)(2), 40 CFR 75.2]
4. The requirements of 40 CFR Parts 74 and 75 shall not affect the responsibility of the operator to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements and other provisions of this permit. [40 CFR 72.9(b)(3), 40 CFR 72.5]

#### Sulfur Dioxide Requirements

5. The owners and operators of each source and each affected unit at the source shall:
    - (A) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR Part 73, Section 73.34(C)) not less than the total annual emissions of SO<sub>2</sub> for the previous calendar year from the unit; and, [40 CFR 72.9(c)(i)],
    - (B) Comply with the applicable acid rain emissions limitations for SO<sub>2</sub>. [40 CFR 72.9(c)(ii)]
  6. Each ton of SO<sub>2</sub> emitted in excess of the acid rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 72.9(g)(7)]
-

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]

7. SO<sub>2</sub> allowances shall be held in, deducted from, or transferred among allowance tracking system accounts in accordance with the Acid Rain Program. [40 CFR 72.9(g)(4)]
8. A SO<sub>2</sub> allowance shall not be deducted in order to comply with the requirements under paragraph 41(A) of the SO<sub>2</sub> requirements prior to the calendar year for which the allowance was allocated. [40 CFR 72.9(g)(5)]
9. An affected unit shall be subject to the SO<sub>2</sub> requirements under the Acid Rain Program as follows:[40 CFR 72.6(a)]
  - (A) Starting January 1, 2000, an affected unit under 40 CFR Part 72, Section 72.6(a)(2); or [40 CFR 72.6(a)(2)]
  - (B) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR Part 75, an affected unit under 40 CFR Part 72, Section 72.6(a)(3). [40CFR 72.6(a)(3)]
10. An allowance allocated by the EPA administrator under the Acid Rain Program is a limited authorization to emit SO<sub>2</sub> in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the acid rain permit application, the acid rain permit, or the written exemption under 40 CFR Part 72, Sections 72.7, 72.8, or 72.14, and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72.9 (c)(6)]
11. An allowance allocated by the EPA Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72.9(c)(7)]

### Excess Emissions Requirements

12. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR 72.9(e)]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]

13. The owners and operators of an affected unit that has excess emissions in any calendar year shall: [40 CFR 72.9(e)(2)]
- (A) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and [40 CFR 72.9(e)(2)(i)]
- (B) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77. [40 CFR 72.9(e)(2)(ii)]

### Recordkeeping and Reporting Requirements

14. Unless otherwise provided, the owners and operators of the source and each affected unit at the source that are subject to the acid rain provisions under Title IV shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the EPA Administrator or the Executive Officer: [40 CFR 72.9(f)(1)]
- (A) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such five year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative; [40 CFR 72.9(f)(1)(i)]
- (B) All emissions monitoring information, in accordance with 40 CFR Part 75; [40 CFR 72.9(f)(1)(ii)]
- (C) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and, [40 CFR 72.9(f)(1)(iii)]
- (D) Copies of all documents used to complete an acid rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program. [40 CFR 72.9(f)(1)(iv)]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]

15. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72 Subpart I and 40 CFR Part 75. [40 CFR 72.9(f)(2)]

#### **Liability**

16. Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete acid rain permit application, an acid rain permit, or a written exemption under 40 CFR Part 72, Sections 72.7, 72.8, or 72.14, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to Section 113(c) of the Act. [40 CFR 72.9 (g)(1)]
17. Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to Section 113(c) of the Act and 18 U.S.C. 1001. [40 CFR 72.9 (g)(2)]
18. No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect. [40 CFR 72.9 (g)(3)]
19. Each affected source and each affected unit shall meet the requirements of the Acid Rain Program. [40 CFR 72.9 (g)(4)]
20. Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source. [40 CFR 72.9 (g)(5)]

---

## FACILITY PERMIT TO OPERATE SOUTHERN CALIFORNIA EDISON

---

### APPENDIX B: RULE EMISSION LIMITS [40CFR 72 - Acid Rain Provisions 11-24-1997]

21. Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR Part 72, Section 72.44 (Phase II repowering extension plans) and 40 CFR Part 76, Section 76.11 (NO<sub>x</sub> averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR Part 75, Sections 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative. [40 CFR 72.9 (g)(6)]
22. Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act. [40 CFR 72.9 (g)(7)]

#### Effect on Other Authorities

23. No provision of the Acid Rain Program, an acid rain permit application, an acid rain permit, or a written exemption under 40 CFR Part 72, Sections 72.7, 72.8, or 72.14 shall be construed as: [40 CFR 72.9 (h)]
- (A) Except as expressly provided in Title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of Title I of the Act relating to applicable National Ambient Air Quality Standards or state implementation plans; [40 CFR 72.9 (h)(1)]
- (B) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act; [40 CFR 72.9 (h)(2)]

---

**FACILITY PERMIT TO OPERATE  
SOUTHERN CALIFORNIA EDISON**

---

**APPENDIX B: RULE EMISSION LIMITS**  
**[40CFR 72 - Acid Rain Provisions 11-24-1997]**

(C) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law; [40 CFR 72.9 (h)(3)]

(D) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or, [40 CFR 72.9 (h)(4)]

(E) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established. [40 CFR 72.9 (h)(5)]