

AUTHORITY TO CONSTRUCT

PERMIT NO: C-311-37-21

ISSUANCE DATE: 09/22/2009

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: PO BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL PRODUCTION
FRESNO COUNTY, CA

SECTION: 25 TOWNSHIP: 20S RANGE: 14E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR STRUTHERS THERMOFLOOD MODEL OH-50-ND-16XAM STEAM GENERATOR (#25-16) WITH A NORTH AMERICAN MODEL GLE LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SERVED BY THE 25D NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS: LIMIT SOX PER 5.4.1.3 (EXHAUST) FOR RULE 4320 COMPLIANCE (EXISTING SCRUBBER)

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. This unit shall be fueled with natural gas, LPG, or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District Rule 2201] Federally Enforceable Through Title V Permit
3. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
4. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

C-311-37-21 : Nov 6 2012 4:33PM -- RICKARDK : Joint Inspection NOT Required

Central Regional Office • 1990 E. Gettysburg Ave. • Fresno, CA 93726 • (559) 230-5900 • Fax (559) 230-6061

7. Total gas consumption shall not exceed 1,404 MMBtu/day nor 457,800 MMBtu/year. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The permittee shall install and maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Whenever well casing vapors and/or tank vapor recovery gas are being burned in this unit, the SO₂ scrubber shall operate and shall reduce SO₂ emissions by 95% by weight, or shall limit exhaust SO₂ to less than or equal to 9 ppmv corrected to 3.0% oxygen. [District Rules 2201 and 4320]
10. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320]
11. PUC quality gas shall be combusted in this unit whenever the scrubber is not being operated. [District Rule 2201]
12. Scrubber liquor pH shall be maintained between 6.5 and 8.0. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Tray packing flowrate shall be operated at 700 to 840 gallons/minute. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Quench flowrate shall be operated at 145 to 185 gallons/minute. [District Rule 2201] Federally Enforceable Through Title V Permit
15. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
16. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
17. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
18. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2, 4305, 4306, 4320, and 4351, 6.2.1]
19. Except during start-up and shutdown periods, emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, 0.052 lb-SO_x/MMBtu, 0.014 lb-PM₁₀/MMBtu, 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rules 2201, 4301, 4305, 4306, and 4320]
20. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. the operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 2201, 4305, 4306, and 4320]

CONDITIONS CONTINUE ON NEXT PAGE

22. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4305, 4306, and 4320]
23. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NOx/day, 8,240 lb-NOx/year, 85.6 lb-CO/day, or 16,939 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
24. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320]
25. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320]
26. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320]
27. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320]
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320]
29. Source testing to measure SOx emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. [District Rule 4320]
30. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320]
31. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320]
32. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

33. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320]
34. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
35. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
36. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
37. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. Waste gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
38. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
39. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
40. Permittee shall record daily total gas consumption. Records shall be retained for at least five years and made available for District inspection upon request. [District Rule 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
41. Daily records of the tray packing flowrate and the quench flowrate shall be maintained, retained on the premises for a period of at least five years, and made available for District inspection upon request. [District Rule 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
42. Permittee shall measure and record the BTU content of the gas burned at the time of NO_x source testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
44. Permittee shall maintain with the permit a current listing of all TEOR and TVR systems providing vapor to this steam generator and shall make such listing readily available for District inspection upon request [District Rule 2201] Federally Enforceable Through Title V Permit
45. Permittee shall maintain daily records of volume of fuel gas burned, TEOR/TVR gas incinerated, and permit number(s) of systems providing gas for incineration. [District Rule 2201] Federally Enforceable Through Title V Permit
46. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320]
47. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

48. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
49. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

AUTHORITY TO CONSTRUCT

PERMIT NO: C-311-38-21

ISSUANCE DATE: 09/22/2009

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: PO BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL PRODUCTION
FRESNO COUNTY, CA

SECTION: 25 TOWNSHIP: 20S RANGE: 14E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 58.5 MMBTU/HR SG 25-17 STRUTHERS THERMOFLOOD STEAM GENERATOR, MODEL OH-50-ND-16XAM, WITH A NORTH AMERICAN GLE LOW NOX AND FLUE GAS RECIRCULATION SERVED BY THE 25D NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS: LIMIT SOX PER 5.4.1.3 (EXHAUST) FOR RULE 4320 COMPLIANCE (EXISTING SCRUBBER)

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. The permittee shall obtain written District approval for the use of any equivalent equipment not specifically approved by this Authority to Construct. Approval of the equivalent equipment shall be made only after the District's determination that the submitted design and performance of the proposed alternate equipment is equivalent to the specifically authorized equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and operational characteristics/parameters. [District Rule 2010] Federally Enforceable Through Title V Permit
4. Alternate equipment shall be of the same class and category of source as the equipment authorized by the Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
5. No emission factor and no emission shall be greater for the alternate equipment than for the proposed equipment. No changes in the hours of operation, operating rate, throughput, or firing rate may be authorized for any alternate equipment. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

C-311-38-21 : Nov 6 2012 4:33PM - RICKARDK : Joint Inspection NOT Required

6. This unit shall be fueled with natural gas, LPG, or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Total gas consumption of this unit shall not exceed either of the following limits: 1,404 MMBtu/day or 457,800 MMBtu/year. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Whenever well casing vapors and/or tank vapor recovery gas are being burned in this unit, the SO₂ scrubber shall operate and shall reduce SO₂ emissions by 95% by weight, or shall limit exhaust SO₂ to less than or equal to 9 ppmv corrected to 3.0% oxygen. [District Rules 2201 and 4320]
10. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320]
11. PUC quality gas shall be combusted in this unit whenever the scrubber is not being operated. [District Rule 2201]
12. Scrubber liquor pH shall be maintained between 6.5 and 8.0. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Tray packing flowrate shall be operated at 700 to 840 gallons/minute. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Quench flowrate shall be operated at 145 to 185 gallons/minute. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
16. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
17. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
18. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
19. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
20. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

21. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2, 4305, 4306, and 4320, and 4351, 6.2.1] Federally Enforceable Through Title V Permit
22. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
23. Emissions from the steam generator shall not exceed any of the following limits: 0.052 lb-SO_x/MMBtu, 0.045 lb-PM₁₀/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO_x @ 3% O₂, equivalent to 0.0182 lb-NO_x/MMBtu or 50 ppmvd CO @ 3% O₂, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 4306, and 4320]
25. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
26. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 4306, and 4320]
27. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4305, 4306, and 4320]
28. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO_x/day, 8,332 lb-NO_x/yr, 51.9 lb-CO/day, or 16,939 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320]
30. Source testing to measure SO_x emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. [District Rule 4320]
31. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
32. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320]
33. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2520, 9.3.2, 4305, 4306, and 4320]
34. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]
35. The results of each source test shall be submitted to the District within 60 days after the source test. [District Rule 1081] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

36. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320]
37. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320]
38. Stack gas moisture content shall be determined using EPA Method 4. [District Rule 2201] Federally Enforceable Through Title V Permit
39. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320]
40. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320]
41. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 2520, 9.4.2, 4305, 4306, and 4320]
42. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2520, 9.3.2, 4305, 4306, and 4320]
43. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. Waste gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
44. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
45. Permittee shall maintain records of daily total gas consumption. [District Rule 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
46. Permittee shall maintain daily records of the tray packing flowrate and the quench flowrate. [District Rule 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
47. Permittee shall measure and record the BTU content of the gas burned at the time of NO_x source testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

48. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
49. Permittee shall maintain with the permit a current listing of all TEOR and TVR systems providing vapor to this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
50. Permittee shall maintain daily records of volume of fuel gas burned, TEOR/TVR gas incinerated, and permit number(s) of systems providing gas for incineration. [District Rule 2201] Federally Enforceable Through Title V Permit
51. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4305, 4306, and 4320]
52. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
53. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
54. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

AUTHORITY TO CONSTRUCT

PERMIT NO: C-311-39-19

ISSUANCE DATE: 09/22/2009

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: PO BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL PRODUCTION
FRESNO COUNTY, CA

SECTION: 25 TOWNSHIP: 20S RANGE: 14E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 58.5 MMBTU/HR STRUTHERS THERMOFLOOD STEAM GENERATOR #25-18, MODEL OH-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GLE BURNER AND FLUE GAS RECIRCULATION SERVED BY THE 25D NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS: LIMIT SOX PER 5.4.1.3 (EXHAUST) FOR RULE 4320 COMPLIANCE (EXISTING SCRUBBER)

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. This unit shall be fueled with natural gas, LPG, or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Total gas consumption shall not exceed 1,404 MMBtu/day nor 457,800 MMBtu/year. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The permittee shall install and maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Whenever well casing vapors and/or tank vapor recovery gas are being burned in this unit, the SO₂ scrubber shall operate and shall reduce SO₂ emissions by 95% by weight, or shall limit exhaust SO₂ to less than or equal to 9 ppmv corrected to 3.0% oxygen. [District Rules 2201 and 4320]
6. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320]

CONDITIONS CONTINUE ON NEXT PAGE

YOU **MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

C-311-39-19 : Nov 6 2012 4:34PM -- RICKARDK : Joint Inspection NOT Required

Central Regional Office • 1990 E. Gettysburg Ave. • Fresno, CA 93726 • (559) 230-5900 • Fax (559) 230-6061

7. PUC quality gas shall be combusted in this unit whenever the scrubber is not being operated. [District Rule 2201]
8. Scrubber liquor pH shall be maintained between 6.5 and 8.0. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Tray packing flowrate shall be operated at 700 to 840 gallons/minute. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Quench flowrate shall be operated at 145 to 185 gallons/minute. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
12. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. Emissions from this unit shall not exceed any of the following limits: 0.0520 lb-SO_x/MMBtu, 0.045 lb-PM₁₀/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rules 2201 and 4320]
14. Except during startup and shutdown, emissions from this unit shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, or 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320]
15. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu nor 0.084 lb-CO/MMBtu. [District Rule 2201]
16. Duration of startup and shutdown shall not exceed two hours each per occurrence. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods. [District Rules 2201, 4305, 4306, and 4320]
17. Startup is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320]
18. Source testing to measure SO_x emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. [District Rule 4320]
19. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320]
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320]
22. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2]
23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
24. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

25. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320]
26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320]
27. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320]
29. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320]
30. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320]
31. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320]
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320]
33. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

34. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
35. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
36. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
37. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2, 4305, 4306, 4320, and 4351, 6.2.1]
38. Stack gas moisture content shall be determined using EPA Method 4. [District Rule 2201] Federally Enforceable Through Title V Permit
39. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. Waste gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
40. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
41. Permittee shall record daily total gas consumption. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
42. Daily records of the tray packing flowrate and the quench flowrate shall be maintained, retained on the premises for a period of at least five years, and made available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
43. Permittee shall measure and record the BTU content of the gas burned at the time of NO_x source testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit
44. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
45. Permittee shall maintain with the permit a current listing of all TEOR and TVR systems providing vapor to this steam generator and shall make such listing readily available for District inspection upon request [District Rule 2201] Federally Enforceable Through Title V Permit
46. Permittee shall maintain daily records of volume of fuel gas burned, TEOR/TVR gas incinerated, and permit number(s) of systems providing gas for incineration. [District Rule 2201] Federally Enforceable Through Title V Permit
47. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320]

CONDITIONS CONTINUE ON NEXT PAGE

48. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
49. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
50. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

AUTHORITY TO CONSTRUCT

PERMIT NO: C-311-40-18

ISSUANCE DATE: 09/22/2009

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: PO BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL PRODUCTION
FRESNO COUNTY, CA

SECTION: 25 TOWNSHIP: 20S RANGE: 14E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 58.5 MMBTU/HR NATURAL GAS, LPG OR PROCESS GAS FIRED STRUTHERS THERMOFLOOD STEAM GENERATOR, MODEL OH-50-ND-16XAM, WITH A NORTH AMERICAN GLE BURNER, FLUE GAS RECIRCULATION SYSTEM, AN OXYGEN CONTROLLER, SERVED BY THE NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS (COMMON TO C-311-37) (SG-25-19): LIMIT SOX PER 5.4.1.3 (EXHAUST) FOR RULE 4320 COMPLIANCE (EXISTING SCRUBBER)

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. This unit shall be fueled with natural gas, LPG, or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Fuel consumption shall not exceed 434,700 MMBtu/year. [District Rule 2201] Federally Enforceable Through Title V Permit
4. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Whenever well casing vapors and/or tank vapor recovery gas are being burned in this unit, the SO₂ scrubber shall operate and shall reduce SO₂ emissions by 95% by weight, or shall limit exhaust SO₂ to less than or equal to 9 ppmv corrected to 3.0% oxygen. [District Rules 2201 and 4320]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

C-311-40-18 : Nov 6 2012 4:34PM -- RICKARDIK : Joint Inspection NOT Required

Central Regional Office • 1990 E. Gettysburg Ave. • Fresno, CA 93726 • (559) 230-5900 • Fax (559) 230-6061

7. Whenever the unit is switched to scrubbed operation, compliance source testing for SO_x shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320]
8. PUC quality gas shall be combusted in this unit whenever the scrubber is not being operated. [District Rule 2201]
9. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
10. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. Emissions from this unit shall not exceed any of the following limits: 0.052 lb-SO_x/MMBtu, 0.045 lb-PM₁₀/MMBtu, or 0.0055 lb-VOC/MMBtu. [District Rules 2201 and 4320]
12. Except during startup and shutdown, emissions from this unit shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, or 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu. [District NSR Rule and District Rules 4305, 4306, and 4320]
13. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu nor 0.084 lb-CO/MMBtu. [District Rule 2201]
14. Duration of startup and shutdown shall not exceed two hours each per occurrence. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods. [District Rules 2201, 4305, 4306, and 4320]
15. Startup is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4305, 4306, and 4320]
16. Source testing to measure SO_x emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. [District Rule 4320]
17. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320]
18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320]
20. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320]
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320]
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320]
25. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320]
26. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320]
27. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320]
28. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320]
29. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
30. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rules 2201 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rules 2201 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2, 4305, 4306, 4320, and 4351, 6.2.1]
34. Copies of all gas purchase contracts, supplier certifications, and test results (including fuel hhv) to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2 and District Rule 2201] Federally Enforceable Through Title V Permit
35. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320]
36. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
37. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
38. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

AUTHORITY TO CONSTRUCT

PERMIT NO: C-311-41-15

ISSUANCE DATE: 09/22/2009

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: PO BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL PRODUCTION
FRESNO COUNTY, CA

SECTION: 25 TOWNSHIP: 20S RANGE: 14E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 58.5 MMBTU/HR SG 25-20 STRUTHERS THERMOFLOOD STEAM GENERATOR, MODEL OH-50-ND-16XAM, WITH A NORTH AMERICAN GLE BURNER AND FLUE GAS RECIRCULATION SYSTEM, SERVED BY THE NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS: LIMIT SOX PER 5.4.1.3 (EXHAUST) FOR RULE 4320 COMPLIANCE (EXISTING SCRUBBER)

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. Total LPG, casing gas, waste gas, and natural gas consumption shall not exceed 435,000 MMBtu/year. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Whenever well casing vapors and/or tank vapor recovery gas are being burned in this unit, the SO2 scrubber shall operate and shall reduce SO2 emissions by 95% by weight, or shall limit exhaust SO2 to less than or equal to 9 ppmv corrected to 3.0% oxygen. [District Rules 2201 and 4320]
4. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320]
5. PUC quality gas shall be combusted in this unit whenever the scrubber is not being operated. [District Rule 2201]
6. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the steam generator. [District Rule 2201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

C-311-41-15 : Nov 6 2012 4:34PM -- RICKARDK : Joint Inspection NOT Required

Central Regional Office • 1990 E. Gettysburg Ave. • Fresno, CA 93726 • (559) 230-5900 • Fax (559) 230-6061

7. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Emissions from this unit shall not exceed any of the following limits: 0.052 lb-SO_x/MMBtu, 0.044 lb-PM₁₀/MMBtu, or 0.0085 lb-VOC/MMBtu. [District Rules 2201 and 4320]
10. Except during startup and shutdown, emissions from this unit shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, or 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu. [District NSR Rule and District Rules 4305, 4306, and 4320]
11. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu nor 0.084 lb-CO/MMBtu. [District Rule 2201]
12. Duration of startup and shutdown shall not exceed two hours each per occurrence. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods. [District Rules 4305, 4306, and 4320]
13. Startup is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 2201, 4305, 4306, and 4320]
14. Source testing to measure SO_x emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. [District Rule 4320]
15. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320]
16. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320]
19. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320]
21. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320]
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

23. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, fuel gas sulfur content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320]
24. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320]
25. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320]
26. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320]
27. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320]
28. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
29. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
30. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rules 2201 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rules 2201 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
32. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2, 4305, 4306, 4320, and 4351, 6.2.1]
34. Copies of all gas purchase contracts, supplier certifications, and test results (including fuel hhv) to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2 and District Rule 2201] Federally Enforceable Through Title V Permit
35. Permittee shall record natural gas, propane, casing gas and waste gas consumption. [District Rules 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
36. Permittee shall measure and record the BTU content of the gas burned at the time of NO_x testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit
37. Permittee shall maintain with the permit a current listing of all TEOR and TVR systems providing vapor to this steam generator and shall make such listing readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
38. Permittee shall maintain daily records of volume of fuel gas burned, TEOR/TVR gas incinerated, and permit number(s) of systems providing gas for incineration. [District Rule 2201] Federally Enforceable Through Title V Permit
39. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320]
40. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

AUTHORITY TO CONSTRUCT

PERMIT NO: C-311-76-15

ISSUANCE DATE: 01/25/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: PO BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL PRODUCTION
FRESNO COUNTY, CA

SECTION: 6C TOWNSHIP: 20S RANGE: 15E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 58.5 MMBTU/HR STRUTHERS THERMOFLOOD (SG 6-38) MODEL OH-50-ND-16XAM NATURAL GAS/LPG/TEOR GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL MAGNA FLAME GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION SYSTEM INCLUDING AN OXYGEN CONTROLLER: LIMIT FUEL GAS SULFUR CONTENT TO 5 GR-S/100 DSCF FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Authority to Construct (ATC) C-311-76-12 shall be implemented prior to or concurrently with this ATC. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The permittee shall install and maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District Rule 2201] Federally Enforceable Through Title V Permit
5. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
6. This unit shall be fired on PUC-quality natural gas, LPG, or a blend of PUC-quality natural gas and well casing and tank vapor recovery (TVR) gas. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

C-311-76-15 : Nov 6 2012 4:34PM -- RICKARDK : Joint Inspection NOT Required

Central Regional Office • 1990 E. Gettysburg Ave. • Fresno, CA 93726 • (559) 230-5900 • Fax (559) 230-6061

7. Fuel gas shall not contain more than 5 grains of total sulfur per 100 standard cubic feet. [District Rule 4320]
8. Total fuel consumption shall not exceed 1,404 MMBtu/day nor 434,700 MMBtu/year. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
10. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
11. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
12. Emissions from the steam generator shall not exceed any of the following limits: 0.0143 lb-SO_x/MMBtu, 0.00675 lb-PM₁₀/MMBtu, or 0.00855 lb-VOC/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu or 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu. [District Rule 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO_x/day, 7,825 lb-NO_x/yr, 66.4 lb-CO/day, and 16,084 lb-CO/yr. [District Rule 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rules 2520, 9.4.2 and 4320] Federally Enforceable Through Title V Permit
19. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculate emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
21. Operator shall provide an annual fuel analysis to the District. [District Rule 4320]
22. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 4306, 4320, and 4351, 6.2.1] Federally Enforceable Through Title V Permit
23. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted within 60 days of initial start-up. [District Rule 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
26. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
27. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The results of each source test shall be submitted to the District within 60 days after completion of the test. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100, Stack Gas Velocity (ft/min) - EPA Method 2, Stack Gas Moisture Content (%) - EPA Method 4, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, Fuel Gas Sulfur Content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
31. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
33. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
34. The portable analyzer shall be calibrated as recommended by the manufacturer. All instrument calibration data shall be kept on file including the date of calibration. The calibration date shall not exceed 3 months prior to the date the stack concentrations are measured and recorded. [District Rule 2520, 9.4.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
35. Natural gas or LPG sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas or LPG shall be tested for sulfur content and higher heating value (hhv) monthly. Casing gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
36. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
37. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
38. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
40. Copies of all , gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
42. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

44. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

AUTHORITY TO CONSTRUCT

PERMIT NO: C-311-84-16

ISSUANCE DATE: 01/25/2010

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: PO BOX 1392
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL PRODUCTION
FRESNO COUNTY, CA

SECTION: 6C TOWNSHIP: 20S RANGE: 15E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 58.5 MMBTU/HR STRUTHERS THERMOFLOOD (SG 6-37) MODEL OH50-ND-16XAM NATURAL GAS/LPG/TEOR GAS (COMMON TO C-311-37, SG 25-19) FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL MAGNA FLAME GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION: LIMIT FUEL GAS SULFUR CONTENT TO 5 GR-S/100 DSCF FOR RULE 4320 COMPLIANCE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. The permittee shall install and maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District Rule 2201] Federally Enforceable Through Title V Permit
4. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
5. This unit shall be fired on PUC-quality natural gas, LPG, or a blend of PUC-quality natural gas and well casing and tank vapor recovery (TVR) gas. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fuel gas shall not contain more than 5 grains of total sulfur per 100 standard cubic feet. [District Rule 4320]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

C-311-84-16 : Nov 6 2012 4:34PM -- RICKARDK : Joint Inspection NOT Required

Central Regional Office • 1990 E. Gettysburg Ave. • Fresno, CA 93726 • (559) 230-5900 • Fax (559) 230-6061

7. Total fuel consumption shall not exceed 1,404 MMBtu/day nor 434,700 MMBtu/year. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
9. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
11. Emissions from the steam generator shall not exceed any of the following limits: 0.0143 lb-SO_x/MMBtu, 0.00675 lb-PM₁₀/MMBtu, or 0.00855 lb-VOC/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown periods emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu or 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu. [District Rule 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO_x/day, 7,825 lb-NO_x/yr, 66.4 lb-CO/day, and 16,084 lb-CO/yr. [District Rule 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rules 2520, 9.4.2 and 4320] Federally Enforceable Through Title V Permit
18. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
19. Operator shall provide an annual fuel analysis to the District. [District Rule 4320]

CONDITIONS CONTINUE ON NEXT PAGE

20. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
24. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The results of each source test shall be submitted to the District within 60 days after completion of the test. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100, Stack Gas Velocity (ft/min) - EPA Method 2, Stack Gas Moisture Content (%) - EPA Method 4, SO_x (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6C or fuel gas sulfur content analysis and EPA Method 19, Fuel Gas Sulfur Content - EPA Method 11 or 15, ASTM D3246 or double GC for H₂S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 4306, 4320, and 4351, 6.2.1] Federally Enforceable Through Title V Permit
29. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
33. Natural gas or LPG sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source; or natural gas or LPG shall be tested for sulfur content and higher heating value (hhv) monthly. Casing gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
34. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
35. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
36. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
37. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
38. Copies of all , gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
39. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

ATTACHMENT C

Emissions Increases

	SSIPE (lb/yr)				
	NOx	VOC	CO	SOx	PM10
All Permits	0	0	0	0	0
TOTAL	0	0	0	0	0

ATTACHMENT D

Application

San Joaquin Valley Air Pollution Control District

www.valleyair.org


RECEIVED

DISTRICT 2011

SJVAPCD
Southern Region

Permit Application For:

ADMINISTRATIVE AMENDMENT
 MINOR MODIFICATION
 SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: <p style="text-align: center;">CHEVRON U.S.A. INC.</p>	
2. MAILING ADDRESS: STREET/P.O. BOX: <u>PO BOX 1392</u>	
CITY: <u>BAKERSFIELD</u>	STATE: <u>CA</u> 9-DIGIT ZIP CODE: <u>93302</u>
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED: STREET: <u>Fresno Heavy Oil Source</u> CITY: _____ _____ ¼ SECTION _____ TOWNSHIP _____ RANGE	INSTALLATION DATE: _____
4. GENERAL NATURE OF BUSINESS: <u>CRUDE OIL AND GAS PRODUCTION</u>	
5. DESCRIPTION OF EQUIPMENT OR MODIFICATION FOR WHICH APPLICATION IS MADE (include Permit #'s if known, and use additional sheets if necessary) Implementation of ATCs C-311-20-16, '-21-7, '-25-6, '-28-16, '-30-16, '-36-17, '37-21'-38-21, '39-19, '-40-18, '-41-15 Add sulfur limits for Rule 4320 compliance	
6. TYPE OR PRINT NAME OF APPLICANT: <u>William R. Fall</u>	TITLE OF APPLICANT: <u>HES Manager</u>
7. SIGNATURE OF APPLICANT: 	DATE: <u>6/16/2011</u> PHONE: (661) 654-7141 FAX: (661) 654-7606 EMAIL: <u>landilr@chevron.com</u>

For APCD Use Only:

DATE STAMP	FILING FEE RECEIVED: \$ _____ CHECK#: _____
	DATE PAID: _____
	PROJECT NO: <u>C-1112109</u> FACILITY ID: <u>C-311</u>

Title V - Minor Mod

RECEIVED

JUN 20 2011

SJVAPCD
Southern Region

San Joaquin Valley Unified Air Pollution Control District

TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)

- SIGNIFICANT PERMIT MODIFICATION ADMINISTRATIVE
 MINOR PERMIT MODIFICATION AMENDMENT

COMPANY NAME: CHEVRON U.S.A. INC.	FACILITY ID: C-311
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: CHEVRON U.S.A. INC.	
3. Agent to the Owner: N/A	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

William Fall

Signature of Responsible Official

6/16/11

Date

William Fall

Name of Responsible Official (please print)

ATCs C-311-20-16, '-21-7, '-25-6, '-28-16, '-30-16,
'-36-17, '37-21'-38-21, '39-19, '-40-18, '-41-15

SJVBU HES Manager

Title of Responsible Official (please print)

San Joaquin Valley Air Pollution Control District

www.valleyair.org

RECEIVED
JUN 20 2011

Permit Application For:

SJVAPCD
Southern Region

[X] ADMINISTRATIVE AMENDMENT [] MINOR MODIFICATION [] SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: <p style="text-align: center;">CHEVRON U.S.A. INC.</p>	
2. MAILING ADDRESS: STREET/P.O. BOX: <u>PO BOX 1392</u> CITY: <u>BAKERSFIELD</u> STATE: <u>CA</u> 9-DIGIT ZIP CODE: <u>93302</u>	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED: STREET: <u>Fresno Heavy Oil Source</u> CITY: _____ _____ ¼ SECTION _____ TOWNSHIP _____ RANGE _____	INSTALLATION DATE:
4. GENERAL NATURE OF BUSINESS: <u>CRUDE OIL AND GAS PRODUCTION</u>	
5. DESCRIPTION OF EQUIPMENT OR MODIFICATION FOR WHICH APPLICATION IS MADE (include Permit #'s if known, and use additional sheets if necessary) Implementation of ATCs C-311-76-15, '84-16 Add sulfur limits for Rule 4320 compliance	
6. TYPE OR PRINT NAME OF APPLICANT: <u>William R. Fall</u>	TITLE OF APPLICANT: <u>HES Manager</u>
7. SIGNATURE OF APPLICANT: 	DATE: <u>6/16/2011</u> PHONE: (661) 654-7141 FAX: (661) 654-7606 EMAIL: <u>landilr@chevron.com</u>

For APCD Use Only:

DATE STAMP	FILING FEE RECEIVED: \$ _____ CHECK#: _____ DATE PAID: _____ PROJECT NO: <u>C-1112110</u> FACILITY ID: <u>C-311</u>
------------	---

Title V - Admin Amend

San Joaquin Valley Unified Air Pollution Control District

TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)

- SIGNIFICANT PERMIT MODIFICATION ADMINISTRATIVE
 MINOR PERMIT MODIFICATION AMENDMENT

COMPANY NAME: CHEVRON U.S.A. INC.	FACILITY ID: C-311
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: CHEVRON U.S.A. INC.	
3. Agent to the Owner: N/A	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

William Fall
Signature of Responsible Official

6/16/11
Date

William Fall
Name of Responsible Official (please print)

ATCs C-311-76-15, '84-16

SJVBU HES Manager
Title of Responsible Official (please print)

ATTACHMENT E

Previous Title V Operating Permits
(C-311-20-14, '-21-5, '-25-4, '-28-14, '-30-14,
'-36-13, '-37-17, '-38-18, '-39-17, '-40-16,
'-41-13, '-76-10, and '-84-10)

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-20-14

EXPIRATION DATE: 12/31/2016

SECTION: 13D **TOWNSHIP:** 20S **RANGE:** 14E

EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR NATURAL GAS-FIRED STRUTHERS SG13-04 STEAM GENERATOR WITH A NORTH AMERICAN MODEL 6131G LOW-NOX BURNER WITH OXYGEN CONTROLLER

PERMIT UNIT REQUIREMENTS

1. This unit shall be fired on PUC-quality natural gas, or a blend of PUC-quality natural gas and well casing and tank vapor recovery (TVR) gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Total gas consumption of this unit shall not exceed either of the following limits: 1,404 MMBtu/day or 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1, 4301, 5.1 and 5.2.3, and 4320, 5.4] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801] Federally Enforceable Through Title V Permit
6. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; and 4305, 6.2.1] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. Emissions from the steam generator shall not exceed any of the following limits: 0.157 lb-SO_x/MMBtu, 0.004 lb-PM₁₀/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO_x @ 3% O₂, equivalent to 0.0182 lb-NO_x/MMBtu or 50 ppmvd CO @ 3% O₂, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
17. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO_x/day, 8,332 lb-NO_x/yr, 51.9 lb-CO/day, or 16,939 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. The emission factor (EF) for SO_x shall be determined and recorded on a monthly basis by using the following formula: $EF = (A + B) \times 2.857 / \text{Total}$, where: A = (the amount (in MMscf) of well casing gas consumed for the month X the sulfur content (in grain/100 scf) as posted in the most recent lab analysis); B = (the amount (in MMscf) of PUC grade natural gas consumed for the month X 0.21; and Total = (the total amount of well casing and PUC grade gas combined consumed (in MMscf) for the month). [District NSR Rule] Federally Enforceable Through Title V Permit
19. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
20. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
21. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
22. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2520, 9.3.2, 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
25. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
26. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The source test plan shall indicate which test method shall be used to demonstrate compliance. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The results of each source test shall be submitted to the District within 60 days after the source test. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
29. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
30. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
31. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
33. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
34. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

35. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
36. When calculating NOx or CO emission limits based on heat input (lb/MMBtu), fuel hhv shall be certified by third party supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
37. The well casing gas shall be sampled monthly from the gas line down stream from the point where the casing gas from all 4 casing collection systems is connected together and upstream from the point where the well casing gas is fed to the steam generators. The gas sample shall be analyzed by the laboratory for total sulfur and the results shall be given in grain/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
38. Permittee shall maintain monthly records of the total amount of well casing gas consumed by the entire bank of steam generators (in MMscf), along with the date and time of the measurement. [District Rule 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
39. Permittee shall maintain monthly records of the total amount of PUC grade gas consumed by the entire bank of steam generators (in MMscf), along with the date and time of the measurement. [District Rule 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
40. Permittee shall maintain records of daily total gas consumption. [District Rule 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
41. Permittee shall maintain records of all lab analyses. [District Rule 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
42. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. Casing gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
44. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
45. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
46. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit
47. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
48. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-21-5

EXPIRATION DATE: 12/31/2016

SECTION: 13 **TOWNSHIP:** 20S **RANGE:** 14

EQUIPMENT DESCRIPTION:

58.5 MBTU/HR SG 13-5 STRUTHERS THERMOFLOOD STEAM GENERATOR, MODEL OH-50-ND-16XAM, WITH A NORTH AMERICAN GLE LOW-NOX BURNER

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
3. This unit shall only be fired natural gas and/or well casing gas. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Total gas consumption shall not exceed either of the following limits: 1,404 MMBtu/day or 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
5. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; and 4305, 6.2.1] Federally Enforceable Through Title V Permit
9. Emissions from the steam generator shall not exceed any of the following limits: 0.157 lb-SO_x/MMBtu, 0.08 lb-PM₁₀/MMBtu, or 0.08 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO_x @ 3% O₂, equivalent to 0.0182 lb-NO_x/MMBtu or 50 ppmvd CO @ 3% O₂, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
11. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO_x/day, 14,940 lb-NO_x/yr, 51.9 lb-CO/day, or 16,939 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of each start-up and shutdown period. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
14. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
15. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
16. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
20. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
21. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
25. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
26. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
28. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. Permittee shall record daily natural gas and well casing gas consumption. [District NSR Rule] Federally Enforceable Through Title V Permit
30. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
31. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
33. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
34. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-25-4

EXPIRATION DATE: 12/31/2016

SECTION: 13 **TOWNSHIP:** 20S **RANGE:** 14E

EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR SG 13-9 STRUTHERS THERMOFLOOD STEAM GENERATOR, MODEL OH-50-ND-16XAM, WITH A NORTH AMERICAN FLUE GAS RECIRCULATION SYSTEM.

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
3. This unit shall be fueled with natural gas, LPG, or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District Rule 2201] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; and 4305, 6.2.1] Federally Enforceable Through Title V Permit
8. Natural gas consumption shall not exceed either of the following limits: 1,404 million MMBtu/day or 434,700 MMBtu/year. [District Rule 2201] Federally Enforceable Through Title V Permit
9. LPG consumption shall not exceed either of the following limits: 1,404 MMBtu/day or 435,000 MMBtu/year. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Emissions from the steam generator shall not exceed any of the following limits: 0.052 lb-SO_x/MMBtu, 0.045 lb-PM₁₀/MMBtu, or 0.009 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO_x @ 3% O₂, equivalent to 0.0182 lb-NO_x/MMBtu or 50 ppmvd CO @ 3% O₂, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
12. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2202] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO_x/day, 15,660 lb-NO_x/yr, 51.9 lb-CO/day, or 16,084 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of each start-up and shutdown period. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
18. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
26. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
27. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
28. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
29. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. Permittee shall record daily natural gas, propane, and well casing gas consumption. [District NSR Rule] Federally Enforceable Through Title V Permit
31. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
32. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit
33. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
34. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-28-14

EXPIRATION DATE: 12/31/2016

SECTION: 13 **TOWNSHIP:** 20S **RANGE:** 14E

EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR STRUTHERS THERMOFLOOD STEAM GENERATOR #13-12, MODEL OH-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GAS AND OIL BURNER, MODEL 6131G-CR-62.5, FLUE GAS RECIRCULATION (FGR), AND AN OXYGEN CONTROLLER.

PERMIT UNIT REQUIREMENTS

1. This unit shall be fueled with natural gas or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Natural gas consumption shall not exceed 1,404 MMBtu/day nor 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall install and maintain a non-resettable, totalizing mass or volumetric flow meter in the fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Duration of startup and shutdown shall not exceed two hours each per occurrence and, combined, shall not exceed 4 hours per day. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods. [District Rule 4306, 5.3.1] Federally Enforceable Through Title V Permit
6. Startup is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
7. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. Emissions from this unit shall not exceed any of the following limits: 0.284 lb-SO_x/MMBtu, 0.005 lb-PM₁₀/MMBtu, or 0.008 lb-VOC/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Except during startup and shutdown, emissions from this unit shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, or 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu. [District NSR Rule and District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
10. During startup and shutdown, emission rates from the unit shall not exceed any of the following limits: 5.85 lb-NO_x/hr, 16.61 lb-SO_x/hr, 0.29 lb-PM₁₀/hr, 4.91 lb-CO/hr, or 0.47 lb-VOC/hr. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
12. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
14. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
15. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.2.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
18. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
23. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
25. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4.2 and 4306, 5.4.2 and 5.5.4] Federally Enforceable Through Title V Permit
26. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
27. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
28. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule Rules 2520, 9.3.2; 4305, 6.2.1; 4306, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

32. Stack gas moisture content shall be determined using EPA Method 4. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Annual test results to the District from unit(s) representing a group of units may be used to measure NOx emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
34. The following conditions must be met for representative unit(s) to be used to test for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
35. All units in a group for which representative units are source for NOx emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
36. All units in a group for which representative units are source tested for NOx emissions for this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
37. The number of representative units source tested for NOx emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
38. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
39. Permittee shall record daily natural gas consumption. Records shall be made available for District inspection upon request. [District Rules 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
40. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for natural gas used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, and 4306] Federally Enforceable Through Title V Permit
42. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
44. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
46. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-30-14

EXPIRATION DATE: 12/31/2016

SECTION: 13 **TOWNSHIP:** 20S **RANGE:** 14E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS THERMOFLOOD STEAM GENERATOR #13-14, MODEL OH-50-ND-16XAM, NATURAL GAS FIRED, WITH A NORTH AMERICAN BURNER, MODEL 613G-CR-62.5, AN OXYGEN CONTROLLER, AND A FLUE GAS RECIRCULATION (FGR) SYSTEM.

PERMIT UNIT REQUIREMENTS

1. This unit shall be fueled with natural gas or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Natural gas consumption shall not exceed 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
4. The permittee shall install and maintain a non-resettable, totalizing mass or volumetric flow meter in the fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
6. Duration of startup and shutdown shall not exceed two hours each per occurrence and, combined, shall not exceed 4 hours per day. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods. [District Rule 4306, 5.3.1] Federally Enforceable Through Title V Permit
7. Startup is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
8. Emissions from this unit shall not exceed any of the following limits: 0.14 lb-SO_x/MMBtu, 0.005 lb-PM₁₀/MMBtu, or 0.003 lb-VOC/MMBtu [District NSR Rule] Federally Enforceable Through Title V Permit
9. Except during startup and shutdown, emissions from this unit shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, or 50 ppmvd CO @ 3% O₂ or 0.37 lb-CO/MMBtu. [District NSR Rule and District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
10. During startup and shutdown, emission rates from the unit shall not exceed any of the following limits: 6.25 lb-NO_x/hr, 8.75 lb-SO_x/hr, 0.31 lb-PM₁₀/hr, 5.25 lb-CO/hr, or 0.19 lb-VOC/hr. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2 and 5.3, and 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
15. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
18. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
23. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
24. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4.2 and 4306, 5.5.2 and 5.5.4] Federally Enforceable Through Title V Permit
26. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
27. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
28. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.4.2; 4305, 6.2.1; 4306, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
32. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
34. Permittee shall maintain accurate annual records of natural gas use, and such records shall be made readily available. [District Rule 1070] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

35. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for natural gas used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, and 4306] Federally Enforceable Through Title V Permit
37. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
38. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
39. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
40. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
41. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-36-13

EXPIRATION DATE: 12/31/2016

SECTION: 25 **TOWNSHIP:** 20S **RANGE:** 14E

EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR STRUTHERS THERMOFLOOD MODEL OH-50-ND-16XAM NATURAL GAS/LPG/WELL CASING GAS/TANK VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (SG #25-15) WITH A NORTH AMERICAN MODEL MAGNA-FLAME GLE LOW NOX BURNER SERVED BY THE 25D NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS FROM SECTIONS 25D AND 6C ONLY

PERMIT UNIT REQUIREMENTS

1. This unit shall be fueled with natural gas, LPG, or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
3. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
5. Total LPG, casing gas, waste gas, and natural gas consumption shall not exceed 435,000 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
6. The permittee shall maintain and operate a non-resettable, totalizing mass or volumetric flow meter in the fuel line to the steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The caustic scrubber shall be operated to control SOx emissions when ever the steam generator is fueled with well casing and/or TVR gas. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Scrubber liquor pH shall be maintained between 6.5 and 8.0. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Tray packing flowrate shall be operated at 700 to 840 gallons/minute. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Quench flowrate shall be operated at 145 to 185 gallons/minute. [District NSR Rule] Federally Enforceable Through Title V Permit
11. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
14. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 4305, and 4351] Federally Enforceable Through Title V Permit
15. Except during start-up and shutdown periods, emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, 0.052 lb-SO_x/MMBtu, 0.014 lb-PM₁₀/MMBtu, 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu, or 0.0085 lb-VOC/MMBtu. [District Rules 2201, 4301, 4305, and 4306] Federally Enforceable Through Title V Permit
16. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. the operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306] Federally Enforceable Through Title V Permit
19. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO_x/day, 7,830 lb-NO_x/year, 49.1 lb-CO/day, or 16,095 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
21. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
25. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
27. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
29. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
30. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
31. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
32. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
33. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
34. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
35. Permittee shall record natural gas, propane, casing gas, and waste gas consumption. [District Rule 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. Permittee shall measure and record the BTU content of the gas burned at the time of NOx testing, except for natural gas purchased from a PUC regulated utility. [District NSR Rule and 4801] Federally Enforceable Through Title V Permit
37. Permittee shall maintain with the permit a current listing of all TEOR and TVR systems providing vapor to this steam generator and shall make such listing readily available for District inspection upon request [District NSR Rule] Federally Enforceable Through Title V Permit
38. Permittee shall maintain daily records of volume of fuel gas burned, TEOR/TVR gas incinerated, and permit number(s) of systems providing gas for incineration. [District NSR Rule] Federally Enforceable Through Title V Permit
39. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rules 1070, 4305, and 4306] Federally Enforceable Through Title V Permit
40. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
41. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
42. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit
43. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
44. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
45. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-37-17

EXPIRATION DATE: 12/31/2016

SECTION: 25 **TOWNSHIP:** 20S **RANGE:** 14E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS THERMOFLOOD MODEL OH-50-ND-16XAM STEAM GENERATOR (#25-16) WITH A NORTH AMERICAN MODEL GLE LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SERVED BY THE 25D NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS

PERMIT UNIT REQUIREMENTS

1. This unit shall be fueled with natural gas, LPG, or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2] Federally Enforceable Through Title V Permit
4. Total gas consumption shall not exceed 1,404 MMBtu/day nor 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The permittee shall install and maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
6. The caustic scrubber shall be operated to control SOx emissions when ever the steam generator is fueled with well casing and/or TVR gas. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Scrubber liquor pH shall be maintained between 6.5 and 8.0. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Tray packing flowrate shall be operated at 700 to 840 gallons/minute. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Quench flowrate shall be operated at 145 to 185 gallons/minute. [District NSR Rule] Federally Enforceable Through Title V Permit
10. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1, 4306, 6.2.1, and 4351, 6.2.1] Federally Enforceable Through Title V Permit
14. Except during start-up and shutdown periods, emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, 0.052 lb-SO_x/MMBtu, 0.014 lb-PM₁₀/MMBtu, 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rules 2201, 4301, 4305, and 4306] Federally Enforceable Through Title V Permit
15. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. the operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
18. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO_x/day, 8,240 lb-NO_x/year, 85.6 lb-CO/day, or 16,939 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
24. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
26. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
27. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
29. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

31. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
32. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
33. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. Waste gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
34. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
35. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
36. Permittee shall record daily total gas consumption. Records shall be retained for at least five years and made available for District inspection upon request. [District Rule 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
37. Daily records of the tray packing flowrate and the quench flowrate shall be maintained, retained on the premises for a period of at least five years, and made available for District inspection upon request. [District Rule 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
38. Permittee shall measure and record the BTU content of the gas burned at the time of NO_x source testing, except for natural gas purchased from a PUC regulated utility. [District NSR Rule and 4801] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
40. Permittee shall maintain with the permit a current listing of all TEOR and TVR systems providing vapor to this steam generator and shall make such listing readily available for District inspection upon request [District NSR Rule] Federally Enforceable Through Title V Permit
41. Permittee shall maintain daily records of volume of fuel gas burned, TEOR/TVR gas incinerated, and permit number(s) of systems providing gas for incineration. [District NSR Rule] Federally Enforceable Through Title V Permit
42. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, and 4306] Federally Enforceable Through Title V Permit
43. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
44. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
45. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

46. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
47. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
48. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-38-18

EXPIRATION DATE: 12/31/2016

SECTION: 25 **TOWNSHIP:** 20S **RANGE:** 14E

EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR SG 25-17 STRUTHERS THERMOFLOOD STEAM GENERATOR, MODEL OH-50-ND-16XAM, WITH A NORTH AMERICAN GLE LOW-NOX BURNER (OR DISTRICT APPROVED EQUIVALENT) AND FLUE GAS RECIRCULATION SERVED BY THE 25D NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS

PERMIT UNIT REQUIREMENTS

1. This unit shall be fueled with natural gas, LPG, or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Total gas consumption of this unit shall not exceed either of the following limits: 1,404 MMBtu/day or 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
4. The caustic scrubber shall be operated to control SOx emissions when ever the steam generator is fueled with well casing and/or TVR gas. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Scrubber liquor pH shall be maintained between 6.5 and 8.0. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Tray packing flowrate shall be operated at 700 to 840 gallons/minute. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Quench flowrate shall be operated at 145 to 185 gallons/minute. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
9. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
10. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
14. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
15. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
16. Emissions from the steam generator shall not exceed any of the following limits: 0.052 lb-SO_x/MMBtu, 0.045 lb-PM₁₀/MMBtu, or 0.008 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Except during start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 15 ppmvd NO_x @ 3% O₂, equivalent to 0.0182 lb-NO_x/MMBtu or 50 ppmvd CO @ 3% O₂, equivalent to 0.037 lb-CO/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, and 4306, 5.1] Federally Enforceable Through Title V Permit
18. During start-up and shutdown periods emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NO_x/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
20. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
21. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: 50.5 lb-NO_x/day, 8,332 lb-NO_x/yr, 51.9 lb-CO/day, or 16,939 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, and 4306, 6.3.1] Federally Enforceable Through Title V Permit
23. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2520, 9.3.2, 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
25. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
26. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The source test plan shall indicate which test method shall be used to demonstrate compliance. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The results of each source test shall be submitted to the District within 60 days after the source test. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
29. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
30. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
31. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 2520, 9.3.2, 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
32. Stack gas moisture content shall be determined using EPA Method 4. [District NSR Rule] Federally Enforceable Through Title V Permit
33. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
34. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

35. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
37. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
38. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
39. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
40. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. Waste gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
41. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
42. Permittee shall maintain records of daily total gas consumption. [District Rule 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
43. Permittee shall maintain daily records of the tray packing flowrate and the quench flowrate. [District Rule 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
44. Permittee shall measure and record the BTU content of the gas burned at the time of NO_x source testing, except for natural gas purchased from a PUC regulated utility. [District NSR Rule and 4801] Federally Enforceable Through Title V Permit
45. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
46. Permittee shall maintain with the permit a current listing of all TEOR and TVR systems providing vapor to this steam generator. [District NSR Rule] Federally Enforceable Through Title V Permit
47. Permittee shall maintain daily records of volume of fuel gas burned, TEOR/TVR gas incinerated, and permit number(s) of systems providing gas for incineration. [District NSR Rule] Federally Enforceable Through Title V Permit
48. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4305, 6.1, and 4306, 6.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

49. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
50. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
51. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
52. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
53. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-39-17

EXPIRATION DATE: 12/31/2016

SECTION: 25 **TOWNSHIP:** 20S **RANGE:** 14E

EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR STRUTHERS THERMOFLOOD STEAM GENERATOR #25-18, MODEL OH-50-ND-16XAM, EQUIPPED WITH A NORTH AMERICAN GAS AND OIL BURNER AND FLUE GAS RECIRCULATION SERVED BY THE 25D NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS.

PERMIT UNIT REQUIREMENTS

1. This unit shall be fueled with natural gas, LPG, or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Total gas consumption shall not exceed 1,404 MMBtu/day nor 457,800 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall install and maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
4. The caustic scrubber shall be operated to control SO_x emissions when ever the steam generator is fueled with well casing and/or TVR gas. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Scrubber liquor pH shall be maintained between 6.5 and 8.0. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Tray packing flowrate shall be operated at 700 to 840 gallons/minute. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Quench flowrate shall be operated at 145 to 185 gallons/minute. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
9. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2 and 5.3, and 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. Emissions from this unit shall not exceed any of the following limits: 0.0520 lb-SO_x/MMBtu, 0.045 lb-PM₁₀/MMBtu, or 0.008 lb-VOC/MMBtu. [District NSR Rule]
11. Except during startup and shutdown, emissions from this unit shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, or 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu. [District NSR Rule and District Rules 4305 and 4306]
12. During startup and shutdown, emission rates from the unit shall not exceed any of the following limits: 5.85 lb-NO_x/hr, 3.04 lb-SO_x/hr, 2.63 lb-PM₁₀/hr, 4.91 lb-CO/hr, or 0.47 lb-VOC/hr. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

13. Duration of startup and shutdown shall not exceed two hours each per occurrence and, combined, shall not exceed 4 hours per day. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods. [District Rule 4306, 5.3.1] Federally Enforceable Through Title V Permit
14. Startup is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
15. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
18. NOx, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
20. Sampling facilities for source testing shall be provided in accordance with the provisions of rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
24. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
25. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
26. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306, 6.2.4] Federally Enforceable Through Title V Permit
27. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

28. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
29. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306, 5.5.4] Federally Enforceable Through Title V Permit
30. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306, 6.1] Federally Enforceable Through Title V Permit
31. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
32. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
34. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
35. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2, 4305, 6.2.1, 4306, 6.2.1, and 4351, 6.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. Stack gas moisture content shall be determined using EPA Method 4. [District NSR Rule] Federally Enforceable Through Title V Permit
37. Natural gas sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas shall be tested for sulfur content and higher heating value (hhv) monthly. Waste gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
38. Annual test results to the District from unit(s) representing a group of units may be used to measure NOx emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
39. The following conditions must be met for representative unit(s) to be used to test for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
40. All units in a group for which representative units are source for NOx emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
41. All units in a group for which representative units are source tested for NOx emissions for this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2, 4306, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
42. The number of representative units source tested for NOx emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
43. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
44. Permittee shall record daily total gas consumption. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
45. Daily records of the tray packing flowrate and the quench flowrate shall be maintained, retained on the premises for a period of at least five years, and made available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
46. Permittee shall measure and record the BTU content of the gas burned at the time of NOx source testing, except for natural gas purchased from a PUC regulated utility. [District NSR Rule and District Rule 4801] Federally Enforceable Through Title V Permit
47. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
48. Permittee shall maintain with the permit a current listing of all TEOR and TVR systems providing vapor to this steam generator and shall make such listing readily available for District inspection upon request [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

49. Permittee shall maintain daily records of volume of fuel gas burned, TEOR/TVR gas incinerated, and permit number(s) of systems providing gas for incineration. [District NSR Rule] Federally Enforceable Through Title V Permit
50. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, and 4306] Federally Enforceable Through Title V Permit
51. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
52. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
53. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
54. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
55. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-40-16

EXPIRATION DATE: 12/31/2016

SECTION: 25 **TOWNSHIP:** 20S **RANGE:** 14E

EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR NATURAL GAS, LPG OR PROCESS GAS FIRED STRUTHERS THERMOFLOOD STEAM GENERATOR, MODEL OH-50-ND-16XAM, WITH A NORTH AMERICAN GLE BURNER, FLUE GAS RECIRCULATION SYSTEM, AN OXYGEN CONTROLLER, SERVED BY THE NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS (COMMON TO C-311-37) (SG-25-19)

PERMIT UNIT REQUIREMENTS

1. This unit shall be fueled with natural gas, LPG, or a blend of natural gas and well casing and tank vapor recovery (TVR) gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Fuel consumption shall not exceed 434,700 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
4. The permittee shall maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the steam generator. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The caustic scrubber shall be operated to control SOx emissions when ever the steam generator is fueled with well casing and/or TVR gas. [District NSR Rule]
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. Emissions from this unit shall not exceed any of the following limits: 0.052 lb-SOx/MMBtu, 0.045 lb-PM10/MMBtu, or 0.0055 lb-VOC/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
9. Except during startup and shutdown, emissions from this unit shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu, or 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District NSR Rule and District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
10. During startup and shutdown, emission rates from the unit shall not exceed any of the following limits: 5.85 lb-NOx/hr, 3.04 lb-SOx/hr, 2.63 lb-PM10/hr, 4.91 lb-CO/hr, or 0.32 lb-VOC/hr. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Duration of startup and shutdown shall not exceed two hours each per occurrence and, combined, shall not exceed 4 hours per day. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods. [District Rule 4306, 5.3.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. Startup is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
13. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
14. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
15. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
16. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
18. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
23. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4.2 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
25. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4.2 and 4306, 5.4.2 and 5.5.4] Federally Enforceable Through Title V Permit
26. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
27. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
28. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and District NSR Rule] Federally Enforceable Through Title V Permit
29. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

32. Annual test results to the District from unit(s) representing a group of units may be used to measure NOx emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
33. The following conditions must be met for representative unit(s) to be used to test for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
34. All units in a group for which representative units are source for NOx emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
35. All units in a group for which representative units are source tested for NOx emissions for this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2, 4306, 6.3.2, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
36. The number of representative units source tested for NOx emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2, 4305, 6.3.2, and 4306, 6.3.2] Federally Enforceable Through Title V Permit
37. Copies of all gas purchase contracts, supplier certifications, and test results (including fuel hhv) to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2 and District NSR Rule] Federally Enforceable Through Title V Permit
38. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, and 4306] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
42. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

43. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-41-13

EXPIRATION DATE: 12/31/2016

SECTION: 25 **TOWNSHIP:** 20S **RANGE:** 14E

EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR SG 25-20 STRUTHERS THERMOFLOOD STEAM GENERATOR, MODEL OH-50-ND-16XAM, WITH A NORTH AMERICAN GLE BURNER AND FLUE GAS RECIRCULATION SYSTEM, SERVED BY THE NEPTUNE AIRPOL CAUSTIC SCRUBBER WHEN FIRING WELL CASING AND/OR TANK VAPOR RECOVERY GAS

PERMIT UNIT REQUIREMENTS

1. Total LPG, casing gas, waste gas, and natural gas consumption shall not exceed 435,000 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The caustic scrubber shall be operated to control SOx emissions when ever the steam generator is fueled with well casing and/or TVR gas. [District NSR Rule]
3. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. Emissions from this unit shall not exceed any of the following limits: 0.052 lb-SOx/MMBtu, 0.044 lb-PM10/MMBtu, or 0.0085 lb-VOC/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Except during startup and shutdown, emissions from this unit shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu, or 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District NSR Rule and District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
7. During startup and shutdown, emission rates from the unit shall not exceed any of the following limits: 5.85 lb-NOx/hr, 3.04 lb-SOx/hr, 2.57 lb-PM10/hr, 4.91 lb-CO/hr, or 0.50 lb-VOC/hr. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Duration of startup and shutdown shall not exceed two hours each per occurrence and, combined, shall not exceed 4 hours per day. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods. [District Rule 4306, 5.3.1] Federally Enforceable Through Title V Permit
9. Startup is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
10. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
13. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
14. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
15. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
16. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305 and 4306, 6.2.2] Federally Enforceable Through Title V Permit
19. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
20. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306, 6.2.4] Federally Enforceable Through Title V Permit
21. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
22. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306, 5.4.2] Federally Enforceable Through Title V Permit
23. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306, 5.5.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306, 6.1] Federally Enforceable Through Title V Permit
25. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
26. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
27. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and District NSR Rule] Federally Enforceable Through Title V Permit
28. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2; 4305, 6.2.1; 4306; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
31. Annual test results to the District from unit(s) representing a group of units may be used to measure NO_x emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. [District Rules 2520, 9.3.2, 4306, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
32. The following conditions must be met for representative unit(s) to be used to test for NO_x limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2, 4306, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
33. All units in a group for which representative units are source for NO_x emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2, 4306, and 4305, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

34. All units in a group for which representative units are source tested for NOx emissions for this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2, 4306, and 4305, 6.3.2] Federally Enforceable Through Title V Permit
35. The number of representative units source tested for NOx emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
36. Copies of all gas purchase contracts, supplier certifications, and test results (including fuel hgv) to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2 and District NSR Rule] Federally Enforceable Through Title V Permit
37. Permittee shall record natural gas, propane, casing gas and waste gas consumption. [District Rules 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
38. Permittee shall measure and record the BTU content of the gas burned at the time of NOx testing, except for natural gas purchased from a PUC regulated utility. [District NSR Rule and District Rule 4801] Federally Enforceable Through Title V Permit
39. Permittee shall maintain with the permit a current listing of all TEOR and TVR systems providing vapor to this steam generator and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
40. Permittee shall maintain daily records of volume of fuel gas burned, TEOR/TVR gas incinerated, and permit number(s) of systems providing gas for incineration. [District NSR Rule] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, and 4306] Federally Enforceable Through Title V Permit
42. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
44. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
45. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
46. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-76-10

EXPIRATION DATE: 12/31/2016

SECTION: 6C **TOWNSHIP:** 20S **RANGE:** 15E

EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR STRUTHERS THERMOFLOOD (SG 6-38) MODEL OH-50-ND-16XAM NATURAL GAS/LPG/TEOR GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL MAGNA FLAME GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION SYSTEM INCLUDING AN OXYGEN CONTROLLER

PERMIT UNIT REQUIREMENTS

1. This unit shall be fired exclusively with natural gas, LPG, or TEOR gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Total fuel consumption shall not exceed 1,404 MMBtu/day nor 434,700 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall install and maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
4. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
6. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
11. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown, emissions from this steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, 0.043 lb-SO_x/MMBtu, 0.00675 lb-PM₁₀/MMBtu, 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu, or 0.00855 lb-VOC/MMBtu. [District NSR Rule and District Rule 4306, 5.1] Federally Enforceable Through Title V Permit
13. During start-up and shutdown, emissions from this steam generator shall not exceed any of the following limits: 0.1 lb-NO_x/MMBtu, 0.043 lb-SO_x/MMBtu, 0.00675 lb-PM₁₀/MMBtu, 0.084 lb-CO/MMBtu, or 0.00855 lb-VOC/MMBtu. [District NSR Rule and District Rule 4306, 5.1] Federally Enforceable Through Title V Permit
14. Maximum emissions from this steam generator, including start-up and shutdown operation, shall not exceed any of the following limits: 50.5 lb-NO_x in any one day, 7,825 lb-NO_x in any calendar year, 66.4 lb-CO in any one day, or 16,084 lb-CO in any calendar year. [District NSR Rule] Federally Enforceable Through Title V Permit
15. Start-up is defined as that period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as that period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.22, 3.25] Federally Enforceable Through Title V Permit
16. The duration of each start-up or each shutdown shall not exceed two hours per occurrence. The emission control system shall be in operation and emissions shall be minimized insofar as technologically feasible during start-up or shutdown. The operator shall maintain daily records of the number and duration of start-up and shutdown periods. [District Rule 4306, 5.3] Federally Enforceable Through Title V Permit
17. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306, 6.3] Federally Enforceable Through Title V Permit
18. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
19. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
20. The source plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days after completion of the test. [District Rule 1081] Federally Enforceable Through Title V Permit
25. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305 and 4306, 6.2] Federally Enforceable Through Title V Permit
26. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
27. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
29. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
31. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
32. The portable analyzer shall be calibrated as recommended by the manufacturer. All instrument calibration data shall be kept on file including the date of calibration. The calibration date shall not exceed 3 months prior to the date the stack concentrations are measured and recorded. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
34. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
35. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rule 2520, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
36. Natural gas or LPG sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source or natural gas or LPG shall be tested for sulfur content and higher heating value (hhv) monthly. Casing gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
37. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
38. Permittee shall record daily natural gas, casing gas, and propane consumption. Records shall be provided to the District upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit
40. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
41. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
43. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
44. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
45. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-311-84-10

EXPIRATION DATE: 12/31/2016

SECTION: 6C **TOWNSHIP:** 20S **RANGE:** 15E

EQUIPMENT DESCRIPTION:

58.5 MMBTU/HR STRUTHERS THERMOFLOOD (SG 6-37) MODELOH50-ND-16XAM NATURAL GAS/LPG/TEOR GAS (COMMON TO C-311-37, SG 25-19) FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL MAGNA FLAME GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. This unit shall be fired exclusively with natural gas, LPG, or TEOR gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Total fuel consumption shall not exceed 1,404 MMBtu/day nor 434,700 MMBtu/year. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The permittee shall install and maintain a non-resettable, totalizing mass or volumetric flow meter in each fuel line to the boiler. [District NSR Rule] Federally Enforceable Through Title V Permit
4. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
6. Emissions of sulfur compounds from this unit shall not exceed 200 lb/hr, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6; or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or a grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD or double GC for H₂S and mercaptans performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. Nitrogen oxide (NO_x) emissions shall not exceed 140 lb/hr, calculated as NO₂. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
11. Except during start-up and shutdown, emissions from this steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, 0.043 lb-SO_x/MMBtu, 0.00675 lb-PM10/MMBtu, 50 ppmvd CO @ 3% O₂ or 0.037 lb-CO/MMBtu, or 0.00855 lb-VOC/MMBtu. [District NSR Rule and District Rule 4306, 5.1] Federally Enforceable Through Title V Permit
12. During start-up and shutdown, emissions from this steam generator shall not exceed any of the following limits: 0.1 lb-NO_x/MMBtu, 0.043 lb-SO_x/MMBtu, 0.00675 lb-PM10/MMBtu, 0.084 lb-CO/MMBtu, or 0.00855 lb-VOC/MMBtu. [District NSR Rule and District Rule 4306, 5.1] Federally Enforceable Through Title V Permit
13. Maximum emissions from this steam generator, including start-up and shutdown operation, shall not exceed any of the following limits: 50.5 lb-NO_x in any one day, 7,825 lb-NO_x in any calendar year, 66.4 lb-CO in any one day, or 16,084 lb-CO in any calendar year. [District NSR Rule] Federally Enforceable Through Title V Permit
14. Start-up is defined as that period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as that period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.22, 3.25] Federally Enforceable Through Title V Permit
15. The duration of each start-up or each shutdown shall not exceed two hours per occurrence. The emission control system shall be in operation and emissions shall be minimized insofar as technologically feasible during start-up or shutdown. The operator shall maintain daily records of the number and duration of start-up and shutdown periods. [District Rule 4306, 5.3] Federally Enforceable Through Title V Permit
16. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306, 6.3] Federally Enforceable Through Title V Permit
17. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
18. NO_x, and CO emissions shall be measured with source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1 and 4306, 5.5.1] Federally Enforceable Through Title V Permit
20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
21. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. The results of each source test shall be submitted to the District within 60 days after completion of the test. [District Rule 1081] Federally Enforceable Through Title V Permit
24. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305 and 4306, 6.2] Federally Enforceable Through Title V Permit
25. CO emissions for source test purposes shall be determined using EPA Method 10, 10B, or ARB Method 100. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
26. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306, 6.2] Federally Enforceable Through Title V Permit
27. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
28. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
29. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
31. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
32. Natural gas or LPG sulfur content and higher heating value (hhv) shall be certified by a third party fuel supplier of each fuel source; or natural gas or LPG shall be tested for sulfur content and higher heating value (hhv) monthly. Casing gas shall be tested for sulfur content and higher heating value (hhv) not less than monthly. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Permittee shall record daily natural gas, casing gas, and propane consumption. Records shall be provided to the District upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
34. Permittee shall maintain records of higher heating value (hhv), in MMBtu/scf, for each gaseous fuel used in this operation. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

35. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
37. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rules 1081 (Amended December 16, 1993), 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
38. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
39. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
40. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
41. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.