



MAR 07 2013

Gerardo C. Rios, Chief  
Permits Office  
Air Division  
U.S. EPA - Region IX  
75 Hawthorne St  
San Francisco, CA 94105

Re: **Notice of Minor Title V Permit Modification**  
**District Facility # S-382**  
**Project # S-1121914**


Dear Mr. Rios:

Enclosed for you to review is an application for minor Title V permit modification for the facility identified above. Occidental of Elk Hills is proposing a Title V minor permit modification to incorporate the recently issued Authority to Construct S-382-422-8 into the Title V operating permit. The ATC allows a 310 BHP Cummins diesel-fired standby IC engine to be designated as compliant dormant.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued Authority to Construct S-382-422-8, emission increases and application. Please submit your written comments on this project within the 45-day comment-period that begins on the date you receive this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura at (661) 392-5500.

Sincerely,



David Warner  
Director of Permit Services

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



MAR 07 2013

Raymond Rodriguez  
Occidental of Elk Hills  
10800 Stockdale Hwy  
Bakersfield, CA 93311

**Re: Notice of Minor Title V Permit Modification  
District Facility # S-382  
Project # S-1121914**

Dear Mr. Rodriguez:

Enclosed is the District's analysis of your application for minor Title V permit modification for the facility identified above. You proposed a Title V minor permit modification to incorporate recently issued Authority to Construct S-382-422-8 into the Title V operating permit. The ATC allows a 310 BHP Cummins diesel-fired standby IC engine to be designated as compliant dormant.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued Authority to Construct S-382-422-8, emission increases and application. This project will be subject to a 45-day EPA commenting period prior to the District taking final action.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura at (661) 392-5500.

Sincerely,



David Warner

Director of Permit Services

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

# TITLE V APPLICATION REVIEW

Minor Modification  
Project #: S-1121914

Engineer: Robert Rinaldi  
Date: March 4, 2013

Facility Number: S-382  
Facility Name: Occidental of Elk Hills  
Mailing Address: 10800 Stockdale Hwy  
Bakersfield, CA 93311

*Reviewed by ASURE AQE*  
MAR 05 2013

Contact Name: Raymond Rodriguez  
Phone: (661) 412-5263

Responsible Official: Armando Gonzalez  
Title: HES Manager

---

## I. PROPOSAL

Occidental of Elk Hills is proposing a Title V minor permit modification to incorporate the recently issued ATC S-382-422-8 into the Title V operating permit for allowing a 310 BHP Cummins diesel-fired standby IC engine to be designated as compliant dormant.

The purpose of this evaluation is to identify all applicable requirements, determine if the facility will comply with the applicable requirements and to provide the legal and factual basis for the proposed revisions.

## II. FACILITY LOCATION

Light Oil Western Source at Elk Hills (Elk Hills Oil & Gas Field). The I.C. Engine is permitted to operate within any site of facility S-382 except within 1000' of a K-12<sup>th</sup> grade school.

### III. EQUIPMENT DESCRIPTION

#### S-382-422-8:

MODIFICATION OF 310 BHP CUMMINS DIESEL-FIRED STANDBY IC ENGINE (P1, UNX# 53262): ALLOW DESIGNATION OF IC ENGINE AS COMPLIANT DORMANT

### IV. SCOPE OF EPA AND PUBLIC REVIEW

This change to a Title V permit is considered to be a minor modification and, as such, requires no public review.

### V. APPLICABLE REQUIREMENTS

District Rule 2520, Federally Mandated Operating Permits (Adopted June 21, 2001)

### VI. DESCRIPTION OF PROPOSED MODIFICATIONS

1. {4561} While dormant, the fuel line shall be physically disconnected from the unit. (Adjust as necessary) [District Rule 2080] ~~N~~ Y
2. {4562} Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] ~~N~~ Y
3. {4565} Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] N

## VII. COMPLIANCE

In accordance with Rule 2520, 3.20, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;
2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;
3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;
4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include:
  - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
  - b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
6. Do not seek to consolidate overlapping applicable requirements.

In accordance with Rule 2520, the application meets the procedural requirements of section 11.4 by including;

1. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
2. The source's suggested draft permit; and
3. Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used.

## **VIII. ATTACHMENTS**

- A. Proposed Title V Operating Permit
- B. Existing Title V Permit
- C. Authority to Construct
- D. Emissions Increases
- E. Application
- F. Compliance Certification Form

# ATTACHMENT A

Proposed Modified Title V Operating Permit No.  
(S-382-422-10)

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-382-422-10

**EXPIRATION DATE:** 10/31/2016

**EQUIPMENT DESCRIPTION:**

MODIFICATION OF 310 BHP CUMMINS DIESEL-FIRED EMERGENCY STANDBY IC ENGINE (P1, UNX# 53262):

## PERMIT UNIT REQUIREMENTS

---

1. While dormant, the fuel line shall be physically disconnected from the unit. (Adjust as necessary) [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. {4565} Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
4. Approved locations for this equipment: any site within facility S-382. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The IC engine shall not operate within 1000' of K-12th grade school [CH&SC 42301.6]
6. The operator shall notify the District in writing at least two weeks prior to starting operations at a new location. [District NSR Rule] Federally Enforceable Through Title V Permit
7. {824} Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
8. {840} Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
9. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
11. This engine shall be operated using only CARB certified diesel fuel. [17 CCR 93115 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rules 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
13. During periods of maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (e.g. oil pressure, exhaust gas temperature, etc.). [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

14. The permittee shall maintain records of hours of emergency and non-emergency operation. Records shall include the date, the initial start-up hours, the number of hours of operation, the purpose of the operation (e.g., load testing, weekly testing, rolling blackout, general area power outage, etc.), and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
15. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
16. {839} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements of SJVUAPCD Rule 4201; Rules 406 (Fresno), 404 (Madera), 407 (Kern, Kings, San Joaquin, Stanislaus, Merced, Tulare). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. {834} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rules 402 (Madera) and 404 (Fresno, Merced, Kern, Kings, San Joaquin, Stanislaus, Tulare). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

# ATTACHMENT B

Existing Title V Permit  
(S-382-422-7)

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-382-422-7

**EXPIRATION DATE:** 10/31/2016

**EQUIPMENT DESCRIPTION:**

310 BHP CUMMINS DIESEL-FIRED EMERGENCY STANDBY IC ENGINE (P1, UNX# 53262)

## PERMIT UNIT REQUIREMENTS

---

1. Approved locations for this equipment: any site within facility S-382. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The operator shall notify the District in writing at least two weeks prior to starting operations at a new location. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
4. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
5. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
7. This engine shall be operated using only CARB certified diesel fuel. [17 CCR 93115 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
8. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rules 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. During periods of maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (e.g. oil pressure, exhaust gas temperature, etc.). [District Rule 4702] Federally Enforceable Through Title V Permit
10. The permittee shall maintain records of hours of emergency and non-emergency operation. Records shall include the date, the initial start-up hours, the number of hours of operation, the purpose of the operation (e.g., load testing, weekly testing, rolling blackout, general area power outage, etc.), and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements of SJVUAPCD Rule 4201; Rules 406 (Fresno), 404 (Madera), 407 (Kern, Kings, San Joaquin, Stanislaus, Merced, Tulare). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rules 402 (Madera) and 404 (Fresno, Merced, Kern, Kings, San Joaquin, Stanislaus, Tulare). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# ATTACHMENT C

Authority to Construct No.  
(S-382-422-8)



## AUTHORITY TO CONSTRUCT

**PERMIT NO:** S-382-422-8

**ISSUANCE DATE:** 05/04/2011

**LEGAL OWNER OR OPERATOR:** OCCIDENTAL OF ELK HILLS INC  
**MAILING ADDRESS:** 10800 STOCKDALE HIGHWAY  
BAKERSFIELD, CA 93311

**LOCATION:** LIGHT OIL WESTERN STATIONARY SOURCE  
KERN COUNTY, CA

**EQUIPMENT DESCRIPTION:**  
MODIFICATION OF 310 BHP CUMMINS DIESEL-FIRED STANDBY IC ENGINE (P1, UNX# 53262): ALLOW DESIGNATION OF IC ENGINE AS COMPLIANT DORMANT

### CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. No modification to this unit shall be performed without an Authority to Construct for such modifications, except for changes specified in the conditions below. [District Rule 2010]
3. Upon seven days prior written notice to the District, this unit may be designated as a dormant emissions unit or an active emissions unit. [District Rule 2080]
4. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080]
5. While dormant, normal source testing and monitoring shall not be required. [District Rule 2080]
6. Upon recommencing operation of this unit, normal monitoring shall resume. [District Rule 2080]
7. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080]
8. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

9. If this unit has become dormant because it does not comply with District Rules, or if the unit becomes out of compliance with District Rules while it is dormant, operation of the unit is not authorized until an Authority to Construct permit is issued approving all necessary retrofits and permit changes required to comply with the respective District Rules. [District Rule 2010]
10. Approved locations for this equipment: any site within facility S-382. [District NSR Rule] Federally Enforceable Through Title V Permit
11. The IC engine shall not operate within 1000' of K-12th grade school [CH&SC 42301.6]
12. The operator shall notify the District in writing at least two weeks prior to starting operations at a new location. [District NSR Rule] Federally Enforceable Through Title V Permit
13. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
14. Particulate emissions shall not exceed at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
15. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
16. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
17. This engine shall be operated using only CARB certified diesel fuel. [17 CCR 93115 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
18. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rules 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
19. During periods of maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (e.g. oil pressure, exhaust gas temperature, etc.). [District Rule 4702] Federally Enforceable Through Title V Permit
20. The permittee shall maintain records of hours of emergency and non-emergency operation. Records shall include the date, the initial start-up hours, the number of hours of operation, the purpose of the operation (e.g., load testing, weekly testing, rolling blackout, general area power outage, etc.), and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
21. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
22. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements of SJVUAPCD Rule 4201; Rules 406 (Fresno), 404 (Madera), 407 (Kern, Kings, San Joaquin, Stanislaus, Merced, Tulare). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
23. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rules 402 (Madera) and 404 (Fresno, Merced, Kern, Kings, San Joaquin, Stanislaus, Tulare). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

# ATTACHMENT D

Emissions Increases

	SSIPE (lb/yr)				
	NOx	VOC	CO	SOx	PM10
S-382-422-8	0	0	0	0	0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

# ATTACHMENT E

Application

5-382-422-10

# San Joaquin Valley Air Pollution Control District

[www.valleyair.org](http://www.valleyair.org)

RECEIVED  
JUN 04 2012  
SJVAPCD  
Southern Region

## Permit Application For:

[ ] ADMINISTRATIVE AMENDMENT    [X] MINOR MODIFICATION    [ ] SIGNIFICANT MODIFICATION

1. PERMIT TO BE ISSUED TO: Occidental of Elk Hills, Inc	
2. MAILING ADDRESS: STREET/P.O. BOX: 10800 Stockdale Hwy CITY: Bakersfield STATE: CA 9-DIGIT ZIP CODE: 93311	
3. LOCATION WHERE THE EQUIPMENT WILL BE OPERATED: STREET: Elk Hills CITY: Tupman ¼ SECTION TOWNSHIP RANGE	INSTALLATION DATE:
4. GENERAL NATURE OF BUSINESS: Oil and Natural Gas Production	
5. DESCRIPTION OF EQUIPMENT OR MODIFICATION FOR WHICH APPLICATION IS MADE (include Permit #'s if known, and use additional sheets if necessary)  Incorporate the following ATC into S-382 Title V Permit: S-382-422-8	
6. TYPE OR PRINT NAME OF APPLICANT: Raymond Rodriguez	TITLE OF APPLICANT: Sr. Environmental Advisor
7. SIGNATURE OF APPLICANT: 	DATE: 5/31/2012 PHONE: (661) 412-5263 FAX: (661) 412-5270 EMAIL: Raymond_rodriguez@oxy.com

**For APCD Use Only:**

Vector

DATE STAMP	FILING FEE RECEIVED: \$ 71.00	CHECK#: 9774
	DATE PAID: 6-4-12 PM	
	PROJECT NO: S-1121914	FACILITY ID: S-382

TV MM

DRR

# ATTACHMENT F

Compliance Certification Form

San Joaquin Valley  
Unified Air Pollution Control District

RECEIVED  
JUN 04 2012  
SJVAPCD  
Southern Region

TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)

- SIGNIFICANT PERMIT MODIFICATION                       ADMINISTRATIVE AMENDMENT  
 MINOR PERMIT MODIFICATION

COMPANY NAME: Occidental of Elk Hills, Inc	FACILITY ID: S - 382
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: Occidental of Elk Hills, Inc	
3. Agent to the Owner: Occidental of Elk Hills, Inc.	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial **all** circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

  
Signature of Responsible Official

6/4/2012  
Date

Armando Gonzalez  
Name of Responsible Official (please print)  
Health, Environmental, Safety & Security Manager  
Title of Responsible Official (please print)