



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT

SEP 12 2012

Gerardo C. Rios, Chief
Permits Office
Air Division
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

Re: **Notice of Minor Title V Permit Modification**
District Facility # S-511
Project # S-1122870

Dear Mr. Rios:

Enclosed for you to review is an application for minor Title V permit modification for the facility identified above. Sycamore Cogeneration Company is proposing a Title V minor permit modification to incorporate the recently issued S-511-1-16, '2-17, '3-17, and '4-16 into the Title V operating permit. These ATC's authorized a specific limiting condition to limit the combined annual NOx emissions from all four turbines.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued S-511-1-16, '2-17, '3-17, and '4-16, emission increases, application, and previous Title V permit. Please submit your written comments on this project within the 45-day comment period that begins on the date you receive this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura at (661) 392-5500.

Sincerely,

David Warner
Director of Permit Services

Enclosures

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061
www.valleyair.org

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT

SEP 12 2012

Neil Burgess
Sycamore Cogeneration Company
PO Box 80598
Bakersfield, CA 93380

**Re: Notice of Minor Title V Permit Modification
District Facility # S-511
Project # S-1122870**

Dear Mr. Burgess:

Enclosed is the District's analysis of your application for minor Title V permit modification for the facility identified above. You proposed a Title V minor permit modification to incorporate recently issued S-511-1-16, '-2-17, '-3-17, and '-4-16 into the Title V operating permit. These ATC's authorized a specific limiting condition to limit the combined annual NOx emissions from all four turbines.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued S-511-1-16, '-2-17, '-3-17, and '-4-16, emission increases, application, and previous Title V permit. This project will be subject to a 45-day EPA commenting period prior to the District taking final action.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura at (661) 392-5500.

Sincerely,

David Warner
Director of Permit Services

Enclosures

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061
www.valleyair.org

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

TITLE V APPLICATION REVIEW

Minor Modification
Project #: S-1122870

Engineer: Dan Klevann
Date: August 30, 2012

Facility Number: S-511
Facility Name: Sycamore Cogeneration Company
Mailing Address: P O Box 80598
Bakersfield, CA 93380

Reviewed by AP SUPP AQE

SEP 10 2012

Contact Name: Neil Burgess
Phone: 661-615-4630

Responsible Official: Neil Burgess
Title: Executive Director

I. PROPOSAL

Sycamore Cogeneration Company (Sycamore) is proposing a Title V minor permit modification to incorporate the recently issued Authorities to Construct (ATC) S-511-1-16, S-511-2-17, S-511-3-17, and S-511-4-16 into the Title V operating permit. These ATC's authorized a specific limiting condition to limit the combined annual NOx emissions from all four turbines.

The purpose of this evaluation is to identify all applicable requirements, determine if the facility will comply with the applicable requirements and to provide the legal and factual basis for the proposed revisions.

II. FACILITY LOCATION

Sycamore Cogeneration Company is located within the Heavy Oil Central Stationary Source in Kern County, CA (North 1/2 of Section 31, Township 28 South, Range 28 East).

III. EQUIPMENT DESCRIPTION

S-511-1-17: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY

DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #1)

S-511-2-18: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #2)

S-511-3-18: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #3)

S-511-4-17: 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #4)

IV. SCOPE OF EPA AND PUBLIC REVIEW

This change to a Title V permit is considered to be a minor modification and, as such, requires no public review.

V. APPLICABLE REQUIREMENTS

District Rule 2520, Federally Mandated Operating Permits (Adopted June 21, 2001)

VI. DESCRIPTION OF PROPOSED MODIFICATIONS

Sycamore is proposing the permanent reduction in operational capability of the turbines S-511-1, '-2, '-3, and '-4. The reduced operation is being driven by a reduced demand for steam for thermally enhanced oil recovery in the nearby oilfields and the reduced demand for electrical power by the utility.

There are no emission increases associated with the proposed modifications.

Condition changes:

S-511-1-17:

Condition 10 was added to the permit. This condition places an annual NOx emission limit on the four turbines.

S-511-2-18:

Condition 10 was added to the permit. This condition places an annual NOx emission limit on the four turbines.

S-511-3-18:

Condition 10 was added to the permit. This condition places an annual NOx emission limit on the four turbines.

S-511-4-17:

Condition 10 was added to the permit. This condition places an annual NOx emission limit on the four turbines.

VII. COMPLIANCE

In accordance with Rule 2520, 3.20, these modifications:

1. Do not violate requirements of any applicable federally enforceable local or federal requirement;
2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions;
3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;

4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include;
 - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
 - b. An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
5. Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
6. Do not seek to consolidate overlapping applicable requirements.

In accordance with Rule 2520, the application meets the procedural requirements of section 11.4 by including;

1. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
2. The source's suggested draft permit; and
3. Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used.

VIII. ATTACHMENTS

- A. Proposed Modified Title V Operating Permit No. S-511-1-17, -2-18, -3-18, and -4-17
- B. Authorities to Construct No. S-511-1-16, -2-17, -3-17, and -4-16
- C. Application
- D. Previous Title V Operating Permit No.'s S-511-1-15, -2-16, -3-16, and -4-15

ATTACHMENT A

Proposed Modified Title V Operating Permit No.
(S-511-1-17, -2-18, -3-18, and -4-17)

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-1-17

EXPIRATION DATE: 11/30/2015

SECTION: 31 TOWNSHIP: 28S RANGE: 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #1)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
9. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
12. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
13. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
14. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
15. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
17. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
18. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
19. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
20. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
21. {2270} All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
22. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
23. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
25. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
26. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
28. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
30. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
31. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
32. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
34. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
35. {2250} The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
36. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
37. {2272} Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

38. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
39. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
40. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 or CO2 concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
41. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
42. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
43. Daily records of NO2 and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
44. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
45. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
46. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
47. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
48. {2254} APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
49. {2251} The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
50. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
51. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
52. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

53. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
54. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
55. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
56. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
57. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
59. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
60. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
61. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
63. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
64. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
65. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

66. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
67. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
68. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
70. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
73. {2282} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-2-18

EXPIRATION DATE: 11/30/2015

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #2)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
9. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
12. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
13. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
14. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NO_x performance test nor shall NO_x emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
15. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
17. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
18. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
19. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
20. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
21. {2270} All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
22. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
23. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
25. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
26. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
28. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
30. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
31. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
32. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
34. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
35. {2250} The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
36. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
37. {2272} Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

38. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
39. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
40. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 or CO2 concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
41. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
42. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
43. Daily records of NO2 and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
44. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
45. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
46. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
47. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
48. {2254} APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
49. {2251} The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
50. When CGT exhausts to bypass stack, the CEM probe located in the transition section shall be used to measure exhaust gas NOx, CO and O2 or CO2 concentration. [District Rule 2201] Federally Enforceable Through Title V Permit
51. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
52. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
53. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

54. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
55. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
56. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
57. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
59. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
60. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
61. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
64. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
65. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
66. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

67. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
68. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
71. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
74. {2282} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-3-18

EXPIRATION DATE: 11/30/2015

SECTION: NW30 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #3)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
9. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
10. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
12. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
13. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
14. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
15. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
17. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
18. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
19. When CGT exhausts to bypass stack, the CEM probe located in the transition section shall be used to measure exhaust gas NOx, CO and O2 or CO2 concentration. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
21. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
22. {2270} All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
23. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
26. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
27. Source testing to determine NO_x and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The owner or operator shall provide source test information annually regarding the exhaust gas NO_x and CO concentration corrected to 15% O₂ (dry). EPA Methods 7E or 20 shall be used for NO_x emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
29. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
30. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
31. The operator shall perform source testing for PM₁₀ concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
32. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
34. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
35. Continuous emission monitoring system for NO_x as NO₂ and continuous monitoring system for CO & CO₂ shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
36. {2250} The continuous NO_x and O₂ monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
37. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

38. {2272} Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
39. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
40. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
41. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
42. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
43. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
44. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
45. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
46. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
47. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
48. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
49. {2254} APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
50. {2251} The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
51. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
52. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

53. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit
54. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
55. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
56. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
57. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
59. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
60. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
61. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
62. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
64. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
65. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

66. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
67. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
68. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
69. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
72. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
74. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
75. {2282} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-4-17

EXPIRATION DATE: 11/30/2015

SECTION: NW30 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #4)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
9. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
12. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
13. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
14. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
15. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
17. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
18. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
19. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
20. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
21. {2270} All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
22. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
23. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
25. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
26. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
28. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
30. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
31. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
32. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
34. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
35. {2250} The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
36. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
37. {2272} Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

38. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
39. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
40. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 or CO2 concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
41. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
42. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
43. Daily records of NO2 and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
44. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
45. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
46. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
47. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
48. {2254} APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
49. {2251} The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
50. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
51. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
52. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

53. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
54. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
55. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
56. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
57. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
59. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
60. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
61. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
63. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
64. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
65. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

66. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
67. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
68. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
73. {2282} Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

ATTACHMENT B

Authorities to Construct No.
(S-511-1-16, -2-17, -3-17, and -4-16)

AUTHORITY TO CONSTRUCT

PERMIT NO: S-511-1-16

ISSUANCE DATE: 06/13/2012

LEGAL OWNER OR OPERATOR: SYCAMORE COGENERATION CO

MAILING ADDRESS: PO BOX 80598
BAKERSFIELD, CA 93380

LOCATION: HEAVY OIL CENTRAL
CA

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #1): ADD NOX SLC WITH -1, -2, -3, -4

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. ATC S-511-1-15 shall be implemented prior to or concurrently with this ATC. [District Rule 2201]
3. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
4. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
6. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

7. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
9. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
10. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
11. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
14. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
15. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
16. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
17. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
19. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
20. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
21. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
23. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
24. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
25. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
27. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
28. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
30. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
31. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
32. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
33. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
34. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
35. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

36. Continuous emission monitoring system for NO_x as NO₂ and continuous monitoring system for CO & CO₂ shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
37. The continuous NO_x and O₂ monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
38. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
39. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
40. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
41. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
42. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
43. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
44. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
45. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
46. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
47. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
48. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
49. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

50. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
51. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
52. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
53. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
54. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit
55. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
56. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
57. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
58. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
59. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
60. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
61. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
62. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

64. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
65. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
66. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
67. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
68. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
69. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
72. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
74. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
75. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

AUTHORITY TO CONSTRUCT

PERMIT NO: S-511-2-17

ISSUANCE DATE: 06/13/2012

LEGAL OWNER OR OPERATOR: SYCAMORE COGENERATION CO

MAILING ADDRESS: PO BOX 80598
BAKERSFIELD, CA 93380

LOCATION: HEAVY OIL CENTRAL
CA

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #2): ADD NOX SLC WITH -1, -2, -3, -4

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. ATC S-511-2-16 shall be implemented prior to or concurrently with this ATC. [District Rule 2201]
3. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
4. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
6. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

7. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
9. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
10. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
11. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
14. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
15. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
16. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
17. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
19. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
20. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
21. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
23. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
24. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
25. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
27. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
28. Source testing to determine NO_x and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the exhaust gas NO_x and CO concentration corrected to 15% O₂ (dry). EPA Methods 7E or 20 shall be used for NO_x emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
30. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
31. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
32. The operator shall perform source testing for PM₁₀ concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
33. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
34. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
35. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

36. Continuous emission monitoring system for NO_x as NO₂ and continuous monitoring system for CO & CO₂ shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
37. The continuous NO_x and O₂ monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
38. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
39. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
40. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
41. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
42. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
43. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
44. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
45. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
46. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
47. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
48. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
49. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

50. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
51. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
52. When CGT exhausts to bypass stack, the CEM probe located in the transition section shall be used to measure exhaust gas NO_x, CO and O₂ or CO₂ concentration. [District Rule 2201] Federally Enforceable Through Title V Permit
53. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
54. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
55. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit
56. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
57. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
58. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
59. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
60. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
61. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
62. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
63. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

64. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
65. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
66. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
67. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
68. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
69. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
70. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
72. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
73. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
74. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
75. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
76. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-511-3-17

ISSUANCE DATE: 06/13/2012

LEGAL OWNER OR OPERATOR: SYCAMORE COGENERATION CO

MAILING ADDRESS: PO BOX 80598
BAKERSFIELD, CA 93380

LOCATION: HEAVY OIL CENTRAL
CA

SECTION: NW30 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #3): ADD NOX SLC WITH -1, -2, -3, -4

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. ATC S-511-3-16 shall be implemented prior to or concurrently with this ATC. [District Rule 2201]
3. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
4. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
6. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

7. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
10. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
11. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
12. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
14. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
15. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
16. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
17. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
19. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
20. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
21. When CGT exhausts to bypass stack, the CEM probe located in the transition section shall be used to measure exhaust gas NOx, CO and O2 or CO2 concentration. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

23. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
24. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
25. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
26. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
28. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
29. Source testing to determine NO_x and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
30. The owner or operator shall provide source test information annually regarding the exhaust gas NO_x and CO concentration corrected to 15% O₂ (dry). EPA Methods 7E or 20 shall be used for NO_x emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
31. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
32. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
33. The operator shall perform source testing for PM₁₀ concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
34. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
35. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
36. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

37. Continuous emission monitoring system for NO_x as NO₂ and continuous monitoring system for CO & CO₂ shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
38. The continuous NO_x and O₂ monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
39. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
40. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
41. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
42. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
43. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration. [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
44. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
45. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
46. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
47. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
48. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
49. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
50. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

51. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
52. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
53. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
54. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
55. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit
56. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
57. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
58. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
59. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
60. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
61. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
62. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
63. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
64. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

65. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
66. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
67. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
68. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
69. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
70. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
71. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
72. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
73. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
74. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
75. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
76. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
77. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-511-4-16

ISSUANCE DATE: 06/13/2012

LEGAL OWNER OR OPERATOR: SYCAMORE COGENERATION CO

MAILING ADDRESS: PO BOX 80598
BAKERSFIELD, CA 93380

LOCATION: HEAVY OIL CENTRAL
CA

SECTION: NW30 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #4): ADD NOX SLC WITH -1, -2, -3, -4

CONDITIONS

1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. ATC S-511-4-15 shall be implemented prior to or concurrently with this ATC. [District Rule 2201]
3. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
4. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
5. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
6. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

7. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
9. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
10. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
11. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Annual NOx emissions (as NO2) from all four CTG's (S-511-1, S-511-2, S-511-3, and S-511-4) calculated on a twelve month rolling basis shall not exceed 271,200 lb NOx / yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit
14. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
15. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
16. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
17. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
19. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
20. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
21. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
23. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
24. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
25. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
27. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
28. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
30. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
31. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
32. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
33. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
34. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
35. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

36. Continuous emission monitoring system for NO_x as NO₂ and continuous monitoring system for CO & CO₂ shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
37. The continuous NO_x and O₂ monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
38. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
39. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
40. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
41. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
42. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
43. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
44. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
45. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
46. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
47. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
48. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
49. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

50. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
51. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
52. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
53. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
54. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit
55. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
56. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
57. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
58. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
59. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
60. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
61. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
62. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

64. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
65. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
66. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
67. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
68. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
69. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
72. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
74. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
75. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

ATTACHMENT C

Application

ATTACHMENT D

Previous Title V Operating Permit No.'s
S-511-1-15, -2-16, -3-16, and -4-15

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-1-15

EXPIRATION DATE: 11/30/2015

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #1)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O₂. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO₂. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM₁₀ - 5.0 lb/hr, SO_x (as SO₂) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM₁₀ - 120.0 lb/day, SO_x (as SO₂) - 21.6 lb/day, NO_x (as NO₂) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NO_x (as NO₂) - 3 ppmvd @ 15% O₂, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O₂, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. NO₂ and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
9. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NO_x on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
12. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
13. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
14. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
15. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
16. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
17. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
19. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
20. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
21. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
22. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
24. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
27. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
28. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
29. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
30. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
31. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
32. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
33. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
34. The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
35. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
36. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
37. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
38. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

39. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 or CO2 concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
40. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
41. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
42. Daily records of NO2 and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
43. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
44. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
45. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
46. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
47. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
48. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
49. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
50. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
51. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit
52. Accurate records of NOx (as NO2) and carbon monoxide (CO) flue gas concentrations corrected to 15% O2, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
53. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
54. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

55. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
56. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
57. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
58. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
59. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
60. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
61. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
62. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
63. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
64. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
65. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
66. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
67. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

68. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
69. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
71. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-2-16

EXPIRATION DATE: 11/30/2015

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #2)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
9. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
12. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
13. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
14. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
15. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
16. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
17. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
19. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
20. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
21. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
22. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
24. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
27. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
28. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
29. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
30. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
31. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
32. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
33. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
34. The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
35. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
36. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
37. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
38. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

39. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 or CO2 concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
40. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
41. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
42. Daily records of NO2 and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
43. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
44. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
45. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
46. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
47. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
48. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
49. When CGT exhausts to bypass stack, the CEM probe located in the transition section shall be used to measure exhaust gas NOx, CO and O2 or CO2 concentration. [District Rule 2201] Federally Enforceable Through Title V Permit
50. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
51. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
52. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit
53. Accurate records of NOx (as NO2) and carbon monoxide (CO) flue gas concentrations corrected to 15% O2, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
54. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

55. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
56. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
57. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
59. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
60. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
61. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
63. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
64. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
65. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
66. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
67. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

68. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
70. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-3-16

EXPIRATION DATE: 11/30/2015

SECTION: NW30 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #3)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O2. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO2. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM10 - 5.0 lb/hr, SOx (as SO2) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM10 - 120.0 lb/day, SOx (as SO2) - 21.6 lb/day, NOx (as NO2) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NOx (as NO2) - 3 ppmvd @ 15% O2, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O2, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NOx on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
9. NO2 and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
10. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
12. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
13. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
14. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
15. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
16. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
17. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
18. When CGT exhausts to bypass stack, the CEM probe located in the transition section shall be used to measure exhaust gas NOx, CO and O2 or CO2 concentration. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
20. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
21. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
22. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
23. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit
26. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
28. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
29. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
30. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
31. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
32. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
33. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
34. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
35. The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
36. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
37. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
38. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

39. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
40. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ or CO₂ concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
41. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
42. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
43. Daily records of NO₂ and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
44. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
45. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
46. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
47. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
48. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
49. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
50. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
51. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
52. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit
53. Accurate records of NO_x (as NO₂) and carbon monoxide (CO) flue gas concentrations corrected to 15% O₂, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
54. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

55. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit
56. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
57. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
58. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
59. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
60. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
61. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
62. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
63. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
64. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
65. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
66. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
67. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

68. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
69. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
71. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
73. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
74. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-511-4-15

EXPIRATION DATE: 11/30/2015

SECTION: NW30 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

75 MW GENERAL ELECTRIC MODEL 7EA NATURAL GAS-FIRED COMBUSTION TURBINE COGENERATION UNIT WITH GE ENHANCED DRY LOW NOX DLN1+ COMBUSTOR TECHNOLOGY DISCHARGING TO ATMOSPHERE THROUGH A BYPASS STACK WHEN OPERATED IN SIMPLE CYCLE MODE OR THROUGH UNFIRED 450,000 LB/HR HEAT RECOVERY STEAM GENERATOR WHEN OPERATED IN COGENERATION MODE (SYCAMORE UNIT #4)

PERMIT UNIT REQUIREMENTS

1. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
2. The CGT combustors shall be a dry low NOx design capable of achieving 3 ppm or lower at 15% O₂. [PSD SJ 85-09, X.B] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
4. Exhaust gas particulate matter concentration shall not exceed 0.0072 gr/scf calculated at 12% CO₂. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emission rates from CGT shall not exceed any of the following: PM₁₀ - 5.0 lb/hr, SO_x (as SO₂) - 0.9 lb/hr, or VOC - 2.5 lb/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emission rates from CGT shall not exceed any of the following: PM₁₀ - 120.0 lb/day, SO_x (as SO₂) - 21.6 lb/day, NO_x (as NO₂) - 552.8 lb/day, VOC - 60.0 lb/day, or CO - 1056.0 lb/day. [District Rule 2201 and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
7. Emission rates from CGT, except during startup, shutdown, tuning start-up, and/or reduced load periods, shall not exceed any of the following: NO_x (as NO₂) - 3 ppmvd @ 15% O₂, 12.4 lb/hr on a 3-hr avg, or CO - 25 ppmvd @ 15% O₂, 44.0 lb/hr on a 3-hr avg. [District Rules 2201 and 4703, 5.1.2 & 5.2; and PSD SJ 85-09, X.E] Federally Enforceable Through Title V Permit
8. NO₂ and CO daily emissions during days of startup/shutdown shall be calculated from natural gas combustion rates and CEM results. [District Rule 1080] Federally Enforceable Through Title V Permit
9. During startup, shutdown, and tuning start-up, emissions shall not exceed any of the following: 140.0 lb/hr of NO_x on a 2-hr avg, 140 lb/hr of CO on a 2-hr avg, or 200 lb/hr of CO on a 1-hr avg. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.29 and 3.26] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. A tuning start-up shall be defined as "the period after a combustor unit replacement in which dynamic performance testing and corresponding operating optimization set point adjustment of the combustion system of the CGT is performed to meet the limits of this permit and Rule 4703". A tuning start-up period shall not exceed a time period of 12 consecutive hours per occurrence. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
12. The duration of each startup or each shut down time shall not exceed two hours. Startup and shutdown emissions shall be counted toward all applicable emission limits. [District Rule 4703, 5.3.1] Federally Enforceable Through Title V Permit
13. Operations during periods of startup, shutdown, and tuning startup shall not constitute representative conditions for the purpose of a NOx performance test nor shall NOx emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
14. Each CGT shall have a maximum heat input rate of 1020 MMBTU/hr on an LHV basis. Firing rate can be increased upon District witnessed emission sampling demonstration that compliance with emission sampling limits can be achieved at higher fuel rates. [District NSR Rule] Federally Enforceable Through Title V Permit
15. Permit unit shall include one unfired heat recovery steam generator (HRSG) for gas turbine engine assembly with rated steam output of 450,000 lb/hr at 80% quality steam production. [District NSR Rule] Federally Enforceable Through Title V Permit
16. CGT may exhaust either through unfired 450,000 lb/hr heat recovery steam generator or through bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
17. When operating in cogeneration mode, exhaust gas ducting from CGT's through HRSG's to the atmosphere shall be gas-tight. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Bypass stack valve preceding each HRSG shall be designed to be gas-tight to the atmosphere when exhaust is discharged through HRSG and shall be designed to be gas-tight to the HRSG when exhaust is discharged through the bypass stack. [District NSR Rule] Federally Enforceable Through Title V Permit
19. At such times as specified by the USEPA, permittee shall conduct or cause to be conducted performance tests (as described in 40 CFR 60.8) for CO on the exhaust stack gases and furnish the District, the California ARB and the USEPA a written report of the results of such tests. All performance tests shall be conducted on an annual basis and at the maximum operating capacity of the emissions unit being tested. Upon written request from permittee, and adequate justification, USEPA may waive a specific annual test and/or allow for testing to be done at less than maximum operating capacity. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
20. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b)] Federally Enforceable Through Title V Permit
21. The USEPA shall be notified in writing at least 30 days in advance of such test to allow time for development of an approvable performance test plan and to arrange for an observer to be present at the test. Such prior approval shall minimize the possibility of USEPA rejection of test results for procedural deficiencies. In lieu of the above mentioned test methods, equivalent methods may be used with prior written approval from the USEPA. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
22. Annual compliance tests shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Operator shall conform with the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
24. For performance test purposes, sampling ports, platforms, and access shall be provided by the facility on the emission unit exhaust system in accordance with 40 CFR 60.8(e). [PSD SJ 85-09] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Source testing to determine NOx and CO emissions and fuel gas sulfur content shall be conducted annually. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The owner or operator shall provide source test information annually regarding the exhaust gas NOx and CO concentration corrected to 15% O2 (dry). EPA Methods 7E or 20 shall be used for NOx emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a), 40 CFR 60.335(b) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
27. Performance tests for the emissions of CO shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60.8 and 40 CFR 60, Appendix A. The performance tests for the emissions of CO shall be conducted using EPA Methods 1 through 4 and 10. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
28. The owner or operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703 (as amended 9/20/07), 5.1.1 and 6.4.6. [40 CFR 60.332(a) and (b) and District Rule 4703, 5.1.1 and 6.4.6] Federally Enforceable Through Title V Permit
29. The operator shall perform source testing for PM10 concentration and emission rate once per permit term using EPA Method 5. [40 CFR 60.8 (b) and (c)] Federally Enforceable Through Title V Permit
30. Audits of continuous emission monitoring system shall be conducted in accordance with EPA guidelines, witnessed at the District's discretion, and reports shall be submitted to the District within 60 days of such an audit. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
31. The Relative Accuracy Audit shall be conducted by an independent laboratory in accordance with EPA guidelines, witnessed or authorized by the District. Results shall be submitted to the District within 60 days. [District Rule 1080 and PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
32. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.1.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
33. Continuous emission monitoring system for NOx as NO2 and continuous monitoring system for CO & CO2 shall serve each CGT flue gas stream, shall conform to SJVUAPCD Rule 1080 specifications, shall meet EPA monitoring performance specifications, & shall be operational whenever the turbine is in operation. [District Rule 1080 and PSD SJ 85-09, X.D.1 and .2] Federally Enforceable Through Title V Permit
34. The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
35. All continuous emissions monitoring systems shall be calibrated and operated according to EPA guidelines as specified in 40 CFR 60, Appendix B and 40 CFR 52, Appendix E. CEM ppm and lb/hr shall be calculated as a three-hour and a 1-hour average. [District Rule 1080 and PSD SJ 85-09 X.D.2] Federally Enforceable Through Title V Permit
36. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
37. Each 1-hour period in a 1, 2 or 3-hour average will commence on the hour. The 3-hour average will be compiled from the three most recent 1-hour periods. The 2-hour average will be compiled from the two most recent 1-hour periods. [District Rule 1080] Federally Enforceable Through Title V Permit
38. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

39. Operator shall operate and maintain in calibration a system which continuously measures and records the following: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 or CO2 concentration . [40 CFR 60.334(b),(c) and District Rules 2520, 9.4.2 and 4703, 6.2.1] Federally Enforceable Through Title V Permit
40. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown, tuning start-up, or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
41. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
42. Daily records of NO2 and CO emission calculations during days of gas turbine startup/shutdown shall be maintained and such records shall be made readily available for District inspection upon request for a period of five years. [District Rule 1080] Federally Enforceable Through Title V Permit
43. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3.2] Federally Enforceable Through Title V Permit
44. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the following: the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(b); District Rules 2520, 9.4.2 and 4703, 6.2.6; PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
45. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
46. The operator performing start-up or shutdown of this unit shall keep records of the duration of start-up or shutdown. [District Rule 4703, 6.2.8] Federally Enforceable Through Title V Permit
47. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
48. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
49. Each exhaust stack shall be equipped with permanent stack sampling provisions consistent with District Rule 1081, EPA reference Methods 5 and 8 and OSHA requirements. [District Rule 1081] Federally Enforceable Through Title V Permit
50. Each CGT shall have a fuel consumption monitor/recorder. [District NSR Rule and PSD SJ 85-09, X.D.1] Federally Enforceable Through Title V Permit
51. Operational records (including but not limited to: fuel characteristics, etc.) shall be maintained by Sycamore Cogeneration Company. [District NSR Rule] Federally Enforceable Through Title V Permit
52. Accurate records of NOx (as NO2) and carbon monoxide (CO) flue gas concentrations corrected to 15% O2, dry and CGT fuel sulfur content shall be maintained and shall be reported as described by District Rule 1080 and upon request. [District Rule 1080] Federally Enforceable Through Title V Permit
53. Operator shall submit a quarterly report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
54. Quarterly continuous emission monitoring system reports shall be submitted to the District, EPA and CEC, as required by EPA regulations as specified in CFR Title 40, Part 58, Appendix B and Part 60 Appendix B. [District Rule 1080 and PSD SJ 85-09, X.D.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

55. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA. The report is due on the 30th day following the end of the calendar quarter and shall include the following: A. time intervals, data and magnitude of excess emissions (computed in accordance with 40 CFR 60.13(h)), nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard. [40 CFR 60.334 (j)(5); District Rule 1080, 8.0 and PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
56. The written report for each calendar quarter shall also include the following: C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. Excess emissions shall be defined as any 3-hour period during which the average emissions for CO, as measured by the CEM system, exceeds the emission limit set forth in PSD SJ 85-09, X.E. [District Rule 1080, 8.0; PSD SJ 85-09, X.D.3 and X.D.5.a through e] Federally Enforceable Through Title V Permit
57. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
58. The APCO shall be notified no later than one hour after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rules 1080, 10.0 and 1100, 6.1; PSD SJ 85-09, X.D.3] Federally Enforceable Through Title V Permit
59. The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in this permit. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
60. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under the conditions of this permit, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
61. CGT shall be fired on natural gas only. There shall be no provisions for oil firing. Natural gas used as fuel shall be pipeline quality with sulfur content of 0.3 gr/100 scf or less (0.001% sulfur by weight). [District NSR Rule; Kern County Rule 407] Federally Enforceable Through Title V Permit
62. The HHV and LHV of the gaseous fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
63. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
64. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3246, D4468 or D6667. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
65. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested in accordance with the requirements of 40 CFR 60.334 (h) and 40 CFR 60.334(i). [40 CFR 60.334 (h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
66. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this permit shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
67. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations. [PSD SJ 85-09] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

68. The cogeneration facility is subject to the federal regulations entitled Standards of Performance for New Stationary Sources (40 CFR 60). The owner or operator shall meet all applicable requirements of Subparts A and GG of this regulation. [PSD SJ 85- 09] Federally Enforceable Through Title V Permit
69. All correspondence as required by this permit shall be forwarded to: a) Director, Enforcement Div (Attn: A-5), EPA Region IX, 75 Hawthorne Street, San Francisco, CA, 94105; b) Chief, Stationary Source Control Division, California Air Resource Board, P.O. Box 2815, Sacramento, CA, 95814; c) Director, SJVUAPCD, 1990 East Gettysburg, Fresno, CA, 93726-0244; and d) the California Energy Commission, 1516 Ninth Street, Sacramento, CA, 95814-5512. [PSD SJ 85-09] Federally Enforceable Through Title V Permit
70. Compliance with permit conditions in the Title V permit shall be deemed compliance with the Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
71. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a), and (b); 60.333 (a); 60.334 (b), (c), (h), (i) and (j)(5); and 60.335 (b). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
72. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.