



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT

MAY 14 2013

Mr. Jeff Paul
CalPeak Power - Panoche, LLC
7365 Mission Gorge Rd, Suite C
San Diego, CA 92120-1273

Re: Notice of Preliminary Decision – Title V Permit Renewal
District Facility # C-3811
Project # C-1123375

Dear Mr. Paul:

Enclosed for your review and comment is the District's analysis of the application to renew the Federally Mandated Operating Permit for CalPeak Power - Panoche, LLC at 43699 West Panoche Road in Firebaugh, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the renewed Federally Mandated Operating Permit. Please submit your written comments on this project within the 30-day public comment period, as specified in the enclosed public notice.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

Enclosures

cc: Mike Tollstrup, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Sayed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061
www.valleyair.org

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

**NOTICE OF PRELIMINARY DECISION
FOR THE PROPOSED RENEWAL OF
THE FEDERALLY MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District solicits public comment on the proposed renewal of the Federally Mandated Operating Permit to CalPeak Power - Panoche, LLC at 43699 West Panoche Road in Firebaugh, California.

The District's analysis of the legal and factual basis for this proposed action, project #C-1123375, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and at any District office. There are no emission changes associated with this proposed action. This will be the public's only opportunity to comment on the specific conditions of the proposed renewal of the Federally Mandated Operating permit. If requested, the District will hold a public hearing regarding issuance of this renewed permit. For additional information, please contact the District at (559) 230-6000. Written comments on the proposed initial permit must be submitted by June 17, 2013 to **DAVID WARNER, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**

**SAN JOAQUIN VALLEY
AIR POLLUTION CONTROL DISTRICT**

**Proposed Title V Permit Renewal Evaluation
CalPeak Power - Panoche, LLC
C-3811**

TABLE OF CONTENTS

I.	PROPOSAL	2
II.	FACILITY LOCATION	2
III.	EQUIPMENT LISTING.....	3
IV.	GENERAL PERMIT TEMPLATE USAGE.....	3
V.	SCOPE OF EPA AND PUBLIC REVIEW.....	3
VI.	FEDERALLY ENFORCEABLE REQUIREMENTS.....	4
VII.	REQUIREMENTS NOT FEDERALLY ENFORCEABLE	5
VIII.	PERMIT REQUIREMENTS.....	6
IX.	PERMIT SHIELD	11
X.	PERMIT CONDITIONS	12
XI.	ATTACHMENTS.....	12
A.	DRAFT RENEWED TITLE V OPERATING PERMIT	
B.	PREVIOUS TITLE V OPERATING PERMIT	
C.	DETAILED FACILITY LIST	

TITLE V PERMIT RENEWAL EVALUATION
Power Generation

Engineer: Gurpreet Brar
Date: February 20, 2013

Facility Number: C-3811

Facility Name: CalPeak Power - Panoche, LLC
Mailing Address: 7365 Mission Gorge Rd, Suite C
San Diego, CA 92120-1273

Contact Name: Jeff Paul
Phone: (619) 229-3770 ext 302

Responsible Official: Jeff Paul
Title: General Manager

Project # : C-1123375
Deemed Complete: December 4, 2012

I. PROPOSAL

CalPeak Power - Panoche Corporation was issued a Title V permit on April 30, 2004. As required by District Rule 2520, the applicant is requesting a permit renewal. The existing Title V permit shall be reviewed and modified to reflect all applicable District and federal rules updated, removed, or added since the issuance of the initial Title V permit.

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions.

II. FACILITY LOCATION

CalPeak Power - Panoche Corporation is located at 43699 West Panoche Road, Firebaugh in Fresno County.

III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment C.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant is requesting to use the following model general permit Templates:

A. Template SJV-UM-0-3 Facility Wide Umbrella

The applicant has requested to utilize template No. SJV-UM-0-3, Facility Wide Umbrella. Based on the information submitted in the Template Qualification Form, the applicant qualifies for the use of this template. Template SJV-UM-0-3 conditions have been added as conditions 1 through 40 for the renewed facility wide requirements (C-3811-0-2) and replace conditions 1 through 40 of the existing facility wide requirements (C-3811-0-1).

V. SCOPE OF EPA AND PUBLIC REVIEW

Certain segments of the final Renewed Operating Permit are based on model general permit templates that have been previously subject to EPA and public review. The terms and conditions from the model general permit templates are included in the final permit and are not subject to further EPA and public review.

For permit applications utilizing model general permit templates, public and agency comments on the District's final actions are limited to the applicant's eligibility for model general permit template, applicable requirements not covered by the model general permit template, and the applicable procedural requirements for issuance of Title V Operating Permits.

The following permit conditions, including their underlying applicable requirements, originate from model general permit templates and are not subject to further EPA or public review.

Conditions 1 through 40 of the facility-wide requirements C-3811-0-2.

VI. FEDERALLY ENFORCEABLE REQUIREMENTS

A. Rules Updated

- District Rule 2020, Exemptions
(amended December 20, 2007 ⇒ amended August 18, 2011)
- District Rule 2201, New and Modified Stationary Source Review Rule
(amended December 18, 2008 ⇒ amended April 21, 2011)
- District Rule 2410, Prevention of Significant Deterioration
(adopted June 16, 2011 ⇒ effective November 26, 2012)

B. Rules Removed

No rules were removed.

C. Rules Added

The following rule, applicable to this facility, has been adopted since issuance of the initial Title V permit.

- 40 CFR 63 Subpart YYYY - National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines

D Rules Not Updated

- District Rule 1070, Inspections (amended December 17, 1992)
- District Rule 1080, Stack Monitoring (amended December 17, 1992)
- District Rule 1081, Source Sampling (amended December 16, 1993)
- District Rule 2520, Federally Mandated Operating Permits (amended June 21, 2001)
- District Rule 4201, Particulate Matter Concentration (amended December 17, 1992)
- District Rule 4202, Particulate Matter - Emission Rate (amended December 17, 1992)

- District Rule 4703, Stationary Gas Turbines (amended September 20, 2007)
- District Rule 4801, Sulfur Compounds (amended December 17, 1992)
- 40 CFR Part 60, Subpart A, Monitoring Requirements
- 40 CFR Part 60, Subpart GG, New Source Performance Standards; Standard of Performance for Stationary Gas Turbines
- 40 CFR 60 Subpart KKKK - Standards of Performance for Stationary Combustion Turbines
- 40 CFR Part 64, Compliance Assurance Monitoring
- 40 CFR Part 72, Permits Regulation
- 40 CFR Part 73, Sulfur Dioxide Allowance System
- 40 CFR Part 75, Continuous Emission Monitoring
- 40 CFR Part 77, Excess Emissions

VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit".

For this facility, the following are not federally enforceable and will not be discussed in further detail:

A. Rules Added

No non-federally enforceable rules have been added to the permit.

B. Rules Not Updated

District Rule 4102, Nuisance (as amended December 17, 1992)

- Condition 57 of facility-wide permit C-3811-0-2 is based on District Rule 4102 and will therefore not be discussed any further.

VIII. PERMIT REQUIREMENTS

The purpose of this evaluation is to review changes to federally enforceable requirements; therefore, this compliance section will only address rules that have been amended or added since the issuance of the initial Title V permit.

C. District Rule 2020–Exemptions

District Rule 2020 lists equipment which are specifically exempt from obtaining permits and specifies recordkeeping requirements to verify such exemptions. The amendments to this rule do not have any affect on current permit requirements and will therefore not be addressed in this evaluation.

D. District Rule 2201–New and Modified Stationary Source Review Rule

District Rule 2201 has been amended since this facility's initial Title V permit was issued. This Title V permit renewal does not constitute a modification per section 3.26, defined as an action including at least one of the following items:

- 1) Any change in hours of operation, production rate, or method of operation of an existing emissions unit, which would necessitate a change in permit conditions.
- 2) Any structural change or addition to an existing emissions unit which would necessitate a change in permit conditions. Routine replacement shall not be considered to be a structural change.
- 3) An increase in emissions from an emissions unit caused by a modification of the Stationary Source when the emissions unit is not subject to a daily emissions limitation.
- 4) Addition of any new emissions unit which is subject to District permitting requirements.
- 5) A change in a permit term or condition proposed by an applicant to obtain an exemption from an applicable requirement to which the source would otherwise be subject.

Therefore, the updated requirements of this rule are not applicable at this time.

E. District Rule 2410 – Prevention of Significant Deterioration

The prevention of significant deterioration (PSD) program is a construction permitting program for new major stationary sources and major modifications to existing major stationary sources located in areas classified as attainment or in areas that are unclassifiable for any criteria air pollutant. The provisions of this rule apply to any source and the owner or operator of any source subject to any requirement under Title 40 Code of Federal Regulations (40 CFR) Part 52.21 as incorporated into this rule.

There are no PSD requirements for this source. Therefore, the facility is not subject to this rule and no further discussion is required.

F. District Rule 2520 – Federally Mandated Operating Permits

There are no federally applicable Greenhouse Gas (GHG) requirements for this source. It should be noted that the Mandatory Greenhouse Gas Reporting rule (40CFR Part 98) is not included in the definition of an applicable requirement within Title V (per 40CFR 71.2). Therefore, there will be no further discussion of GHG in this evaluation.

G. 40 CFR 63 Subpart YYYY - National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines

This subpart applies to stationary combustion turbines that are located at a major source of HAP emissions is a contiguous site under common control that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year.

As per District's Toxics Inventory, this facility is not major source of HAP emissions, requirements of this subpart does not apply.

F. 40 CFR Part 60, Subpart GG, Standard of Performance for Stationary Gas Turbines

This requirement limits emissions of nitrogen oxides. Emissions shall not exceed a NO_x emission rate of 75 ppmv or 150 ppmv, depending on the unit size (at 15% O₂ with the ISO correction factor). The following analysis shows that the proposed requirement of District Rule 4703 is more stringent than 40 CFR requirements pertaining to NO_x emissions. Streamlining procedures, as documented in the following steps is utilized to substitute the proposed set of requirements for the otherwise applicable requirements.

The following table has side-by-side comparison of applicable requirements:

Type of Requirement	District Rule 4703	Subpart GG, § 60.332, 60.333 and 60.334	Proposed Requirement
Emissions Limit	Section 5.1.2 - for > 10 MW, 5 ppmv @ 15% O ₂ . (Tier II Standard Option)	60.332(a)(1) – 75 ppmv @ 15% O ₂ . (Lowest possible concentration) 60.333(a) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contain sulfur dioxide in excess of 0.015% by volume at 15% oxygen and on a dry basis.	3.4 ppmv @ 15% O ₂ .
Work place standards	N/A	60.333(b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel, which contains sulfur in excess of 0.8% by weigh (8000 ppmw).	This unit shall be fired exclusively on PUC-quality natural gas which has a total sulfur content of less than or equal to 1.0 gr/100 scf
Monitoring	(6.2.1) Except for units subject to Section 6.2.3, for turbines with exhaust gas NO _x control devices, the owner or operator shall either install, operate, and maintain continuous emissions monitoring equipment for NO _x and oxygen, as identified in Rule 1080 (Stack Monitoring), or install and maintain APCO-approved alternate monitoring	60.334(a) The owner or operator of any stationary gas turbine subject to the provisions of this subpart and using water injection to control NO _x emissions shall install or operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water to fuel being fired in the turbine. 60.334(b) Install, certify, maintain, operate, and quality-assure a continuous emissions monitoring system for NO _x and O ₂ . 60.334(h)(3) The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) demonstrated by representative fuel sampling data which shows that sulfur content of gas does not exceed 0.25 gr/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of Appendix D of 40 CFR part 75 is required	The owner or operator shall install, , certify, maintain, operate, and quality-assure a system which continuously measures and records the exhaust gas NO _x and O ₂ concentrations. The sulfur content of each fuel source shall be documented in a valid purchase contract, a supplier certification, a tariff sheet, or a transportation contract.

Type of Requirement	District Rule 4703	Subpart GG, § 60.332, 60.333 and 60.334	Proposed Requirement
Reporting	As per District Rule 1080: Time intervals, data and magnitude of excess NO _x emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred	60.334(J) the owner or operator shall submit reports of excess emissions and monitor downtime as required under §60.7(c), periods of excess emissions that shall be reported are defined as follows: 60.334(J)(1)(iii) - An hour of excess emissions shall be any operating hour in which 4-hour rolling average NO _x concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NO _x or diluent (or both). 60.334(J)(5): all reports required under §60.7(c) shall be post marked by 30 th day following the end of each calendar quarter.	The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NO _x emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. Excess emissions shall be defined as any operating hour in which 4-hour rolling average NO _x concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NO _x or diluent (or both)
Testing	Annual Testing for nitrogen oxides (NO _x) concentrations using EPA Method 20 or 7E and oxygen (O ₂) using Method 3, 3A, or 20.	Initial NO _x performance testing using EPA method 20 or 7E and EPA method 3, 3A for O ₂ .	Annual Testing for nitrogen oxides (NO _x) concentrations using EPA Method 20 or 7E and oxygen (O ₂) using Method 3, 3A, or 20.

The District Rule 4703 requirement to limit NO_x concentration to 5 ppmv @ 15% O₂ is clearly more stringent than the Subpart GG emissions limit of 75 ppmv as discussed below. Condition 18 & 19 on the draft PTOs (C-3811-1-8 & -2-8) assures compliance with this requirement.

The SO_x emissions are limited to be below 150 ppmv which is lower than 8000 ppmv allowed by NSPS Subpart GG. Condition 33 on the draft PTOs (C-3811-1-8 & -2-8) assures compliance with this requirement.

Conditions 12 and 34 on the draft PTOs (C-3811-1-8 & -2-8) assure compliance with the requirements of the fuel sulfur content:

G. 40 CFR Part 64, Compliance Assurance Monitoring

40 CFR Part 64 requires Compliance Assurance Monitoring (CAM) for units that meet the following three criteria:

- 1) the unit must have an emission limit for the pollutant;
- 2) the unit must have add-on controls for the pollutant; these are devices such as flue gas recirculation (FGR), baghouses, and catalytic oxidizers; and
- 3) the unit must have a pre-control potential to emit of greater than the major source thresholds.

AP-42, Section 3.1 lists the control efficiency for SCR as 90% for NO_x. In condition 19 of the requirements for permit units C-3811-1-8 and -2-8 the controlled emission are limited to 3.08 lb NO_x per hour. The uncontrolled NO_x emissions from each turbine is calculated to be 135 tons of NO_x per year [(3.08 lb-NO_x/hour ÷ 0.1) x 8,760 hour/year], are greater than the Major source threshold of 10 tons-NO_x per year (20,000 lb). Therefore, the turbines are subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for NO_x. There are no effective stack controls utilized for PM₁₀ or SO_x, and the pre-controlled emissions are below the major source thresholds for CO and VOC; therefore, per items #2 and #3 above, CAM is not triggered for these emissions.

40 CFR 64.3(d) states that the use of Continuous Emissions Monitoring system (CEMs) which is required pursuant to other authority under the Act or state or local law shall be used to satisfy the requirements of 40 CFR Part 64. Furthermore, CEMs that satisfies the monitoring requirements listed in Section 63.4(d)(2) shall be deemed to satisfy the general design criteria in paragraph (a) and (b) of Section 64.3.

The gas turbines operated at CalPeak Power – Panoche are equipped with CEM systems for NO_x emissions, CO emissions, and O₂ concentrations satisfying Appendix P of 40 CFR Part 51, 40 CFR 60.13, 40 CFR Part 75, and Appendix B of 40 CFR Part 60 and therefore, compliance with the requirements of 40 CFR Part 64, Compliance Assurance Monitoring.

- Conditions 5 to 8, and 27 to 31 of the requirements for permit units C-3811-1-8 and C-3811-2-8 assure compliance with the requirements of the 40 CFR Part 64.

H. 40 CFR Part 72, Permits Regulation

The 24.7 MW simple-cycle natural gas fired turbines, permit unit C-3811-1 and C-3811-2, are subject to the provisions of the Title IV, Acid Rain Program of the Clean Air Act (40 CFR Part 72) since these units are “new unit” (commenced commercial operation on or after November 15, 1990) as defined in 40 CFR 72.2. By reference the requirements of 40 CFR Parts 73, 75, and 77 are included in 40 CFR Part 72. These provisions have been included as conditions 41 to 56 on facility-wide permit C-3811-0-2.

IX. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

A. Requirements Addressed by Model General Permit Templates

By submitting Model General Permit Template SJV-UM-0-3 qualification form, the applicant has requested that a permit shield be granted for all the applicable requirements identified by the template. Therefore, the permit shields as granted in Model General Permit Template are included as conditions 39 and 40 of the facility-wide requirements (C-3811-0-2).

B. Requirements not Addressed by Model General Permit Templates

The applicant has not requested any permit shield other than as discussed above.

C. Obsolete Permit Shields From Existing Permit Requirements

There is no change to the existing permit shields already included in their Title V operating permit. Therefore, all of the existing permit shields will be maintained on the revised permit for this renewal project.

X. PERMIT CONDITIONS

See Attachment A – Draft Renewed Title V Operating Permit.

XI. ATTACHMENTS

- A. Draft Renewed Title V Operating Permit
- B. Previous Title V Operating Permit
- C. Detailed Facility List

ATTACHMENT A

Draft Renewed Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: C-3811-0-2

EXPIRATION DATE: 05/31/2013

FACILITY-WIDE REQUIREMENTS

1. {4362} The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. {4363} The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. {4364} The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. {4365} Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. {4366} The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. {4367} A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. {4368} Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. {4369} The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: CAL PEAK POWER - PANOCHE, LLC
Location: 43699 WEST PANOCHE RD, FIREBAUGH, CA 93622-9720
C-3811-0-2; Feb 21 2013 2:47PM - BRARG

9. {4370} The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. {4371} The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. {4372} Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. {4373} If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. {4374} It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. {4375} The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. {4376} The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. {4377} The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. {4378} The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. {4379} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. {4380} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. {4381} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. {4382} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. {4383} No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
23. {4384} No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. {4385} All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. {4386} The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. {4387} With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. {4388} If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. {4389} If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. {4390} Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. {4391} Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. {4392} An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. {4393} Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. {4394} Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. {4395} Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. {4396} Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit
36. {4397} The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. {4398} The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. {4399} When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Fresno County Rule 110. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. {4401} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) Have an Acid Rain permit. [40 CFR 72] Federally Enforceable Through Title V Permit
42. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
43. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
44. The owners and operators of each source and each affected unit at the source shall: (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

45. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
46. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
47. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
48. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
49. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
50. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit
51. The owners and operators of each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit
52. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
53. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) Pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
54. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
55. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
56. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit
57. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
58. When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan when mandated by the regulation. [40 CFR Part 68] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

59. On April 30, 2004, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin May 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-3811-1-8

EXPIRATION DATE: 05/31/2013

EQUIPMENT DESCRIPTION:

24.7 MW NOMINALLY RATED SIMPLE-CYCLE PEAK-DEMAND POWER GENERATING SYSTEM #1 CONSISTING OF PRATT & WHITNEY MODEL FT-8 NATURAL GAS-FIRED GAS TURBINE ENGINE WITH DRY LOW NOX (DLN) COMBUSTORS, SERVED BY A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM AND AN OXIDATION CATALYST WITH A 49.5 MW GENERATOR (SHARED WITH C-3811-2)

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. Selective catalytic reduction (SCR) system and oxidation catalyst shall serve the common exhaust duct from C-3811-1 and C-3811-2. Common exhaust ducting shall be equipped with a fresh air inlet and blower to be used to lower the exhaust temperature prior to inlet of the SCR system catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas turbine engine shall be equipped with a continuous monitoring system to measure and record hours of operation and fuel consumption. [District Rules 2201 and 4703, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
6. The owner or operator shall certify, maintain, operate, and quality-assure a system which continuously measures and records the exhaust gas NOx and O2 concentrations. [40 CFR 60.334(b) and District Rule 4703] Federally Enforceable Through Title V Permit
7. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and District Rule 1080] Federally Enforceable Through Title V Permit
8. The NOx and O2 CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specification 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 60.334(b)(1) and District Rule 1080] Federally Enforceable Through Title V Permit
9. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
10. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and provisions to sample stack gases at ground level with a portable NO_x, CO, and O₂ analyzer. [District Rule 1081] Federally Enforceable Through Title V Permit
12. This unit shall be fired exclusively on natural gas as defined in 40 CFR 60.331(u) which has a total sulfur content of less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b) and Fresno County Rule 406] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703] Federally Enforceable Through Title V Permit
14. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
15. Number of startups and shutdowns shall not exceed 365 in one calendar year. [District Rules 2201] Federally Enforceable Through Title V Permit
16. Each startup or shutdown shall not exceed 30 minutes. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
17. Combined emission rates from units C-3811-1 and C-3811-2 during startup or shutdown shall not exceed : 8.28 lb NO_x/hr, 1.42 lb SO_x/hr, 3.42 lb PM₁₀/hr, 35.46 lb CO/hr, and 1.28 lb VOC/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Except during startup and shutdown, emission rates from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed any of the following limits: PM₁₀ - 3.24 lb/hr, SO_x (as SO₂) - 1.42 lb/hr, NO_x (as NO₂) - 3.4 ppmvd @ 15% O₂ and 6.16 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O₂ and 1.28 lb/hr, CO - 30 ppmvd @ 15% O₂ and 33.2 lb/hr, or ammonia - 10 ppmvd @ 15% O₂. All emission limits are three hour rolling averages. [40 CFR 60.332, District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
19. Except during startup and shutdown, emission rates from gas turbine engine C-3811-1 shall not exceed any of the following limits: PM₁₀ - 1.62 lb/hr, SO_x (as SO₂) - 0.71 lb/hr, NO_x (as NO₂) - 3.4 ppmvd @ 15% O₂ and 3.08 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O₂ and 0.64 lb/hr, CO - 30 ppmvd @ 15% O₂ and 16.6 lb/hr, or ammonia - 10 ppmvd @ 15% O₂. All emission limits are three hour rolling averages. [40 CFR 60.332, District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
20. Daily emissions from gas turbine engine C-3811-1 shall not exceed any of the following emission limits, regardless of type of operation: 74.0 lb NO_x/day, 17.0 lb SO_x/day, 38.9 lb PM₁₀/day, 385.2 lb CO/day, and 15.4 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Combined emission from units C-3811-1 and C-3811-2 shall not exceed any of the following emission limits, regardless of type of operation: 148.0 lb NO_x/day, 34.0 lb SO_x/day, 77.8 lb PM₁₀/day, 770.0 lb CO/day, and 30.8 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
22. NO_x emissions from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed 20,000 lb/year. [District Rule 2201] Federally Enforceable Through Title V Permit
23. Compliance with ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O₂ = $((a-(b \times (c-d)/1,000,000)) \times 1,000,000/b)$, where a = ammonia injection rate (lb/hr)/17 (lb/lb mol), b = dry exhaust gas flow rate (lb/hr)/29 (lb/lb mol), c = SCR inlet NO_x concentration ppmv at 15% O₂ for the operating load determined by the most recent source test data, and d = SCR outlet NO_x concentration ppmv at 15% O₂ from the continuous emission monitor. [District Rule 4102]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Compliance testing to demonstrate compliance with the PM₁₀, NO_x (as NO₂), VOC, CO, and ammonia emission limits, and fuel gas sulfur content shall be conducted at least once every twelve months. Compliance testing may be demonstrated when both C-3811-1 and C-3811-2 are operating. NO_x emission concentration at the SCR inlet shall be determined for 50%, 75%, 90%, and 100% loads during annual compliance testing by measuring NO_x emissions at each load for a minimum of 5 minutes or until NO_x concentration has stabilized. [District Rules 1081 and 4703] Federally Enforceable Through Title V Permit
25. Compliance demonstration (source testing) shall be District witnessed, or authorized and samples shall be collected by a California Air Resources Board certified testing laboratory. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The following test methods shall be used PM₁₀: EPA method 5 (front half and back half), NO_x: EPA Method 7E or 20, CO: EPA method 10 or 10B, O₂: EPA Method 3, 3A, or 20, VOC: EPA method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.8(a), 40 CFR 60.335(c)(3), District Rules 1081 and 4703] Federally Enforceable Through Title V Permit
27. Results of continuous emissions monitoring shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
28. In lieu of the cylinder gas audit requirements of Appendix F to Part 60, quarterly audits of continuous emission monitors shall be conducted per the procedures and frequencies specified in Appendix B to Part 75, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified 48-hours prior to conducting the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rules 1080 and 4703, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
29. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NO_x emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080] Federally Enforceable Through Title V Permit
30. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 60.7(b) and District Rule 1080] Federally Enforceable Through Title V Permit
31. The permittee shall maintain the following records: hours of operation, fuel consumption (scf/hr and scf/rolling twelve month period), continuous emission monitor measurements, calculated ammonia slip, and calculated NO_x mass emission rates (lb/hr and lb/twelve month rolling period). [40 CFR 60.334(a), District Rules 2201 and 4703, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
32. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080] Federally Enforceable Through Title V Permit
33. The owner or operator shall be required to conform to the compliance testing and sampling procedures described in District Rule 1081 (as amended 12/16/93). [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a), Fresno County Rules 406, and District Rule 4801] Federally Enforceable Through Title V Permit
35. The sulfur content of each fuel source shall be documented in a valid purchase contract, a supplier certification, a tariff sheet, or a transportation contract. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
36. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
37. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703] Federally Enforceable Through Title V Permit
38. All records shall be maintained, retained on-site for a minimum of five years and shall be made available for District inspection upon request. [District Rule 4703] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-3811-2-8

EXPIRATION DATE: 05/31/2013

EQUIPMENT DESCRIPTION:

24.7 MW NOMINALLY RATED SIMPLE-CYCLE PEAK-DEMAND POWER GENERATING SYSTEM #2 CONSISTING OF PRATT & WHITNEY MODEL FT-8 NATURAL GAS-FIRED GAS TURBINE ENGINE WITH DRY LOW NOX (DLN) COMBUSTORS, SERVED BY A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM AND AN OXIDATION CATALYST WITH A 49.5 MW GENERATOR (SHARED WITH C-3811-1)

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. Selective catalytic reduction (SCR) system and oxidation catalyst shall serve the common exhaust duct from C-3811-1 and C-3811-2. Common exhaust ducting shall be equipped with a fresh air inlet and blower to be used to lower the exhaust temperature prior to inlet of the SCR system catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas turbine engine shall be equipped with a continuous monitoring system to measure and record hours of operation and fuel consumption. [District Rule 2201, District Rule 4703, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
6. The owner or operator shall certify, maintain, operate, and quality-assure a system which continuously measures and records the exhaust gas NOx and O2 concentrations. [40 CFR 60.334(b) and District Rule 4703] Federally Enforceable Through Title V Permit
7. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and District Rule 1080] Federally Enforceable Through Title V Permit
8. The NOx and O2 CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specification 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 60.334(b)(1) and District Rule 1080] Federally Enforceable Through Title V Permit
9. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
10. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and provisions to sample stack gases at ground level with a portable NO_x, CO, and O₂ analyzer. [District Rule 1081] Federally Enforceable Through Title V Permit
12. This unit shall be fired exclusively on natural gas as defined in 40 CFR 60.331(u) which has a total sulfur content of less than or equal to 1.0 gr/100 scf. [40.CFR 60.333(b) and Fresno County Rule 406] Federally Enforceable Through Title V Permit
13. Startup shall be defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operations. Shutdown shall be defined as the period of time during which a unit is taken from an operational to a non-operational status as the fuel supply to the unit is completely turned off. [District Rule 4703] Federally Enforceable Through Title V Permit
14. Number of startups and shutdowns shall not exceed 365 in one calendar year. [District Rules 2201] Federally Enforceable Through Title V Permit
15. Each startup or shutdown shall not exceed 30 minutes. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
16. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
17. Combined emission rates from units C-3811-1 and C-3811-2 during startup or shutdown shall not exceed : 8.28 lb NO_x/hr, 1.42 lb SO_x/hr, 3.42 lb PM₁₀/hr, 35.46 lb CO/hr, and 1.28 lb VOC/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Except during startup and shutdown, emission rates from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed any of the following limits: PM₁₀ - 3.24 lb/hr, SO_x (as SO₂) - 1.42 lb/hr, NO_x (as NO₂) - 3.4 ppmvd @ 15% O₂ and 6.16 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O₂ and 1.28 lb/hr, CO - 30 ppmvd @ 15% O₂ and 33.2 lb/hr, or ammonia - 10 ppmvd @ 15% O₂. All emission limits are three hour rolling averages. [40 CFR 60.332, District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
19. Except during startup and shutdown, emission rates from gas turbine engine C-3811-1 shall not exceed any of the following limits: PM₁₀ - 1.62 lb/hr, SO_x (as SO₂) - 0.71 lb/hr, NO_x (as NO₂) - 3.4 ppmvd @ 15% O₂ and 3.08 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O₂ and 0.64 lb/hr, CO - 30 ppmvd @ 15% O₂ and 16.6 lb/hr, or ammonia - 10 ppmvd @ 15% O₂. All emission limits are three hour rolling averages. [40 CFR 60.332, District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
20. Daily emissions from gas turbine engine C-3811-2 shall not exceed any of the following emission limits, regardless of type of operation: 74.0 lb NO_x/day, 17.0 lb SO_x/day, 38.9 lb PM₁₀/day, 385.2 lb CO/day, and 15.4 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Combined emission from units C-3811-1 and C-3811-2 shall not exceed any of the following emission limits, regardless of type of operation: 148.0 lb NO_x/day, 34.0 lb SO_x/day, 77.8 lb PM₁₀/day, 770.4 lb CO/day, and 30.8 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
22. NO_x emissions from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed 20,000 lb/year. [District Rule 2201] Federally Enforceable Through Title V Permit
23. Compliance with ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O₂ = ((a-(b×(c-d)/1,000,000)) × 1,000,000/b), where a = ammonia injection rate (lb/hr)/17 (lb/lb mol), b = dry exhaust gas flow rate (lb/hr)/29 (lb/lb mol), c = SCR inlet NO_x concentration ppmv at 15% O₂ for the operating load determined by the most recent source test data, and d = SCR outlet NO_x concentration ppmv at 15% O₂ from the continuous emission monitor. [District Rule 4102]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Compliance testing to demonstrate compliance with the PM₁₀, NO_x (as NO₂), VOC, CO, and ammonia emission limits, and fuel gas sulfur content shall be conducted at least once every twelve months. Compliance testing may be demonstrated when both C-3811-1 and C-3811-2 are operating. NO_x emission concentration at the SCR inlet shall be determined for 50%, 75%, 90%, and 100% loads during annual compliance testing by measuring NO_x emissions at each load for a minimum of 5 minutes or until NO_x concentration has stabilized. [District Rules 1081 and 4703] Federally Enforceable Through Title V Permit
25. Compliance demonstration (source testing) shall be District witnessed, or authorized and samples shall be collected by a California Air Resources Board certified testing laboratory. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The following test methods shall be used PM₁₀: EPA method 5 (front half and back half), NO_x: EPA Method 7E or 20, CO: EPA method 10 or 10B, O₂: EPA Method 3, 3A, or 20, VOC: EPA method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.8(a), 40 CFR 60.335(c)(3), District Rules 1081 and 4703] Federally Enforceable Through Title V Permit
27. Results of continuous emissions monitoring shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
28. In lieu of the cylinder gas audit requirements of Appendix F to Part 60, quarterly audits of continuous emission monitors shall be conducted per the procedures and frequencies specified in Appendix B to Part 75, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified 48-hours prior to conducting the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rules 1080 and 4703, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
29. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NO_x emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080] Federally Enforceable Through Title V Permit
30. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 60.7(b) and District Rule 1080] Federally Enforceable Through Title V Permit
31. The permittee shall maintain the following records: hours of operation, fuel consumption (scf/hr and scf/rolling twelve month period), continuous emission monitor measurements, calculated ammonia slip, and calculated NO_x mass emission rates (lb/hr and lb/twelve month rolling period). [40 CFR 60.334(a), District Rules 2201 and 4703, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
32. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080] Federally Enforceable Through Title V Permit
33. The owner or operator shall be required to conform to the compliance testing and sampling procedures described in District Rule 1081 (as amended 12/16/93). [District Rule 1081] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a), Fresno County Rules 406, and District Rule 4801] Federally Enforceable Through Title V Permit
35. The sulfur content of each fuel source shall be documented in a valid purchase contract, a supplier certification, a tariff sheet, or a transportation contract. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
36. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
37. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703] Federally Enforceable Through Title V Permit
38. All records shall be maintained, retained on-site for a minimum of five years and shall be made available for District inspection upon request. [District Rule 4703] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

ATTACHMENT B

Previous Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: C-3811-0-1

EXPIRATION DATE: 05/31/2013

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1 and Fresno County Rule 110] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0 and Fresno County Rule 110] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/19/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: CAL PEAK POWER - PANOCHE, LLC

Location: 43699 WEST PANOCHE RD, FIREBAUGH, CA 93622-9720

C-3811-0-1: Feb 21 2013 3:15PM - BRARG

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (2/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials for architectural coatings subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Fresno County Rule 110. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (8/19/04); 8031 (8/19/04); 8041 (8/19/04); 8051 (8/19/04); 8061 (8/19/04); and 8071 (9/16/04). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin April 30 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. . [District Rule 2520] Federally Enforceable Through Title V Permit
42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
43. When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan when mandated by the regulation. [40 CFR 68]
44. On April 30, 2004, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin June 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-3811-1-7

EXPIRATION DATE: 05/31/2013

EQUIPMENT DESCRIPTION:

24.7 MW NOMINALLY RATED SIMPLE-CYCLE PEAK-DEMAND POWER GENERATING SYSTEM #1 CONSISTING OF PRATT & WHITNEY MODEL FT-8 NATURAL GAS-FIRED GAS TURBINE ENGINE WITH DRY LOW NOX (DLN) COMBUSTORS, SERVED BY A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM AND AN OXIDATION CATALYST WITH A 49.5 MW GENERATOR (SHARED WITH C-3811-2)

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. Selective catalytic reduction (SCR) system and oxidation catalyst shall serve the common exhaust duct from C-3811-1 and C-3811-2. Common exhaust ducting shall be equipped with a fresh air inlet and blower to be used to lower the exhaust temperature prior to inlet of the SCR system catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas turbine engine shall be equipped with a continuous monitoring system to measure and record hours of operation and fuel consumption. [District Rule 2201, District Rule 4703, 6.2.6, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
6. The owner or operator shall certify, maintain, operate, and quality-assure a system which continuously measures and records the exhaust gas NOx and O2 concentrations. [40 CFR 60.334(b) and District Rule 4703, 6.2.1] Federally Enforceable Through Title V Permit
7. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
8. The NOx and O2 CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specification 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 60.334(b)(1) and District Rule 1080, 6.3, 6.5, 6.6, & 7.2] Federally Enforceable Through Title V Permit
9. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
11. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and provisions to sample stack gases at ground level with a portable NOx, CO, and O2 analyzer. [District Rule 1081] Federally Enforceable Through Title V Permit
12. This unit shall be fired exclusively on natural gas as defined in 40 CFR 60.331(u) which has a total sulfur content of less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b) and Fresno County Rule 406] Federally Enforceable Through Title V Permit
13. The transitional period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 5.3.1.1] Federally Enforceable Through Title V Permit
14. Number of startups and shutdowns shall not exceed 365 in one calendar year. [District Rules 2201] Federally Enforceable Through Title V Permit
15. Each startup or shutdown shall not exceed 30 minutes. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
16. Combined emission rates from units C-3811-1 and C-3811-2 during startup or shutdown shall not exceed : 8.28 lb NOx/hr, 1.42 lb SOx/hr, 3.42 lb PM10/hr, 35.46 lb CO/hr, and 1.28 lb VOC/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Except during startup and shutdown, emission rates from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed any of the following limits: PM10 - 3.24 lb/hr, SOx (as SO2) - 1.42 lb/hr, NOx (as NO2) - 3.4 ppmvd @ 15% O2 and 6.16 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O2 and 1.28 lb/hr, CO - 30 ppmvd @ 15% O2 and 33.2 lb/hr, or ammonia - 10 ppmvd @ 15% O2. All emission limits are three hour rolling averages. [40 CFR 60.332, District Rules 2201, and District Rule 4703, 5.1 and 5.2] Federally Enforceable Through Title V Permit
18. Except during startup and shutdown, emission rates from gas turbine engine C-3811-1 shall not exceed any of the following limits: PM10 - 1.62 lb/hr, SOx (as SO2) - 0.71 lb/hr, NOx (as NO2) - 3.4 ppmvd @ 15% O2 and 3.08 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O2 and 0.64 lb/hr, CO - 30 ppmvd @ 15% O2 and 16.6 lb/hr, or ammonia - 10 ppmvd @ 15% O2. All emission limits are three hour rolling averages. [40 CFR 60.332, District Rules 2201, and District Rule 4703, 5.1 and 5.2] Federally Enforceable Through Title V Permit
19. Daily emissions from gas turbine engine C-3811-1 shall not exceed any of the following emission limits, regardless of type of operation: 74.0 lb NOx/day, 17.0 lb SOx/day, 38.9 lb PM10/day, 385.2 lb CO/day, and 15.4 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Combined emission from units C-3811-1 and C-3811-2 shall not exceed any of the following emission limits, regardless of type of operation: 148.0 lb NOx/day, 34.0 lb SOx/day, 77.8 lb PM10/day, 770.0 lb CO/day, and 30.8 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
21. NOx emissions from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed 20,000 lb/year. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Compliance with ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O2 = ((a-(bxc-d)/1,000,000)) x 1,000,000/b, where a = ammonia injection rate (lb/hr)/17 (lb/lb mol), b = dry exhaust gas flow rate (lb/hr)/29 (lb/lb mol), c = SCR inlet NOx concentration ppmv at 15% O2 for the operating load determined by the most recent source test data, and d = SCR outlet NOx concentration ppmv at 15% O2 from the continuous emission monitor. [District Rule 4102]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. Compliance testing to demonstrate compliance with the PM10, NOx (as NO2), VOC, CO, and ammonia emission limits, and fuel gas sulfur content shall be conducted at least once every twelve months. Compliance testing may be demonstrated when both C-3811-1 and C-3811-2 are operating. NOx emission concentration at the SCR inlet shall be determined for 50%, 75%, 90%, and 100% loads during annual compliance testing by measuring NOx emissions at each load for a minimum of 5 minutes or until NOx concentration has stabilized. [District Rule 1081 and District Rule 4703, 6.3.1] Federally Enforceable Through Title V Permit
24. Compliance demonstration (source testing) shall be District witnessed, or authorized and samples shall be collected by a California Air Resources Board certified testing laboratory. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The following test methods shall be used PM10: EPA method 5 (front half and back half), NOx: EPA Method 7E or 20, CO: EPA method 10 or 10B, O2: EPA Method 3, 3A, or 20, VOC: EPA method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.8(a), 40 CFR 60.335(c)(3), District Rule 1081, and District Rule 4703, 6.4] Federally Enforceable Through Title V Permit
26. Results of continuous emissions monitoring shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
27. In lieu of the cylinder gas audit requirements of Appendix F to Part 60, quarterly audits of continuous emission monitors shall be conducted per the procedures and frequencies specified in Appendix B to Part 75, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified 48-hours prior to conducting the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080, District Rule 4703, 6.2.3, 40 CFR 60.334(iii) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
28. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
29. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
30. The permittee shall maintain the following records: hours of operation, fuel consumption (scf/hr and scf/rolling twelve month period), continuous emission monitor measurements, calculated ammonia slip, and calculated NOx mass emission rates (lb/hr and lb/twelve month rolling period). [40 CFR 60.334(a), District Rule 2201, District Rule 4703, 6.2.6, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
31. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
32. The owner or operator shall be required to conform to the compliance testing and sampling procedures described in District Rule 1081 (as amended 12/16/93). [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a), Fresno County Rules 406, and District Rule 4801] Federally Enforceable Through Title V Permit
34. The sulfur content of each fuel source shall be documented in a valid purchase contract, a supplier certification, a tariff sheet, or a transportation contract. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
35. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
36. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
37. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) Have an Acid Rain permit. [40 CFR 72] Federally Enforceable Through Title V Permit
38. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
39. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
40. The owners and operators of each source and each affected unit at the source shall: (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit
41. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
42. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
43. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
44. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
45. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
46. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit
47. The owners and operators of each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

48. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
49. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) Pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
50. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
51. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
52. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-3811-2-7

EXPIRATION DATE: 05/31/2013

EQUIPMENT DESCRIPTION:

24.7 MW NOMINALLY RATED SIMPLE-CYCLE PEAK-DEMAND POWER GENERATING SYSTEM #2 CONSISTING OF PRATT & WHITNEY MODEL FT-8 NATURAL GAS-FIRED GAS TURBINE ENGINE WITH DRY LOW NOX (DLN) COMBUSTORS, SERVED BY A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM AND AN OXIDATION CATALYST WITH A 49.5 MW GENERATOR (SHARED WITH C-3811-1)

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. Selective catalytic reduction (SCR) system and oxidation catalyst shall serve the common exhaust duct from C-3811-1 and C-3811-2. Common exhaust ducting shall be equipped with a fresh air inlet and blower to be used to lower the exhaust temperature prior to inlet of the SCR system catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas turbine engine shall be equipped with a continuous monitoring system to measure and record hours of operation and fuel consumption. [District Rule 2201, District Rule 4703, 6.2.6, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
6. The owner or operator shall certify, maintain, operate, and quality-assure a system which continuously measures and records the exhaust gas NO_x and O₂ concentrations. [40 CFR 60.334(b) and District Rule 4703, 6.2.1] Federally Enforceable Through Title V Permit
7. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
8. The NO_x and O₂ CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specification 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 60.334(b)(1) and District Rule 1080, 6.3, 6.5, 6.6, & 7.2] Federally Enforceable Through Title V Permit
9. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
11. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and provisions to sample stack gases at ground level with a portable NOx, CO, and O2 analyzer. [District Rule 1081] Federally Enforceable Through Title V Permit
12. This unit shall be fired exclusively on natural gas as defined in 40 CFR 60.331(u) which has a total sulfur content of less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b) and Fresno County Rule 406] Federally Enforceable Through Title V Permit
13. The transitional period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 5.3.1.1] Federally Enforceable Through Title V Permit
14. Number of startups and shutdowns shall not exceed 365 in one calendar year. [District Rules 2201] Federally Enforceable Through Title V Permit
15. Each startup or shutdown shall not exceed 30 minutes. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
16. Combined emission rates from units C-3811-1 and C-3811-2 during startup or shutdown shall not exceed : 8.28 lb NOx/hr, 1.42 lb SOx/hr, 3.42 lb PM10/hr, 35.46 lb CO/hr, and 1.28 lb VOC/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Except during startup and shutdown, emission rates from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed any of the following limits: PM10 - 3.24 lb/hr, SOx (as SO2) - 1.42 lb/hr, NOx (as NO2) - 3.4 ppmvd @ 15% O2 and 6.16 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O2 and 1.28 lb/hr, CO - 30 ppmvd @ 15% O2 and 33.2 lb/hr, or ammonia - 10 ppmvd @ 15% O2. All emission limits are three hour rolling averages. [40 CFR 60.332, District Rules 2201, and District Rule 4703, 5.1 and 5.2] Federally Enforceable Through Title V Permit
18. Except during startup and shutdown, emission rates from gas turbine engine C-3811-1 shall not exceed any of the following limits: PM10 - 1.62 lb/hr, SOx (as SO2) - 0.71 lb/hr, NOx (as NO2) - 3.4 ppmvd @ 15% O2 and 3.08 lb/hr, VOC (as methane) - 2.0 ppmvd @ 15% O2 and 0.64 lb/hr, CO - 30 ppmvd @ 15% O2 and 16.6 lb/hr, or ammonia - 10 ppmvd @ 15% O2. All emission limits are three hour rolling averages. [40 CFR 60.332, District Rules 2201, and District Rule 4703, 5.1 and 5.2] Federally Enforceable Through Title V Permit
19. Daily emissions from gas turbine engine C-3811-2 shall not exceed any of the following emission limits, regardless of type of operation: 74.0 lb NOx/day, 17.0 lb SOx/day, 38.9 lb PM10/day, 385.2 lb CO/day, and 15.4 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Combined emission from units C-3811-1 and C-3811-2 shall not exceed any of the following emission limits, regardless of type of operation: 148.0 lb NOx/day, 34.0 lb SOx/day, 77.8 lb PM10/day, 770.4 lb CO/day, and 30.8 lb VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
21. NOx emissions from gas turbine engines C-3811-1 and C-3811-2 combined, shall not exceed 20,000 lb/year. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Compliance with ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O2 = ((a-(b x (c-d)/1,000,000)) x 1,000,000/b), where a = ammonia injection rate (lb/hr)/17 (lb/lb mol), b = dry exhaust gas flow rate (lb/hr)/29 (lb/lb mol), c = SCR inlet NOx concentration ppmv at 15% O2 for the operating load determined by the most recent source test data, and d = SCR outlet NOx concentration ppmv at 15% O2 from the continuous emission monitor. [District Rule 4102]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. Compliance testing to demonstrate compliance with the PM₁₀, NO_x (as NO₂), VOC, CO, and ammonia emission limits, and fuel gas sulfur content shall be conducted at least once every twelve months. Compliance testing may be demonstrated when both C-3811-1 and C-3811-2 are operating. NO_x emission concentration at the SCR inlet shall be determined for 50%, 75%, 90%, and 100% loads during annual compliance testing by measuring NO_x emissions at each load for a minimum of 5 minutes or until NO_x concentration has stabilized. [District Rule 1081 and District Rule 4703, 6.3.1] Federally Enforceable Through Title V Permit
24. Compliance demonstration (source testing) shall be District witnessed, or authorized and samples shall be collected by a California Air Resources Board certified testing laboratory. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The following test methods shall be used PM₁₀: EPA method 5 (front half and back half), NO_x: EPA Method 7E or 20, CO: EPA method 10 or 10B, O₂: EPA Method 3, 3A, or 20, VOC: EPA method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.8(a), 40 CFR 60.335(c)(3), District Rule 1081, and District Rule 4703, 6.4] Federally Enforceable Through Title V Permit
26. Results of continuous emissions monitoring shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
27. In lieu of the cylinder gas audit requirements of Appendix F to Part 60, quarterly audits of continuous emission monitors shall be conducted per the procedures and frequencies specified in Appendix B to Part 75, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified 48-hours prior to conducting the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080, District Rule 4703, 6.2.3, 40 CFR 60.334(iii) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
28. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NO_x emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
29. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
30. The permittee shall maintain the following records: hours of operation, fuel consumption (scf/hr and scf/rolling twelve month period), continuous emission monitor measurements, calculated ammonia slip, and calculated NO_x mass emission rates (lb/hr and lb/twelve month rolling period). [40 CFR 60.334(a), District Rule 2201, District Rule 4703, 6.2.6, and 40 CFR Part 64] Federally Enforceable Through Title V Permit
31. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
32. The owner or operator shall be required to conform to the compliance testing and sampling procedures described in District Rule 1081 (as amended 12/16/93). [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. Sulfur compound emissions shall not exceed 0.015% by volume, 150 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a), Fresno County Rules 406, and District Rule 4801] Federally Enforceable Through Title V Permit
34. The sulfur content of each fuel source shall be documented in a valid purchase contract, a supplier certification, a tariff sheet, or a transportation contract. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
35. All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device. [40 CFR 60.13(b) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
36. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
37. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) Have an Acid Rain permit. [40 CFR 72] Federally Enforceable Through Title V Permit
38. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
39. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
40. The owners and operators of each source and each affected unit at the source shall: (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit
41. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
42. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
43. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
44. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
45. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
46. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit
47. The owners and operators of each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

48. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
49. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) Pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
50. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
51. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
52. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C

Detailed Facility List

Detailed Facility Report
For Facility=3811 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

CAL PEAK POWER - PANOCHÉ, LLC 43699 WEST PANOCHÉ RD FIREBAUGH, CA 93622-9720	FAC #: STATUS: TELEPHONE:	C 3811 A 6192293770	TYPE: TOXIC ID:	TitleV	EXPIRE ON: AREA: INSP. DATE:	05/31/2013 3 / 04/13
---	---------------------------------	--	--------------------	---------------	------------------------------------	---

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
C-3811-1-7	24.7 MW	3020-08A F	1	8,171.00	8,171.00	A	24.7 MW NOMINALLY RATED SIMPLE-CYCLE PEAK-DEMAND POWER GENERATING SYSTEM #1 CONSISTING OF PRATT & WHITNEY MODEL FT-8 NATURAL GAS-FIRED GAS TURBINE ENGINE WITH DRY LOW NOX (DLN) COMBUSTORS, SERVED BY A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM AND AN OXIDATION CATALYST WITH A 49.5 MW GENERATOR (SHARED WITH C-3811-2)
C-3811-2-7	24.7 MW	3020-08A F	1	8,171.00	8,171.00	A	24.7 MW NOMINALLY RATED SIMPLE-CYCLE PEAK-DEMAND POWER GENERATING SYSTEM #2 CONSISTING OF PRATT & WHITNEY MODEL FT-8 NATURAL GAS-FIRED GAS TURBINE ENGINE WITH DRY LOW NOX (DLN) COMBUSTORS, SERVED BY A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM AND AN OXIDATION CATALYST WITH A 49.5 MW GENERATOR (SHARED WITH C-3811-1)

Number of Facilities Reported: 1