



JUN 22 2016

Mr. Christopher Sherman
Shell Pipelline Company LP
1801 Petrol Rd
Bakersfield, CA 93308-8793

**Re: Notice of Preliminary Decision – Title V Permit Renewal
District Facility # S-83
Project # 116077**


Dear Mr. Sherman:

Enclosed for your review and comment is the District's analysis of the application to renew the Federally Mandated Operating Permit for Shell Pipelline Company LP at 11300 Maricopa Hwy, Mettler, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the renewed Federally Mandated Operating Permit. Please submit your written comments on this project within the 30-day public comment period, as specified in the enclosed public notice.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,


Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT

Proposed Title V Permit Renewal Evaluation

TABLE OF CONTENTS

I.	PROPOSAL.....	2
II.	FACILITY LOCATION	2
III.	EQUIPMENT LISTING.....	3
IV.	GENERAL PERMIT TEMPLATE USAGE.....	3
V.	SCOPE OF EPA AND PUBLIC REVIEW	3
VI.	FEDERALLY ENFORCEABLE REQUIREMENTS.....	4
VII.	REQUIREMENTS NOT FEDERALLY ENFORCEABLE	5
VIII.	PERMIT REQUIREMENTS.....	6
IX.	PERMIT SHIELD	8
X.	PERMIT CONDITIONS.....	9
XI.	ATTACHMENTS	9
A.	DRAFT RENEWED TITLE V OPERATING PERMIT	
B.	PREVIOUS TITLE V OPERATING PERMIT	
C.	DETAILED FACILITY LIST	

TITLE V PERMIT RENEWAL EVALUATION
Crude Petroleum Pipeline Facility

Engineer: Richard Edgehill
Date: May 12, 2016

Facility Number: S-83
Facility Name: Shell Pipeline Company LP
Mailing Address: 1801 Petrol Rd
Bakersfield, CA 93308-9793

Contact Name: Christopher Sherman
Phone: (661) 391-2413

Responsible Official: Michael W. Bringham
Title: Operations Manager

Project # : 1160777
Deemed Complete: March 21, 2016

I. PROPOSAL

Shell Pipeline Company LP was issued a Title V permit which was last renewed on October 11, 2011. As required by District Rule 2520, the applicant is requesting a permit renewal. The existing Title V permit shall be reviewed and modified to reflect all applicable District and federal rules updated, removed, or added since the issuance of the renewed Title V permit.

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions.

II. FACILITY LOCATION

The facility is located at 11300 Maricopa Hwy, Mettler.

III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment A.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant is requesting to use the following model general permit Templates:

A. Template SJV-UM-0-3 Facility Wide Umbrella

The facility wide permit includes the conditions on template No. SJV-UM-0-3, Facility Wide Umbrella in addition to the following specific conditions:

1. *{118} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102] N*
42. *On June 30, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin July 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Y*

V. SCOPE OF EPA AND PUBLIC REVIEW

Certain segments of the proposed Renewed Operating Permit are based on model general permit templates that have been previously subject to EPA and public review. The terms and conditions from the model general permit templates are included in the proposed permit and are not subject to further EPA and public review.

For permit applications utilizing model general permit templates, public and agency comments on the District's proposed actions are limited to the applicant's eligibility for model general permit template, applicable requirements not covered by the model general permit template, and the applicable procedural requirements for issuance of Title V Operating Permits.

The following permit conditions, including their underlying applicable requirements, originate from model general permit templates and are not subject to further EPA or public review.

Conditions 2 through 41 of the requirements for permit unit S-82-0-3.

VI. FEDERALLY ENFORCEABLE REQUIREMENTS

A. Rules Updated

- District Rule 2020, Exemptions (amended December 18, 2014)
- District Rule 2201, New and Modified Stationary Source Review Rule (amended February 18, 2016)
- District Rule 4702, Internal Combustion Engines – Phase 2 (Amended November 14, 2013)
- 40 CFR Part 82, Subpart B Stratospheric Ozone (June 25, 2013)
- 40 CFR Part 82, Subpart F Stratospheric Ozone (June 25, 2013)

B. Rules Removed

None

C. Rules Added

Following rules are that are applicable to operation of this facility has been adopted since issuance of the initial Title V permit.

- District Rule 2410, Prevention of Significant Deterioration (adopted June 16, 2011, effective November 26, 2012)

D. Rules Not Updated

- District Rule 1070 Inspections (Amended December 17, 1992)
- District Rule 1080, Stack Monitoring (amended December 17, 1992)
- District Rule 1081, Source Sampling (amended December 16, 1993)
- District Rule 1100, Equipment Breakdown (amended December 17, 1992)
- District Rule 1160, Emission Statements (adopted November 18, 1992)
- District Rule 2010, Permits Required (amended December 17, 1992)
- District Rule 2031, Transfer of Permits (amended December 17, 1992)
- District Rule 2040, Applications (amended December 17, 1992)
- District Rule 2070, Standards for Granting Applications (amended December 17, 1992)
- District Rule 2080, Conditional Approval (amended December 17, 1992)
- District Rule 2520, Federally Mandated Operating Permits (amended June 21, 2001)
- District Rule 4002 National Emissions Standards for Hazardous Air Pollutants (Amended May 20, 2004)

40 CFR Subpart ZZZZ - -- National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)

- District Rule 4101, Visible Emissions (amended February 17, 2005)
- District Rule 4201, Particulate Matter Concentration (amended December 17, 1992)
- District Rule 4301, Fuel Burning Equipment (amended December 17, 1992)
- District Rule 4305, Boilers, Steam Generators and Process Heaters - Phase 2 (amended August 21, 2003)
- District Rule 4306, Boilers, Steam Generators and Process Heaters - Phase 3 (amended October 16, 2008)
- District Rule 4320, Advanced Emission Reduction Options for Boilers, Steam Generators and Process Heaters greater than 5.0 MMBtu/hr (adopted October 16, 2008)
- District Rule 4623, Storage of Organic Liquids (Amended 5/19/05)
- District Rule 4801, Sulfur Compounds (amended December 17, 1992)
- 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos
- 40 CFR Part 82, Subpart F, Stratospheric Ozone
- 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos (7/20/04)
- 40 CFR Part 64, Compliance Assurance Monitoring (10/22/97)
- District Rule 4601 Architectural Coatings (Amended December 17, 2009)
- 40 CFR Part 60 Appendix F (7/1/91)
- 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos (7/20/04)
- 40 CFR Part 64, Compliance Assurance Monitoring (CAM)

VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit".

For this facility, the following are not federally enforceable and will not be discussed in further detail:

A. Rules Added

None

B. Rules Not Updated

District Rule 4102, Nuisance (as amended December 17, 1992)

Condition 1 of permit unit -0-3 is based on District Rule 4102 and will therefore not be discussed any further.

VIII. PERMIT REQUIREMENTS

The purpose of this evaluation is to review changes to federally enforceable requirements; therefore, this compliance section will only address rules that have been amended or added since the issuance of the initial Title V permit or most recent renewal of the Title V permit.

A. District Rule 2020 - Exemptions

District Rule 2020 lists equipment which are specifically exempt from obtaining permits and specifies recordkeeping requirements to verify such exemptions. The amendments to this rule do not have any effect on current permit requirements and will therefore not be addressed in this evaluation.

A. District Rule 2201 - New and Modified Stationary Source Review Rule

District Rule 2201 has been amended since this facility's initial Title V permit was issued. However the requirements of this rule are only triggered at the time the source undergoes a modification. All applicable requirements from any NSR permit actions have already been incorporated into the current Title V permit.

B. District Rule 2520 - Federally Mandated Operating Permits

This last amendment of the rule incorporated several administrative corrections, clarified rule language, and added procedures for implementing compliance schedules. The only amendments to this rule that will have an effect on current permit requirements are the corrections to Section 9 rule references, as described in the following table:

Old Rule Section	Corrected Rule Section
9.3	9.2
9.4	9.3
9.5	9.4
9.6	9.5
9.7	9.6
9.8	9.7
9.9	9.8
9.10	9.9
9.11	9.10
9.12	9.11
9.13	9.12
9.14	9.13
9.15	9.14
9.16	9.15
9.17	9.16
9.18	9.17
9.19	9.18

C. District Rule 4101 - Visible Emissions

District Rule 4101 has been submitted to the EPA to replace SIP approved Rule 401 (all counties of the SJVUAPCD). EPA made a preliminary determination that District Rule 4101 is "more stringent" than the county versions previously referenced, per correspondence dated August 20, 1996.

Section 5.0 prohibits the discharge of any air contaminant for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker in shade as that designated as No. 1 on the Ringelmann Chart; or is of such opacity as to obscure an observer's view to a degree equal to or greater than the smoke described in Section 5.1 of Rule 4101. Condition 23 of permit unit -0-3 ensures compliance.

D. District Rule 4601 - Architectural Coatings

This rule limits the emissions of VOCs from architectural coatings. It requires limiting the application of any architectural coating to no more than what is listed in the Table of Standards (Section 5.0). This rule further specifies labeling requirements, coatings thinning recommendations, and storage requirements.

The following changes were included in the latest rule amendment that resulted in adding new permit requirements and/or revising current permit requirements:

- The tables outlining the VOC content of different specialty coatings has been largely replaced with the Table of Standards in Section 5.0.
- New labeling, reporting, test methodology and other requirements have been incorporated into the rule in order to allow ARB to administer the Averaging Program as detailed in Section 8.0.

The following permit requirements were added and/or revised to ensure compliance with this rule:

a. S-83-0-3 – Brief Equipment Description

- Conditions 23, 24, and 25 ensure compliance with the revised requirements of this rule.

F. 40 CFR Part 64-CAM

40 CFR Part 64 requires Compliance Assurance Monitoring (CAM) for units that meet the following three criteria:

- 1) the unit must have an emission limit for the pollutant;
- 2) the unit must have add-on controls for the pollutant; these are devices such as flue gas recirculation (FGR), baghouses, and catalytic oxidizers; and
- 3) the unit must have a pre-control potential to emit of greater than the major source thresholds.

None of the permit units at this facility are subject to CAM.

IX. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

Conditions 40 and 41 on the proposed permit S-83-0-3 are permit shields for the facility.

X. PERMIT CONDITIONS

See Attachment A - Draft Renewed Title V Operating Permit.

XI. ATTACHMENTS

- A. Draft Renewed Title V Operating Permit
- B. Previous Title V Operating Permit
- C. Detailed Facility List

ATTACHMENT A

Draft Renewed Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: S-83-0-3

EXPIRATION DATE: 08/31/2016

FACILITY-WIDE REQUIREMENTS

1. {118} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. {4362} The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. {4363} The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
4. {4364} The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
5. {4365} Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
6. {4366} The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
7. {4367} A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
8. {4368} Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
9. {4369} The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: SHELL PIPELINE COMPANY LP
Location: EMIDIO STATION, METTLER, CA
S-83-0-3 : May 16 2016 8:42AM - EDGEHILL

10. {4370} The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
11. {4371} The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
12. {4372} Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
13. {4373} If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
14. {4374} It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
15. {4375} The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
16. {4376} The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
17. {4377} The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
18. {4378} The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
19. {4379} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
20. {4380} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
21. {4381} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
22. {4382} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. {4383} No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
24. {4384} No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
25. {4385} All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
26. {4386} The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
27. {4387} With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
28. {4388} If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
29. {4389} If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
30. {4390} Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8021 and 8011] Federally Enforceable Through Title V Permit
31. {4391} Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8031 and 8011] Federally Enforceable Through Title V Permit
32. {4392} An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8041 and 8011] Federally Enforceable Through Title V Permit
33. {4393} Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8051 and 8011] Federally Enforceable Through Title V Permit
34. {4394} Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8061 and Rule 8011] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. {4395} Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8071 and Rule 8011] Federally Enforceable Through Title V Permit
36. {4396} Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit
37. {4397} The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
38. {4398} The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
39. {4399} When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
40. {4400} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. {4401} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. On June 30, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin July 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-1-4

EXPIRATION DATE: 08/31/2016

SECTION: SE 7 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

3,360,000 GALLON RIVETED INTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #80102 WITH METALLIC SHOE PRIMARY AND SECONDARY WIPER SEAL

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.3.1.3] Federally Enforceable Through Title V Permit
2. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred as the secondary seal. [District Rule 4623, 5.3.1.2] Federally Enforceable Through Title V Permit
3. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
5. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
6. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
7. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
8. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
9. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 18 inches above the stored liquid surface. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
10. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.2.3] Federally Enforceable Through Title V Permit
11. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3.2.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.2.5] Federally Enforceable Through Title V Permit
13. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3.2.2.6] Federally Enforceable Through Title V Permit
14. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.2 & 5.5.1] Federally Enforceable Through Title V Permit
15. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.11] Federally Enforceable Through Title V Permit
16. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.1.1] Federally Enforceable Through Title V Permit
17. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5.2.1.2] Federally Enforceable Through Title V Permit
18. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.1.3] Federally Enforceable Through Title V Permit
19. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.1.4] Federally Enforceable Through Title V Permit
20. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5.2.1.5] Federally Enforceable Through Title V Permit
21. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5.2.1.6] Federally Enforceable Through Title V Permit
22. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repaired, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1.3.2.1] Federally Enforceable Through Title V Permit
23. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1.3.2.2] Federally Enforceable Through Title V Permit
24. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1.3.2.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5] Federally Enforceable Through Title V Permit
26. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
27. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
28. The true vapor pressure (TVP), at storage conditions, of the organic liquid stored in the internal floating roof tank shall be less than 11.0 psia [District Rule 4623, 5.1.1] Federally Enforceable Through Title V Permit
29. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 12 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D.323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-2-6

EXPIRATION DATE: 08/31/2016

SECTION: SE 7 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

3,360,000 GALLON RIVETED INTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #80103 EQUIPPED WITH A NEW INTERNAL FLOATING ROOF WITH HITEQ PRIMARY METALLIC SHOE AND SECONDARY WIPER SEALS.

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.3.1.3] Federally Enforceable Through Title V Permit
2. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred as the secondary seal. [District Rule 4623, 5.3.1.2] Federally Enforceable Through Title V Permit
3. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
5. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
6. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
7. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
8. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
9. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 18 inches above the stored liquid surface. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
10. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.2.3] Federally Enforceable Through Title V Permit
11. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3.2.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.2.5] Federally Enforceable Through Title V Permit
13. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3.2.2.6] Federally Enforceable Through Title V Permit
14. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.2 & 5.5.1] Federally Enforceable Through Title V Permit
15. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.11] Federally Enforceable Through Title V Permit
16. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.1.1] Federally Enforceable Through Title V Permit
17. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5.2.1.2] Federally Enforceable Through Title V Permit
18. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.1.3] Federally Enforceable Through Title V Permit
19. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.1.4] Federally Enforceable Through Title V Permit
20. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5.2.1.5] Federally Enforceable Through Title V Permit
21. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5.2.1.6] Federally Enforceable Through Title V Permit
22. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repaired, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1.3.2.1] Federally Enforceable Through Title V Permit
23. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1.3.2.2] Federally Enforceable Through Title V Permit
24. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1.3.2.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5] Federally Enforceable Through Title V Permit
26. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
27. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
28. The true vapor pressure (TVP), at storage conditions, of the organic liquid stored in the internal floating roof tank shall be less than 11.0 psia [District Rule 4623, 5.1.1] Federally Enforceable Through Title V Permit
29. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 12 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-3-4

EXPIRATION DATE: 08/31/2016

SECTION: SE 7 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

3,360,000 GALLON RIVETED INTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #80104 EQUIPPED WITH NEW INTERNAL FLOATING ROOF WITH HITEQ PRIMARY METALLIC SHOE AND SECONDARY WIPER SEALS

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.3.1.3] Federally Enforceable Through Title V Permit
2. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred to as the secondary seal. [District Rule 4623, 5.3.1.2] Federally Enforceable Through Title V Permit
3. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
5. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
6. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
7. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
8. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
9. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 18 inches above the stored liquid surface. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
10. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.2.3] Federally Enforceable Through Title V Permit
11. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3.2.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.2.5] Federally Enforceable Through Title V Permit
13. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3.2.2.6] Federally Enforceable Through Title V Permit
14. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.2 & 5.5.1] Federally Enforceable Through Title V Permit
15. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.11] Federally Enforceable Through Title V Permit
16. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.1.1] Federally Enforceable Through Title V Permit
17. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5.2.1.2] Federally Enforceable Through Title V Permit
18. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.1.3] Federally Enforceable Through Title V Permit
19. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.1.4] Federally Enforceable Through Title V Permit
20. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5.2.1.5] Federally Enforceable Through Title V Permit
21. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5.2.1.6] Federally Enforceable Through Title V Permit
22. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repaired, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1.3.2.1] Federally Enforceable Through Title V Permit
23. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1.3.2.2] Federally Enforceable Through Title V Permit
24. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1.3.2.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5] Federally Enforceable Through Title V Permit
26. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
27. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
28. The true vapor pressure (TVP), at storage conditions, of the organic liquid stored in the internal floating roof tank shall be less than 11.0 psia [District Rule 4623, 5.1.1] Federally Enforceable Through Title V Permit
29. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 12 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-5-11

EXPIRATION DATE: 08/31/2016

SECTION: SE 7 **TOWNSHIP:** 11N **RANGE:** 20W

EQUIPMENT DESCRIPTION:

12.5 MMBTU/HR NATURAL GAS OR LPG FIRED HEATER WITH FLUE GAS RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
8. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
9. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
10. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.0] Federally Enforceable Through Title V Permit
11. The unit shall only be fired on PUC-regulated natural gas or LPG. [District Rule 2201] Federally Enforceable Through Title V Permit
12. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed in each fuel line, utilized and maintained. [District Rules 2201, 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
13. Maximum annual heat input of the unit shall not exceed 30 billion Btu per calendar year. [District Rules 2201, 4305, 5.2 and 4306, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

14. Except during start-up and shutdown emissions rates from the use of natural gas to fire this unit shall not exceed the following limits: 30 ppmv NO_x @ 3% O₂ or 0.036 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 400 ppmv CO @ 3%O₂ or 0.296 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, and 4351, 5.1] Federally Enforceable Through Title V Permit
15. Except during start-up and shutdown emissions rates from the use of LPG to fire this unit shall not exceed the following limits: 30 ppmv NO_x @ 3% O₂ or 0.036 lb-NO_x/MMBtu, 0.0164 lb-SO_x/MMBtu, 0.0066 lb-PM₁₀/MMBtu, 400 ppmv CO @ 3%O₂ or 0.296 lb-CO/MMBtu, or 0.0058 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, and 4351, 5.1] Federally Enforceable Through Title V Permit
16. During start-up and shutdown periods emissions from the process heater shall not exceed the following limits: 1.25 lb-NO_x/hr, 0.21 lb-SO_x/hr, 0.10 lb-PM₁₀/hr, 3.70lb-CO/hr, or 0.07 lb-VOC/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence, two hours per day, and 400 hours per year. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
20. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4 and 5.5] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
24. Source testing to measure NOx and CO emissions from natural gas-combustion and LPG-combustion in this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, and 4351, 6.3.1] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
26. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
27. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
29. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
31. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
32. Records of monthly and annual heat input of the unit shall be maintained. [District Rules 2201, 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
33. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
34. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted fuel is LPG or natural gas provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
35. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
36. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-7-10

EXPIRATION DATE: 08/31/2016

SECTION: SE07 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

33.75 MMBTU/HR G.C. BROACH NATURAL GAS-FIRED CRUDE OIL PIPELINE PROCESS HEATER WITH A NORTH AMERICAN LEX MODEL 4213-42/X5257 ULTRA LOW NOX BURNER

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The unit shall only be fired on PUC-regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Emission rates, except during startup and shutdown shall not exceed any of the following: NOx (as NO₂): 7 ppmv @3% O₂ or 0.008 lb/MMBtu, PM₁₀: 0.0076 lb/MMBtu, SOx (as SO₂): 0.00285 lb/MMBtu, CO: 400 ppmvd @ 3% O₂, VOC: 0.0055 lb/MMBtu. [District Rule 2201; District Rules 4301, 5.2, 4305, 5.1, 4306, 5.1 and 4320,5.2] Federally Enforceable Through Title V Permit
5. Daily emissions shall not exceed either of the following: NOx: 29.2 lbs/day, or 2,365 lbs/year. [District Rules 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320,5.6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
8. The permittee shall monitor and record the stack concentration of NOx, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320,5.7.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320,5.2.1] Federally Enforceable Through Title V Permit
10. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320,5.7.1] Federally Enforceable Through Title V Permit
11. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320,6.1] Federally Enforceable Through Title V Permit
12. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2, 4306, 5.5.2, and 4320,5.8.2] Federally Enforceable Through Title V Permit
13. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, and 4320,6.3.1.1] Federally Enforceable Through Title V Permit
14. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
15. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1, and 4320,5.7.5] Federally Enforceable Through Title V Permit
16. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2, and 4320,6.2.5] Federally Enforceable Through Title V Permit
17. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2, and 4320,6.2.3] Federally Enforceable Through Title V Permit
18. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2, and 4320] Federally Enforceable Through Title V Permit
19. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5, and 4320,5.8.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4305, 6.1, 4306, 6.1, and 4320,6.1] Federally Enforceable Through Title V Permit
22. The owner or operator of a boiler, steam generator, or process heater subject to the requirement of District Rule 4320 shall be in full compliance with the rule, in accordance with the deadlines stated in section 7.0 of the rule. [District Rule 4320, 7.0] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-8-9

EXPIRATION DATE: 08/31/2016

SECTION: SE07 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

33.75 MMBTU/HR G.C. BROACH NATURAL GAS-FIRED CRUDE OIL PIPELINE HEATER WITH NORTH AMERICAN LEX SERIES 4213-42/X5257 ULTRA-LOW NOX BURNER WITH FGR AND FUEL FLOW METER (EMIDIO PUMP STATION)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rules 4201, 3.0 and 4301, 5.1] Federally Enforceable Through Title V Permit
3. This heater shall be fired only on PUC-regulated natural Gas. [District Rules 4801, 3.1, 4320, 5.2 and County Rule 407 (Kern)] Federally Enforceable Through Title V Permit
4. Emission rates, except during startup and shutdown, shall not exceed any of the following: PM10: 0.0137 lb/MMBtu, SOx (as SO2): 0.00285 lb/MMBtu, NOx (as NO2): 0.008 lb/MMBtu or 7 ppmv @ 3% O2, VOC: 0.0028 lb/MMBtu, CO: 0.30 lb/MMBtu or 400 ppmv @ 3% O2. [District Rule 2201; District Rules 4301, 5.2, 4305, 5.1, 4306, 5.1, and 4320, 5.2] Federally Enforceable Through Title V Permit
5. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320, 5.6.1] Federally Enforceable Through Title V Permit
6. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22 and 4320, 3.29] Federally Enforceable Through Title V Permit
7. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, and 4320, 6.3.1.1] Federally Enforceable Through Title V Permit
8. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, and 4320, 5.7.5] Federally Enforceable Through Title V Permit
10. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2.2, 4306, and 4320, 6.2.5] Federally Enforceable Through Title V Permit
11. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2.3, 4306 and 4320, 6.2.3] Federally Enforceable Through Title V Permit
12. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2.4, 4306 and 4320, 6.2.4] Federally Enforceable Through Title V Permit
13. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no emissions measurements shall be made within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2, 4306, 5.5.2, and 4320, 5.8.2] Federally Enforceable Through Title V Permit
14. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.4, 4306, and 4320, 5.8.5] Federally Enforceable Through Title V Permit
15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4.2, 4306, 5.4, and 4320, 5.7.1] Federally Enforceable Through Title V Permit
17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4.2, 4306, 6.1, and 4320, 5.2.1] Federally Enforceable Through Title V Permit
18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5.4, 4306, 5.4, and 4320, 5.7.1] Federally Enforceable Through Title V Permit
19. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, and 4320, 6.1] Federally Enforceable Through Title V Permit
20. Daily average fuel use shall not exceed 607.5 MMBtu/day in any calendar quarter. Permittee shall maintain records of volume of gas combusted in each calendar quarter. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. Records of monthly and annual heat input of the unit shall be maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
22. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4305, 6.1, 4306, and 4320, 6.1] Federally Enforceable Through Title V Permit
23. The owner or operator of a boiler, steam generator, or process heater subject to the requirement of District Rule 4320 shall be in full compliance with the rule, in accordance with the deadlines stated in section 7.0 of the rule. [District Rule 4320, 7.0] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-9-5

EXPIRATION DATE: 08/31/2016

SECTION: NW07 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

7,770,000 GALLON (185,000 BBL) EXTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #185GK5 WITH PRIMARY METALLIC SHOE SEAL AND ROOF MOUNTED WIPER TYPE SECONDARY SEAL

PERMIT UNIT REQUIREMENTS

1. Tank shall be equipped with operational temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The true vapor pressure (TVP) of any liquid introduced, placed, or stored shall not exceed 4.5 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Throughput shall not exceed 100,000 bbl/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. VOC emission rate shall not exceed 38.1 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred as the secondary seal. [District Rule 2201; District Rule 4623, 5.3.1.2 and 40 CFR 60.112b(a)(2)(i)] Federally Enforceable Through Title V Permit
6. The external floating roof shall float on the surface of the stored liquid at all times (i.e., off the roof leg supports) except during the initial fill until the roof is lifted off the leg supports and when the tank is completely emptied and subsequently refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five calendar days prior to performing the work. The tank must be in compliance with this rule before it may land on its legs. [District Rule 4623, 5.3.1.3 and 40 CFR 60.112b(a)(2)(iii)] Federally Enforceable Through Title V Permit
7. Gaps between the tank shell and the primary seal shall not exceed 1 1/2 inches. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
8. The cumulative length of all gaps between the tank shell and the primary seal greater than 1/2 inch shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
9. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
10. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
11. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.1.2, 6.1 and 40 CFR 60.113b(b)(4)(ii)(B)] Federally Enforceable Through Title V Permit
12. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.1.2 and 40 CFR 60.113b(b)(4)(ii)(B)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

13. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 24 inches above the stored liquid surface. [District Rule 4623, 5.3.2.1.3 and 40 CFR 60.113b(b)(4)(i)(A)] Federally Enforceable Through Title V Permit
14. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 3 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.1.4] Federally Enforceable Through Title V Permit
15. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. Except for gaps meeting permit requirements, the primary seal shall completely cover the annular space between the edge of the floating roof and tank wall. [District Rule 4623, 5.3.2.1.5; 40 CFR 60.112b(a)(2)(i)(A), 40 CFR 60.113b(b)(4)(i)(B) and 60.113b(b)(4)(ii)(C)] Federally Enforceable Through Title V Permit
16. The secondary seal shall allow easy insertion of probes of up to 1 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.1.6] Federally Enforceable Through Title V Permit
17. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. Except for gaps meeting permit requirements, the secondary seal shall completely cover the annular space between the external floating roof and the wall of the storage vessel in a continuous fashion. [District Rule 4623, 5.3.2.1.7; 40 CFR 60.112b(a)(2)(i)(B) and 40 CFR 60.113b(b)(4)(ii)(A)] Federally Enforceable Through Title V Permit
18. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.2 & 5.5.1] Federally Enforceable Through Title V Permit
19. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.10 and 6.4.8] Federally Enforceable Through Title V Permit
20. Except for automatic bleeder vents, rim vents, and pressure relief vents, each opening in a non-contact external floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.2.1, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
21. Except for automatic bleeder vents and rim vents, roof drains, and leg sleeves, each opening in the roof shall be equipped with a gasketed cover, seal, or lid that shall be maintained in a closed position at all times (i.e., no visible gap) except when in actual use. [District Rule 4623, 5.5.2.2.2, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
22. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.2.3, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
23. Rim vents shall be equipped with a gasket and shall be set to open when the roof is being floated off the roof leg supports or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.2.4, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
24. Each emergency roof drain shall be provided with a slotted membrane fabric cover that covers at least 90 percent of the area of the opening. The fabric cover must be impermeable if the liquid is drained into the contents of the tanks. [District Rule 4623, 5.5.2.2.5, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
25. External floating roof legs shall be equipped with vapor socks or vapor barriers in order to maintain a gas-tight condition so as to prevent VOC emissions from escaping through the roof leg opening. [District Rule 4623, 5.5.2.2.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

26. All wells and similar fixed projections through the floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.3.1] Federally Enforceable Through Title V Permit
27. The solid guidepole well shall be equipped with a pole wiper and a gasketed cover, seal or lid which shall be in a closed position at all times (i.e., no visible gap) except when the well is in use. [District Rule 4623, 5.5.2.3.2] Federally Enforceable Through Title V Permit
28. The gap between the pole wiper and the solid guidepole shall be added to the gaps measured to determine compliance with the secondary seal requirement, and in no case shall exceed 1/2 inch. [District Rule 4623, 5.5.2.3.3] Federally Enforceable Through Title V Permit
29. The slotted guidepole well on an external floating roof shall be equipped with the following: a sliding cover, a well gasket, a pole sleeve, a pole wiper, and an internal float and float wiper designed to minimize the gap between the float and the well, and provided the gap shall not exceed 1/8 inch; or shall be equipped with a well gasket, a zero gap pole wiper seal and a pole sleeve that projects below the liquid surface. [District Rule 4623, 5.5.2.4.2] Federally Enforceable Through Title V Permit
30. The gap between the pole wiper and the slotted guidepole shall be added to the gaps measured to determine compliance with the secondary seal requirement, and in no case shall exceed 1/8 inch. [District Rule 4623, 5.5.2.4.3] Federally Enforceable Through Title V Permit
31. The permittee of external floating roof tanks shall make the primary seal envelope available for unobstructed inspection by the APCO on an annual basis at locations selected along its circumference at random by the APCO. In the case of riveted tanks with toroid-type seals, a minimum of eight locations shall be made available; in all other cases, a minimum of four locations shall be made available. If the APCO suspects a violation may exist the APCO may require such further unobstructed inspection of the primary seal as may be necessary to determine the seal condition for its entire circumference. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
32. Measurements of gaps between the tank wall and the primary and secondary seal shall be performed during the hydrostatic testing of the vessel or within 60 days of the initial fill with a volatile organic liquid. [40 CFR 60.113b(b)(1)(i)] Federally Enforceable Through Title V Permit
33. If any source ceases to store volatile organic liquid for a period of 1 year or more, subsequent introduction of volatile organic liquid into the vessel shall be considered an initial fill. [40 CFR 60.113b(b)(1)(iii)] Federally Enforceable Through Title V Permit
34. The permittee shall inspect all floating roof tanks at least once every 12 months to determine compliance with the requirements of this rule. The actual gap measurements of the floating roof primary and secondary seals shall be recorded. Permittee shall measure seal gaps, at one or more floating roof levels when the roof is floating off the roof leg supports, around the entire circumference of the tank in each place where a 0.32-cm diameter uniform probe passes freely (without forcing or binding against seal) between the seal and the wall of the storage vessel and measure the circumferential distance of each such location. The inspection results shall be submitted to the APCO as specified in Section 6.3.5. [County Rule 107 (40 CFR 60.113b(b)(1)(i) & (ii); and 40 CFR 60.113b(b)(2)(i) & (ii)] Federally Enforceable Through Title V Permit
35. The permittee shall inspect the primary and secondary seals for compliance with the requirements of this rule every time a tank is emptied or degassed. Actual gap measurements shall be performed when the liquid level is static but not more than 48 hours after the tank roof is re-floated. If the external floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, the owner or operator shall repair the items as necessary before filling or refilling the storage vessel. The owner or operator shall notify the APCO in writing at least 30 days prior to the filling or refilling of each storage vessel to afford the APCO the opportunity to inspect the storage vessel prior to refilling. [District Rule 4623, 6.1.3.2 and 40 CFR 60.113b(b)(6)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5 and 40 CFR 60.115b(b)] Federally Enforceable Through Title V Permit
37. ~~Permittee shall maintain the records of the external floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit~~
38. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3 and 40 CFR 60.116b(a)] Federally Enforceable Through Title V Permit
39. Permittee shall notify District at least 30 days prior to the date when unobstructed primary and secondary seal/gap measurements will occur to afford the APCO the opportunity to have an observer present. [40 CFR 60.113b(b)(5)] Federally Enforceable Through Title V Permit
40. Permittee shall maintain a record of the liquid stored, the period of storage, and the maximum true vapor pressure of that liquid during the respective storage period. [40 CFR 60.116b(c)] Federally Enforceable Through Title V Permit
41. Permittee shall make necessary repairs or empty the storage vessel within 45 days of identification in any inspection for seals not meeting the requirements listed in 40 CFR 60.113b(b)(4)(i) and (ii). If necessary repairs cannot be made within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the APCO. Such an extension request must include a demonstration of unavailability of alternate storage capacity and a specification of a schedule that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible. [40 CFR 60.113b(b)(4)] Federally Enforceable Through Title V Permit
42. The owner or operator of each storage vessel shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel. Such records shall be retained for the life of the source. [40 CFR 60.116b(b)] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of daily throughput. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
44. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rule 2520, 9.3.2, 4623, 6.4.3 and 6.2] Federally Enforceable Through Title V Permit
45. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (amended May 19, 2005) and 40CFR60 Subpart Kb. A permit shield is granted from this requirement. [District Rule 2520, 13.2]

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-11-4

EXPIRATION DATE: 08/31/2016

SECTION: NW7 **TOWNSHIP:** 11N **RANGE:** 20W

EQUIPMENT DESCRIPTION:

235 HP CATERPILLAR MODEL 3208 DIESEL-FIRED EMERGENCY IC ENGINE WITH TURBOCHARGER DRIVING EMERGENCY FIRE WATER PUMP

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
2. Engine shall be equipped with a turbocharger. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Engine shall be equipped with positive crankcase ventilation (PVC) system or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Emissions shall not exceed 4.3 g NOx/hp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
6. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. Engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. Engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
10. Engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702 and 40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
11. Engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. Engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. Engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. Engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. Permittee shall maintain records of performance tests and performance evaluations as required in §63.10(b)(2)(viii) and records of required maintenance performed on the air pollution control and monitoring equipment. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. Permittee shall maintain records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. Permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
19. Permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [District Rule 2520, 9.4 and 17 CCR 93115] Federally Enforceable Through Title V Permit
20. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rules 1070, 4702, 2520, 17 CCR 93115, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-12-9

EXPIRATION DATE: 08/31/2016

SECTION: SE 7 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

4,200,000 GALLON (100,000 BBL) WELDED EXTERNAL FLOATING ROOF PETROLEUM STORAGE TANK # 100GK6 WITH METALLIC SHOE PRIMARY SEAL AND ROOF MOUNTED WIPER TYPE SECONDARY SEAL

PERMIT UNIT REQUIREMENTS

1. Vapor control requirements of NSPS Subpart Kb and Rule 4623 are not applicable when the tank stores, places, or holds organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4001 and 4623] Federally Enforceable Through Title V Permit
2. Before switching to the storage of organic liquids with true vapor pressure greater than or equal to 0.5 psia, all covers, seals, and lids shall be inspected by the facility operator to ensure compliance with the provisions of this permit. This includes all conditions containing District Rule 4623 or 40 CFR 60 Subpart Kb references. [District Rule 2080] Federally Enforceable Through Title V Permit
3. Within one week after switching from storage of organic liquids with TVP greater than or equal to 0.5 psia to storage of organic liquids with TVP less than 0.5 psia, the TVP of the organic liquid shall be determined in accordance with the test methods of District Rule 4623 Section 6.4 (Amended May 19, 2005) or an equivalent method approved by the APCO, ARB, and EPA. [District Rule 4623,6.4] Federally Enforceable Through Title V Permit
4. Tank shall be equipped with operational temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Throughput shall not exceed 100,000 bbl/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. VOC emission rate shall not exceed 84.1 lb/day on a monthly average daily basis. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The True Vapor Pressure (TVP) of any liquid introduced, placed, or stored shall be less than 11.0 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
8. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred to as the secondary seal. [District Rule 2201; District Rule 4623, 5.3.1.2 and 40 CFR 60.112b(a)(2)(i)] Federally Enforceable Through Title V Permit
9. The external floating roof shall float on the surface of the stored liquid at all times (i.e., off the roof leg supports) except during the initial fill until the roof is lifted off the leg supports and when the tank is completely emptied and subsequently refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five calendar days prior to performing the work. The tank must be in compliance with this rule before it may land on its legs. [District Rule 4623, 5.3.1.3 and 40 CFR 60.112b(a)(2)(iii)] Federally Enforceable Through Title V Permit
10. Gaps between the tank shell and the primary seal shall not exceed 1 1/2 inches. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. The cumulative length of all gaps between the tank shell and the primary seal greater than 1/2 inch shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
12. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
13. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
14. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.1.2, 6.1 and 40 CFR 60.113b(b)(4)(ii)(B)] Federally Enforceable Through Title V Permit
15. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.1.2 and 40 CFR 60.113b(b)(4)(ii)(B)] Federally Enforceable Through Title V Permit
16. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 24 inches above the stored liquid surface. [District Rule 4623, 5.3.2.1.3 and 40 CFR 60.113b(b)(4)(i)(A)] Federally Enforceable Through Title V Permit
17. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 3 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.1.4] Federally Enforceable Through Title V Permit
18. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. Except for gaps meeting permit requirements, the primary seal shall completely cover the annular space between the edge of the floating roof and tank wall. [District Rule 4623, 5.3.2.1.5; 40 CFR 60.112b(a)(2)(i)(A), 40 CFR 60.113b(b)(4)(i)(B) and 60.113b(b)(4)(ii)(C)] Federally Enforceable Through Title V Permit
19. The secondary seal shall allow easy insertion of probes of up to 1 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.1.6] Federally Enforceable Through Title V Permit
20. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. Except for gaps meeting permit requirements, the secondary seal shall completely cover the annular space between the external floating roof and the wall of the storage vessel in a continuous fashion. [District Rule 4623, 5.3.2.1.7; 40 CFR 60.112b(a)(2)(i)(B) and 40 CFR 60.113b(b)(4)(ii)(A)] Federally Enforceable Through Title V Permit
21. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.2 & 5.5.1] Federally Enforceable Through Title V Permit
22. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.10 and 6.4.8] Federally Enforceable Through Title V Permit
23. Except for automatic bleeder vents, rim vents, and pressure relief vents, each opening in a non-contact external floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.2.1, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
24. Except for automatic bleeder vents and rim vents, roof drains, and leg sleeves, each opening in the roof shall be equipped with a gasketed cover, seal, or lid that shall be maintained in a closed position at all times (i.e., no visible gap) except when in actual use. [District Rule 4623, 5.5.2.2.2, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

25. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.2.3, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
26. Rim vents shall be equipped with a gasket and shall be set to open when the roof is being floated off the roof leg supports or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.2.4, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
27. Each emergency roof drain shall be provided with a slotted membrane fabric cover that covers at least 90 percent of the area of the opening. The fabric cover must be impermeable if the liquid is drained into the contents of the tanks. [District Rule 4623, 5.5.2.2.5, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
28. External floating roof legs shall be equipped with vapor socks or vapor barriers in order to maintain a gas-tight condition so as to prevent VOC emissions from escaping through the roof leg opening. [District Rule 4623, 5.5.2.2.6] Federally Enforceable Through Title V Permit
29. All wells and similar fixed projections through the floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.3.1] Federally Enforceable Through Title V Permit
30. The solid guidepole well shall be equipped with a pole wiper and a gasketed cover, seal or lid which shall be in a closed position at all times (i.e., no visible gap) except when the well is in use. [District Rule 4623, 5.5.2.3.2] Federally Enforceable Through Title V Permit
31. The gap between the pole wiper and the solid guidepole shall be added to the gaps measured to determine compliance with the secondary seal requirement, and in no case shall exceed 1/2 inch. [District Rule 4623, 5.5.2.3.3] Federally Enforceable Through Title V Permit
32. The slotted guidepole well on a external floating roof shall be equipped with the following: a sliding cover, a well gasket, a pole sleeve, a pole wiper, and an internal float and float wiper designed to minimize the gap between the float and the well, and provided the gap shall not exceed 1/8 inch; or shall be equipped with a well gasket, a zero gap pole wiper seal and a pole sleeve that projects below the liquid surface. [District Rule 4623, 5.5.2.4.2] Federally Enforceable Through Title V Permit
33. The gap between the pole wiper and the slotted guidepole shall be added to the gaps measured to determine compliance with the secondary seal requirement, and in no case shall exceed 1/8 inch. [District Rule 4623, 5.5.2.4.3] Federally Enforceable Through Title V Permit
34. The permittee of external floating roof tanks shall make the primary seal envelope available for unobstructed inspection by the APCO on an annual basis at locations selected along its circumference at random by the APCO. In the case of riveted tanks with toroid-type seals, a minimum of eight locations shall be made available; in all other cases, a minimum of four locations shall be made available. If the APCO suspects a violation may exist the APCO may require such further unobstructed inspection of the primary seal as may be necessary to determine the seal condition for its entire circumference. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
35. Measurements of gaps between the tank wall and the primary and secondary seal shall be performed during the hydrostatic testing of the vessel or within 60 days of the initial fill with a volatile organic liquid. [40 CFR 60.113b(b)(1)(i)] Federally Enforceable Through Title V Permit
36. If any source ceases to store volatile organic liquid for a period of 1 year or more, subsequent introduction of volatile organic liquid into the vessel shall be considered an initial fill. [40 CFR 60.113b(b)(1)(iii)] Federally Enforceable Through Title V Permit
37. The permittee shall inspect all floating roof tanks at least once every 12 months to determine compliance with the requirements of this rule. The actual gap measurements of the floating roof primary and secondary seals shall be recorded. Permittee shall measure seal gaps, at one or more floating roof levels when the roof is floating off the roof leg supports, around the entire circumference of the tank in each place where a 0.32-cm diameter uniform probe passes freely (without forcing or binding against seal) between the seal and the wall of the storage vessel and measure the circumferential distance of each such location. The inspection results shall be submitted to the APCO as specified in Section 6.3.5. [District Rule 4623, 6.1.3.1; 40 CFR 60.113b(b)(1)(i) & (ii); and 40 CFR 60.113b(b)(2)(i) & (ii)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

38. The permittee shall inspect the primary and secondary seals for compliance with the requirements of this rule every time a tank is emptied or degassed. Actual gap measurements shall be performed when the liquid level is static but not more than 48 hours after the tank roof is re-floated. If the external floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, the owner or operator shall repair the items as necessary before filling or refilling the storage vessel. The owner or operator shall notify the APCO in writing at least 30 days prior to the filling or refilling of each storage vessel to afford the APCO the opportunity to inspect the storage vessel prior to refilling. [District Rule 4623, 6.1.3.2 and 40 CFR 60.113b(b)(6)] Federally Enforceable Through Title V Permit
39. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5 and 40 CFR 60.115b(b)] Federally Enforceable Through Title V Permit
40. Permittee shall notify District at least 30 days prior to the date when unobstructed primary and secondary seal/gap measurements will occur to afford the APCO the opportunity to have an observer present. [40 CFR 60.113b(b)(5)] Federally Enforceable Through Title V Permit
41. Permittee shall make necessary repairs or empty the storage vessel within 45 days of identification in any inspection for seals not meeting the requirements listed in 40 CFR 60.113b(b)(4)(i) and (ii). If necessary repairs cannot be made within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the APCO. Such an extension request must include a demonstration of unavailability of alternate storage capacity and a specification of a schedule that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible. [40 CFR 60.113b(b)(4)] Federally Enforceable Through Title V Permit
42. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rules 2520, 9.3.2 and 4623, 6.2] Federally Enforceable Through Title V Permit
43. The owner or operator of each storage vessel shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel. Such records shall be retained for the life of the source. [40 CFR 60.116b(b)] Federally Enforceable Through Title V Permit
44. Permittee shall maintain records of average daily throughput. [District Rule 2201 and District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
45. Permittee shall maintain the records of the external floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
46. Permittee shall maintain a record of the liquid stored, the period of storage, and the maximum true vapor pressure of that liquid during the respective storage period. [District Rule 2201 and 40 CFR 60.116b(c)] Federally Enforceable Through Title V Permit
47. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3 and 40 CFR 60.116b(a)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

48. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (amended may 19, 2005) and 40CFR60 Subpart Kb. A permit shield is granted from this requirement. [District Rule 2520, 13.2]

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

ATTACHMENT B

Previous Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: S-83-0-2

EXPIRATION DATE: 08/31/2016

FACILITY-WIDE REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
4. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
5. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
6. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
7. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
8. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
9. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
10. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: SHELL PIPELINE COMPANY LP
Location: EMIDIO STATION, METTLER, CA
S-83-0-2 : May 18 2016 9:41AM - EDSEHILR

11. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
12. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [~~District Rules 2520, 9.5.2 and 1100, 7.0~~] Federally Enforceable Through Title V Permit
13. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
14. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
15. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
16. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
17. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
18. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
22. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
23. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
25. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
26. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
27. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
28. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
29. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
30. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8021 and 8011] Federally Enforceable Through Title V Permit
31. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8031 and 8011] Federally Enforceable Through Title V Permit
32. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8041 and 8011] Federally Enforceable Through Title V Permit
33. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8051 and 8011] Federally Enforceable Through Title V Permit
34. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8061 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8071 and Rule 8011] Federally Enforceable Through Title V Permit
36. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

37. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
38. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
39. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. On June 30, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin July 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-1-3

EXPIRATION DATE: 08/31/2016

SECTION: SE 7 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

3,360,000 GALLON RIVETED INTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #80102 WITH METALLIC SHOE PRIMARY AND SECONDARY WIPER SEAL

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.3.1.3] Federally Enforceable Through Title V Permit
2. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred as the secondary seal. [District Rule 4623, 5.3.1.2] Federally Enforceable Through Title V Permit
3. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
5. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
6. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
7. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
8. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
9. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 18 inches above the stored liquid surface. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
10. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.2.3] Federally Enforceable Through Title V Permit
11. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3.2.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.2.5] Federally Enforceable Through Title V Permit
13. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3.2.2.6] Federally Enforceable Through Title V Permit
14. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.2 & 5.5.1] Federally Enforceable Through Title V Permit
15. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.10] Federally Enforceable Through Title V Permit
16. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.1.1] Federally Enforceable Through Title V Permit
17. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5.2.1.2] Federally Enforceable Through Title V Permit
18. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.1.3] Federally Enforceable Through Title V Permit
19. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.1.4] Federally Enforceable Through Title V Permit
20. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5.2.1.5] Federally Enforceable Through Title V Permit
21. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5.2.1.6] Federally Enforceable Through Title V Permit
22. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repaired, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1.3.2.1] Federally Enforceable Through Title V Permit
23. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1.3.2.2] Federally Enforceable Through Title V Permit
24. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1.3.2.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5] Federally Enforceable Through Title V Permit
26. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
27. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
28. The true vapor pressure (TVP), at storage conditions, of the organic liquid stored in the internal floating roof tank shall be less than 11.0 psia [District Rule 4623, 5.1.1] Federally Enforceable Through Title V Permit
29. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 12 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-2-4

EXPIRATION DATE: 08/31/2016

SECTION: SE 7 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

3,360,000 GALLON RIVETED INTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #80103 EQUIPPED WITH A NEW INTERNAL FLOATING ROOF WITH HITEQ PRIMARY METALLIC SHOE AND SECONDARY WIPER SEALS.

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.3.1.3] Federally Enforceable Through Title V Permit
2. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred to as the secondary seal. [District Rule 4623, 5.3.1.2] Federally Enforceable Through Title V Permit
3. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
5. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
6. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
7. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
8. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
9. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 18 inches above the stored liquid surface. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
10. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.2.3] Federally Enforceable Through Title V Permit
11. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3.2.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.2.5] Federally Enforceable Through Title V Permit
13. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3.2.2.6] Federally Enforceable Through Title V Permit
14. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.2 & 5.5.1] Federally Enforceable Through Title V Permit
15. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.10] Federally Enforceable Through Title V Permit
16. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.1.1] Federally Enforceable Through Title V Permit
17. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5.2.1.2] Federally Enforceable Through Title V Permit
18. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.1.3] Federally Enforceable Through Title V Permit
19. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.1.4] Federally Enforceable Through Title V Permit
20. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5.2.1.5] Federally Enforceable Through Title V Permit
21. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5.2.1.6] Federally Enforceable Through Title V Permit
22. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repaired, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1.3.2.1] Federally Enforceable Through Title V Permit
23. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1.3.2.2] Federally Enforceable Through Title V Permit
24. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1.3.2.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5] Federally Enforceable Through Title V Permit
26. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
27. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
28. The true vapor pressure (TVP), at storage conditions, of the organic liquid stored in the internal floating roof tank shall be less than 11.0 psia [District Rule 4623, 5.1.1] Federally Enforceable Through Title V Permit
29. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 12 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-3-3

EXPIRATION DATE: 08/31/2016

SECTION: SE 7 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

3,360,000 GALLON RIVETED INTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #80104 EQUIPPED WITH NEW INTERNAL FLOATING ROOF WITH HITEQ PRIMARY METALLIC SHOE AND SECONDARY WIPER SEALS

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.3.1.3] Federally Enforceable Through Title V Permit
2. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred to as the secondary seal. [District Rule 4623, 5.3.1.2] Federally Enforceable Through Title V Permit
3. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
5. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
6. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
7. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
8. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
9. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 18 inches above the stored liquid surface. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
10. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.2.3] Federally Enforceable Through Title V Permit
11. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3.2.2.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.2.5] Federally Enforceable Through Title V Permit
13. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3.2.2.6] Federally Enforceable Through Title V Permit
14. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.2 & 5.5.1] Federally Enforceable Through Title V Permit
15. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.10] Federally Enforceable Through Title V Permit
16. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.1.1] Federally Enforceable Through Title V Permit
17. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5.2.1.2] Federally Enforceable Through Title V Permit
18. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.1.3] Federally Enforceable Through Title V Permit
19. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.1.4] Federally Enforceable Through Title V Permit
20. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5.2.1.5] Federally Enforceable Through Title V Permit
21. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5.2.1.6] Federally Enforceable Through Title V Permit
22. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repaired, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1.3.2.1] Federally Enforceable Through Title V Permit
23. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1.3.2.2] Federally Enforceable Through Title V Permit
24. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1.3.2.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5] Federally Enforceable Through Title V Permit
26. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
27. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
28. The true vapor pressure (TVP), at storage conditions, of the organic liquid stored in the internal floating roof tank shall be less than 11.0 psia [District Rule 4623, 5.1.1] Federally Enforceable Through Title V Permit
29. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 12 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-5-10

EXPIRATION DATE: 08/31/2016

SECTION: SE 7 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

12.5 MMBTU/HR NATURAL GAS OR LPG FIRED HEATER WITH FLUE GAS RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
7. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
8. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
9. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
10. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.0] Federally Enforceable Through Title V Permit
11. The unit shall only be fired on PUC-regulated natural gas or LPG. [District Rule 2201] Federally Enforceable Through Title V Permit
12. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed in each fuel line, utilized and maintained. [District Rules 2201, 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
13. Maximum annual heat input of the unit shall not exceed 30 billion Btu per calendar year. [District Rules 2201, 4305, 5.2 and 4306, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

14. Except during start-up and shutdown emissions rates from the use of natural gas to fire this unit shall not exceed the following limits: 30 ppmv NO_x @ 3% O₂ or 0.036 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 400 ppmv CO @ 3%O₂ or 0.296 lb-CO/MMBtu, or 0.0055 lb-VOC/MMBtu [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, and 4351, 5.1] Federally Enforceable Through Title V Permit
15. Except during start-up and shutdown emissions rates from the use of LPG to fire this unit shall not exceed the following limits: 30 ppmv NO_x @ 3% O₂ or 0.036 lb-NO_x/MMBtu, 0.0164 lb-SO_x/MMBtu, 0.0066 lb-PM₁₀/MMBtu, 400 ppmv CO @ 3%O₂ or 0.296 lb-CO/MMBtu, or 0.0058 lb-VOC/MMBtu. [District Rules 2201, 4301, 5.2, 4305, 5.1, 4306, 5.1, and 4351, 5.1] Federally Enforceable Through Title V Permit
16. During start-up and shutdown periods emissions from the process heater shall not exceed the following limits: 1.25 lb-NO_x/hr, 0.21 lb-SO_x/hr, 0.10 lb-PM₁₀/hr, 3.70lb-CO/hr, or 0.07 lb-VOC/hr. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence, two hours per day, and 400 hours per year. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
20. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4 and 4306, 5.4] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4 and 4306, 5.4 and 5.5] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2 and 4306, 5.5.2] Federally Enforceable Through Title V Permit
24. Source testing to measure NO_x and CO emissions from natural gas-combustion and LPG-combustion in this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, and 4351, 6.3.1] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1 and 4306, 6.3.1] Federally Enforceable Through Title V Permit
26. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
27. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
28. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
29. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2 and 4306, 6.2] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5 and 4306, 5.5.5] Federally Enforceable Through Title V Permit
31. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
32. Records of monthly and annual heat input of the unit shall be maintained. [District Rules 2201, 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
33. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4305, 6.1 and 4306, 6.1] Federally Enforceable Through Title V Permit
34. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted fuel is LPG or natural gas provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
35. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
36. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-7-7

EXPIRATION DATE: 08/31/2016

SECTION: SE07 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

33.75 MMBTU/HR G.C. BROACH NATURAL GAS-FIRED CRUDE OIL PIPELINE PROCESS HEATER WITH A NORTH AMERICAN LEX MODEL 4213-42/X5257 ULTRA LOW NOX BURNER

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The unit shall only be fired on PUC-regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Emission rates, except during startup and shutdown shall not exceed any of the following: NOx (as NO2): 7 ppmv @3% O2 or 0.008 lb/MMBtu, PM10: 0.0076 lb/MMBtu, SOx (as SO2): 0.00285 lb/MMBtu, CO: 400 ppmvd @ 3% O2, VOC: 0.0055 lb/MMBtu. [District NSR Rule; District Rules 4301, 5.2, 4305, 5.1, 4306, 5.1 and 4320,5.2] Federally Enforceable Through Title V Permit
5. Daily emissions shall not exceed either of the following: NOx: 29.2 lbs/day, or 2,365 lbs/year. [District Rules 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320,5.6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
8. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4, 4306, 5.4 and 4320,5.7.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4, 4306, 5.4 and 4320,5.2.1] Federally Enforceable Through Title V Permit
10. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4, 4306, 5.4 and 4320,5.7.1] Federally Enforceable Through Title V Permit
11. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1, 4306, 6.1 and 4320,6.1] Federally Enforceable Through Title V Permit
12. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2, 4306, 5.5.2, and 4320,5.8.2] Federally Enforceable Through Title V Permit
13. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, and 4320,6.3.1.1] Federally Enforceable Through Title V Permit
14. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
15. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, 4306, 5.5.1, and 4320,5.7.5] Federally Enforceable Through Title V Permit
16. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2, 4306, 6.2, and 4320,6.2.5] Federally Enforceable Through Title V Permit
17. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2, and 4320,6.2.3] Federally Enforceable Through Title V Permit
18. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2, 4306, 6.2, and 4320] Federally Enforceable Through Title V Permit
19. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, 5.5.5, and 4320,5.8.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4305, 6.1, 4306, 6.1, and 4320,6.1] Federally Enforceable Through Title V Permit
22. The owner or operator of a boiler, steam generator, or process heater subject to the requirement of District Rule 4320 shall be in full compliance with the rule, in accordance with the deadlines stated in section 7.0 of the rule. [District Rule 4320, 7.0] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-8-6

EXPIRATION DATE: 08/31/2016

SECTION: SE07 **TOWNSHIP:** 11N **RANGE:** 20W

EQUIPMENT DESCRIPTION:

33.75 MMBTU/HR G.C. BROACH NATURAL GAS-FIRED CRUDE OIL PIPELINE HEATER WITH NORTH AMERICAN LEX SERIES 4213-42/X5257 ULTRA-LOW NOX BURNER WITH FGR AND FUEL FLOW METER (EMIDIO PUMP STATION)

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rules 4201, 3.0 and 4301, 5.1] Federally Enforceable Through Title V Permit
3. This heater shall be fired only on PUC-regulated natural Gas. [District Rules 4801, 3.1, 4320, 5.2 and County Rule 407 (Kern)] Federally Enforceable Through Title V Permit
4. Emission rates, except during startup and shutdown, shall not exceed any of the following: PM10: 0.0137 lb/MMBtu, SOx (as SO2): 0.00285 lb/MMBtu, NOx (as NO2): 0.008 lb/MMBtu or 7 ppmv @ 3% O2, VOC: 0.0028 lb/MMBtu, CO: 0.30 lb/MMBtu or 400 ppmv @ 3% O2. [District NSR Rule; District Rules 4301, 5.2, 4305, 5.1 and 4320, 5.2] Federally Enforceable Through Title V Permit
5. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320, 5.6.1] Federally Enforceable Through Title V Permit
6. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22 and 4320, 3.29] Federally Enforceable Through Title V Permit
7. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, and 4320, 6.3.1.1] Federally Enforceable Through Title V Permit
8. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5.1, and 4320, 5.7.5] Federally Enforceable Through Title V Permit
10. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 6.2.2, 4306, and 4320, 6.2.5] Federally Enforceable Through Title V Permit
11. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 6.2.3, 4306 and 4320, 6.2.3] Federally Enforceable Through Title V Permit
12. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 6.2.4, 4306 and 4320, 6.2.4] Federally Enforceable Through Title V Permit
13. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no emissions measurements shall be made within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2, 4306, and 4320, 6.8.2] Federally Enforceable Through Title V Permit
14. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 5.5.5, 4306, and 4320, 5.8.5] Federally Enforceable Through Title V Permit
15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4.2, 4306 and 4320, 5.7.1] Federally Enforceable Through Title V Permit
17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4.2, 4306 and 4320, 5.2.1] Federally Enforceable Through Title V Permit
18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.5.4, 4306, and 4320, 5.7.1] Federally Enforceable Through Title V Permit
19. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 5.4.2, 4306, and 4320, 6.1] Federally Enforceable Through Title V Permit
20. Daily average fuel use shall not exceed 607.5 MMBtu/day in any calendar quarter. Permittee shall maintain records of volume of gas combusted in each calendar quarter. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. Records of monthly and annual heat input of the unit shall be maintained. [District NSR Rule] Federally Enforceable Through Title V Permit
22. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4305, 6.1, 4306, and 4320, 6.1] Federally Enforceable Through Title V Permit
23. The owner or operator of a boiler, steam generator, or process heater subject to the requirement of District Rule 4320 shall be in full compliance with the rule, in accordance with the deadlines stated in section 7.0 of the rule. [District Rule 4320, 7.0] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-9-4

EXPIRATION DATE: 08/31/2016

SECTION: NW07 TOWNSHIP: 11N RANGE: 20W

EQUIPMENT DESCRIPTION:

7,770,000 GALLON (185,000 BBL) EXTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #185GK5 WITH PRIMARY METALLIC SHOE SEAL AND ROOF MOUNTED WIPER TYPE SECONDARY SEAL

PERMIT UNIT REQUIREMENTS

1. Tank shall be equipped with operational temperature indicator. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The true vapor pressure (TVP) of any liquid introduced, placed, or stored shall not exceed 4.5 psia. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Throughput shall not exceed 100,000 bbl/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. VOC emission rate shall not exceed 38.1 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
5. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred as the secondary seal. [District NSR Rule; District Rule 4623, 5.3.1.2 and 40 CFR 60.112b(a)(2)(i)] Federally Enforceable Through Title V Permit
6. The external floating roof shall float on the surface of the stored liquid at all times (i.e., off the roof leg supports) except during the initial fill until the roof is lifted off the leg supports and when the tank is completely emptied and subsequently refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five calendar days prior to performing the work. The tank must be in compliance with this rule before it may land on its legs. [District Rule 4623, 5.3.1.3 and 40 CFR 60.112b(a)(2)(iii)] Federally Enforceable Through Title V Permit
7. Gaps between the tank shell and the primary seal shall not exceed 1 1/2 inches. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
8. The cumulative length of all gaps between the tank shell and the primary seal greater than 1/2 inch shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
9. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
10. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
11. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.1.2, 6.1 and 40 CFR 60.113b(b)(4)(ii)(B)] Federally Enforceable Through Title V Permit
12. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.1.2 and 40 CFR 60.113b(b)(4)(ii)(B)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 24 inches above the stored liquid surface. [District Rule 4623, 5.3.2.1.3 and 40 CFR 60.113b(b)(4)(i)(A)] Federally Enforceable Through Title V Permit
14. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 3 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.1.4] Federally Enforceable Through Title V Permit
15. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. Except for gaps meeting permit requirements, the primary seal shall completely cover the annular space between the edge of the floating roof and tank wall. [District Rule 4623, 5.3.2.1.5; 40 CFR 60.112b(a)(2)(i)(A), 40 CFR 60.113b(b)(4)(i)(B) and 60.113b(b)(4)(ii)(C)] Federally Enforceable Through Title V Permit
16. The secondary seal shall allow easy insertion of probes of up to 1 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.1.6] Federally Enforceable Through Title V Permit
17. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. Except for gaps meeting permit requirements, the secondary seal shall completely cover the annular space between the external floating roof and the wall of the storage vessel in a continuous fashion. [District Rule 4623, 5.3.2.1.7; 40 CFR 60.112b(a)(2)(i)(B) and 40 CFR 60.113b(b)(4)(ii)(A)] Federally Enforceable Through Title V Permit
18. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.2 & 5.5.1] Federally Enforceable Through Title V Permit
19. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.10 and 6.4.8] Federally Enforceable Through Title V Permit
20. Except for automatic bleeder vents, rim vents, and pressure relief vents, each opening in a non-contact external floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.2.1, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
21. Except for automatic bleeder vents and rim vents, roof drains, and leg sleeves, each opening in the roof shall be equipped with a gasketed cover, seal, or lid that shall be maintained in a closed position at all times (i.e., no visible gap) except when in actual use. [District Rule 4623, 5.5.2.2.2, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
22. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.2.3, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
23. Rim vents shall be equipped with a gasket and shall be set to open when the roof is being floated off the roof leg supports or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.2.4, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
24. Each emergency roof drain shall be provided with a slotted membrane fabric cover that covers at least 90 percent of the area of the opening. The fabric cover must be impermeable if the liquid is drained into the contents of the tanks. [District Rule 4623, 5.5.2.2.5, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
25. External floating roof legs shall be equipped with vapor socks or vapor barriers in order to maintain a gas-tight condition so as to prevent VOC emissions from escaping through the roof leg opening. [District Rule 4623, 5.5.2.2.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

26. All wells and similar fixed projections through the floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.3.1] Federally Enforceable Through Title V Permit
27. The solid guidepole well shall be equipped with a pole wiper and a gasketed cover, seal or lid which shall be in a closed position at all times (i.e., no visible gap) except when the well is in use. [District Rule 4623, 5.5.2.3.2] Federally Enforceable Through Title V Permit
28. The gap between the pole wiper and the solid guidepole shall be added to the gaps measured to determine compliance with the secondary seal requirement, and in no case shall exceed 1/2 inch. [District Rule 4623, 5.5.2.3.3] Federally Enforceable Through Title V Permit
29. The slotted guidepole well on a external floating roof shall be equipped with the following: a sliding cover, a well gasket, a pole sleeve, a pole wiper, and an internal float and float wiper designed to minimize the gap between the float and the well, and provided the gap shall not exceed 1/8 inch; or shall be equipped with a well gasket, a zero gap pole wiper seal and a pole sleeve that projects below the liquid surface. [District Rule 4623, 5.5.2.4.2] Federally Enforceable Through Title V Permit
30. The gap between the pole wiper and the slotted guidepole shall be added to the gaps measured to determine compliance with the secondary seal requirement, and in no case shall exceed 1/8 inch. [District Rule 4623, 5.5.2.4.3] Federally Enforceable Through Title V Permit
31. The permittee of external floating roof tanks shall make the primary seal envelope available for unobstructed inspection by the APCO on an annual basis at locations selected along its circumference at random by the APCO. In the case of riveted tanks with toroid-type seals, a minimum of eight locations shall be made available; in all other cases, a minimum of four locations shall be made available. If the APCO suspects a violation may exist the APCO may require such further unobstructed inspection of the primary seal as may be necessary to determine the seal condition for its entire circumference. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
32. Measurements of gaps between the tank wall and the primary and secondary seal shall be performed during the hydrostatic testing of the vessel or within 60 days of the initial fill with a volatile organic liquid. [40 CFR 60.113b(b)(1)(i)] Federally Enforceable Through Title V Permit
33. If any source ceases to store volatile organic liquid for a period of 1 year or more, subsequent introduction of volatile organic liquid into the vessel shall be considered an initial fill. [40 CFR 60.113b(b)(1)(iii)] Federally Enforceable Through Title V Permit
34. The permittee shall inspect all floating roof tanks at least once every 12 months to determine compliance with the requirements of this rule. The actual gap measurements of the floating roof primary and secondary seals shall be recorded. Permittee shall measure seal gaps, at one or more floating roof levels when the roof is floating off the roof leg supports, around the entire circumference of the tank in each place where a 0.32-cm diameter uniform probe passes freely (without forcing or binding against seal) between the seal and the wall of the storage vessel and measure the circumferential distance of each such location. The inspection results shall be submitted to the APCO as specified in Section 6.3.5. [County Rule 107 (40 CFR 60.113b(b)(1)(i) & (ii); and 40 CFR 60.113b(b)(2)(i) & (ii)] Federally Enforceable Through Title V Permit
35. The permittee shall inspect the primary and secondary seals for compliance with the requirements of this rule every time a tank is emptied or degassed. Actual gap measurements shall be performed when the liquid level is static but not more than 24 hours after the tank roof is re-floated. If the external floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, the owner or operator shall repair the items as necessary before filling or refilling the storage vessel. The owner or operator shall notify the APCO in writing at least 30 days prior to the filling or refilling of each storage vessel to afford the APCO the opportunity to inspect the storage vessel prior to refilling. [District Rule 4623, 6.1.3.1.2 and 40 CFR 60.113b(b)(6)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5 and 40 CFR 60.115b(b)] Federally Enforceable Through Title V Permit
37. Permittee shall maintain the records of the external floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
38. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3 and 40 CFR 60.116b(a)] Federally Enforceable Through Title V Permit
39. Permittee shall notify District at least 30 days prior to the date when unobstructed primary and secondary seal/gap measurements will occur to afford the APCO the opportunity to have an observer present. [40 CFR 60.113b(b)(5)] Federally Enforceable Through Title V Permit
40. Permittee shall maintain a record of the liquid stored, the period of storage, and the maximum true vapor pressure of that liquid during the respective storage period. [40 CFR 60.116b(c)] Federally Enforceable Through Title V Permit
41. Permittee shall make necessary repairs or empty the storage vessel within 45 days of identification in any inspection for seals not meeting the requirements listed in 40 CFR 60.113b(b)(4)(i) and (ii). If necessary repairs cannot be made within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the APCO. Such an extension request must include a demonstration of unavailability of alternate storage capacity and a specification of a schedule that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible. [40 CFR 60.113b(b)(4)] Federally Enforceable Through Title V Permit
42. The owner or operator of each storage vessel shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel. Such records shall be retained for the life of the source. [40 CFR 60.116b(b)] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of daily throughput. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
44. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rule 2520, 9.3.2, 4623, 6.4.3 and 6.2] Federally Enforceable Through Title V Permit
45. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (amended May 19, 2005) and 40CFR60 Subpart Kb. A permit shield is granted from this requirement. [District Rule 2520, 13.2]

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-11-3

EXPIRATION DATE: 08/31/2016

SECTION: NW7 **TOWNSHIP:** 11N **RANGE:** 20W

EQUIPMENT DESCRIPTION:

235 HP CATERPILLAR MODEL 3208 DIESEL-FIRED EMERGENCY IC ENGINE WITH TURBOCHARGER DRIVING EMERGENCY FIRE WATER PUMP

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
2. Engine shall be equipped with a turbocharger. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The engine shall be equipped with positive crankcase ventilation (PVC) system or a crankcase emissions control device of at least 90% control efficiency. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Emissions shall not exceed 4.3 g NOx/hp-hr. [District NSR Rule] Federally Enforceable Through Title V Permit
5. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
6. All records shall be maintained and retained on-site for a minimum of (5) five years, and shall be made available for DIstrict inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations and the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [District Rule 2520, 9.4 and 17 CCR 93115] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-83-12-8

EXPIRATION DATE: 08/31/2016

SECTION: SE 7 **TOWNSHIP:** 11N **RANGE:** 20W

EQUIPMENT DESCRIPTION:

4,200,000 GALLON (100,000 BBL) WELDED EXTERNAL FLOATING ROOF PETROLEUM STORAGE TANK # 100GK6 WITH METALLIC SHOE PRIMARY SEAL AND ROOF MOUNTED WIPER TYPE SECONDARY SEAL

PERMIT UNIT REQUIREMENTS

1. Vapor control requirements of NSPS Subpart Kb and Rule 4623, included in Conditions #10 through #43 below, are not applicable when the tank stores, places, or holds organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4001 and 4623] Federally Enforceable Through Title V Permit
2. Before switching to the storage of organic liquids with true vapor pressure greater than or equal to 0.5 psia, all covers, seals, and lids shall be inspected by the facility operator to ensure compliance with the provisions of this permit. This includes all conditions containing District Rule 4623 or 40 CFR 60 Subpart Kb references. [District Rule 2080] Federally Enforceable Through Title V Permit
3. Within one week after switching from storage of organic liquids with TVP greater than or equal to 0.5 psia to storage of organic liquids with TVP less than 0.5 psia, the TVP of the organic liquid shall be determined in accordance with the test methods of District Rule 4623 Section 6.4 (Amended May 19, 2005) or an equivalent method approved by the APCO, ARB, and EPA. [District Rule 4623,6.4] Federally Enforceable Through Title V Permit
4. Tank shall be equipped with operational temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Throughput shall not exceed 100,000 bbl/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. VOC emission rate shall not exceed 84.1 lb/day on a monthly average daily basis. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The True Vapor Pressure (TVP) of any liquid introduced, placed, or stored shall be less than 11.0 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
8. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred as the secondary seal. [District Rule 2201; District Rule 4623, 5.3.1.2 and 40 CFR 60.112b(a)(2)(i)] Federally Enforceable Through Title V Permit
9. The external floating roof shall float on the surface of the stored liquid at all times (i.e., off the roof leg supports) except during the initial fill until the roof is lifted off the leg supports and when the tank is completely emptied and subsequently refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five calendar days prior to performing the work. The tank must be in compliance with this rule before it may land on its legs. [District Rule 4623, 5.3.1.3 and 40 CFR 60.112b(a)(2)(iii)] Federally Enforceable Through Title V Permit
10. Gaps between the tank shell and the primary seal shall not exceed 1 1/2 inches. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. The cumulative length of all gaps between the tank shell and the primary seal greater than 1/2 inch shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
12. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
13. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.1.1 and 40 CFR 60.113b(b)(4)(i)] Federally Enforceable Through Title V Permit
14. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.1.2, 6.1 and 40 CFR 60.113b(b)(4)(ii)(B)] Federally Enforceable Through Title V Permit
15. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.1.2 and 40 CFR 60.113b(b)(4)(ii)(B)] Federally Enforceable Through Title V Permit
16. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 24 inches above the stored liquid surface. [District Rule 4623, 5.3.2.1.3 and 40 CFR 60.113b(b)(4)(i)(A)] Federally Enforceable Through Title V Permit
17. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 3 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.1.4] Federally Enforceable Through Title V Permit
18. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. Except for gaps meeting permit requirements, the primary seal shall completely cover the annular space between the edge of the floating roof and tank wall. [District Rule 4623, 5.3.2.1.5; 40 CFR 60.112b(a)(2)(i)(A), 40 CFR 60.113b(b)(4)(i)(B) and 60.113b(b)(4)(ii)(C)] Federally Enforceable Through Title V Permit
19. The secondary seal shall allow easy insertion of probes of up to 1 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.1.6] Federally Enforceable Through Title V Permit
20. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. Except for gaps meeting permit requirements, the secondary seal shall completely cover the annular space between the external floating roof and the wall of the storage vessel in a continuous fashion. [District Rule 4623, 5.3.2.1.7; 40 CFR 60.112b(a)(2)(i)(B) and 40 CFR 60.113b(b)(4)(ii)(A)] Federally Enforceable Through Title V Permit
21. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.2 & 5.5.1] Federally Enforceable Through Title V Permit
22. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 3.10 and 6.4.8] Federally Enforceable Through Title V Permit
23. Except for automatic bleeder vents, rim vents, and pressure relief vents, each opening in a non-contact external floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.2.1, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
24. Except for automatic bleeder vents and rim vents, roof drains, and leg sleeves, each opening in the roof shall be equipped with a gasketed cover, seal, or lid that shall be maintained in a closed position at all times (i.e., no visible gap) except when in actual use. [District Rule 4623, 5.5.2.2.2, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.2.3, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
26. Rim vents shall be equipped with a gasket and shall be set to open when the roof is being floated off the roof leg supports or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.2.4, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
27. Each emergency roof drain shall be provided with a slotted membrane fabric cover that covers at least 90 percent of the area of the opening. The fabric cover must be impermeable if the liquid is drained into the contents of the tanks. [District Rule 4623, 5.5.2.2.5, and 40 CFR 60.112b(a)(2)(ii)] Federally Enforceable Through Title V Permit
28. External floating roof legs shall be equipped with vapor socks or vapor barriers in order to maintain a gas-tight condition so as to prevent VOC emissions from escaping through the roof leg opening. [District Rule 4623, 5.5.2.2.6] Federally Enforceable Through Title V Permit
29. All wells and similar fixed projections through the floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.3.1] Federally Enforceable Through Title V Permit
30. The solid guidepole well shall be equipped with a pole wiper and a gasketed cover, seal or lid which shall be in a closed position at all times (i.e., no visible gap) except when the well is in use. [District Rule 4623, 5.5.2.3.2] Federally Enforceable Through Title V Permit
31. The gap between the pole wiper and the solid guidepole shall be added to the gaps measured to determine compliance with the secondary seal requirement, and in no case shall exceed 1/2 inch. [District Rule 4623, 5.5.2.3.3] Federally Enforceable Through Title V Permit
32. The slotted guidepole well on a external floating roof shall be equipped with the following: a sliding cover, a well gasket, a pole sleeve, a pole wiper, and an internal float and float wiper designed to minimize the gap between the float and the well, and provided the gap shall not exceed 1/8 inch; or shall be equipped with a well gasket, a zero gap pole wiper seal and a pole sleeve that projects below the liquid surface. [District Rule 4623, 5.5.2.4.2] Federally Enforceable Through Title V Permit
33. The gap between the pole wiper and the slotted guidepole shall be added to the gaps measured to determine compliance with the secondary seal requirement, and in no case shall exceed 1/8 inch. [District Rule 4623, 5.5.2.4.3] Federally Enforceable Through Title V Permit
34. The permittee of external floating roof tanks shall make the primary seal envelope available for unobstructed inspection by the APCO on an annual basis at locations selected along its circumference at random by the APCO. In the case of riveted tanks with toroid-type seals, a minimum of eight locations shall be made available; in all other cases, a minimum of four locations shall be made available. If the APCO suspects a violation may exist the APCO may require such further unobstructed inspection of the primary seal as may be necessary to determine the seal condition for its entire circumference. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
35. Measurements of gaps between the tank wall and the primary and secondary seal shall be performed during the hydrostatic testing of the vessel or within 60 days of the initial fill with a volatile organic liquid. [40 CFR 60.113b(b)(1)(i)] Federally Enforceable Through Title V Permit
36. If any source ceases to store volatile organic liquid for a period of 1 year or more, subsequent introduction of volatile organic liquid into the vessel shall be considered an initial fill. [40 CFR 60.113b(b)(1)(iii)] Federally Enforceable Through Title V Permit
37. The permittee shall inspect all floating roof tanks at least once every 12 months to determine compliance with the requirements of this rule. The actual gap measurements of the floating roof primary and secondary seals shall be recorded. Permittee shall measure seal gaps, at one or more floating roof levels when the roof is floating off the roof leg supports, around the entire circumference of the tank in each place where a 0.32-cm diameter uniform probe passes freely (without forcing or binding against seal) between the seal and the wall of the storage vessel and measure the circumferential distance of each such location. The inspection results shall be submitted to the APCO as specified in Section 6.3.5. [District Rule 4623, 6.1.3.1; 40 CFR 60.113b(b)(1)(i) & (ii); and 40 CFR 60.113b(b)(2)(i) & (ii)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

38. The permittee shall inspect the primary and secondary seals for compliance with the requirements of this rule every time a tank is emptied or degassed. Actual gap measurements shall be performed when the liquid level is static but not more than 48 hours after the tank roof is re-floated. If the external floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, the owner or operator shall repair the items as necessary before filling or refilling the storage vessel. The owner or operator shall notify the APCO in writing at least 30 days prior to the filling or refilling of each storage vessel to afford the APCO the opportunity to inspect the storage vessel prior to refilling. [District Rule 4623, 6.1.3.2 and 40 CFR 60.113b(b)(6)] Federally Enforceable Through Title V Permit
39. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5 and 40 CFR 60.115b(b)] Federally Enforceable Through Title V Permit
40. Permittee shall notify District at least 30 days prior to the date when unobstructed primary and secondary seal/gap measurements will occur to afford the APCO the opportunity to have an observer present. [40 CFR 60.113b(b)(5)] Federally Enforceable Through Title V Permit
41. Permittee shall make necessary repairs or empty the storage vessel within 45 days of identification in any inspection for seals not meeting the requirements listed in 40 CFR 60.113b(b)(4)(i) and (ii). If necessary repairs cannot be made within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the APCO. Such an extension request must include a demonstration of unavailability of alternate storage capacity and a specification of a schedule that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible. [40 CFR 60.113b(b)(4)] Federally Enforceable Through Title V Permit
42. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rules 2520, 9.3.2 and 4623, 6.2] Federally Enforceable Through Title V Permit
43. The owner or operator of each storage vessel shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel. Such records shall be retained for the life of the source. [40 CFR 60.116b(b)] Federally Enforceable Through Title V Permit
44. Permittee shall maintain records of average daily throughput. [District Rule 2201 and District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
45. Permittee shall maintain the records of the external floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
46. Permittee shall maintain a record of the liquid stored, the period of storage, and the maximum true vapor pressure of that liquid during the respective storage period. [District Rule 2201 and 40 CFR 60.116b(c)] Federally Enforceable Through Title V Permit
47. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3 and 40 CFR 60.116b(a)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

48. Compliance with permit conditions in the Title V permit shall be deemed compliance with District Rule 4623 (amended may 19, 2005) and 40CFR60 Subpart Kb. A permit shield is granted from this requirement. [District Rule 2520, 13.2]

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C

Detailed Facility List

SJVUAPCD
SOUTHERN

Detailed Facility Report
For Facility=83

5/16/16
3:55 pm

Sorted by Facility Name and Permit Number

SHELL PIPELINE COMPANY LP	EMIDIO STATION	METTLER, CA	FAC #	S 83	TYPE:	TH6V	EXP. ON:
			STATUS:	A	TOXIC ID:	50254	AREA:
			TELEPHONE:				102 /
							07/16
							INSP. DATE:

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-83-1-3	3,360,000 gal	3020-05 G	1	401.00	401.00	A	3,360,000 GALLON RIVETED INTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #80102 WITH METALLIC SHOE PRIMARY AND SECONDARY WIPER SEAL
S-83-2-4	3,360,000 gallons	3020-05 G	1	401.00	401.00	A	3,360,000 GALLON RIVETED INTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #80103 EQUIPPED WITH A NEW INTERNAL FLOATING ROOF WITH HITEQ PRIMARY METALLIC SHOE AND SECONDARY WIPER SEALS.
S-83-3-3	3,360,000 gal	3020-05 G	1	401.00	401.00	A	3,360,000 GALLON RIVETED INTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #80104 EQUIPPED WITH NEW INTERNAL FLOATING ROOF WITH HITEQ PRIMARY METALLIC SHOE AND SECONDARY WIPER SEALS
S-83-5-10	12,500 KBTU/hr	3020-02 G	1	855.00	855.00	A	12.5 MMBTU/HR NATURAL GAS OR LPG FIRED HEATER WITH FLUE GAS RECIRCULATION
S-83-6-0	5,000,000 BTU/HR	3020-02 G	1	855.00	855.00	D	CLASS 1 LIGHT CRUDE OIL LOADING FACILITY INCLUDING BOTTOM LOADING WITH "DRY BREAK" LIQUID COUPLERS, VAPOR COLLECTION SYSTEM WITH POPPETED GAS COUPLERS, AND 5 MMBTU/HR VAPOR INCINERATION FLARE
S-83-7-7	33.75 MMBTU/HR	3020-02 H	1	1,080.00	1,080.00	A	33.75 MMBTU/HR G.C. BROACH NATURAL GAS-FIRED CRUDE OIL PIPELINE PROCESS HEATER WITH A NORTH AMERICAN LEX MODEL 4213-42X5257 ULTRA LOW NOX BURNER
S-83-8-6	30.75 MMBTU/HR	3020-02 H	1	1,080.00	1,080.00	A	33.75 MMBTU/HR G.C. BROACH NATURAL GAS-FIRED CRUDE OIL PIPELINE HEATER WITH NORTH AMERICAN LEX SERIES 4213-42X5257 ULTRA-LOW NOX BURNER WITH FGR AND FUEL FLOW METER (EMIDIO PUMP STATION)
S-83-9-4	7,770,000 Gallons	3020-05 G	1	401.00	401.00	A	7,770,000 GALLON (185,000 BBL) EXTERNAL FLOATING ROOF PETROLEUM STORAGE TANK #185GKS WITH PRIMARY METALLIC SHOE SEAL AND ROOF MOUNTED WIPER TYPE SECONDARY SEAL
S-83-11-3	235 hp	3020-10 C	1	252.00	252.00	A	235 HP CATERPILLAR MODEL 3208 DIESEL-FIRED EMERGENCY IC ENGINE WITH TURBOCHARGER DRIVING EMERGENCY FIRE WATER PUMP
S-83-12-8	4,200,000 gallons	3020-05 G	1	401.00	401.00	A	4,200,000 GALLON (100,000 BBL) WELDED EXTERNAL FLOATING ROOF PETROLEUM STORAGE TANK # 100GK6 WITH METALLIC SHOE PRIMARY SEAL AND ROOF MOUNTED WIPER TYPE SECONDARY SEAL

Number of Facilities Reported: 1