San Bernardino Municipal Water Department Water Quality Monthly Report
Newmark OU/Towers/19th St GAC/Muscoy OU
Month of September 2005

						Week 1-9/01/05		Week 2-9/08/05		Week 3-9/15/05		Week 4-9/22/05		Week 5-9/29/05		
19th Street NORTH GAC Treatment Plant	DATE	Colilert P/A	MPN Total	MPN Fecal	HPC	PCE (ug/L)	TCE (ug/L)	PCE (ug/L)	TCE (ug/L)	PCE (ug/L)	TCE (ug/L)	PCE (ug/L)	TCE (ug/L)	PCE (ug/L)	TCE (ug/L)	NO_3 (mg/L)
EPA 001	9/22/2005	A			<1.0											
EPA 108	9/22/2005	A			1.0											
EPA 109	9/22/2005	A			2.0											
EPA 110	9/22/2005	A			1.0											
EPA 111	9/22/2005	A			1.0											
EPA 112	9/22/2005	A			4.0											
Combined Influent	9/13/2005									5.2	1.0					
LEAD VESSEL 1A	9/22/2005		<1.1	<1.1	1.0	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 2A	9/22/2005		<1.1	<1.1	1.0	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 3A	9/22/2005		<1.1	<1.1	1.5	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 4A	9/22/2005		<1.1	<1.1	1.0	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 5A	9/22/2005		<1.1	<1.1	1.0	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 6A	9/22/2005		<1.1	<1.1	1.0	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 8A	9/22/2005		<1.1	<1.1	1.0	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 9A	9/22/2005		<1.1	<1.1	2.5	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 10A	9/22/2005		<1.1	<1.1	1.5	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 11A	9/22/2005		<1.1	<1.1	1.0	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 12A	9/22/2005		<1.1	<1.1	3.5	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
LEAD VESSEL 13A	9/22/2005		<1.1	<1.1	1.5	0.0	0.0	0.0	0.0	0.0	0.0	<0.5	<0.5	<0.5	<0.5	
Combined Effluent	9/22/2005		<1.1	<1.1	3.0	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	N/A*	N/A*	<0.5	<0.5	

N/A* due to laboratory sample hold-time error - Resampled 9/29/05

Waterman Stripping Towers	DATE	Colilert P/A	MPN Total	MPN Fecal	HPC	PCE	TCE	TB	FB
Waterman Combined Tower Influent	9/13/2005					5.2	0.8	<0.5	<0.5
Waterman N. Tower Effluent	9/13/2005	A			1.0	<0.5	<0.5	<0.5	<0.5
Waterman S. Tower Effluent	9/13/2005	A			1.5	<0.5	<0.5	<0.5	<0.5

Newmark Stripping Towers	DATE	Colilert P/A	MPN Total	MPN Fecal	HPC	PCE	TCE	TB	FB
Newmark W. Tower Influent	9/13/2005					<0.5	<0.5	<0.5	<0.5
Newmark W. Tower Effluent	9/13/2005	A			<1.0	<0.5	<0.5	<0.5	<0.5
Newmark E. Tower Influent	9/13/2005					*	*	*	*
Newmark E. Tower Effluent	9/13/2005	A			1.0	*	*	*	*

* No Sample

NOTE: If any VOC contaminant is detected in the Towers' Effluent Samples, the laboratory report(s) will be attached for DHS review.