

## Newmark/Muscoy Team Conference Call Notes

13 June 2005 (2:00 P.M.)

### Conference Call Members Present for Call:

- |                                                          |                                                         |
|----------------------------------------------------------|---------------------------------------------------------|
| <input type="checkbox"/> Dwayne Deutscher/URS            | <input checked="" type="checkbox"/> Kim Hoang/EPA       |
| <input checked="" type="checkbox"/> Dennis Bane/URS      | <input type="checkbox"/> Jackie Lane/EPA                |
| <input checked="" type="checkbox"/> Matt Dwyer/URS       | <input type="checkbox"/> Francisco Arcaute/EPA          |
| <input type="checkbox"/> Adam Harvey/URS                 |                                                         |
| <input checked="" type="checkbox"/> Connie Biedel/URS    | <input type="checkbox"/> Stacey Aldstadt/SBMWD          |
| <input checked="" type="checkbox"/> Kit Veldman/URS      | <input checked="" type="checkbox"/> Bill Bryden/SBMWD   |
|                                                          | <input checked="" type="checkbox"/> Mark Eisen/SBMWD    |
| <input checked="" type="checkbox"/> Tom Perina/CH2M Hill | <input type="checkbox"/> Terry Tonn/SBMWD               |
| <input checked="" type="checkbox"/> Bob Kemmerle/E2      | <input type="checkbox"/> Mike Lowe/SBMWD                |
|                                                          | <input checked="" type="checkbox"/> Lana Kennerly/SBMWD |

### Construction (Matt Dwyer)

- Last week, all the differential pressure transducers were removed from the GAC vessels, packed up and shipped back to Connecticut. Matt will update status each week.
- The Encanto probe installation should begin this week.
- Minor items left on the punch list for electrical.
- Bill will call Sam Fuller at MUNI to verify that MUNI SCADA equipment can receive signals from Encanto Park SCADA equipment.

### Well Construction (Dennis Bane)

- The first round of water levels were done before shutdown today. At 3:00 P.M. today, Mike will shutdown, then Dennis will collect another sample of water levels.
- Kim will send email out to everyone on status of shutdown later today.

### General

- None.

### Community

- None.

### Next Conference Call

Monday, 20 June 2005, 2:00 P.M.; Call in #: 202-275-0170; Participant Code: 7860 (#).

*The minutes of this meeting represent the writer's understanding of the events as discussed. Should an attendee's understanding differ, please contact Dwayne Deutscher at 916-679-2051, or [dwayne\\_deutscher@urscorp.com](mailto:dwayne_deutscher@urscorp.com). The minutes contained herein will stand if not corrected within ten (10) days of this writing.*