



DEC 15 2011

Mr. Gregg A. Lies
SFPP, LP
1100 Town & Country Road
Orange, CA 92868

**Re: Final - Authority to Construct / Certificate of Conformity (Significant Mod)
District Facility # C-1077
Project # C-1074133**

Dear Mr. Lies:

The Air Pollution Control Officer has issued an Authority to Construct (ATC # C-1077-52-0) with a Certificate of Conformity to SFPP, LP at 4149 Maple Avenue in Fresno. The applicant proposes to install an off-specification product truck unloading station. During the noticing period, the applicant proposed to limit the number of unloading events instead of the number of trucks unloaded. The number of unloading events is calculated as the number of trucks multiplied by the number of truck compartments. There is no change in emissions with the revision (number of unloading events = number of trucks x number of compartments per truck).

Original proposed condition

- The maximum number of trucks unloaded shall not exceed either of the following limits: 9 trucks/day or 3,280 trucks/year. [District Rule 2201]

Revised condition

- The maximum number of unloading events shall not exceed either of the following limits: 45 events/day or 16,400 events/year. [District Rule 2201]

Enclosed is the Authority to Construct. The application and proposal were sent to US EPA Region IX on November 8, 2011. All comments received have been addressed by the District.

The notice of final decision for this project will be published approximately three days from the date of this letter.

Prior to operating with modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5.

Enclosed is an invoice for the engineering evaluation fees. Please remit the amount owed, along with a copy of the attached invoice, within 30 days.

Syed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Mr. Gregg A. Lies
Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

A handwritten signature in black ink, appearing to read "David Warner", with a long, sweeping horizontal flourish extending to the right.

David Warner
Director of Permit Services

Enclosures
st



DEC 15 2011

Gerardo C. Rios, Chief
Permits Office
Air Division
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

**Re: Final - Authority to Construct / Certificate of Conformity (Significant Mod)
District Facility # C-1077
Project # C-1074133**

Dear Mr. Rios:

The Air Pollution Control Officer has issued an Authority to Construct (ATC # C-1077-52-0) with a Certificate of Conformity to SFPP, LP at 4149 Maple Avenue in Fresno. The applicant proposes to install an off-specification product truck unloading station. During the noticing period, the applicant proposed to limit the number of unloading events instead of the number of trucks unloaded. The number of unloading events is calculated as the number of trucks multiplied by the number of truck compartments. There is no change in emissions with the revision (number of unloading events = number of trucks x number of compartments per truck).

Enclosed is a copy of the Authority to Construct. The application and proposal were sent to US EPA Region IX on November 8, 2011. All comments received have been addressed by the District.

The notice of final decision for this project will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

Enclosures
st

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



DEC 15 2011

Mike Tollstrup, Chief
Project Assessment Branch
Air Resources Board
P O Box 2815
Sacramento, CA 95812-2815

**Re: Final - Authority to Construct / Certificate of Conformity (Significant Mod)
District Facility # C-1077
Project # C-1074133**

Dear Mr. Tollstrup:

The Air Pollution Control Officer has issued an Authority to Construct (ATC # C-1077-52-0) with a Certificate of Conformity to SFPP, LP at 4149 Maple Avenue in Fresno. The applicant proposes to install an off-specification product truck unloading station. During the noticing period, the applicant proposed to limit the number of unloading events instead of the number of trucks unloaded. The number of unloading events is calculated as the number of trucks multiplied by the number of truck compartments. There is no change in emissions with the revision (number of unloading events = number of trucks x number of compartments per truck).

Enclosed is a copy of the Authority to Construct. The application and proposal were sent to US EPA Region IX on November 8, 2011. All comments received have been addressed by the District.

The notice of final decision for this project will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

Enclosures
st

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

**NOTICE OF FINAL DECISION
FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT AND
THE PROPOSED SIGNIFICANT MODIFICATION OF FEDERALLY
MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District has made its final decision to issue an Authority to Construct to SFPP, LP for bulk fuel terminal located at 4149 Maple Avenue in Fresno, California. The applicant proposes to install an off-specification product truck unloading station. During the noticing period, the applicant proposed to limit the number of unloading events instead of the number of trucks unloaded. The number of unloading events is calculated as the number of trucks multiplied by the number of truck compartments. There is no change in emissions with the revision (number of unloading events = number of trucks x number of compartments per truck).

The District's analysis of the legal and factual basis for this proposed action, project #C-1074133, is available for public inspection at the District office at the address below. For additional information regarding this matter, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900, or contact David Warner, Director of Permit Services, in writing at SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 E. GETTYSBURG AVE, FRESNO, CA 93726-0244.



AUTHORITY TO CONSTRUCT

PERMIT NO: C-1077-52-0

ISSUANCE DATE: 12/12/2011

LEGAL OWNER OR OPERATOR: SFPP, L.P.
MAILING ADDRESS: 1100 TOWN & COUNTRY ROAD
ORANGE, CA 92868

LOCATION: 4149 S MAPLE AVE
FRESNO, CA 93725

EQUIPMENT DESCRIPTION:

OFF-SPECIFICATION PRODUCT TRUCK UNLOADING STATION WITH ONE UNLOADING CONNECTION GRAVITY DRAINED TO ONE PUMP SLEEVE, ONE PUMP, AIR ELIMINATOR, METER AND SUPPORT EQUIPMENT, AND VAPOR RETURN SYSTEM (VAPOR VENTED BACK TO TANKER TRUCK)


CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender (pollutant) emission reduction credits for the following quantities of emissions: 1st quarter - 95 lb, 2nd quarter - 95 lb, 3rd quarter - 95 lb, and fourth quarter - 95 lb. Offsets shall be provided at the applicable offset ratio specified in Table 4-2 of Rule 2201 (as amended 04/21/11). [District Rule 2201] Federally Enforceable Through Title V Permit
4. ERC Certificate Number S-2464-1 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO


DAVID WARNER, Director of Permit Services
1077-52-0, Dec 12 2011 9:09AM - TOMS : Joint Inspection NOT Required

5. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
6. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
7. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
8. Vapor return hose(s) shall connect displaced vapors to the delivery truck whenever tank truck, trailer, or car is unloading organic liquid. [District Rules 2201 and 4624] Federally Enforceable Through Title V Permit
9. All delivery trucks must be equipped with vapor collection equipment capable of undergoing a pressure change of no more than 1 inch of water within 5 minutes after it is pressured to 18 inches of water. This must be demonstrated annually for each truck using the procedures specified in EPA Method 27 of 40 CFR 60, Appendix A or CARB Test Methods CP-204, TP-204.1, TP204-2, and TP-204.3. [District NSR Rule] Federally Enforceable Through Title V Permit
10. The vapor collection and control system shall operate such that the pressure in the delivery tank being unloaded does not exceed 18 inches water column pressure and six (6) inches water column vacuum. [District Rule 4624] Federally Enforceable Through Title V Permit
11. The transfer rack and vapor collection equipment shall be designed, installed, maintained and operated such that there are no leaks and no excess organic liquid drainage at disconnections. [District Rule 4624] Federally Enforceable Through Title V Permit
12. A leak is defined as the dripping of VOC-containing liquid at a rate of more than three (3) drops per minute, or the detection of any gaseous or vapor emissions with a concentration of VOC greater than 1,000 ppmv as methane above a background when measured using a portable hydrocarbon detection instrument in accordance with EPA Method 21. [District Rule 4624] Federally Enforceable Through Title V Permit
13. The operator shall inspect the vapor collection system, the vapor disposal system, and each transfer rack handling organic liquids for leaks during transfer at least once every calendar quarter using the EPA Method 21. [District Rule 4624, 5.9] Federally Enforceable Through Title V Permit
14. All leaking components shall be repaired or replaced within 72 hours of discovery. If the leaking component cannot be repaired or replaced within 72 hours, the component shall be taken out of service until such time the component is repaired or replaced. The repaired or replacement equipment shall be reinspected the first time the equipment is in operation after the repair or replacement. [District Rule 4624, 5.9] Federally Enforceable Through Title V Permit
15. An operator may apply for a written approval from the APCO to change the inspection frequency from quarterly to annually provided no leaks were found during five consecutive quarterly inspections. Upon identification of any leak during an annual inspection, the inspection frequency shall revert back to quarterly, and the operator shall contact the APCO in writing within 14 days. [District Rule 4624, 5.9] Federally Enforceable Through Title V Permit
16. Unloading VOC emissions from the unloading system shall not exceed 0.093 lb-VOC/1000 gallons. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Unloading VOC emissions from the unloading system shall not exceed 0.7 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
18. The maximum number of unloading events shall not exceed either of the following limits: 45 events/day or 16,400 events/year. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Fugitive component VOC emissions from the unloading system shall not exceed 0.06 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
20. The maximum volume of liquid spillage/leaks from each hose disconnect shall not exceed 10 milliliters. [District Rule 2201] Federally Enforceable Through Title V Permit
21. VOC emissions from truck unloading connections shall not exceed 0.3 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. Permittee shall maintain accurate component count for tank according to EPA's "Protocol for Equipment Leak Emission Estimate," Table 2-3, Marketing Terminal Average Emission Factors. Permittee shall update such records when new components are approved and installed. [District Rule 2201] Federally Enforceable Through Title V Permit
23. The maximum throughput of off-specification product unloaded shall not exceed any of the following: 75,600 gallons per day or 27,552,000 gallons per year. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
25. Daily records of amount of off-specification product unloaded and number of trucks unloaded at the unloading system shall be maintained. [District Rules 1070, 2201, 4624] Federally Enforceable Through Title V Permit
26. Permittee shall maintain the following records for each truck: 1) the annual vapor collection equipment test result, 2) date the test was performed, and 3) truck identification. [District NSR Rule] Federally Enforceable Through Title V Permit
27. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 72 hours after detection. [District Rules 1070 and 4624] Federally Enforceable Through Title V Permit
28. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit