

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><i>ENGINEERING &amp; COMPLIANCE DIVISION</i></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 1
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

**PERMIT TO CONSTRUCT/OPERATE**

COMPANY NAME: Eastern Municipal Water District  
Temecula Valley Regional Water Reclamation Fac.

MAILING ADDRESS: 2270 Trumble Road  
Perris, CA 92572-8300

EQUIPMENT LOCATION: 42565 Avenida Alvarado  
Temecula, CA  
Facility ID#: 1703

FACILITY TYPE: Title V

**EQUIPMENT DESCRIPTION**

INTERNAL COMBUSTION ENGINE, CATERPILLAR, COMPRESSION IGNITION, MODEL NO. C-32, DIESEL OIL NO. 2 FUELED, FOUR CYCLES, TWELVE CYLINDERS, TURBOCHARGED, 1502 BHP, DRIVING A 1000 KW EMERGENCY ELECTRICAL GENERATOR

**BACKGROUND**

Eastern Municipal Water District (EMWD) provides water distribution and sewage treatment in the greater area of Riverside County. It operates several desalination plants, water pumping stations and four sewage treatment plants in this area. The equipment in this application is located at Temecula Valley Regional Water Reclamation Facility located at 4265 Avenida Alvarado, Temecula, California.

This engine has been certified by AQMD and was given an application no. 452094 (see attached evaluation submitted by the applicant).

Table 1 lists permit processing fees and equipment information.

**Table 1: PERMIT APPLICATION TRACKING INFORMATION**

<i>Application No. 503585</i>	<i>Information</i>
Equipment Description	IC Engine, Emergency, 1502 HP
Date Received	11/10/2009

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><i>ENGINEERING &amp; COMPLIANCE DIVISION</i></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 2
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

Deemed Complete Date	12/10/2009
Application Type	10
Application Status	21
Previous Application No.	N/A
B-CAT No./ C-CAT No	043901/00
Fee Schedule	B
Fee Required	\$ 2,051.52
Title V fees	\$ 843.80
Total paid fees	\$ 2,859.32

### **COMPLIANCE RECORD REVIEW**

A review of the AQMD Compliance Database showed no Notice of Violation (NOV) and 1 Notice to Comply (NC) issued to Eastern Municipal Water District in the past two years (12/01/2008-12/17/2009). The notice to comply is in compliance status. A summary of the NOV and NC is provided in Attachment 1. The Eastern Municipal Water District is currently in compliance.

### **PROCESS DESCRIPTION**

The ICE will drive an electrical generator at the facility. This 12-cylinder engine will operate on diesel fuel. The engine is turbocharged and aftercooled to improve engine performance. Following is the information on the engine:

IC Engine: Caterpillar  
 Model: C-32  
 Rating: 1502 BHP

### **EMISSIONS CALCULATION**

The manufacturer's emissions data for the Caterpillar C-32 Engine is as follows:

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><b>ENGINEERING &amp; COMPLIANCE DIVISION</b></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 3
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

**Table 2: ENGINE EMISSION DATA**

<i>SOx</i>	<i>ROG</i>	<i>NOx</i>	<i>CO</i>	<i>PM</i>	<i>PM10</i>
0.0048 <sup>(2)</sup> grams/bhp- hr	0.1 <sup>(1)</sup> grams/bhp- hr	3.76 <sup>(1)</sup> grams/bhp- hr	0.34 <sup>(1)</sup> grams/bhp- hr	0.052 <sup>(1)</sup> grams/bhp- hr	0.050 <sup>(1)</sup> grams/bhp- hr

(1) Data sheet attached in the application

(2) based on sulfur content of 15 ppm by weight with the standard specified by Rule 431.2 ( 0.000015 lb-S/lb-diesel x 7.1 lb-diesel/gal x 2 lb-SO<sub>2</sub>/lb-S x 2542.5 Btu/hp-hr ÷ 137,000 Btu/gal ÷ 0.37 hp-out/hp-in x 453.6 g/lb = 0.0048 g/bhp-hr SOx (as SO<sub>2</sub>))

$$\begin{aligned} \text{NOx (lb/hr)} &= 3.76 \text{ g/hp-hr} \times (1502\text{hp}) \times (\text{lb}/453.6\text{g}) \\ &= 12.45 \text{ lb/hr} \end{aligned}$$

Maximum Operating Time: 1 hour/day; 1 day/week, 30 days/month, 4.33 hours/month, 50 hrs/year

The overall mass emissions are summarized below in Table 3. (See Attachment 2 for emissions calculations)

**Table 3-Estimated Emissions for the C-32 Engine**

	<i>Units</i>	<i>Estimated Emissions for C32 Engine</i>				
		<i>VOC</i>	<i>NOX</i>	<i>SOX</i>	<i>CO</i>	<i>PM10</i>
Hourly	lb/hr	0.33	12.45	0.016	1.126	0.17
Max Daily	Lb/day	0	12	0	1.0	0
Average Daily (1)	Lbs/day	0	2.0	0	0	0
Annual (2)	Lb/yr	16.56	622.53	0.79	56.29	8.61

(1)Average daily emissions are based on 4.33 hours /month

(2)Annual emissions are based on 50 hours/year for testing and maintenance.

## RULES EVALUATION

### **PART 1: SCAQMD REGULATIONS**

**Rule 212**      Standards for Approving and Issuing Public Notice (Amended Nov 14, 1997)

212 (a)            The applicant is required to show that the equipment, the use of which may cause the issuance of air contaminants or the use of

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><i>ENGINEERING &amp; COMPLIANCE DIVISION</i></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 4
	APPL. NO. 503585	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

which may eliminate, reduce, or control the issuance of air contaminants, is so designed, controlled, or equipped with such air pollution control equipment that it may be expected to operate without emitting air contaminants in violation of provisions of Division 26 of the State Health and Safety Code of these rules. The operation of this ICE is expected to comply with this requirement.

212(c)(1) Public notification is required if any new or modified permit unit, source under Regulation XX, or equipment under Regulation XXX may emit air contaminants located within 1000 feet from the outer boundary of a school. The source is not within 1000 feet of a school, public notification is therefore not required.

212(c)(2) Public notification is required if any new or modified facility has on-site increases exceeding any of the daily maximums specified in subdivision (g) of this rule. The increase in emissions does not exceed the threshold as specified, public notification is therefore not required.

212(c)(3) Public notification is required if the maximum individual cancer risk (MICR), based on Rule 1401, exceeds one in a million (1 x 10<sup>-6</sup>). Even though the ICE is exempt from Rule 1401 according to Rule 1401(g)(1)(F), a MICR analysis should still be performed to determine if a public notice is required. MCIR analysis was performed and based on Tier 3 Toxics Analysis, results show that the maximum incremental cancer risk (MICR) to the Maximum Exposed Individual Worker (MEIW) associated with the IC Engine is 9.34E-07 and to the Maximum Exposed Individual Resident (MEIR) was calculated to be 2.75 E-07, which is below the Rule 1401 threshold limits of 1 in a million. Public notification is therefore not required.(see attachment 3 for Tier3 analysis).

212(g) This subdivision sets forth the process for federal public notification and distribution and specifies the daily maximum emissions increase as follows:

<u>Air Contaminant</u>	<u>Daily Maximum in lbs/day</u>
Volatile Organic Compounds	30
Nitrogen Oxides	40
PM10	30
Sulfur Dioxide	60
Carbon Monoxide	220
Lead	3

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><b>ENGINEERING &amp; COMPLIANCE DIVISION</b></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 5
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

The increase in emissions does not exceed the daily maximum specified, public notification is therefore not required.

**Rule 401**     Visible Emissions (Amended Nov. 9, 2001)

Operation of the ICE is not expected to result in visible emissions. Therefore, compliance with this rule is expected.

**Rule 402**     Nuisance (Adopted May 7, 1976)

Operation of the ICE is not expected to result in a public nuisance. Therefore, compliance with this rule is expected.

**Rule 404**     Particulate Matter – Concentration (Amended February 7, 1986)

The exhaust flow rate for this engine is 1951.2 cfm at standard condition. The maximum concentration of particulate matter allowed according to Table 404(a) is 0.1462 grains per cubic feet.

Based on the manufacturer's emission factor data for PM, the PM emission rate for this engine is calculated below:

PM emission factor: 0.052 grams/bhp-hr  
Exhaust flow rate: 1951.2 scfm

$$\frac{0.052 \text{ grams}}{\text{bhp} - \text{hr}} \times \frac{\text{lb}}{454 \text{ grams}} \times 1502 \text{ hp} \times \frac{\text{min}}{1951 \text{ } .2 \text{ scf}} \times \frac{\text{hr}}{60 \text{ min}} \times \frac{7000 \text{ grains}}{1 \text{ lb}} = 0.0102863$$

The calculated PM rate of 0.0102863 gr/cf is much less than the allowed rate of 0.1462 gr/cf. Compliance is expected.

**Rule 407**     Liquid and Gaseous Air Contaminants (Amended April 2, 1982)

The provisions of this rule do not apply to emissions from stationary internal combustion engines.

**Rule 409**     Combustion Contaminants (Amended August 7, 1981)

The provisions of this rule do not apply to emissions from internal combustion engines.

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><i>ENGINEERING &amp; COMPLIANCE DIVISION</i></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 6
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

**Rule 431.2** Sulfur Content of Liquid Fuels (Amended September 15, 2000)

According to Rule 431.2(e)(3), the facility shall not purchase any diesel fuel with the sulfur content greater than 15 ppm by weight as supplied by the supplier. Permit Condition prohibits the facility from purchasing diesel fuel with sulfur content greater than 15 ppm by weight. Therefore, compliance with this rule is expected.

**Rule 1110.2** Emissions from Gaseous- and Liquid-Fueled Engines (Amended June 3, 2005)

According to Rule 1110.2(h)(2), the provisions of subdivision (d) of this rule do not apply to emergency standby engines, as approved by the Executive Officer, which operate less than 200 hours per year as determined by an elapsed operating time meter. Permit Condition limits the operation of this engine to less than 200 hours, therefore the provisions of subdivision (d) of this rule do not apply to this engine.

**Reg XIII** New Source Review (NSR)

Rule 1303: Requirements (Amended Dec. 6, 2002)

1303(a) Best Available Control Technology (BACT)

BACT means the most stringent emission limitation or control technique which: (1) has been achieved in practice; or (2) is contained in any State Implementation Plan approved by the US EPA; or (3) is any other emission limitation or control technique approved by the Executive Officer and cost effective as compared to measures listed in the Air Quality Management Plan.

Manufacturer's engine emissions data as listed in Table 2 on page 3 show that this engine will comply with the Tier 2 BACT standards for SO<sub>x</sub>, ROG, NO<sub>x</sub>, CO and PM<sub>10</sub> as outlined in the BACT Guidelines for ICE, Stationary, Emergency, Compression Ignition [Table 1. Tier 2 - 7/13/2006] as shown in Table 4 below.

This engine is certified by EPA and CARB as Tier 2 nonroad engine ( see attachment for certification). It is also a SCAQMD certified engine. Compliance with the requirements of BACT is expected.

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><b>ENGINEERING &amp; COMPLIANCE DIVISION</b></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 7
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

**Table 4: BACT LIMITS**

<i>Rating/Size</i>	<i>NMHC + NOx</i>	<i>SOx</i>	<i>CO</i>	<i>PM</i>
HP>750	4.8 <sup>(1)</sup> grams/bhp-hr	15 ppm <sup>(3)</sup> by weight Rule 431.2	2.6 <sup>(1)</sup> grams/bhp-hr	0.15 <sup>(2)</sup> grams/bhp-hr

(1) USEPA Tier 2 Certification levels required for compression ignition engines (after 7/7/2006) for engines HP>750

(2) Rule 1470 limit of 0.15 g/bhp-hr for new emergency diesel engines

(3) based on sulfur content of 15 ppm by weight with the standard specified by Rule 431.2 ( 0.000015 lb-S/lb-diesel x 7.1 lb-diesel/gal x 2 lb-SO2/lb-S x 2542.5 Btu/hp-hr ÷ 137,000 Btu/gal ÷ 0.37 hp-out/hp-in x 453.6 g/lb = **0.0048 g/bhp-hr SOx (as SO2)**)

1303(b) This subdivision lists the following requirements for a Permit to Construct for any new or modified source which results in a net emission increase of any nonattainment air contaminant at a facility.

1303(b)(1) Modeling

According to Rule 1304(a)(4), this engine is exempt from the modeling requirement because the source is exclusively used as emergency standby equipment, and does not operate more than 200 hours per year as evidenced by an engine hour meter.

1303(b)(2) Emission Offsets

The IC Engine is exclusively used as emergency standby equipment, and does not operate less than 200 hours per year as evidenced by an engine hour meter, is exempt from offset under Rule 1304(a)(4). SOx, CO, PM and ROG monthly emissions are 0 lb/day, no offset is needed. However, NOx emissions are 2 lbs/day. It is exempt under Rule 1304(a)(4).

1303(b)(3) Sensitive Zone Requirements

Since Emission Reduction Credits were not required, this section does not apply.

1303(b)(4) Facility Compliance

The facility is expected to comply with all applicable rules and regulations of the District. For facility compliance see compliance record review in page 2 of this evaluation.

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><i>ENGINEERING &amp; COMPLIANCE DIVISION</i></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 8
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

- 1303(b)(5) Major Polluting Facilities
- A. Alternative Analysis
  - B. Statewide Compliance
  - C. Protection of Visibility
  - D. Compliance Through California Environmental Quality Act

This application is considered a major modification according to the definition in R1302(r), since the increase in NOx emissions is greater than 1 lb/day. This section does apply. Compliance must be demonstrated prior to the issuance of the Permit to Construct. A certified Statewide Compliance letter has been provided by the Eastern Municipal Water District. (see attachment 4). Compliance expected.

**Reg XIV** Toxics and Other Non-Criteria Pollutants

Rule 1401: New Source Review of Toxic Air Contaminants (Amended March 4, 2005)

According to Rule 1401(g)(1)(F), the requirements of subdivision (d) of this rule do not apply to emergency internal combustion engines that are exempted under Rule 1304. This ICE is exempted under Rule 1304; therefore, the provisions of this rule do not apply.

Rule 1470: Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Ignition Engines (Amended March 4, 2005)

This rule applies to any person who own or operates a stationary compression ignition engines in the SCAQMD with a rated brake horsepower greater than 50.

1470(c) Requirements

1470(c)(1) Fuel and Fuel Additive Requirements

1470(c)(1)(A) The IC engine will use CARB diesel fuel with a sulfur content of 15 ppm or less as imposed in Condition No. B61.6. Compliance is expected.

1470(c)(2) Operating Requirements and Emission Standards

1470(c)(2)(A) The IC engine are not located 500 feet or less from a school, this section does not apply.

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><b>ENGINEERING &amp; COMPLIANCE DIVISION</b></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 9
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

1470(c)(2)(B) The IC engine can only operate under rotating outages, no more than 30 minutes prior to the outage forecast. Compliance is expected.

1470(c)(2)(C) Based on the manufacturer's data, this engine meets the PM limit of 0.15 g/bhp-hr and the EPA NMHC + NOx and CO standards for Tier II non-road diesel engines. Per Rule 1470 (f)(1)(B), the engine manufacturer test data may be used to meet the emission data requirements of paragraph (c) (2). Compliance is therefore expected.

The IC engine will not operate more than 50 hours per year for testing and maintenance as imposed in permit condition. Compliance is expected.

1470(c)(7) Demand Response Program

This section lists requirements for new emergency diesel-fueled engines used in Demand Response Program (DRP). DRP is a program for reducing electrical demand using an interruptible service contract (ISC). This engine will not be used in DRP-condition no. 6 prohibits its use in DRP.

1470(d) Recordkeeping, Reporting and Monitoring Requirements

1470(d)(1) The facility submitted all the required information in this section.

1470(d)(4) The facility submitted the engine manufacturer emission test data which shows compliance to subparagraph (c)(2)(C).

1470(d)(7) By permit condition a non-resettable totalizing timer shall be installed on the engine to indicate elapsed operating time. Compliance is expected.

1470(d)(9) By permit condition the operator of the engine will keep records according to this provision. Compliance is expected.

**Reg XX** Regional Clean Air Incentives Market (RECLAIM)

Rule 2005: New Source Review for RECLAIM (May 6, 2005)

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><i>ENGINEERING &amp; COMPLIANCE DIVISION</i></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 10
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

EMWD's Temecula Valley Regional Water Reclamation facility is not a RECLAIM facility.

**Reg XXX**     Title V Permits

3002(a): Requirements

Eastern Municipal Water District – Temecula Valley Regional Water Reclamation Facility (ID 1703) is a Title V facility and the addition of the IC Engine is considered a significant revision to the existing Title V permit. As a significant revision, the permit is subject to a 30 day public notice and a 45 day EPA review and comment period.

3004(a)(4): Periodic Monitoring

Conditions have been added for record keeping and reporting requirements.

**PART 2: STATE REGULATIONS**

**CEQA**     California Environmental Quality Act

CEQA requires that the environmental impacts of proposed projects be evaluated and that feasible methods to reduce, avoid or eliminate identified significant adverse impacts of these projects be considered. The CEQA Applicability Form (400-CEQA) submitted by Eastern Municipal Water District indicates that the project does not have any impacts which trigger the preparation of a CEQA document; therefore a CEQA analysis is not required.

**PART 3**     **FEDERAL REGULATIONS**

**40CFR Part 60 Subpart III New Source Performance Standard (NSPS) for Stationary Compression Ignition Internal Combustion Engines, June 28, 2006**

This subpart applies to a new stationary diesel engine which is defined as one that is constructed or ordered after July 11, 2005 and manufactured after April 1, 2006. Since this engine has a manufactured date of April 19, 2006, this subpart applies to this engine.

For Engines before the 2007 model year, the owner/operator is required to purchase a certified nonroad engine to comply with the regulatory requirement. Since this engine is an EPA certified Tier 2 engine, compliance is expected.

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><i>ENGINEERING &amp; COMPLIANCE DIVISION</i></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 11
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

**40CFR Part 63 Subpart ZZZ National Emission Standard for Hazardous Air Pollutants Reciprocating Internal Combustion Engines (RICE MACT), June 26, 2006**

This subpart applies to RICE located at major sources of HAPs. This subpart delineates the requirements for stationary RICE, including compression ignition engines. Applicable engines are required to meet either emissions limitations, or meet other specified subparts.

Emergency IC engines are exempt from the requirements of this subpart, except for the initial notification requirements under §63.6445(d). Under this subsection, the owner or operator of an affected source that has an initial startup before the effective date of a standard shall notify the Administrator in writing that the source is subject to the relevant standard. Since the effective date for the RICE NESHAP has already passed, no notification is required. Compliance expected.

**CONCLUSION AND RECOMMENDATION**

This equipment is expected to comply with all applicable District Rules and Regulations. Therefore, a Permit to Construct and Operate is recommended subject to the following conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED.
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITIONS AT ALL TIMES.
3. THIS ENGINE SHALL NOT BE OPERATED MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING.
4. AN OPERATIONAL NON-RESETTING TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
5. THE OPERATION OF ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><i>ENGINEERING &amp; COMPLIANCE DIVISION</i></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 12
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.

6. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
7. ON OR BEFORE JANUARY 15TH OF EACH YEAR THE OPERATOR SHALL RECORD IN THE ENGINE OPERATING LOG:
  - a. THE TOTAL HOURS OF ENGINE OPERATION FOR THE PREVIOUS CALENDAR YEAR, AND
  - b. THE TOTAL HOURS OF ENGINE OPERATION FOR MAINTENANCE AND TESTING FOR THE PREVIOUS CALENDAR YEAR.

ENGINE OPERATION LOG(S) SHALL BE RETAINED ON SITE FOR A MINIMUM OF FIVE CALENDAR YEARS AND SHALL BE MADE AVAILABLE TO THE EXECUTIVE OFFICER OR REPRESENTATIVE UPON REQUEST.

8. THE OPERATOR SHALL KEEP A LOG OF ENGINE OPERATIONS DOCUMENTING THE TOTAL TIME THE ENGINE IS OPERATED EACH MONTH AND THE SPECIFIC REASON FOR OPERATION AS:

 <p>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</p> <p><i>ENGINEERING &amp; COMPLIANCE DIVISION</i></p> <p>APPLICATION PROCESSING AND CALCULATIONS</p>	PAGES 13	PAGE 13
	APPL. NO. <b>503585</b>	DATE 12/19/09
	PROCESSED BY SA Andrawis	CHECKED BY

- a. EMERGENCY USE
- b. MAINTENANCE AND TESTING
- c. OTHER (BE SPECIFIC).

IN ADDITION, FOR EACH TIME THE ENGINE IS MANUALLY STARTED, THE LOG SHALL INCLUDE THE DATE OF ENGINE OPERATION, THE SPECIFIC REASON FOR OPERATION, AND THE TOTALIZING HOUR METER READING (IN HOURS AND TENTHS OF HOURS) AT THE BEGINNING AND THE END OF THE OPERATION.

9. THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470.