

**FACILITY PERMIT TO OPERATE  
EXXONMOBIL OIL CORP**

**PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO  
OPERATE  
(SECTION H)**

This section consists of a table listing all individual Permits to Construct issued to various equipment at the facility. Each permit will list operating conditions, including periodic monitoring requirements and applicable emission limits and requirements. Also included are the rule origin and authority of each emission limit and permit condition.

**FACILITY PERMIT TO OPERATE  
EXXONMOBIL OIL CORP**

**PERMITTED EQUIPMENT LIST**

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AT THIS FACILITY:

| <b>APPLICATION NUMBER</b> | <b>PERMIT TO CONSTRUCT NUMBER</b> | <b>EQUIPMENT DESCRIPTION</b>                                  | <b>PAGE NO.</b> |
|---------------------------|-----------------------------------|---|-----------------|
| 577163                    | 577163                            | SOIL VAPOR EXTRACTION, GASOLINE IN-SITU, ICE THERMAL OXIDIZER | 3               |

**NOTE:** EQUIPMENT LISTED ABOVE ARE ISSUED PERMITS TO CONSTRUCT. THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW. ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT.

## FACILITY PERMIT TO OPERATE EXXONMOBIL OIL CORP

### PERMIT TO CONSTRUCT

A/N 577163  
Granted TBD

#### Equipment Description:

SOIL VAPOR EXTRACTION AND TREATMENT SYSTEM, RSI MODEL NO. V3, FOR NON-HALOGENATED HYDROCARBON IN SITU SOIL REMEDIATION ONLY, CONSISTING OF:

1. VAPOR EXTRACTION WELL(S).
2. VACUUM EXTRACTION FLEXIBLE HOSE WITH AIR FILTER, INDUCED SUCTION BY ENGINE INTAKE, MAXIMUM FLOW RATE 120 SCFM.
3. VAPOR LIQUID SEPARATOR.
4. INTERNAL COMBUSTION ENGINE, RSI (MODIFIED) MODEL NO. LSG-875, SPARK IGNITION, FOUR STROKE, RICH BURN, WITH 8 CYLINDERS, NATURALLY ASPIRATED, 49 BHP, COMBINED WITH CAR SOUND 3-WAY CATALYTIC CONVERTOR MODEL NO.95000, AND A COMPUTERIZED RSI OXYGEN (AIR) TO FUEL RATIO SENSING AND CONTROL UNIT, MODEL PHOENIX 1000.
5. EXHAUST STACK, 3" I.D. X 11.5' H., WITHOUT RAIN CAP.

#### Conditions:

- 1) CONSTRUCTION AND OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.  
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.  
[RULE 204]
- 3) PRIOR TO CONNECTING ANY VAPOR EXTRACTION WELLS TO THE COLLECTION SYSTEM, THE COMPLETED WELLS SHALL BE CAPPED TO PREVENT VAPORS FROM VENTING TO THE ATMOSPHERE.  
[RULE 204]
- 4) UPON COMPLETION, ANY VAPOR EXTRACTION WELLS AND DUCTS SHALL BE SHALL BE CAPPED TO PREVENT VAPORS FROM VENTING TO THE ATMOSPHERE. VAPORS SHALL NOT BE EXTRACTED FROM THE SOIL UNLESS THEY ARE VENTED TO THE VAPOR CONTROL SYSTEM, WITH NO DETECTABLE LEAKS BETWEEN THE OUTLET OF THE VAPOR WELLS AND THE OUTLET OF THE VAPOR CONTROL SYSTEM.  
[RULE 204]
- 5) PRIOR TO OPERATING THIS EQUIPMENT UNDER WHICH THIS PERMIT IS GRANTED, THE OPERATOR SHALL NOTIFY SCAQMD BY SUBMITTING A RULE 1166 NOTIFICATION FORM WITH THE APPROPRIATE FEES PER THE FORM INSTRUCTIONS.  
[RULE 1166]

## FACILITY PERMIT TO OPERATE EXXONMOBIL OIL CORP

- 6) AN IDENTIFICATION TAG OR NAMEPLATE SHALL BE DISPLAYED ON THE EQUIPMENT TO SHOW MANUFACTURER, MODEL NUMBER, SERIAL NUMBER, AND POWER RATING. THE TAG(S) OR PLATE(S) SHALL BE ISSUED BY THE MANUFACTURER AND SHALL BE ADHERED TO THE EQUIPMENT IN A PERMANENT AND CONSPICUOUS POSITION.  
[RULE 204]
- 7) THE CURRENT CONTACT PERSON'S NAME, COMPANY, AND PHONE NUMBER SHALL BE DISPLAYED IN A PERMANENT AND CONSPICUOUS POSITION.  
[RULE 204]
- 8) THIS EQUIPMENT SHALL NOT BE USED TO GENERATE ANY ELECTRICITY OR PRODUCE ANY MECHANICAL WORK AS A RESULT OF THE ENGINES RECIPROCATING MOTION. IT SHALL ONLY BE USED TO COMBUST INCOMING SOIL VAPORS AND FUEL TO CONTROL SOIL GAS EMISSIONS.  
[RULE 204]
- 9) THE INTERNAL COMBUSTION ENGINE SHALL ONLY BE FIRED ON PROPANE AS SUPPLEMENTAL FUEL.  
[RULE 204]
- 10) THIS EQUIPMENT SHALL ONLY BE USED FOR THE TREATMENT OF NON-HALOGENATED PETROLEUM HYDROCARBON VAPORS. THIS SHALL BE DEMONSTRATED BY AN ONSITE SOIL CHARACTERIZATION ANALYSIS REPORT.  
[RULE 204, 1401]
- 11) THIS EQUIPMENT SHALL NOT BE OPERATED WITHOUT THE USE OF AN RSI AUTOMATIC AIR TO FUEL RATIO CONTROLLER WHICH SHALL BE MAINTAINED AND KEPT IN PROPER OPERATING CONDITION AT ALL TIMES AS SPECIFIED BY THE MANUFACTURER.  
[RULE 204, 1303(A)(1)-BACT]
- 12) A CONTINUOUS FLOW INDICATOR AND RECORDER SHALL BE INSTALLED AND MAINTAINED AT ALL INLET STREAM(S) TO THE VAPOR TREATMENT SYSTEM TO INDICATE THE TOTAL AIR FLOW RATE IN STANDARD CUBIC FEET PER MINUTE (SCFM). THE TOTAL FLOW RATE TO THE VAPOR CONTROL SYSTEM SHALL NOT EXCEED 120 SCFM. IF A PRESSURE SENSOR DEVICE IS USED IN PLACE OF THE FLOW INDICATOR, A CONVERSION CHART SHALL BE MADE AVAILABLE TO INDICATE THE CORRESPONDING FLOW RATE, IN SCFM, TO THE PRESSURE READING. THE FLOW RATE TO THE VAPOR CONTROL SYSTEM SHALL BE RECORDED ON A WEEKLY BASIS.  
[RULE 204, 1303(B)(2)-OFFSETS, 1313(G)-EMISSION LIMITATION, 1401]
- 13) UNCONTROLLED ENGINE INLET VOC EMISSIONS SHALL BE LESS THAN 10 TONS IN ANY ONE CALENDAR YEAR. INLET MASS EMISSIONS SHALL BE CALCULATED BASED ON THE AVERAGE WEEKLY INLET FLOW RATE MEASURED IN CONDITION 13 AND THE MEASURED INLET CONCENTRATION. THE INLET CONCENTRATION RECORDED EACH 7 OPERATING DAYS AS OUTLINED IN CONDITION 24 SHALL BE USED FOR THIS CALCULATION FOR EACH DAY PRIOR UNTIL THE SUBSEQUENT INLET CONCENTRATION MEASUREMENT OCCURS.  
[RULE 204]
- 14) THE LABORATORY DETECTION LIMITS (LDL) FOR BENZENE, ETHYL BENZENE, MTBE,

## FACILITY PERMIT TO OPERATE EXXONMOBIL OIL CORP

1,3-BUTADIENE, FORMALDEHYDE, NAPHTHALENE, AND ACETALDEHYDE, SHALL BE LOWER THAN THE EMISSION LIMITS SPECIFIED IN THESE CONDITIONS. IF THE CONCENTRATION IS DETERMINED TO BE BELOW THE LDL, THE LDL SHALL BE REPORTED.  
[RULE 204]

- 15) A NON-RESETTABLE OPERATIONAL TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE, IN CUMULATIVE HOURS, THE ENGINE ELAPSED OPERATING TIME. THE ELAPSED OPERATING TIME SHALL BE RECORDED AT LEAST ONCE EACH WEEK OF OPERATION.  
[RULE 204]
- 16) A CONTINUOUS MONITORING AND RECORDING DEVICE SHALL BE FACTORY CALIBRATED AND MAINTAINED AT THE INLET OF THE CATALYTIC CONVERTOR TO MEASURE AND RECORD THE OXYGEN CONTENT. THE OXYGEN CONTENT AT THE INLET OF THE CATALYTIC CONVERTOR SHALL BE MAINTAINED AT LESS THAN 1% BY VOLUME WHENEVER THE ENGINE IS IN OPERATION. THE ENGINE EXHAUST SENSOR ELECTRICAL OUTPUT SHALL BE MEASURED BY THE PHOENIX1000 CONTROL SYSTEM IN REAL TIME AND RECORDED IN 30 MINUTE INTERVALS. THE CONTROLLER SHALL CONTROL THE AIR/FUEL MIXTURE SO THAT THE OXYGEN SENSOR OUTPUT REMAINS BETWEEN 212 AND 637 MILLIVOLTS (MV) (SCALED AS 1000 TO 3000 ON CONTROLLER OUTPUT). AT ANY POINT IN TIME, IF THE OUTPUT ON THE PHOENIX 1000 AIR/FUEL RATIO CONTROLLER IS LESS THAN 1000 (212 MV), THEN THE OXYGEN CONCENTRATION IN THE EXHAUST PRIOR TO THE CATALYTIC CONVERTOR SHALL BE DEEMED TO BE GREATER THAN 1% BY VOLUME AND THEREFORE OUT OF COMPLIANCE.  
[RULE 204, 1303(A)(1)-BACT]
- 17) A TEMPERATURE MEASUREMENT AND RECORDING DEVICE WITH AN ACCURACY OF PLUS OR MINUS 5 DEGREES FAHRENHEIT SHALL BE INSTALLED AND MAINTAINED TO ACCURATELY AND CONTINUOUSLY INDICATE THE TEMPERATURE AT THE INLET AND OUTLET OF THE CATALYTIC CONVERTOR AND RECORD THE TEMPERATURE MEASUREMENTS IN 30 MINUTE INTERVALS WHILE THE SYSTEM IS IN OPERATION.  
[RULE 204, 1303(A)(1)-BACT]
- 18) WHENEVER THE ENGINE IS OPERATING, THE TEMPERATURE AT THE INLET OF THE CATALYTIC OXIDIZER SHALL BE MAINTAINED BETWEEN 600 DEGREES FAHRENHEIT AND 1100 DEGREES FAHRENHEIT.  
[RULE 204, 1303(A)(1)-BACT]
- 19) A HIGH TEMPERATURE SHUT-DOWN MECHANISM SHALL BE INSTALLED AT THE OUTLET PORT OF THE CATALYTIC CONVERTOR AND SET TO 1300 DEGREES FAHRENHEIT OR LESS.  
[RULE 204, 1303(A)(1)-BACT]
- 20) THE CATALYST IN THE CONVERTOR SHALL BE MAINTAINED IN GOOD WORKING CONDITION. THE OPERATOR SHALL MAINTAIN RECORDS OF CATALYST CLEANING PERIODS AND REPLACEMENT FREQUENCY.  
[RULE 204]

## FACILITY PERMIT TO OPERATE EXXONMOBIL OIL CORP

- 21) THE CATALYTIC CONVERTOR SHALL BE REPLACED AFTER 4320 HOURS OF OPERATION OR WHEN A TEMPERATURE RISE ACROSS THE CATALYTIC CONVERTOR OF LESS THAN 25 DEGREES FAHRENHEIT OCCURS WHILE UNDER NORMAL OPERATION. THE TOTAL NUMBER OF HOURS THE CATALYST HAS BEEN IN USE SHALL BE RECORDED. THESE RECORDS SHALL BE MAINTAINED ON SITE.  
[RULE 204]
- 22) THE OXYGEN SENSOR SHALL BE REPLACED AFTER 4320 HOURS OF OPERATION. THE TOTAL NUMBER OF HOURS THE OXYGEN SENSOR HAS BEEN IN USE SHALL BE RECORDED. THESE RECORDS SHALL BE MAINTAINED ON SITE.  
[RULE 204]
- 23) VOLATILE ORGANIC COMPOUND (VOC) CONCENTRATION SHALL BE MEASURED DAILY AT THE INLET AND OUTLET OF THE VAPOR TREATMENT SYSTEM DURING THE FIRST SEVEN DAYS OF OPERATION, THEN AT LEAST ONCE EVERY SEVEN OPERATING DAYS BY USING A FLAME IONIZATION DETECTOR, PHOTO IONIZATION DETECTOR, OR A DISTRICT APPROVED ORGANIC VAPOR ANALYZER (OVA) CALIBRATED IN PARTS PER MILLION BY VOLUME (PPMV) OF HEXANE (IF OTHER CALIBRATING AGENT WAS USED, IT SHALL BE CORRELATED TO AND EXPRESSED AS HEXANE). CALIBRATION SHALL BE PERFORMED WITH EACH MONITORING VISIT.  
[RULE 204, 1303(B)(2)-OFFSETS]
- 24) VOC OUTLET PPMV READINGS SHALL BE CONVERTED TO LBS/DAY USING THE CURRENT PPMV READING FOR THE PREVIOUS 7 OPERATING DAYS UNTIL A SUBSEQUENT VOC MEASUREMENT IS RECORDED. INLET FLOW RATE DETERMINED IN CONDITION 13 FOR VAPOR WELL FLOW, DILUTION AIR FLOW, AND PROPANE FLOW IN SCFM SHALL BE COMBINED TO DETERMINE OUTLET SCFM FLOW. THIS OUTLET FLOW SHALL BE USED FOR THE PREVIOUS 7 OPERATING DAYS UNTIL A SUBSEQUENT READING IS RECORDED. OUTLET MASS EMISSIONS RATE SHALL BE CALCULATED AND RECORDED EVERY 7 OPERATING DAYS.  
[RULE 204, 1303(B)(2)-OFFSETS]
- 25) SAMPLES SHALL BE COLLECTED AND ANALYZED DURING THE FIRST WEEK OF OPERATION UNDER THIS PERMIT FOR VOLATILE ORGANIC COMPOUNDS AND SPECIATED FOR BENZENE, ETHYL BENZENE, MTBE, 1,3-BUTADIENE, FORMALDEHYDE, NAPHTHALENE, ACETALDEHYDE AND OTHER TOXICS AS REQUIRED IN PARAGRAPH (E) AS FOLLOWS:
  - A. SAMPLES SHALL BE COLLECTED AT THE INLET OF THE ENGINE AND THE OUTLET OF THE CATALYTIC CONVERTOR.
  - B. SAMPLING AND ANALYSIS SHALL BE CONDUCTED BY AN INDEPENDENT LABORATORY PER RULE 304. THE PERSONNEL CONDUCTING THE SAMPLING SHALL HAVE BEEN PROPERLY TRAINED IN SAMPLING METHODOLOGY.
  - C. SAMPLING SHALL CONFORM TO CARB METHOD 422 OR EQUIVALENT. SAMPLES WITH HIGH MOISTURE SHALL BE COLLECTED USING AN APPROPRIATE METHOD SUCH AS SCAQMD METHOD 25.1/25.3 OR OTHER METHODS APPROVED BY SCAQMD.
  - D. ANALYSIS SHALL BE CONDUCTED USING EPA METHOD TO-15, TO-3, OR OTHER METHOD APPROVED BY SCAQMD.

## FACILITY PERMIT TO OPERATE EXXONMOBIL OIL CORP

- E. THE INLET SAMPLE SHALL ALSO BE ANALYZED FOR ALL VOLATILE ORGANIC COMPOUNDS THAT WERE BOTH DETECTED BY THE PHASE II SITE ASSESSMENT (SOIL AND GROUNDWATER CHARACTERIZATION STUDIES) AND FOUND ON THE RULE 1401 COMPOUND LIST. IF NO ASSESSMENTS OF SOIL OR GROUNDWATER EXIST, THE INLET SAMPLE SHALL BE ANALYZED FOR ALL VOLATILE ORGANIC COMPOUNDS LISTED IN SCAQMD RULE 1401, UNLESS OTHERWISE APPROVED IN WRITING BY SCAQMD.  
[RULE 204, 304, 1303, 1401]
- 26) SAMPLES SHALL BE COLLECTED AND ANALYZED ONCE EACH MONTH OF OPERATION FOR VOLATILE ORGANIC COMPOUNDS AND SPECIATED FOR BENZENE, ETHYL BENZENE, MTBE, 1,3-BUTADIENE, FORMALDEHYDE, NAPHTHALENE, ACETALDEHYDE AND OTHER CARCINOGENS AS FOLLOWS:
- A. SAMPLES SHALL BE COLLECTED AT THE INLET OF THE ENGINE AND THE OUTLET OF THE CATALYTIC CONVERTOR.
- B. SAMPLING SHALL CONFORM TO CARB METHOD 422 OR EQUIVALENT. SAMPLES WITH HIGH MOISTURE SHALL BE COLLECTED USING AN APPROPRIATE METHOD SUCH AS SCAQMD METHOD 25.1/25.3 OR OTHER METHODS APPROVED BY SCAQMD.
- C. ANALYSIS SHALL BE CONDUCTED USING EPA METHOD TO-15, TO-3, OR OTHER METHOD APPROVED BY SCAQMD.  
[RULE 204, 1303, 1401]
- 27) THIS EQUIPMENT SHALL ONLY EXHAUST THROUGH A STACK AT A HEIGHT OF AT LEAST 11.5 FEET ABOVE GRADE, WITH NO RAIN CAP.  
[RULE 204, 1401]
- 28) THIS EQUIPMENT SHALL NOT EXTRACT OR TREAT VAPORS FROM SOILS CONTAMINATED WITH ANY RULE 1401 LISTED CARCINOGENIC AIR CONTAMINANTS (AS AMENDED JUNE 5, 2015) WITH THE EXCEPTION OF BENZENE, ETHYL BENZENE, MTBE, 1,3-BUTADIENE, FORMALDEHYDE, NAPHTHALENE, ACETALDEHYDE, AND ANY OTHER TRACE CONTAMINANTS WITH A CANCER POTENTIAL GREATER THAN  $0.27 \text{ (MG/KG-DAY)}^{-1}$  (AS OUTLINED IN PERMIT PACKAGE APPLICATION "M" USED IN CONJUNCTION WITH THE RISK ASSESSMENT PROCEDURES FOR RULES 1401, 1401.1, AND 212). THIS SHALL BE VERIFIED BY SITE ASSESSMENT, PERFORMANCE TEST RESULTS, VAPOR SAMPLING, OR OTHER APPROPRIATE STUDIES.  
[RULE 204, 1401]

## FACILITY PERMIT TO OPERATE EXXONMOBIL OIL CORP

- 29) THE OPERATOR SHALL SUBMIT TO THE SCAQMD IN WRITING THE RESULTS OF THE FIRST MONTH OF OPERATIONS, INCLUDING BUT NOT LIMITED TO: MONITORING, LAB ANALYSES, FLOW READINGS, AND TEMPERATURE READINGS SUFFICIENT TO PROVE COMPLIANCE WITH THE CONDITIONS OF THIS PERMIT. SUBMITTAL SHALL BE WITHIN 30 DAYS OF LAST MONITORING/SAMPLING DAY AND ADDRESSED TO:

SCAQMD  
BULK TERMINALS AND WASTE MANAGEMENT TEAM  
ENGINEERING AND COMPLIANCE DIVISION  
21865 COPLEY DRIVE  
DIAMOND BAR, CA 91765

DATA FOR SUBSEQUENT MONTHS OF OPERATION SHALL BE MAINTAINED ON SITE AND MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST.  
[RULE 204]

- 30) RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO SCAQMD PERSONNEL UPON REQUEST.  
[RULE 204]
- 31) THIS PERMIT TO CONSTRUCT SHALL EXPIRE ONE YEAR FROM THE DATE OF ISSUANCE UNLESS AN EXTENSION IS GRANTED BY THE EXECUTIVE OFFICER.  
[RULE 205]
- 32) THE OWNER OR OPERATOR SHALL PERFORM A PERFORMANCE TEST WITHIN 90 DAYS OF STARTUP WHILE EXCLUSIVELY FIRED ON PROPANE SUPPLEMENTAL FUEL FOR NOX, CO, AND VOC, TO DEMONSTRATE COMPLIANCE WITH THE EMISSION LIMITS OF THIS PERMIT. A WRITTEN PROTOCOL AND NOTIFICATION OF THE TEST SHALL BE SUBMITTED AT LEAST 30 DAYS BEFORE THE PERFORMANCE TEST IS SCHEDULED TO BEGIN. RESULTS SHALL BE SUBMITTED WITHIN 30 DAYS OF COMPLETION OF THE TEST(S). THE PERFORMANCE TEST SHALL CONSIST OF THREE SEPARATE TEST RUNS AT VARIOUS LOADINGS COVERING THE RANGE OF NORMAL OPERATION, EACH RUN SHALL LAST FOR AT LEAST ONE HOUR, USING APPROVED METHODS. THE TEST SHALL DETERMINE, AT A MINIMUM, THE FOLLOWING:
- A. CONCENTRATION (PPMV), AND MASS EMISSIONS RATE (LB/HR) & (GRAMS/BHP-HR) FOR NOX, CO, & VOC.
  - B. PERCENT OXYGEN, NITROGEN, MOISTURE, TEMPERATURE & FLOW RATE.
  - C. BTU INPUT AND/OR SUPPLEMENTAL FUEL FLOW RATE.
  - D. THE TEST SHALL BE PERFORMED BY A TESTING LABORATORY CERTIFIED TO MEET THE CRITERIA IN SCAQMD RULE 304(M) (CONFLICT OF INTEREST).
  - E. SAMPLING FACILITIES SHALL COMPLY WITH SCAQMD "GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES" PURSUANT TO RULE 217. [RULE 304, 1303(A)(1)-BACT, 1303(B)(2) - OFFSETS, 1313(G)-EMISSION LIMITATION]

**Periodic Monitoring: NONE**

## FACILITY PERMIT TO OPERATE EXXONMOBIL OIL CORP

### Emissions and Requirements:

- 33) THE CONCENTRATIONS OF THE FOLLOWING COMPOUNDS MEASURED AT THE OUTLET OF THE VAPOR TREATMENT SYSTEM SHALL NOT EXCEED THE FOLLOWING:

VOC: 0.41 LBS/DAY, RULE 1303(A)(1)-BACT, 1303(B)(2)-OFFSETS, 1313(G)-EMISSION LIMITATION

NOX: 0.48 LBS/DAY, RULE 1303(A)(1)-BACT, 1313(G)-EMISSION LIMITATION

CO: 1.44 LBS/DAY, RULE 1303(A)(1)-BACT, 1313(G)-EMISSION LIMITATION

BENZENE: 0.93 PPMV, RULE 1401

ETHYL BENZENE: 0.28 PPMV, RULE 1401

MTBE: 0.60 PPMV, RULE 1401

1,3-BUTADIENE: 0.28 PPMV, RULE 1401

FORMALDEHYDE: 2.86 PPMV, RULE 1401

NAPHTHALENE: 0.01 PPMV, RULE 1401

ACETALDEHYDE: 0.26 PPMV, RULE 1401

TRACE CONTAMINANTS\* 0.28 PPMV, RULE 1401

\*TRACE CONTAMINANTS ARE DEFINED AS THOSE CARCINOGENS WITH A CANCER POTENTIAL LESS THAN OR EQUAL TO 0.27 (MG/KG-DAY)<sup>-1</sup> (AS OUTLINED IN PERMIT PACKAGE APPLICATION "M" USED IN CONJUNCTION WITH THE RISK ASSESMENT PROCEDURES FOR RULES 1401, 1401.1, AND 212)