



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 19, 2014

Mr. Gerardo C. Rios
US EPA Region IX
75 Hawthorne Street, Air 3
San Francisco, CA 94105

Re: Transmittal of Proposed Title V Permit Revision (A/N 554606) for the City of LA, Sanitation Bureau, Hyperion Treatment Plant - HTP (Facility ID 800214)

Dear Mr. Rios:


Enclosed for your 45-day review is the proposed revision to the Title V Permit for City of LA, Sanitation Bureau, Hyperion Treatment Plant - HTP, located at 12000 Vista Del Mar, Playa del Rey, CA. This revision is considered to be a minor revision due to equipment modifications resulting in no change in emissions. We are enclosing proposed Section D, including the revised permit as shown below and the engineering evaluations.

SECTION D: PERMITS TO OPERATE

Appl. Nos.	Equipment	Description
554605	Sewage Treatment Facility (Headworks)	Modification of Headworks Facility (P/O # D93840) by: 1) Replacing grit grinders with screening grinders, removing screening pumps and dewatering screens, and reducing number of compactors. 2) Reducing number of grit pumps and dewatering screw conveyors, and removing holding hoppers. 3) Removing scum wetwells, dewatering pumps, and scum pumps. Also, the above application will be used to consolidate the equipment operating under the Wastewater Treatment Plant.

This request is being made via electronic submittal in order to facilitate your review. If you have any questions or need additional information, please contact Mr. Abdi Majidifar at (909) 396-2449 or by email at amajidifar@aqmd.gov.

Very truly yours,

A handwritten signature in black ink, appearing to read "Andrew Lee". The signature is fluid and cursive, with a large initial "A" and "L".

Andrew Lee, P.E.
Senior Engineering Manager
Waste Management/Terminals -
Permitting

AL: CDT: AM

Enclosures

cc: Timeyin Dafeta, Plant Manager, City of LA, Sanitation Bureau (HTP) w/o evaluation
A/N 554606 - TV permit revision