FACILITY PERMIT TO OPERATE

DISNEYLAND RESORT
1313 S HARBOR BLVD
ANAHEIM, CA 92802

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER

By Ed Merchbacher for
Mohsen Nazemi, P.E.
Deputy Executive Officer
Engineering & Compliance

FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	2	08/03/2012
B	RECLAIM Annual Emission Allocation	6	08/03/2012
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	11	08/03/2012
E	Administrative Conditions	1	08/03/2012
F	RECLAIM Monitoring and Source Testing Requirements	1	08/03/2012
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	1	08/03/2012
H	Permit To Construct and Temporary Permit to Operate	5	08/03/2012
I	Compliance Plans & Schedules	1	08/03/2012
J	Air Toxics	1	08/03/2012
K	Title V Administration	3	08/03/2012
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	1	08/03/2012
B	Rule Emission Limits	3	08/03/2012

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR:	DISNEYLAND RESORT
LEGAL OPERATOR (if different than owner):	
EQUIPMENT LOCATION:	1313 S HARBOR BLVD ANAHEIM, CA 92802
MAILING ADDRESS:	P O BOX 3232 ENV AFFAIRS/TDA 219N ANAHEIM, CA 92803-3232
RESPONSIBLE OFFICIAL:	DAVID ONTKO
TITLE:	DEPUTY CHIEF COUNSEL
TELEPHONE NUMBER:	(714) 781-7848
CONTACT PERSON:	HAO JIANG
TITLE:	ENVIRONMENTAL ENGINEER
TELEPHONE NUMBER:	(714) 781-4504
TITLE V PERMIT ISSUED:	August 03, 2012
TITLE V PERMIT EXPIRATION DATE:	August 02, 2017

TITLE V	RECLAIM	
YES	NOx:	YES
	SOx:	NO
	CYCLE:	1
	ZONE:	COASTAL

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NOx RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NOx emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year Begin (month/year)	End	Zone	NOx RTC Initially Allocated	NOx RTC [1] Holding as of 08/03/2012 (pounds)	Non-Tradable [2] Non-Usable RTCs (pounds)
1/2010	12/2010	Coastal	136764	39448	11078
1/2011	12/2011	Coastal	136764	13776	14771
1/2012	12/2012	Coastal	136764	105992	14771
1/2013	12/2013	Coastal	136764	105992	14771
1/2014	12/2014	Coastal	136764	105992	14771
1/2015	12/2015	Coastal	136764	105992	14771
1/2016	12/2016	Coastal	136764	105992	14771
1/2017	12/2017	Coastal	136764	105992	14771
1/2018	12/2018	Coastal	136764	105992	14771
1/2019	12/2019	Coastal	136764	105992	14771
1/2020	12/2020	Coastal	136764	105992	14771
1/2021	12/2021	Coastal	136764	105992	14771
1/2022	12/2022	Coastal	136764	105992	14771
1/2023	12/2023	Coastal	136764	105992	14771
1/2024	12/2024	Coastal	136764	105992	14771
1/2025	12/2025	Coastal	136764	105992	14771
1/2026	12/2026	Coastal	136764	105992	14771

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.

2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NOx RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NOx emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year Begin (month/year)	Year End (month/year)	Zone	NOx RTC Initially Allocated	NOx RTC Holding as of 08/03/2012 (pounds) [1]	Non-Tradable Non-Usable RTCs (pounds) [2]
1/2027	12/2027	Coastal	136764	105992	14771

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.

2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. If the facility submits a permit application to increase in an annual allocation to a level greater than the facility's starting Allocation plus Non-Tradable credits as listed below, the application will be evaluated for compliance with Rule 2005 (c)(4). Rule 2005 (e) - Trading Zone Restrictions applies if an annual allocation is increased to a level greater than the facility's Starting Allocation plus Non-Tradable Credits:

Year Begin (month/year)	Year End (month/year)	Zone	NOx RTC Starting Allocation (pounds)	Non-Tradable Credits(NTC) (pounds)
1/1994	12/1994	Coastal	189356	0

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION C: FACILITY PLOT PLAN

(TO BE DEVELOPED)

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
System 1: EMERGENCY					
INTERNAL COMBUSTION ENGINE, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, GENERAC, MODEL 133DN, WITH TURBOCHARGER, 210 HP A/N: 478422	D1		NOX: PROCESS UNIT**	**HAP**: (10) [**40CFR 63 Subpart ZZZZ, 1-18-2008**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.11, D12.1, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, GENERAC, MODEL 64DT, WITH TURBOCHARGER, 137 HP A/N: 478423	D2		NOX: PROCESS UNIT**	**HAP**: (10) [**40CFR 63 Subpart ZZZZ, 1-18-2008**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.11, D12.1, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, GENERAC, MODEL 133DT, WITH TURBOCHARGER, 290 HP A/N: 478424	D4		NOX: PROCESS UNIT**	**HAP**: (10) [**40CFR 63 Subpart ZZZZ, 1-18-2008**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.11, D12.1, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, GENERAC, MODEL 64DT, WITH TURBOCHARGER, 137 HP A/N: 478425	D7		NOX: PROCESS UNIT**	**HAP**: (10) [**40CFR 63 Subpart ZZZZ, 1-18-2008**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.11, C177.1, D12.1, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, GENERAC, MODEL 64DTA, WITH AFTERCOOLER, TURBOCHARGER, 163 HP A/N: 478426	D8		NOX: PROCESS UNIT**	**HAP**: (10) [**40CFR 63 Subpart ZZZZ, 1-18-2008**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.11, C177.1, D12.1, E116.1, H23.6, H23.11, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 133DTA, WITH AFTERCOOLER, TURBOCHARGER, 368 HP A/N: 195818	D10		NOX: PROCESS UNIT**	**NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.2, C1.27, C177.1, D12.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, GENERAC, MODEL 6.4DTA, WITH AFTERCOOLER, TURBOCHARGER, 160 HP A/N: 478430	D12		NOX: PROCESS UNIT**	**HAP**: (10) [**40CFR 63 Subpart ZZZZ, 1-18-2008**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.11, D12.1, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CATERPILLAR, MODEL 3208TA, WITH AFTERCOOLER, TURBOCHARGER, 299 HP A/N: 478431	D15		NOX: PROCESS UNIT**	**HAP**: (10) [**40CFR 63 Subpart ZZZZ, 1-18-2008**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.20, C177.1, D12.1, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, DETROIT DIESEL, MODEL 40-8.7LT, WITH TURBOCHARGER, 205 BHP A/N: 478432	D95		NOX: PROCESS UNIT**	**HAP**: (10) [**40CFR 63 Subpart ZZZZ, 1-18-2008**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.11, C177.1, D12.1, E116.1, H23.6, H23.11, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CATERPILLAR, MODEL 3508 DITA, WITH AFTERCOOLER, TURBOCHARGER, 1337 BHP A/N: 303611	D98		NOX: PROCESS UNIT**	**HAP**: (10) [**40CFR 63 Subpart ZZZZ, 1-18-2008**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.3, C1.20, C177.1, D12.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, DIESEL FUEL, JOHN DEERE, MODEL 6059T, WITH A TURBOCHARGER, 166 BHP A/N: 478433	D99		NOX: PROCESS UNIT**	**HAP**: (10) [**40CFR 63 Subpart ZZZZ, 1-18-2008**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.20, C177.1, D12.1, E116.1, H23.6, H23.11, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, NATURAL GAS, GENERAC 7.4GN, MODEL CG070, 8 CYLINDERS, WITH CATALYTIC REDUCTION, 116 HP WITH A/N: 334912	D101		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **NOX**: 37.9 LBS/MMSCF NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a) (1)-BACT, 12-6-2002*]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN7S, WITH AN AIR TO FUEL RATIO CONTROLLER	C310				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP WITH A/N: 344925	D115		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-13S, WITH AN AIR TO FUEL RATIO CONTROLLER	C311				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP WITH A/N: 344926	D116		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-13S, WITH AN AIR TO FUEL RATIO CONTROLLER	C312				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP WITH A/N: 344927	D117		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-13S, WITH AN AIR TO FUEL RATIO CONTROLLER	C313				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP WITH A/N: 344928	D118		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-13S, WITH AN AIR TO FUEL RATIO CONTROLLER	C314				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP WITH A/N: 344929	D119		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-13S, WITH AN AIR TO FUEL RATIO CONTROLLER	C315				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3306SITA, NATURAL GAS, RICH BURN, WITH TURBOCHARGER AND AFTERCOOLER, WITH CATALYTIC REDUCTION, 194 BHP WITH A/N: 344913	D120		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-9S, WITH AN AIR TO FUEL RATIO CONTROLLER	C316				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3304SINA, NATURAL GAS, WITH CATALYTIC REDUCTION, 95 BHP WITH A/N: 344914	D121		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-7S, WITH AN AIR TO FUEL RATIO CONTROLLER	C317				
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3516SITA, NATURAL GAS, LEAN BURN, WITH TURBOCHARGER AND AFTERCOOLER, 1482 BHP A/N: 344899	D122		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP WITH A/N: 344933	D123		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-12S, WITH AN AIR TO FUEL RATIO CONTROLLER	C318				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMEREGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP WITH A/N: 344934	D124		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-12S, WITH AN AIR TO FUEL RATIO CONTROLLER	C319				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP WITH A/N: 344935	D125		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-12S, WITH AN AIR TO FUEL RATIO CONTROLLER	C320				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP WITH A/N: 344936	D126		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-12S, WITH AN AIR TO FUEL RATIO CONTROLLER	C321				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP WITH A/N: 344937	D127		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-12S, WITH AN AIR TO FUEL RATIO CONTROLLER	C322				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP WITH A/N: 344938	D128		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-12S, WITH AN AIR TO FUEL RATIO CONTROLLER	C323				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP WITH A/N: 344939	D129		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MN-12S, WITH AN AIR TO FUEL RATIO CONTROLLER	C324				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DRIVING AN EMERGENCY FIRE PUMP, GASOLINE, FORD, MODEL LSG-875R-6003-C, WITH CATALYTIC REDUCTION, 193 HP WITH A/N: 359091	D131		NOX: PROCESS UNIT**	**CO**: 0.6 GRAM/BHP-HR GASOLINE (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]; **NOX**: 0.15 GRAM/BHP-HR GASOLINE (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 0.15 GRAM/BHP-HR GASOLINE (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]	C1.1, D12.1, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, CARSOUND, MODEL NO. 298035, WITH AN AIR TO FUEL RATIO CONTROLLER, MODEL NO. KAT2000	C326				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 7.5 DTA, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 184 BHP WITH A/N: 362182	D133		NOX: PROCESS UNIT**	**CO**: 8.5 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]; **NOX**: 6.9 GRAM/BHP-HR DIESEL (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 264 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM10**: 0.38 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **ROG**: 1 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]	C1.1, C1.20, D12.1, E202.2, H23.6, K67.16
CO OXIDATION CATALYST, ENGELHARD, MODEL NO. PTX5801	C327				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, CUMMINS, MODEL 800 GTA 500 G3, NATURAL GAS, 16 CYLINDERS, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 1334 BHP WITH A/N: 360419	D134		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, D12.1, E202.3, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. QUI-EX, WITH AN AIR TO FUEL RATIO CONTROLLER, ALTRONIC, MODEL NO. 691302	C325				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CATERPILLAR, MODEL 3303 ATACC, WITH AFTERCOOLER, TURBOCHARGER, 377 BHP A/N: 378803	D149		NOX: PROCESS UNIT**	**CO**: 8.5 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **NOX**: 6.9 GRAM/BHP-HR DIESEL (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 302 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM10**: 0.38 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **ROG**: 1 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]	C1.1, C1.11, D12.1, E71.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, PARADISE PIER HOTEL, DRIVING AN EMERGENCY FIRE PUMP, DIESEL FUEL, CUMMINS, MODEL N-855-F, 6 CYLINDERS, FOUR CYCLE, NATURALLY ASPIRATED, SERIAL NO. 1815303, 240 HP A/N: 311603	D152		NOX: PROCESS UNIT**	**NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.22, D12.1, H23.6, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, PARADISE PIER HOTEL, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CATERPILLAR, MODEL 3508DI, 8 CYLINDERS, INTERCOOLED, SERIAL NO. 28Z00641, WITH TURBOCHARGER, 712 HP A/N: 478427	D153		NOX: PROCESS UNIT**	**NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.20, C177.1, D12.1, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CUMMINS, MODEL 4BT3.9-G4, 4 CYLINDERS, SERIAL NO. 45901859, WITH TURBOCHARGER, 102 HP A/N: 363159	D159		NOX: PROCESS UNIT**	**CO**: 8.5 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]; **NOX**: 6.9 GRAM/BHP-HR DIESEL (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM10**: 0.38 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **ROG**: 1 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]	C1.8, C1.20, D12.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CUMMINS, MODEL 6CT8.3G, 6 CYLINDERS, FOUR CYCLE, WITH TURBOCHARGER, 207 HP A/N: 478428	D160		NOX: PROCESS UNIT**	**NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.11, D12.1, E116.1, H23.6, H23.11, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CUMMINS, MODEL 6CT8.3G, 6 CYLINDERS, FOUR CYCLE, WITH TURBOCHARGER, 207 HP A/N: 241137	D162		NOX: PROCESS UNIT**	**NOX**: 2.9 LBS/HR DIESEL (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 0.11 LBS/HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]	C1.1, C1.20, D12.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CUMMINS, MODEL 6CT8.3G, 6 CYLINDERS, FOUR CYCLE, WITH TURBOCHARGER, 207 HP A/N: 241138	D163		NOX: PROCESS UNIT**	**NOX**: 2.9 LBS/HR DIESEL (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 0.11 LBS/HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]	C1.1, C1.20, D12.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DISNEYLAND HOTEL, DIESEL FUEL, CLARKE GM DIESEL INC, MODEL MD-4-1226, 4 CYLINDERS, SERIAL NO. 47463, 73 HP A/N: 241139	D164		NOX: PROCESS UNIT**	**NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.8, C1.22, D12.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, ALLIS-CHALMERS, MODEL 649, 6 CYLINDERS, FOUR CYCLE, SERIAL NO. K820640605, 73 HP A/N: 478429	D168		NOX: PROCESS UNIT**	**NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]	C1.1, C1.20, D12.1, E116.1, H23.6, H23.11, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, JOHN DEERE, MODEL 6081A, WITH AFTERCOOLER, TURBOCHARGER, 250 BHP A/N: 397419	D169		NOX: PROCESS UNIT**	**CO**: 8.5 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]; **NOX**: 6.9 GRAM/BHP-HR DIESEL (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 304 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM10**: 0.38 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **ROG**: 1 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]	C1.1, C1.11, D12.1, E71.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DRIVING AN EMERGENCY FIRE PUMP, DIESEL FUEL, CUMMINS, MODEL 6BTA5.9F1, PARADISE PIER HOTEL, WITH AFTERCOOLER, TURBOCHARGER, 182 BHP A/N: 408907	D172		NOX: PROCESS UNIT**	**CO**: 8.5 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]; **NOX**: 6.9 GRAM/BHP-HR DIESEL (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM10**: 0.38 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **ROG**: 1 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]	B61.1, C1.1, C1.22, D12.1, H23.6, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, CATERPILLAR, MODEL G3412STIA/450KW, SERIAL NO. 7DM, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 622 BHP WITH A/N: 412302	D173		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, C1.11, D12.1, E71.1, E202.3, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, JOHNSON MATTHEY, MODEL NO. QXC-30-08, WITH AN AIR TO FUEL RATIO CONTROLLER	C328				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, CUMMINS, MODEL GTA14 GS/GC 280 KW, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 431 BHP WITH A/N: 419597	D174		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a) (1)-BACT, 12-6-2002*]	C1.1, C1.11, D12.1, E202.3, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MIRATECH, MODEL NO. MCS-22Y1515-08-C2, WITH AN AIR TO FUEL RATIO CONTROLLER	C329				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, PERKINS, MODEL 1004-40T, WITH TURBOCHARGER, 95.2 BHP A/N: 425385	D175		NOX: PROCESS UNIT**	**CO**: 3.7 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **NOX**: 469 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX + ROG**: 5.6 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002;* **RULE 2005, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.3 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]	C1.1, C1.11, D12.1, H23.6, K67.14, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, CATERPILLAR, MODEL G3406SITA (250 KW), WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 367 BHP WITH A/N: 431660	D176		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, C1.28, D12.1, E71.5, E202.3, K67.14, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, JOHNSON MATTHEY, MODEL NO. QXC20, WITH AN AIR TO FUEL RATIO CONTROLLER, WOODWARD, MODEL NO. GECO	C330				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, FORD, MODEL WSG-1068, WITH CATALYTIC REDUCTION, TURBOCHARGER, 176 BHP WITH A/N: 436095	D178		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2192.45 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.1, C1.28, D12.1, E202.3, K67.14, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MINE-X, MODEL NO. DC47, WITH AN AIR TO FUEL RATIO CONTROLLER	C331				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CATERPILLAR, MODEL G3456 DITA AA, WITH AFTERCOOLER, TURBOCHARGER, 685 BHP A/N: 445773	D179		NOX: PROCESS UNIT**	**CO**: 2.6 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **NOX**: 221 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX + ROG**: 4.8 GRAM/BHP-HR DIESEL (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470, 6-1-2007]; **PM10**: 0.15 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]	C1.1, C1.11, D12.1, E116.1, H23.6, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CATERPILLAR, MODEL G3456 DITA AA, WITH AFTERCOOLER, TURBOCHARGER, 685 BHP A/N: 445774	D180		NOX: PROCESS UNIT**	**CO**: 2.6 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **CO**: 2.6 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]; **NOX**: 221 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX + ROG**: 4.8 GRAM/BHP-HR DIESEL (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX + ROG**: 4.8 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470, 6-1-2007]; **PM**: 0.15 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]; **PM10**: 0.15 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]	C1.1, C1.11, D12.1, E116.1, H23.6, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CATERPILLAR, MODEL G3456 DITA AA, WITH AFTERCOOLER, TURBOCHARGER, 685 BHP A/N: 445775	D181		NOX: PROCESS UNIT**	**CO**: 2.6 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **CO**: 2.6 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]; **NOX**: 221 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX + ROG**: 4.8 GRAM/BHP-HR DIESEL (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX + ROG**: 4.8 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470, 6-1-2007]; **PM10**: 0.15 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]; **PM10**: 0.15 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]	C1.1, C1.11, D12.1, E116.1, H23.6, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, WITH NSCR, MODEL L102, WITH AIR FUEL RATIO CONTROLLER, FORD, MODEL ESG-642, WITH CATALYTIC REDUCTION, 67 BHP WITH A/N: 444735	D182		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a) (1)-BACT, 12-6-2002*]; **NOX**: 437 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a) (1)-BACT, 12-6-2002*]	C1.1, C1.28, D12.1, E71.5, K67.14, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, MODEL NO. L102, WITH AN AIR TO FUEL RATIO CONTROLLER	C332				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CATERPILLAR, MODEL 3306ATACC, WITH AFTERCOOLER, TURBOCHARGER, 377 BHP A/N: 445546	D183		NOX: PROCESS UNIT**	**CO**: 2.6 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **NOX**: 209 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX + ROG**: 4.8 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002;* **RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470, 6-1-2007]; **PM10**: 0.15 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]	C1.1, C1.11, D12.1, E116.1, H23.6, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, DIESEL FUEL, CATERPILLAR, MODEL C-9 DITA, LOCATED AT NEMO SITE, WITH AFTERCOOLER, TURBOCHARGER, 398 BHP A/N: 459428	D223		NOX: PROCESS UNIT**	**CO**: 2.6 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]; **CO**: 2.6 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **NOX**: 136 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX + ROG**: 3 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002;* **RULE 2005, 5-6-2005**]; **NOX + ROG**: 3 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470, 6-1-2007]; **PM10**: 0.15 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **PM10**: 0.15 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]	C1.1, C1.11, D12.1, E116.1, H23.6, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, CATERPILLAR, MODEL G3046 SITA, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 367 BHP WITH A/N: 478405	D259		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **CO**: 4 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]; **NOX**: 413 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **VOC**: 1 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]	C1.1, C1.28, D12.1, E71.5, E116.1, E202.3, K67.14, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, JOHNSON MATTHEY, MODEL NO. QXE10-8, WITH AN AIR TO FUEL RATIO CONTROLLER	C333				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, GENERAL MOTORS, MODEL VORTEC 8.1 L POWERTRAIN, WITH CATALYTIC REDUCTION, TURBOCHARGER, 195 BHP WITH A/N: 499582	D276		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **CO**: 4 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]; **NOX**: 390 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a) (1)-BACT, 12-6-2002*]; **VOC**: 1 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]	C1.1, C1.28, D12.1, E71.5, E202.3, K67.14, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, CLEANAIR, MODEL NO. CQD0950BCCN40, WITH AN AIR TO FUEL RATIO CONTROLLER	C334				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL C9 ATAAC, SIX CYLIINDERS, WITH AFTERCOOLER, TURBOCHARGER, 480 BHP A/N: 513584	D289		NOX: PROCESS UNIT**	**CO**: 2.6 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]; **CO**: 2.6 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **NOX**: 132 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX + ROG**: 3 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a) (1)-BACT, 12-6-2002;* **RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX + ROG**: 3 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM10**: 0.15 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002;* RULE 1470, 6-1-2007]; **PM10**: 0.15 GRAM/BHP-HR DIESEL (8) [**40CFR 60 Subpart IIII, 7-11-2006**]	C1.1, C1.11, D12.1, E116.1, H23.6, K67.16

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, LOCATED AT CARSLAND NORTH, NATURAL GAS,G248, RICH BURN, DOOSAN, MODEL D183TIC, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, WITH CATALYTIC REDUCTION, TURBOCHARGER, 530 BHP WITH A/N: 515138	D290		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **CO**: 4 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]; **NOX**: 575 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **VOC**: 1 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]	C1.1, C1.28, D12.1, E71.5, E175.3, E202.3, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, TWO NSCRS, WITH AN AIR TO FUEL RATIO CONTROLLER GENERATOR, 395 KW	C335				

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, LOCATED AT CARSLAND NORTH, NATURAL GAS, G244, RICH BURN, DOOSAN, MODEL D146L, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 402 BHP WITH A/N: 515140	D291		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **CO**: 4 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]; **NOX**: 477 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **VOC**: 1 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]	C1.1, C1.28, D12.1, E71.5, E175.3, E202.3, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, TWO NSCRS, WITH AN AIR TO FUEL RATIO CONTROLLER	C336				
GENERATOR, 300 KW					

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, LOCATED AT CARSLAND EAST, NATURAL GAS, G250, RICH BURN, DOOSAN, MODEL D146L, DRIVING AN EMERGENCY ELECTRICAL GENERATOR, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 402 BHP WITH A/N: 515141	D292		NOX: PROCESS UNIT**	**CO**: 2 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **CO**: 4 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]; **NOX**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 2 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]; **NOX**: 477 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: 1.5 GRAM/BHP-HR NATURAL GAS (4) [**RULE 1303(a)(1) -BACT, 5-10-1996;** *RULE 1303(a)(1)-BACT, 12-6-2002*]; **VOC**: 1 GRAM/BHP-HR NATURAL GAS (8) [**40CFR 60 Subpart JJJJ, 1-18-2008**]	C1.1, C1.28, D12.1, E71.5, E175.3, E202.3, K67.16
NON-SELECTIVE CATALYTIC REDUCTION, TWO NSCRS, WITH AN AIR TO FUEL RATIO CONTROLLER	C337				
GENERATOR, 300 KW					
System 2: NON - EMERGENCY					

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COMBUSTION, INDUSTRIAL					
INTERNAL COMBUSTION ENGINE, NON-EMERGENCY, DIESEL FUEL, JOHN DEERE, MODEL 4045TF275, ON-SITE PORTABLE DRIVING A WOOD CHIPPER, WITH TURBOCHARGER, 115 BHP A/N: 432411	D177		NOX: PROCESS UNIT**	**CO**: 3.7 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]; **NOX**: 188 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX + ROG**: 4.9 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996; RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.22 GRAM/BHP-HR DIESEL (4) [**RULE 1303(a)(1) -BACT, 5-10-1996**]	C1.12, D12.1, D323.2, K67.15
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, EAST UNIT # 2, NATURAL GAS, SUPERIOR, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 12.57 MMBTU/HR WITH A/N: 535760 BURNER, INDUSTRIAL COMBUSTION, MODEL 13-5-1500-W160-M-LNDG145, WITH LOW NOX BURNER	D16		NOX: LARGE SOURCE**	**CO**: 400 PPMV (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 30 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	D12.3, D12.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, WEST UNIT # 2, NATURAL GAS, SUPERIOR, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 9.95 MMBTU/HR WITH A/N: 535761 BURNER, INDUSTRIAL COMBUSTION, MODEL 13-5-1250-W160-M-LNDG105, WITH LOW NOX BURNER	D17		NOX: PROCESS UNIT**	**CO**: 400 PPMV (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 47.75 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	D12.4, H23.4
BOILER, EAST UNIT # 1, NATURAL GAS, SUPERIOR, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 12.57 MMBTU/HR WITH A/N: 535763 BURNER, INDUSTRIAL COMBUSTION, MODEL 13-5-1500-W160-M-LNDG145, WITH LOW NOX BURNER	D18		NOX: LARGE SOURCE**	**CO**: 400 PPMV (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 30 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	D12.3, D12.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, WEST UNIT # 1, NATURAL GAS, SUPERIOR, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 9.95 MMBTU/HR WITH A/N: 535764 BURNER, INDUSTRIAL COMBUSTION, MODEL 13-5-1250-W160-M-LNDG105, WITH LOW NOX BURNER	D19		NOX: PROCESS UNIT**	**CO**: 400 PPMV (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 47.75 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	D12.4, H23.4
BOILER, B1, NATURAL GAS, CLEAVER BROOKS, MODEL FLX, WITH LOW NOX BURNER, 8.5 MMBTU/HR WITH A/N: 360389 BURNER, NATURAL GAS, ALZETA, MODEL CSB84	D135		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	D12.4, E202.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, B2, NATURAL GAS, CLEAVER BROOKS, MODEL FLX, WITH LOW NOX BURNER, 8.5 MMBTU/HR WITH A/N: 360386 BURNER, NATURAL GAS, ALZETA, MODEL CSB84	D137		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5A) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV NATURAL GAS (5) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF NATURAL GAS (5) [**RULE 409, 8-7-1981**]	D12.4, E202.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, B3, NATURAL GAS, CLEAVER BROOKS, MODEL FLX, WITH LOW NOX BURNER, 8.5 MMBTU/HR WITH A/N: 360387 BURNER, NATURAL GAS, ALZETA, MODEL CSB84	D138		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5A) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV NATURAL GAS (5) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF NATURAL GAS (5) [**RULE 409, 8-7-1981**]	D12.4, E202.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, B4, NATURAL GAS, CLEAVER BROOKS, MODEL FLX, WITH LOW NOX BURNER, 8.5 MMBTU/HR WITH A/N: 360388 BURNER, NATURAL GAS, ALZETA, MODEL CSB84	D139		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5A) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV NATURAL GAS (5) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF NATURAL GAS (5) [**RULE 409, 8-7-1981**]	D12.4, E202.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PARADISE PIER HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 1, 5 MMBTU/HR WITH A/N: 459430 BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D206		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	D12.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PARADISE PIER HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 2, 5 MMBTU/HR WITH A/N: 459431 BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D207		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	D12.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PARADISE PIER HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 3, 5 MMBTU/HR WITH A/N: 459432 BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D209		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	D12.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PARADISE PIER HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 4, 5 MMBTU/HR WITH A/N: 459433 BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D211		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	D12.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 1, 5 MMBTU/HR WITH A/N: 473755 BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D214		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	C1.13, D12.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 2, 5 MMBTU/HR WITH A/N: 473757 BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D215		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	C1.13, D12.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 3, 5 MMBTU/HR WITH A/N: 473758 BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D217		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	C1.13, D12.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 4, 5 MMBTU/HR WITH A/N: 473761 BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D219		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	C1.13, D12.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 5, 5 MMBTU/HR WITH A/N: 473762 BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D221		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV NATURAL GAS (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 12 PPMV NATURAL GAS (3) [**RULE 2012, 5-6-2005**]; **NOX**: 12 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	C1.13, D12.4, H23.4
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, STEAM X, MODEL DELCO, S/N VH0103, 0.28 MMBTU/HR A/N: 471807	D225		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, STEAM X, MODEL VANGUARD, S/N 10062708, 0.28 MMBTU/HR A/N: 471808	D226		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, D12.8, K67.24

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, A&M EQUIPMENT SERVICE, MODEL AMHGD-2003, NO. 2,, S/N 15016495, 0.21 MMBTU/HR A/N: 471810	D228		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 1, S/N 239325, 0.3 MMBTU/HR A/N: 471811	D229		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 2, S/N 239326, 0.3 MMBTU/HR A/N: 471812	D230		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 1, S/N 228121, 0.3 MMBTU/HR A/N: 471813	D231		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 2, S/N 234517, 0.3 MMBTU/HR A/N: 471814	D232		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 3, S/N 206382, 0.3 MMBTU/HR A/N: 471816	D233		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 4, S/N 266334, 0.3 MMBTU/HR A/N: 471817	D234		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 5, S/N 205669, 0.3 MMBTU/HR A/N: 471818	D235		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 6, S/N 206383, 0.3 MMBTU/HR A/N: 471820	D236		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 7, S/N 206385, 0.3 MMBTU/HR A/N: 471821	D237		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 8, S/N 227965, 0.3 MMBTU/HR A/N: 471822	D238		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 9, S/N 228794, 0.3 MMBTU/HR A/N: 471823	D239		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 10 S/N 243798, 0.3 MMBTU/HR A/N: 471824	D240		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 281, NO. 4, S/N 20925, 0.56 MMBTU/HR A/N: INACTIVE	D244		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.17, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 247, NO. 4, S/N 20928, 0.56 MMBTU/HR A/N: 471840	D253		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 11, S/N 245187, 0.3 MMBTU/HR A/N: 478418	D255		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.18, D12.8, K67.24

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 12, S/N 247032, 0.3 MMBTU/HR A/N: 478419	D256		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.18, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 13, S/N 244141, 0.3 MMBTU/HR A/N: 478420	D257		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.18, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO.14, S/N 244142, 0.3 MMBTU/HR A/N: 478421	D258		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.18, D12.8, K67.24

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
HEATER, CPI, NO. 1, NATURAL GAS, FULTON, MODEL FT0400-C, WITH LOW NOX BURNER, 5.128 MMBTU/HR A/N: 478416	D260		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 20 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 24.57 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	C1.19, C1.21, D12.4, E202.4, H23.4
HEATER, CPI, NO. 2, NATURAL GAS, FULTON, MODEL FT0400-C, WITH LOW NOX BURNER, 5.128 MMBTU/HR A/N: 478417	D261		NOX: PROCESS UNIT**	**CO**: 50 PPMV NATURAL GAS (4) [**RULE 1303(a)(1)-BACT, 5-10-1996;** *RULE 1303(a)(1) -BACT, 12-6-2002*]; **CO**: 400 PPMV (5) [**RULE 1146, 11-17-2000;** *RULE 1146, 9-5-2008*]; **CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 20 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 24.57 LBS/MMSCF NATURAL GAS (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	C1.19, C1.21, D12.4, E202.4, H23.4

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 3, S/N 250379, 0.3 MMBTU/HR A/N: 487371	D262		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 4, S/N 250376, 0.3 MMBTU/HR A/N: 487373	D263		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 5, S/N 250375, 0.3 MMBTU/HR A/N: 487374	D264		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 6, S/N 250377, 0.3 MMBTU/HR A/N: 487375	D265		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.14, C1.16, D12.8, K67.24

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO.1, 0.16 MMBTU/HR A/N: 498054	D266		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF DIESEL (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO. 2, 0.16 MMBTU/HR A/N: 498055	D267		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO.3, 0.16 MMBTU/HR A/N: 498056	D268		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO. 4, 0.16 MMBTU/HR A/N: 498057	D269		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.23, D12.8, K67.22

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE51, NO. 1, 0.175 MMBTU/HR A/N: 498058	D270		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE51, NO. 2, 0.175 MMBTU/HR A/N: 498059	D271		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE52, NO. 1, 0.219 MMBTU/HR A/N: 498060	D272		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE52, NO. 2, 0.219 MMBTU/HR A/N: 498061	D273		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.23, D12.8, K67.22

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE52, NO. 2, 0.219 MMBTU/HR A/N: 498062	D274		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 409, 8-7-1981**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.23, D12.8, K67.22
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL HOT2-1100, NO. 1, S/N 250378, 0.16 MMBTU/HR A/N: 499580	D275		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.24, D12.8, K67.22
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216X4, NO. 1, S/N 254070, 0.3 MMBTU/HR A/N: 504518	D284		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216X4, NO. 2, S/N 254071, 0.3 MMBTU/HR A/N: 504519	D285		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216X4, NO. 3, S/N 254072, 0.3 MMBTU/HR A/N: 504520	D286		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216X4, NO. 4, S/N 254073, 0.3 MMBTU/HR A/N: 504521	D287		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, AM CLEANING EQUIPMENT, MODEL AM-HGD-2403, S/N 15040755, 0.21 MMBTU/HR A/N: 504522	D288		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257084, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515325	D297		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257411, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515326	D298		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257086, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515327	D299		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257439, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515329	D300		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257440, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515330	D301		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257085, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515331	D302		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257126, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515332	D303		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257438, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515333	D304		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV DIESEL (5) [**RULE 407, 4-2-1982**]	B59.2, C1.16, C1.26, D12.8, K67.23
Process 3: ORGANIC SOLVENT SURFACE COATING					
SPRAY COATING OPERATION, BINKS, 10 FT. W X 7 FT. L X 20 FT. D., WITH A 5 HP FAN, WATER WASH TYPE, WITH SPRAY BOOTH A/N: 12162X	D20			**PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	D322.2, H23.2, K67.3
SPRAY COATING OPERATION, PRENCO, 14 FT. W X 12 FT 2 IN. L X 8 FT. H, MODEL NO. DF-L-1489-125M, FLOOR TYPE, WITH A 5 HP FAN, WITH 24 EXHAUST FILTERS, EACH 20" X 25" X 2", WITH SPRAY BOOTH A/N: 214087	D21			**PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	A63.1, B27.4, C6.1, D322.1, E175.1, H23.2, K67.2
SPRAY COATING OPERATION, PRENCO, 12 FT. W X 12 FT 2 IN. L X 8 FT. H, MODEL NO. DF-L-1489-125M, FLOOR TYPE, WITH 5 HP FAN, WITH 24 EXHUAST FILTERS, EACH 20" X 25" X 2", WITH SPRAY BOOTH A/N: 214086	D22			**PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	A63.1, B27.4, C6.1, D322.1, E175.1, H23.2, K67.2

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 3: ORGANIC SOLVENT SURFACE COATING					
SPRAY COATING OPERATION, DEVILBLISS, 14 FT. W X 12 FT. L X 28 FT. D, MODEL NO. DLFA-602, AUTOMOTIVE TYPE, WITH A 5 HP FAN, WITH 22 EXHAUST FILTERS, EACH 20" X 25" X 2", WITH SPRAY BOOTH A/N: 19482X	D24			**PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	C6.1, D322.1, E175.1, H23.2, K67.2
SPRAY COATING OPERATION, SPRAY BOOTH (PORTABLE INTRA-FACILITY), SHOP PRO, MODEL NO. 5410, FLOOR TYPE, WITH 2 EXHUAST FILTERS, EACH 20" X 20" X 1", AND A 1.5 HP BLOWER, WITH SPRAY BOOTH A/N: 519363	D305			**PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	A63.2, B59.3, C6.1, D322.1, E175.1, H23.2, K67.2
SPRAY COATING OPERATION, SPRAY SYSTEMS, MODEL NO. BB-96,, FLOOR TYPE, WITH 20 EXHUAST FILTERS, EACH 20" X 25", AND A 0.75 HP BLOWER, WITH SPRAY BOOTH A/N: 519365	D306			**PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	A63.2, B59.3, C6.1, D322.1, E175.1, H23.2, K67.2
SPRAY COATING OPERATION, SPRAY SYSTEMS, INC., MODEL NO. I-1487, FLOOR TYPE, WITH 24 EXHUAST FILTERS, EACH 20" X 25", AND A 2 HP BLOWER, WITH SPRAY BOOTH A/N: 519366	D307			**PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	A63.2, B59.3, C6.1, D322.1, E175.1, H23.2, K67.2

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 3: ORGANIC SOLVENT SURFACE COATING					
SPRAY COATING OPERATION, SOLVENT, DISNEYLAND HOTEL, AUTOMOTIVE TYPE, WITH 44 EXHAUST FILTERS, EACH 20" X 25" X 1.5", WITH SPRAY BOOTH A/N: 241140	D165			**PM**: (9) [**RULE 404, 2-7-1986**]; **ROG**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1145, 2-14-1997;** *RULE 1145, 12-4-2009;* **RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	B27.4, C1.9, C1.10, C6.1, D322.1, E175.2, H23.2, K67.2, K67.8
Process 4: PETROLEUM MARKETING, CONSUMER FLEET FUELING					
STORAGE TANK, UNDERGROUND, GASOLINE, METHANOL COMPATIBLE, WITH OPW (VR-102-E/J), 10000 GALS A/N: 500099	D277				C1.25, D330.1, E193.3, J373.3, K67.21
STORAGE TANK, UNDERGROUND, GASOLINE, METHANOL COMPATIBLE, WITH OPW (VR-102-E/J), 10000 GALS A/N: 500099	D278				C1.25, D330.1, E193.3, J373.3, K67.21
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR-201-J/N) DISPENSING 3 PRODUCTS A/N: 500099	D279				D330.1, E193.3, J373.3
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR-201-J/N) DISPENSING 3 PRODUCTS A/N: 500099	D280				D330.1, E193.3, J373.3

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 4: PETROLEUM MARKETING, CONSUMER FLEET FUELING					
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR-201-J/N) DISPENSING 3 PRODUCTS A/N: 500099	D281				D330.1, E193.3, J373.3
LOADING ARM, GASOLINE, TWO GASOLINE HOSES WITH DRY BREAK CONNECT COUPLER FOR BOTTOM LOADING A/N: 500099	D282				C1.25, E193.3, J373.3, K67.21
LOADING ARM, GASOLINE, TWO GASOLINE VAPOR RECOVERY HOSES WITH CAMLOCK QUICK CONNECT COUPLER A/N: 500099	D283				C1.25, E193.3, J373.3, K67.21
System 1: FUEL STORAGE AND DISPENSING SYSTEMS					
DISPENSE MOBILE FUELER, GASOLINE, FRANZEN-HILL (G-70-193), WITH TWO HEALY 100 JET PUMPS, 400 GALS; WIDTH: 3 FT 8 IN; HEIGHT: 3 FT 10 IN; LENGTH: 7 FT 1 IN A/N: 367066	D147				C1.6, C1.7, E71.2, J110.1, J397.1, K67.6
FUEL DISPENSING NOZZLE, GASOLINE, EQUIPPED WITH PHASE II VAPOR RECOVERY, HEALY, MODEL 400 ORVR A/N: 367066	D148				
Process 5: FABRICATED METALS					
System 1:					

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 5: FABRICATED METALS					
ABRASIVE BLASTING, OPEN, KELCO, MODEL NO. K114-A, PORTABLE, PLANT AIR AT 125 PSIG, SAND, WITH A POT, 150 POUNDS CAPACITY WITH A/N: 193050 ABRASIVE BLASTING NOZZLE, DIAMETER: .38 IN	D44			**PM**: (9) [**RULE 1140, 2-1-1980;** *RULE 1140, 8-2-1985;* **RULE 405, 2-7-1986**]	D323.1, K67.5
ABRASIVE BLASTING, ROOM, SAND, BAGHOUSE SERVICES, WITH 3000 LB POT, WIDTH: 15 FT 8 IN; HEIGHT: 15 FT 11 IN; LENGTH: 28 FT WITH A/N: 385807 ABRASIVE BLASTING NOZZLE, 2, MAXIMUM WORKING PRESSURE OF 120 PSI, DIAMETER: .63 IN	D156	C158		**PM**: (9) [**RULE 1140, 2-1-1980;** *RULE 1140, 8-2-1985;* **RULE 405, 2-7-1986**]	B27.2, D323.3, K67.11
BAGHOUSE, UNITED AIR SPECIALIST, MODEL SBD24-3, PULSE JET CLEANING, SERIAL NO. 60042645, 7440 SQ.FT.; 24 CARTRIDGE A/N: 385808	C158	D156		**PM**: (9) [**RULE 404, 2-7-1986**]	A63.3, C6.2, D322.3, D381.1, E102.1, H23.12, K67.10

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 5: FABRICATED METALS					
ABRASIVE BLASTING, CARBON DIOXIDE (DRY ICE), COLDJET, MODEL 2000, WITH 40 POUND CAPACITY HOPPER WITH A/N: 404957 ABRASIVE BLASTING NOZZLE, 1, WITH A MAX. THROAT AREA OF 0.068 IN2, 140 PSIA	D170			**PM**: (9) [**RULE 1140, 2-1-1980;** *RULE 1140, 8-2-1985;* **RULE 405, 2-7-1986**]	B59.1, D381.1, H23.5, K67.11
Process 7: FABRICATED METALS, MACHINING OPERATIONS					
System 1:					
PLASMA ARC CUTTER, DUAL CARRIAGE TYPE, WITH A FOUR TORCH CAPACITY, LINDE, MODEL NO. CM-50 A/N: 243063	D48	C49		**PM**: (9) [**RULE 405, 2-7-1986**]	D323.1
ELECTROSTATIC PRECIPITATOR, 3 FT. 4 IN. W X 4 FT. 4 IN. L X 3 FT. 7 IN. H., TEPCO TRION, MODEL T5200, DOUBLE PASS ELECTRONIC CLEANER TYPE, WITH A 3 H.P. BLOWER A/N: 249015	C49	D48		**PM**: (9) [**RULE 404, 2-7-1986**]	A63.3, D381.2, E202.1, H23.12, K67.10
Process 8: SMOKE EFFECTS					
System 1:					
FILTER, HEPA, FIVE FILTERS, EACH 2 FT. 0 IN. W X 12 IN. DIA. X 3 FT. 0 IN. H., FARR, EXHAUST SYTEM WITH TWO 15 HP, ONE 7.5 HP, ONE 5 HP, AND 0.75 HP BLOWERS A/N: 288923	C96			**PM**: (9) [**RULE 404, 2-7-1986**]	A63.3, D322.1, D323.1, K67.2
Process 9: R-219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECFIC RULES					

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 9: R-219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECFIC RULES					
RULE 219 EXEMPT EQUIPMENT, AIR CONDITIONING UNITS, COMFORT A/C	E102				H23.3
RULE 219 EXEMPT EQUIPMENT, REFRIGERANT RECOVERY AND/OR RECYCLING UNITS,	E103				H23.14
RULE 219 EXEMPT EQUIPMENT, PRINTING EQUIPMENT, WITH RELATED COATING, LAMINATING AND DRYING EQUIPMENT	E104			**VOC**: (9) [**RULE 1130, 10-8-1999; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	H23.13
RULE 219 EXEMPT EQUIPMENT, CLEANING EQUIPMENT, SMALL, UNHEATED, NON-CONVEYORIZED	E105			**ROG**: (9) [**RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	H23.1
RULE 219 EXEMPT EQUIPMENT, REFRIGERATION UNITS	E106				H23.15
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS	E107			**ROG**: (9) [**RULE 1113, 11-8-1996;** *RULE 1113, 6-3-2011;* **RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	K67.1
RULE 219 EXEMPT EQUIPMENT, HAND LAY, BRUSH AND ROLL UP RESIN OPERATIONS	E108			**ROG**: (9) [**RULE 1162, 11-17-2000;** *RULE 1162, 7-8-2005;* **RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	H23.13
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, LOW USE OR EMISSIONS	E111			**ROG**: (9) [**RULE 1106.1, 2-12-1999; RULE 1151, 12-11-1998;** *RULE 1151, 12-2-2005;* **RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	H23.13
RULE 219 EXEMPT EQUIPMENT, LAMINATING EQUIPMENT, LOW USE OR EMISSIONS	E112			**ROG**: (9) [RULE 1168, 1-7-2005; **RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	H23.13

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 9: R-219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECFIC RULES					
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, LOW USE OR EMISSIONS	E113			**ROG**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1145, 2-14-1997;** *RULE 1145, 12-4-2009;* **RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	H23.13
RULE 219 EXEMPT EQUIPMENT, ABRASIVE BLASTING EQUIPMENT, GLOVE-BOX, <= 53 FT3, WITH DUST FILTER	E338			**PM**: (9) [**RULE 1140, 2-1-1980;** *RULE 1140, 8-2-1985;* **RULE 404, 2-7-1986; RULE 405, 2-7-1986**]	D322.3, D381.2, E102.1, K67.10

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: DEVICE ID INDEX

The following sub-section provides an index to the devices that make up the facility description sorted by device ID.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	**Section D Page No.**	**Process**	**System**
D1	1	1	1
D2	1	1	1
D4	1	1	1
D7	1	1	1
D8	1	1	1
D10	2	1	1
D12	2	1	1
D15	2	1	1
D16	43	2	0
D17	44	2	0
D18	44	2	0
D19	45	2	0
D20	71	3	0
D21	71	3	0
D22	71	3	0
D24	72	3	0
D44	75	5	1
D48	76	7	1
C49	76	7	1
D95	2	1	1
C96	76	8	1
D98	3	1	1
D99	3	1	1
D101	4	1	1
E102	77	9	0
E103	77	9	0
E104	77	9	0
E105	77	9	0
E106	77	9	0
E107	77	9	0
E108	77	9	0
E111	77	9	0
E112	77	9	0
E113	78	9	0
D115	5	1	1

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	**Section D Page No.**	**Process**	**System**
D116	6	1	1
D117	7	1	1
D118	8	1	1
D119	9	1	1
D120	10	1	1
D121	11	1	1
D122	11	1	1
D123	12	1	1
D124	13	1	1
D125	14	1	1
D126	15	1	1
D127	16	1	1
D128	17	1	1
D129	18	1	1
D131	19	1	1
D133	20	1	1
D134	21	1	1
D135	45	2	0
D137	46	2	0
D138	47	2	0
D139	48	2	0
D147	74	4	1
D148	74	4	1
D149	22	1	1
D152	22	1	1
D153	23	1	1
D156	75	5	1
C158	75	5	1
D159	23	1	1
D160	23	1	1
D162	24	1	1
D163	24	1	1
D164	24	1	1
D165	73	3	0
D168	24	1	1

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	**Section D Page No.**	**Process**	**System**
D169	25	1	1
D170	76	5	1
D172	25	1	1
D173	26	1	1
D174	27	1	1
D175	28	1	1
D176	29	1	1
D177	43	1	2
D178	30	1	1
D179	31	1	1
D180	32	1	1
D181	33	1	1
D182	34	1	1
D183	35	1	1
D206	49	2	0
D207	50	2	0
D209	51	2	0
D211	52	2	0
D214	53	2	0
D215	54	2	0
D217	55	2	0
D219	56	2	0
D221	57	2	0
D223	36	1	1
D225	57	2	0
D226	57	2	0
D228	58	2	0
D229	58	2	0
D230	58	2	0
D231	58	2	0
D232	59	2	0
D233	59	2	0
D234	59	2	0
D235	59	2	0
D236	60	2	0

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	**Section D Page No.**	**Process**	**System**
D237	60	2	0
D238	60	2	0
D239	60	2	0
D240	61	2	0
D244	61	2	0
D253	61	2	0
D255	61	2	0
D256	62	2	0
D257	62	2	0
D258	62	2	0
D259	37	1	1
D260	63	2	0
D261	63	2	0
D262	64	2	0
D263	64	2	0
D264	64	2	0
D265	64	2	0
D266	65	2	0
D267	65	2	0
D268	65	2	0
D269	65	2	0
D270	66	2	0
D271	66	2	0
D272	66	2	0
D273	66	2	0
D274	67	2	0
D275	67	2	0
D276	38	1	1
D277	73	4	0
D278	73	4	0
D279	73	4	0
D280	73	4	0
D281	74	4	0
D282	74	4	0
D283	74	4	0

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	**Section D Page No.**	**Process**	**System**
D284	67	2	0
D285	67	2	0
D286	68	2	0
D287	68	2	0
D288	68	2	0
D289	39	1	1
D290	40	1	1
D291	41	1	1
D292	42	1	1
D297	68	2	0
D298	69	2	0
D299	69	2	0
D300	69	2	0
D301	70	2	0
D302	70	2	0
D303	70	2	0
D304	71	2	0
D305	72	3	0
D306	72	3	0
D307	72	3	0
C310	4	1	1
C311	5	1	1
C312	6	1	1
C313	7	1	1
C314	8	1	1
C315	9	1	1
C316	10	1	1
C317	11	1	1
C318	12	1	1
C319	13	1	1
C320	14	1	1
C321	15	1	1
C322	16	1	1
C323	17	1	1
C324	18	1	1

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	**Section D Page No.**	**Process**	**System**
C325	21	1	1
C326	19	1	1
C327	20	1	1
C328	26	1	1
C329	27	1	1
C330	29	1	1
C331	30	1	1
C332	34	1	1
C333	37	1	1
C334	38	1	1
C335	40	1	1
C336	41	1	1
C337	42	1	1
E338	78	9	0

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

F1.1 The operator shall limit the material processed to no more than 2000 lb(s) in any one year.

For the purpose of this condition, material processed shall be defined as 1,1,1 trichloroethane.

[H&S 44300, 7-1-1988]

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[**RULE 401, 3-2-1984;** RULE 401, 11-9-2001]

F14.2 The operator shall not purchase diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

[RULE 431.2, 9-15-2000]

F14.3 The operator shall not burn fuel oil containing sulfur compounds in excess of 0.05 percent by weight.

[**RULE 431.2, 5-4-1990;** RULE 431.2, 9-15-2000]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

F48.1 The operator shall not operate at this facility non chain driven, uncontrolled charbroiler exceeding the opacity limits specified in Rule 401.

[**RULE 401, 3-2-1984;** RULE 401, 11-9-2001]

DEVICE CONDITIONS

A. Emission Limits

A63.1 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
VOC	Less than or equal to 10 LBS IN ANY ONE DAY

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D21, D22]

A63.2 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
VOC	Less than or equal to 14 LBS IN ANY ONE MONTH

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

For the purposes of this condition, the limit(s) shall be based on the total combined emissions from equipment under device numbers D305, D306, and D307.

To ensure compliance with the monthly Volatile Organic Compound (VOC) emission limit(s) of this condition, the operator shall comply with the following recordkeeping requirements:

(1) The operator shall comply with Rule 109 (Recordkeeping for Volatile Organic Compound Emissions).

(2) Within 14 calendar days after the end of each month, the operator shall total and record VOC emissions for the month from all equipment and operations covered by the monthly emission limit(s). The record shall include any procedures used to account for control device efficiencies and/or waste disposal. It shall be signed and certified for accuracy by the highest ranking individual responsible for compliance with District rules.

(3) The operator shall maintain a single list which includes only the name and address of each person from whom the facility acquired VOC-containing material regulated by the District that was used or stored at the facility during the preceding 12 months.

(4) The operator shall retain all purchase invoices for all VOC-containing material used or stored at the facility, and all waste manifests for all waste VOC-containing material removed from the facility, for five years.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D305, D306, D307]

A63.3 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Visible emissions	Less than or equal to 0 Percent Opacity

[RULE 1155, 12-4-2009]

[Devices subject to this condition : C49, C96, C158]

B. Material/Fuel Type Limits

B27.2 The operator shall not use abrasive material (except for abrasive containing nickel) containing any carcinogenic compounds identified in the SCAQMD Rule 1401, as amended 18-aug-2000.

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D156]

B27.4 The operator shall not use materials containing any compounds identified in the SCAQMD Rule 1401, as amended 12/07/1990.

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D21, D22, D165]

B59.1 The operator shall only use the following material(s) in this device :

Dry Ice

[RULE 1140, 8-2-1985]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D170]

B59.2 The operator shall only use the following material(s) in this device :

diesel fuel or bio-diesel

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]

[Devices subject to this condition : D225, D226, D228, D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D244, D253, D255, D256, D257, D258, D262, D263, D264, D265, D266, D267, D268, D269, D270, D271, D272, D273, D274, D275, D284, D285, D286, D287, D288, D297, D298, D299, D300, D301, D302, D303, D304]

B59.3 The operator shall not use the following material(s) in this device :

Compounds identified in the SCAQMD Rule 1401, as amended 09/10/2010, except for Zinc and Zinc Compounds (CAS No. 7440-66-6)

[RULE 1401, 9-10-2010]

[Devices subject to this condition : D305, D306, D307]

B61.1 The operator shall only use fuel oil containing the following specified compounds:

Compound	ppm by weight
Sulfur less than or equal to	15

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D172]

C. Throughput or Operating Parameter Limits

C1.1 The operator shall limit the operating time to no more than 200 hour(s) in any one year.

[RULE 1110.2, 7-9-2010; **RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(b)(1) -Modeling, 5-10-1996; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D15, D95, D99, D101, D115, D116, D117, D118, D119, D120, D121, D122, D123, D124, D125, D126, D127, D128, D129, D131, D133, D134, D149, D152, D153, D160, D162, D163, D168, D169, D172, D173, D174, D175, D176, D178, D179, D180, D181, D182, D183, D223, D259, D276, D289, D290, D291, D292]

C1.2 The operator shall limit the operating time to no more than 125 hour(s) in any one year.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 10-20-2000; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996**]

[Devices subject to this condition : D10]

C1.3 The operator shall limit the operating time to no more than 100 hour(s) in any one year.

[**RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996**]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D98]

C1.6 The operator shall limit the gasoline dispensed to no more than 240000 gallon(s) per year.

[RULE 1401, 8-18-2000]

[Devices subject to this condition : D147]

C1.7 The operator shall limit the gasoline dispensed to no more than 20000 gallon(s) in any one calendar month.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D147]

C1.8 The operator shall limit the operating time to no more than 199 hour(s) in any one year.

[RULE 1110.2, 7-9-2010; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996**]

[Devices subject to this condition : D159, D164]

C1.9 The operator shall limit the coating and solvent usage to no more than 4 gallon(s) per day.

[**RULE 1303(b)(2)-Offset, 5-10-1996**]

[Devices subject to this condition : D165]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

C1.10 The operator shall limit the coating and solvent usage to no more than 88 gallon(s) per month.

[**RULE 1303(b)(2)-Offset, 5-10-1996**]

[Devices subject to this condition : D165]

C1.11 The operator shall limit the maintenance testing to no more than 50 hour(s) in any one year.

The operation of the engine beyond the 50 hours per year allotted for engine maintenance and testing shall be allowed only in the event of a loss of grid power or up to 30 minutes prior to a rotating outage, provided that the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time, and the engine is located in a utility service block that is subject to the rotating outage. Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1470, 6-1-2007]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D95, D149, D160, D169, D173, D174, D175, D179, D180, D181, D183, D223, D289]

C1.12 The operator shall limit the operating time to no more than 1092 in any one calendar year.

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D177]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

C1.13 The operator shall limit the natural gas fuel usage to no more than 15.569 MM cubic feet in any one calendar month.

The fuel usage limit of 15.569 mmcf/month is the total fuel to be used in the five boilers operating under Device Numbers D214, D215, D217, D219, and D221.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D214, D215, D217, D219, D221]

C1.14 The operator shall limit the operating time to no more than 300 hour(s) in any one month.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005; **RULE 2012, 5-6-2005**]

[Devices subject to this condition : D225, D226, D228, D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D244, D253, D262, D263, D264, D265]

C1.16 The operator shall limit the operating time to no more than 22 hour(s) in any one day.

To comply with this condition, the operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the pressure washer.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D255, D256, D257, D258, D262, D263, D264, D265, D284, D285, D286, D287, D288, D297, D298, D299, D300, D301, D302, D303, D304]

C1.17 The operator shall limit the operating time to no more than 12 hour(s) in any one day.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]

[Devices subject to this condition : D244]

C1.18 The operator shall limit the operating time to no more than 330 hour(s) in any one month.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]

[Devices subject to this condition : D255, D256, D257, D258]

C1.19 The operator shall limit the fuel usage to no more than 6.156 MM cubic feet in any one calendar month.

This limit shall be based on the total combined limit for equipment D260 and D261.

This equipment shall only use natural gas as a fuel.

The operator shall identify the primary and secondary heater fuel usage.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D260, D261]

C1.20 The operator shall limit the maintenance and testing to no more than 30 hour(s) in any one year.

The operation of engine beyond 30 hours per year allotted for engine maintenance and testing shall be allowed only in the event of a loss of grid power or up to 30 minutes prior to a rotating outage, provided that the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time, and the engine is located in a utility service block that is subject to the rotating outage.

[RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(1)-Modeling, 5-10-1996;** RULE 1470, 6-1-2007]

[Devices subject to this condition : D15, D98, D99, D133, D153, D159, D162, D163, D168]

C1.21 The operator shall limit the fuel usage to no more than 2.637 MM cubic feet in any one calendar month.

This equipment shall only use natural gas as a fuel.

The operator shall identify the primary and secondary heater.

This condition only applies to the secondary heater.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D260, D261]

C1.22 The operator shall limit the maintenance testing to no more than 34 hour(s) in any one year.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[RULE 1470, 6-1-2007]

[Devices subject to this condition : D152, D164, D172]

C1.23 The operator shall limit the operating time to no more than 200 hour(s) in any one calendar month.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D266, D267, D268, D269, D270, D271, D272, D273, D274]

C1.24 The operator shall limit the operating time to no more than 160 hour(s) in any one calendar month.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D275]

C1.25 The operator shall limit the gasoline dispensed to no more than 15000 gallon(s) in any one calendar month.

This condition only applies to bulk loading operations.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D277, D278, D282, D283]

C1.26 The operator shall limit the operating time to no more than 572 hour(s) in any one month.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005; **RULE 2012, 5-6-2005**]

[Devices subject to this condition : D284, D285, D286, D287, D288, D297, D298, D299, D300, D301, D302, D303, D304]

C1.27 The operator shall limit the maintenance and testing to no more than 20 hour(s) in any one year.

The operation of engine beyond 20 hours per year allotted for engine maintenance and testing shall be allowed only in the event of a loss of grid power or up to 30 minutes prior to a rotating outage, provided that the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time, and the engine is located in a utility service block that is subject to the rotating outage.

[RULE 1470, 6-1-2007]

[Devices subject to this condition : D10]

C1.28 The operator shall limit the maintenance and testing to no more than 50 hour(s) in any one year.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D176, D178, D182, D259, D276, D290, D291, D292]

C6.1 The operator shall use this equipment in such a manner that the differential pressure being monitored, as indicated below, does not exceed 0.25 inches water column.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

To comply with this condition, the operator shall install and maintain a(n) differential pressure gauge to accurately indicate the differential pressure across the filters.

The operator shall determine and record the parameter being monitored once every 7 days.

[**RULE 1303(a)(1)-BACT, 5-10-1996**]

[Devices subject to this condition : D21, D22, D24, D165, D305, D306, D307]

C6.2 The operator shall use this equipment in such a manner that the differential pressure being monitored, as indicated below, does not exceed 5 inches water column.

To comply with this condition, the operator shall install and maintain a(n) differential pressure gauge to accurately indicate the differential pressure across the filters.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C158]

C177.1 The operator shall set and maintain the fuel injection timing of the engine at 4 degrees retarded relative to standard timing.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D7, D8, D10, D15, D95, D98, D99, D153]

D. Monitoring/Testing Requirements

D12.1 The operator shall install and maintain a(n) timer to accurately indicate the elapsed operating time of the engine.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[RULE 1110.2, 7-9-2010; **RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1) -BACT, 12-6-2002; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 2005, 5-6-2005; RULE 2005, 6-3-2011; RULE 2012, 5-6-2005**]

[Devices subject to this condition : D1, D2, D4, D7, D8, D10, D12, D15, D95, D98, D99, D101, D115, D116, D117, D118, D119, D120, D121, D122, D123, D124, D125, D126, D127, D128, D129, D131, D133, D134, D149, D152, D153, D159, D160, D162, D163, D164, D168, D169, D172, D173, D174, D175, D176, D177, D178, D179, D180, D181, D182, D183, D223, D259, D276, D289, D290, D291, D292]

D12.3 The operator shall install and maintain a(n) flow meter to accurately indicate the flue gas flow in the flue gas recirculation system.

For the purpose of this condition a flue gas flow regulator that indicates the percent open setting in the FGR system may be used instead of a flow meter.

[**RULE 1303(a)(1)-BACT, 5-10-1996**]

[Devices subject to this condition : D16, D18]

D12.4 The operator shall install and maintain a(n) non-resettable totalizing fuel flow meter to accurately indicate the fuel usage of the equipment.

[**RULE 2012, 5-6-2005**]

[Devices subject to this condition : D16, D17, D18, D19, D135, D137, D138, D139, D206, D207, D209, D211, D214, D215, D217, D219, D221, D260, D261]

D12.8 The operator shall install and maintain a(n) timer to accurately indicate the elapsed operating time from the pressure washer.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005; **RULE 2012, 5-6-2005**]

[Devices subject to this condition : D225, D226, D228, D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D244, D253, D255, D256, D257, D258, D262, D263, D264, D265, D266, D267, D268, D269, D270, D271, D272, D273, D274, D275, D284, D285, D286, D287, D288, D297, D298, D299, D300, D301, D302, D303, D304]

D322.1 The operator shall perform a weekly inspection of the equipment and filter media for leaks, broken or torn filter media, and improperly installed filter media.

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D21, D22, D24, C96, D165, D305, D306, D307]

D322.2 The operator shall perform a weekly inspection to check for the water wash integrity.

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D20]

D322.3 The operator shall perform annual inspection of the equipment and filter media for leaks, broken or torn filter media, and improperly installed filter media.

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : C158, E338]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D323.1 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on a semi-annual basis, at least, unless the equipment did not operate during the entire semi-annual period. The routine semi-annual inspection shall be conducted while the equipment is in operation and during daylight hours.

If any visible emissions (not including condensed water vapor) are detected that last more than three minutes in any one hour, the operator shall verify and certify within 24 hours that the equipment causing the emission and any associated air pollution control equipment are operating normally according to their design and standard procedures and under the same conditions under which compliance was achieved in the past, and either:

1). Take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit; or

2). Have a CARB-certified smoke reader determine compliance with the opacity standard, using EPA Method 9 or the procedures in the CARB manual "Visible Emission Evaluation", within three business days and report any deviations to AQMD.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

1). Stack or emission point identification;

2). Description of any corrective actions taken to abate visible emissions;

3). Date and time visible emission was abated; and

4). All visible emission observation records by operator or a certified smoke reader.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D44, D48, C96]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D323.2 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on a monthly basis, at least, unless the equipment did not operate during the entire monthly period. The routine monthly inspection shall be conducted while the equipment is in operation and during daylight hours.

If any visible emissions (not including condensed water vapor) are detected that last more than three minutes in any one hour, the operator shall verify and certify within 24 hours that the equipment causing the emission and any associated air pollution control equipment are operating normally according to their design and standard procedures and under the same conditions under which compliance was achieved in the past, and either:

1). Take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit; or

2). Have a CARB-certified smoke reader determine compliance with the opacity standard, using EPA Method 9 or the procedures in the CARB manual "Visible Emission Evaluation", within three business days and report any deviations to AQMD.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

1). Stack or emission point identification;

2). Description of any corrective actions taken to abate visible emissions;

3). Date and time visible emission was abated; and

4). All visible emission observation records by operator or a certified smoke reader.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D177]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

D323.3 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on an annual basis, at least, unless the equipment did not operate during the entire annual period. The routine annual inspection shall be conducted while the equipment is in operation and during daylight hours.

If any visible emissions (not including condensed water vapor) are detected that last more than three minutes in any one hour, the operator shall verify and certify within 24 hours that the equipment causing the emission and any associated air pollution control equipment are operating normally according to their design and standard procedures and under the same conditions under which compliance was achieved in the past, and either:

1). Take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit; or

2). Have a CARB-certified smoke reader determine compliance with the opacity standard, using EPA Method 9 or the procedures in the CARB manual "Visible Emission Evaluation", within three business days and report any deviations to AQMD.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

1). Stack or emission point identification;

2). Description of any corrective actions taken to abate visible emissions;

3). Date and time visible emission was abated; and

4). All visible emission observation records by operator or a certified smoke reader.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D156]

D330.1 The operator shall have a person that has been trained in accordance with Rule 461conduct a semi-annual inspection of the gasoline transfer and dispensing equipment. The first inspection shall be in accordance with Rule 461, Attachment B, the second inspection shall be in accordance with Rule 461, Attachment C, and the subsequent inspections shall alternate protocols. The operator shall keep records of the inspection and the repairs in accordance to Rule 461 and Section K of this Permit.

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D277, D278, D279, D280, D281]

D381.1 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on a quarterly basis, at least, unless the equipment did not operate during the entire quarterly period. The routine quarterly inspection shall be conducted while the equipment is in operation and during daylight hours. If any visible emissions (not including condensed water vapor) are detected, the operator shall take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

1). Stack or emission point identification;

2). Description of any corrective actions taken to abate visible emissions; and

3). Date and time visible emission was abated.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : C158, D170]

D381.2 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on an annual basis, at least, unless the equipment did not operate during the entire annual period. The routine annual inspection shall be conducted while the equipment is in operation and during daylight hours. If any visible emissions (not including condensed water vapor) are detected, the operator shall take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

1). Stack or emission point identification;

2). Description of any corrective actions taken to abate visible emissions; and

3). Date and time visible emission was abated.

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : C49, E338]

E. Equipment Operation/Construction Requirements

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E71.1 The operator shall only operate this equipment during emergencies resulting in an interruption of service of the primary power supply or during stage II or III electrical emergency declared by the California Independent system operator (in addtion to maintenance and testing of this engine)..

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D149, D169, D173]

E71.2 The operator shall only operate this equipment using the manufacturers recommendation for the installation, operation and maintenance of the phase I and phase II vapor recovery equipment. The manufacturers manuals shall be readily accessible on site and made available to District representatives upon request.

[**RULE 461, 6-3-2005;** RULE 461, 3-7-2008]

[Devices subject to this condition : D147]

E71.5 The operator shall only operate this equipment during operation beyond 50 hours per year, this engine shall only operate during emergencies resulting in an interruption of service of the primary power supply or during stage II or III electrical emergency declared by the electrical grid operator. Operators may use this engine as part of interruptible electrical service program.

An interruptible electric service program is a program in which the facility receives payment or reduced rate in return for a requirement to reduce its electric load on the grid when requested to do so by the utility, the grid operator, or other organization.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D176, D182, D259, D276, D290, D291, D292]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

E102.1 The operator shall discharge dust collected in this equipment only into closed containers.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : C158, E338]

E116.1 This engine shall not be used as part of a demand response program using interruptible service contract in which a facility receives a payment or reduced rates in return for reducing its electric load on the grid when requested to do so by the utility or the grid operator.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470, 6-1-2007]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D15, D95, D99, D153, D160, D168, D179, D180, D181, D183, D223, D259, D289]

E175.1 The operator shall not use this equipment unless all exhaust air passes through the following:

filter media at least 2 inches thick

[**RULE 1303(a)(1)-BACT, 5-10-1996**]

[Devices subject to this condition : D21, D22, D24, D305, D306, D307]

E175.2 The operator shall not use this equipment unless all exhaust air passes through the following:

filter media at least 1.5 inches thick

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 1303(a)(1)-BACT, 5-10-1996**]

[Devices subject to this condition : D165]

E175.3 The operator shall not use this equipment unless all exhaust air passes through the following:

This engine shall not be operated unless its exhaust is vented to the non-selective catalytic reduction uniit which is in full operation and which is in good operating condition at all times.

[**RULE 1303(a)(1)-BACT, 5-10-1996; RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]

[Devices subject to this condition : D290, D291, D292]

E193.3 The operator shall operate and maintain this equipment as follows:

Operation of this equipment shall be in compliance with all data and specifications submitted with the application under which this permit was issued, unless otherwise noted below.

This equipment shall be properly maintained and kept in good operating condition at all times.

All phase I and phase II vapor recovery equipment at this facility shall be installed, operated and maintained to meet all California Air Resources Board certification requirements

Phase I vapor recovery systems shall be in full operation whenever fuel is being transferred into storage tanks

Phase II vapor recovery systems shall be in full operation whenever fuel is being transferred into motor vehicles, as defined in Rule 461

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 461, 6-3-2005;** RULE 461, 3-7-2008; **RULE 462, 5-14-1999**]

[Devices subject to this condition : D277, D278, D279, D280, D281, D282, D283]

E202.1 The operator shall clean and maintain this equipment according to the following specifications:

Thoroughly clean the ionizers and collector cells quarterly

[**RULE 1303(a)(1)-BACT, 5-10-1996; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : C49]

E202.2 The operator shall clean and maintain this equipment according to the following specifications:

the diesel catalyst shall be inspected once every calendar year and cleaned, if necessary. If cleaning is necessary, all loose soot deposits shall be removed and the catalyst shall be washed according to manfacturers specifications

[**RULE 1303(a)(1)-BACT, 5-10-1996**]

[Devices subject to this condition : D133]

E202.3 The operator shall clean and maintain this equipment according to the following specifications:

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

the engine shall not be operated without the use of an automatic air to fuel ratio controller which shall be maintained and kept in proper operating conditions at all times as specified by the manufacturer

the catalytic converter temperature and exhaust oxygen concentration shall be maintained within the effective operating range of the catalytic converter as specified by the manufacturer

[**RULE 1303(a)(1)-BACT, 5-10-1996; RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]

[Devices subject to this condition : D134, D173, D174, D176, D178, D259, D276, D290, D291, D292]

E202.4 The operator shall clean and maintain this equipment according to the following specifications:

Records shall be maintained of inspections and maintenance of the burners

The operator shall follow the procedures specified by the manufacturer to tune-up and maintain the combustion system (including but not limited to the burner and air/fuel control device) of this heater

Manufacturers maintenance procedures shall be kept by the operator and made available at the request of AQMD

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]

[Devices subject to this condition : D135, D137, D138, D139, D260, D261]

H. Applicable Rules

H23.1 This equipment is subject to the applicable requirements of the following rules or regulations:

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	1122

[**RULE 1122, 10-1-2004;** RULE 1122, 5-1-2009]

[Devices subject to this condition : E105]

H23.2 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	109
PM	District Rule	481

[**RULE 109, 5-2-2003; RULE 481, 1-11-2002**]

[Devices subject to this condition : D20, D21, D22, D24, D165, D305, D306, D307]

H23.3 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Refrigerants	District Rule	1415
Refrigerants	40CFR82, SUBPART	F

[RULE 1415, 12-3-2010; **40CFR 82 Subpart F, 5-14-1993**]

[Devices subject to this condition : E102]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

H23.4 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
CO	District Rule	1146

This CO emissions (concentration) shall be tested at least once per year per Rule 1146.

[**RULE 1146, 11-17-2000;** RULE 1146, 9-5-2008]

[Devices subject to this condition : D16, D17, D18, D19, D135, D137, D138, D139, D206, D207, D209, D211, D214, D215, D217, D219, D221, D260, D261]

H23.5 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM	District Rule	1140

[**RULE 1140, 2-1-1980;** RULE 1140, 8-2-1985]

[Devices subject to this condition : D170]

H23.6 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM	District Rule	1470

[RULE 1470, 6-1-2007]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D1, D2, D4, D7, D8, D10, D12, D15, D95, D98, D99, D133, D149, D152, D153, D159, D160, D162, D163, D164, D168, D169, D172, D175, D179, D180, D181, D183, D223, D289]

H23.11 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM	District Rule	1472

[RULE 1472, 3-7-2008]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D15, D95, D99, D153, D160, D168]

H23.12 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM	District Rule	1155

[RULE 1155, 12-4-2009]

[Devices subject to this condition : C49, C158]

H23.13 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	109

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 109, 5-2-2003**]

[Devices subject to this condition : E104, E108, E111, E112, E113]

H23.14 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Refrigerants	District Rule	1415
Refrigerants	District Rule	1415.1

[RULE 1415, 12-3-2010; RULE 1415.1, 12-3-2010]

[Devices subject to this condition : E103]

H23.15 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Refrigerants	District Rule	1415.1

[RULE 1415.1, 12-3-2010]

[Devices subject to this condition : E106]

J. Rule 461

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

J110.1 The operator shall use, except for diesel transfer, the phase II vapor recovery system in full operation whenever gasoline from this equipment is dispensed to motor vehicles as defined in Rule 461. This system shall be installed, operated and maintained to meet all CARB certification requirements.

[**RULE 461, 6-3-2005;** RULE 461, 3-7-2008]

[Devices subject to this condition : D147]

J373.3 The operator shall comply with the following gasoline transfer and dispensing requirements:

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

New equipment installations and subsequent service and repairs for any certified component for which this permit was issued, shall only be performed by a current and certified person who has successfully completed the manufacturer's training course and appropriate international code council (icc) certification. Completion of any AQMD training course does not constitute as a substitute for this requirement. Proof of successful completion of any manufacturer training course shall be with the manufacturer.

Depending on the system configuration, a leak rate test of the drop tube/drain valve assembly shall be conducted to quantify the pressure integrity of both the drop tube and drain valve seal or a leak rate test of the drop tube overfill prevention device and drain valve shall be conducted to quantify the pressure integrity of the drop tube overfill prevention device and the pressure integrity of the spill container drain valve.

From the above condition, either test shall be conducted as a performance test and as a reverification test. The test shall be conducted in accordance with test procedure method TP-201.1C (October 8, 2003) or TP-201.1D (October 8, 2003), respectively. Results shall be submitted to the AQMD, office of engineering and compliance, within seventy-two (72) hours of test.

A leak rate and cracking pressure test of pressure/vacuum relief vent valves shall be conducted within thirty days (30) after the start of operation of the OPW phase I EVR equipment and at least once every three (3) years thereafter to determine the pressure and vacuum at which the pressure/vacuum vent valve actuates, and to determine the volumetric leak rate at a given pressure. The test shall be conducted in accordance with the test procedure method TP-201.1E (October 8, 2003).

The above results shall be submitted to the AQMD, office of Engineering and Compliance, within seventy-two (72) hours of test. This test result shall be kept on site for five (5) years and made available to District representatives upon request

A static torque test of rotatable phase I adaptors shall be conducted to quantify the amount of static torque required to start the rotation of the rotatable phase I adaptors. The test shall be conducted in accordance with the test procedure method outlined in TP-201.1B (October 8, 2003) as a performance test and as a reverification test.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Results shall be submitted to the AQMD, office of Engineering and Compliance, within seventy-two (72) hours of test.

a). The Phase II vapor recovery systems shall be installed, operated, and maintained such that the maximum allowable pressure through the system including nozzle, vapor hose, swivels, and underground piping does not exceed the dynamic back pressures described by the California Air Resources Board (CARB) Executive Order by which the system was certified:

Nitrogen Flowrates (CFH)	Dynamic Back Pressure (Inches of Water)
60	0.50

The above dynamic back pressure tests shall be conducted to determine the phase II system vapor recovery back pressures. The tests shall be conducted in accordance with CARB test procedure TP-201.4, methodology 4 and 6 (July 3, 2002); as a performance test. This test shall be a one-time performance test and the results kept permanently on site. The results of the above test shall be submitted to the AQMD, office of Engineering and Compliance, within seventy-two (72) hours of tests.

A static pressure leak decay test shall be conducted to demonstrate that the storage tanks, the remote and/or nozzle vapor recovery check valves, associated vapor return piping and fittings are free from vapor leaks. The test shall be conducted in accordance with CARB test procedure method TP-201.3 (march 17, 1999) as a performance test and as a reverification test. Results shall be submitted to the AQMD, office of Engineering and Compliance, within seventy-two (72) hours of test.

A static pressure performance test for the Healy clean air separator using both the vacuum decay procedure and the positive pressure procedure shall be conducted to quantify the vapor tightness of the Healy clean air separator tank pressure management system. The test shall be conducted in accordance with exhibit 4 of CARB executive order VR-201-J as a performance test and reverification test. Results shall be submitted to the AQMD, office of Engineering and Compliance within seventy-two (72) hours of tes

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

A vapor to liquid volume ratio test shall be conducted to quantify the vapor to liquid (v/l) volumetric ratio of the Healy clean air separator system. The test shall be conducted in accordance with exhibit 5 of CARB executive order VR-201-J as a performance test and reverification test. Results shall be submitted to the AQMD, office of Engineering and Compliance within seventy-two (72) hours of test.

A nozzle bag test shall be conducted on the Healy phase II EVR nozzles to verify the integrity of the vapor valve. The test shall be conducted on any newly installed or replaced Healy Phase II EVR nozzles and in accordance with exhibit 7 of CARB executive order VR-201-J. Results shall be submitted to the AQMD, office of Engineering and Compliance within seventy-two (72) hours of test.

The static pressure leak decay test TP-201.3, shall be conducted in accordance with exhibit 8 of CARB executive order VR-201-J. Verification of completing each step as outlined shall be documented by submitting a copy of exhibit 8 to the AQMD, office of Engineering and Compliance within seventy-two (72) hours of test.

Unless AQMD Rule 461 requires a more frequent testing or inspection schedule, the owner/operator shall be responsible to perform the scheduled weekly, quarterly, and annual inspections as outlined in the ARB approved installation, operation, and maintenance manual for the Healy Phase II EVR systems, as well as all the required vapor recovery system tests as per the current and appropriate ARB executive order.

The AQMD shall be notified by e-mail at r461testing@aqmd.gov or by facsimile at telephone number (909) 396-3606 at least seventy-two (72) hours prior to any of the above mentioned testing requirements. Such notification shall include the name of the owner or operator; the name of the contractor; the location of the facility; and the scheduled start and completion dates of the tests to be performed

The testing for the above mentioned tests shall be conducted in accordance with the most recent Rule 461 amendment or CARB executive order requirements, whichever is more stringent.

Should the facility dispense more than 600,000 gallons of gasoline in any calendar year, the operator shall file an application for a new permit to construct/operate to

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

install an ARB certified in station diagnostic (ISD) system. The ISD system shall be fully installed, tested, and operative based on gasoline throughput per calendar year greater than 1.8 million gallons by September 1, 2009 or gasoline throughput per calendar year greater than between 600,000 and 1.8 million gallons by September 1, 2010

The bulk loading equipment shall be operated for bottom loading only during the transfer of gasoline fuel from the underground storage tanks into any tank truck. All vapor return lines shall be connected between the underground gasoline storage tanks and tank truck.

The transfer equipment from the bulk loading operations shall be operated and maintained so that there are no overfills, system vapor leaks, or liquid leaks from disconnect operations.

The bulk loading equipment shall be operated so that the backpressure in the vapor recovery system does not exceed 18 inches of water column pressure.

This class "B" bulk loading facility shall be installed, operated, and maintained in accordance with District rule 462.

The bulk loading vapor recovery system shall be certified by ARB as required in district rule 462. The copy of the ARB bulk plant vapor recovery certification test results shall be retained on site and made available to District representatives upon request.

Records of daily and monthly gasoline fuel dispensed for both the gasoline dispensing facility operation and for the bulk loading operation shall be prepared and maintained.

All records and test results that are required to be maintained by district rules 461 and 462 shall be kept on site for five years and made available to District representatives upon request

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 461, 6-3-2005;** RULE 461, 3-7-2008; **RULE 462, 5-14-1999**]

[Devices subject to this condition : D277, D278, D279, D280, D281, D282, D283]

J397.1 The operator shall comply with the following CARB Executive Order G-70-193:

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

1. The owner or operator of this equipment shall conduct a physical inspection of the equipment and manually monitor the system gauge levels during gasoline dispensing on a daily operating basis per site. The equipment shall operate within the following gauge levels:

a)	Vapor return line vacuum:	35" to 65" wc
b)	Gasoline supply pressure:	27 psig to 35 psig
c)	Cargo tank pressure:	less than 18" wc

All physical inspections and gauge observations shall be recorded in a systems log and be kept on board the mobile fueler at all times.

2. If a violation of the gauge ranges specified in conditions 1a, 1b, or 1c occurs, the owner or operator of this equipment shall:

a) Record the date, time period, and fuel totalizing meter reading when the system first began to fail to operate within the specified range.

b) Record the date and time that contact was made with an authorized representative to have the system inspected and repaired.

c) Record the date and time that the authorized representative inspected the system, provide a written description of the repairs performed, and record the fuel totalizing meter reading.

3. This equipment shall cease all gasoline dispensing operations when any one of the following conditions occur:

a) One of the jet pumps is disabled;

b) Failing to achieve the minimum operating vacuum of 35" wc within five seconds after the system has been activated for three consecutive dispensing episodes;

c) A vacuum level below 15" wc for more than three seconds after the system has reached 35" wc;

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

d) A vacuum level above 85" wc during a dispensing episode to non-ORVR vehicles;

e) Except during testing operations, a closed valve at the vapor return line connection to each jet pump;

f) A pressure in the cargo tank headspace exceeding 18" wc for more than five minutes (accumulated) during any sixty minute gasoline dispensing period;

g) Except during repair operations, an open drain valve in the liquid drop out pot;

h) Except during testing operations, a closed drain valve at the liquid drop out pot in the liquid removal line;

i) Any observation of breaks, cracks, or holes in the tank insulation, which affects the insulating properties or durability of the insulation;

j) The accumulated length of all tears of the nozzle boot (including rips, slits, cracks, etc.) exceeds 0.5" in length; or

k) The faceplate and fill pipe interface cannot achieve a seal of at least 25 percent of the accumulated circumference of the faceplate.

4. Within thirty (30) days of initial operation and at least once every twelve months from the previous test, a vapor return line vacuum integrity test shall be conducted and pass in accordance with Exhibit 3 of CARB Executive Order G-70-193. Results shall be submitted to the AQMD, Office of Engineering and Compliance, within forty-eight (48) hours of test.

The AQMD shall be notified at telephone number (909) 396-3886 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator of this equipment; the name of the testing contractor; the location of the mobile fueler; and the scheduled start and completion dates of the vapor return line vacuum integrity test.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

5. Within thirty (30) days of initial operation and at least once every twelve months from the previous test, a fill pipe pressure regulation fueling test shall be conducted and pass in accordance with Exhibit 4 of CARB Executive Order G-70-193. Results shall be submitted to the AQMD, Office of Engineering and Compliance, within forty-eight (48) hours of test.

The AQMD shall be notified at telephone number (909) 396-3886 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator of this equipment; the name of the testing contractor; the location of the mobile fueler; and the scheduled start and completion dates of the fill pipe pressure regulation fueling test.

6. Within thirty (30) days of initial operation and at least once every twelve months from the previous test, a ten gallon per minute flowrate limitation test shall be conducted and pass in accordance with Exhibit 5 of CARB Executive Order G-70-193. Results shall be submitted to the AQMD, Office of Engineering and Compliance, within forty-eight (48) hours of test.

The AQMD shall be notified at telephone number (909) 396-3886 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator of this equipment; the name of the testing contractor; the location of the mobile fueler; and the scheduled start and completion dates of the ten gallon per minute limitation test.

7. The individual and company performing any maintenance on any part of the vapor recovery system shall provide at a minimum for the owner or operator of the mobile fueler, a chronological record consisting of the following information for the mobile fueler's maintenance log. The date of service, name of maintenance technician, a contact phone number, a description of and location of any equipment replaced including appropriate test results, and a description of the system problems repaired.

8. A current CARB certification decal shall be displayed on the mobile fueler in a manner approved by the executive officer.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

9. Except for necessary inspections due to equipment failures, and for scheduled maintenance and repairs; the mobile fueler dome hatch shall remain closed and latched at all times. Furthermore, the mobile fueler dome hatch shall remain closed and latched until the head space pressure is less than 2" wc.

10. All physical inspection and gauge observation records; all test results; and all maintenance records as required by this CARB Executive Order shall be prepared, shall be retained for two years, and shall be kept within the mobile fueler and made available to district representatives upon request.

[**RULE 461, 6-3-2005;** RULE 461, 3-7-2008]

[Devices subject to this condition : D147]

K. Record Keeping/Reporting

K67.1 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

For architectural applications where no thinners, reducers, or other VOC containing materials are added, maintain semi-annual records for all coating consisting of (a) coating type, (b) VOC content as supplied in grams per liter (g/l) of materials for low-solids coatings, (c) VOC content as supplied in g/l of coating, less water and exempt solvent, for other coatings.

For architectural applications where thinners, reducers, or other VOC containing materials are added, maintain daily records for each coating consisting of (a) coating type, (b) VOC content as applied in grams per liter (g/l) of materials used for low-solids coatings, (c) VOC content as applied in g/l of coating, less water and exempt solvent, for other coatings.

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : E107]

K67.2 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the filter

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D21, D22, D24, C96, D165, D305, D306, D307]

K67.3 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the water wash

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D20]

K67.5 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Purchase records of abrasive used or daily records of abrasives used and evidence of ARB certification

If abrasives are re-used, records to demonstrate that such abrasives are tested with CARB Method 371-A

Daily records of the description of items blasted to demonstrate compliance

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D44]

K67.6 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

All maintenance, monthly and annual gasoline dispensed records, shall be prepared, shall be retained for five years, and shall be kept within the mobile fueler and made available to District representatives upon request.

All daily inspection records shall be completed immediately after the daily inspecton.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; **RULE 461, 6-3-2005;** RULE 461, 3-7-2008]

[Devices subject to this condition : D147]

K67.8 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The operator shall retain all purchase invoices for all VOC-containing material used or stored at the facility, and all waste manifest for all waste VOC containing material removed from the facility, for 60 months.

The operator shall maintain a single list which includes only the name and address of each person from whom the facility acquired VOC-containing material regulated by the district that was used or stored at the facility during the preceding 12 months.

The operator shall keep records in accordance with the requirements of rule 109 (record keeping for volatile organic compound emissions). Such records shall be retained for a period of five years and shall be made available to any district representative upon request.

Within 14 calendar days after the end of each month, the operator shall total and record VOC emissions for the month from all permitted equipment covered by the monthly limit. The record shall include any procedures used to account for control device efficiencies and/or waste disposal. It shall be signed and certified for accuracy by the highest ranking individual responsible for operation of equipment subject to the permit.

[**RULE 109, 5-2-2003; RULE 1303(b)(2)-Offset, 5-10-1996**]

[Devices subject to this condition : D165]

K67.10 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the date, time and description of any maintenance or repairs resulting from the inspection

the name of the person performing the inspection and/or maintenance of the filter media

the date, time and results of the inspection

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : C49, C158, E338]

K67.11 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

copy of MSDS shall be kept for the abrasive material used in this equipment

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D156, D170]

K67.14 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

An engine operating log shall be kept and maintained on file to record when this engine is started manually. The log shall list the date of operation, the timer reading in hours at the beginning and end of operation, and the reason for operation for a minimum of five calendar years prior to the current year and made available to District personnel upon request. The total hours of operation (include hours for manual and automatic operation) shall be recorded sometime during the first 15 days of January

[RULE 1110.2, 7-9-2010; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]

[Devices subject to this condition : D175, D176, D178, D182, D259, D276]

K67.15 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

The hours of operation per year.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1401, 12-7-1990]

[Devices subject to this condition : D177]

K67.16 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

An engine operating log shall be maintained which shall include manual and automatic operation and shall list all engine operations in each of the following areas:

A. Emergency use hours of operation,

B. Maintenance and testing hours,

C. Other operating hours (describe the reason for operation).

In addition, each time the engine is started manually, the log shall include the date of operation and the timer reading in hours at the beginning and end of operation. The log shall be kept for a minimum of five calendar years prior to the current year and made available to District personnel upon request.

[RULE 1110.2, 7-9-2010; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;** RULE 1470, 6-1-2007; **RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]

[Devices subject to this condition : D1, D2, D4, D7, D8, D10, D12, D15, D95, D98, D99, D101, D115, D116, D117, D118, D119, D120, D121, D122, D123, D124, D125, D126, D127, D128, D129, D131, D133, D134, D149, D152, D153, D159, D160, D162, D163, D164, D168, D169, D172, D173, D174, D175, D176, D178, D179, D180, D181, D182, D183, D223, D259, D276, D289, D290, D291, D292]

K67.21 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Records of monthly fuel dispensed only during bulk loading operations shall be prepared, shall be retained on site for five years, and shall be made available to District representatives upon request.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D277, D278, D282, D283]

K67.22 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Operating time records as required per conditons C1.23 and C1.24.

The records shall be kept for at least five years and made available to District personnel upon request

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D266, D267, D268, D269, D270, D271, D272, D273, D274, D275]

K67.23 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Operating time records as required per conditions C1.16 and C1.26

The records shall be kept for at least five years and made available to District personnel upon request

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D284, D285, D286, D287, D288, D297, D298, D299, D300, D301, D302, D303, D304]

K67.24 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Operating time records as required per conditons C1.14, C1.16 and C1.18

The records shall be kept for at least five years and made available to District personnel upon request

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]

[Devices subject to this condition : D225, D226, D228, D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D244, D253, D255, D256, D257, D258, D262, D263, D264, D265]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]

   a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]

   b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]

   c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]

2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]

3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statutes of other governmental agencies. [204]

4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION E: ADMINISTRATIVE CONDITIONS

5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]

6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least: [204]

   a. Three years for a facility not subject to Title V; or

   b. Five years for a facility subject to Title V.

7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]

   a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134, 204]

   b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]

   c. For a large NOx source, compliance with a RECLAIM concentration limit shall be measured over a continuous 60 minutes for that source; [2012]

   d. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION E: ADMINISTRATIVE CONDITIONS

e. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO2) and be averaged over 15 consecutive minutes; [407]

f. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO2) at standard conditions and averaged over 15 consecutive minutes. [409]

g. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O2) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]

8. All equipment operating under the RECLAIM program shall comply concurrently with all provisions of AQMD Rules and Regulations, except those listed in Table 1 of Rule 2001 for NOx RECLAIM sources and Table 2 of Rule 2001 for SOx RECLAIM sources. Those provisions listed in Tables 1 or 2 shall not apply to NOx or SOx emissions after the date the facility has demonstrated compliance with all monitoring and reporting requirements of Rules 2011 or 2012, as applicable. Provisions of the listed AQMD rules in Tables 1 or 2 which have initial implementation dates in 1994 shall not apply to a RECLAIM NOx or SOx source, respectively. [2001]

9. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]

a. Brief description of the equipment tested.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION E: ADMINISTRATIVE CONDITIONS

b. Brief process description, including maximum and normal operating temperatures, pressures, through-put, etc.

c. Operating conditions under which the test will be performed.

d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, and distances of flow disturbances, (e,g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).

e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.

f. Description of calibration and quality assurance procedures.

g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (no conflict of interest).

10. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD Rules or equipment-specific conditions. The report shall contain the following information: [204]

a. The results of the source test.

b. Brief description of the equipment tested.

c. Operating conditions under which test will be performed.

d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).

e. Field and laboratory data forms, strip charts and analyses.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION E: ADMINISTRATIVE CONDITIONS

f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.

11. The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]

12. Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

The Facility shall comply with all applicable monitoring and source testing requirements in Regulation XX. These requirements may include but are not limited to the following:

I. NOx Monitoring Conditions

A. The Operator of a NOx Major Source, as defined in Rule 2012, shall, as applicable:

Not Applicable

B. The Operator of a NOx large Source, as defined in Rule 2012, shall, as applicable:

1. Install, maintain, and operate a totalizing fuel meter and any device specified by the Executive Officer as necessary to determine monthly fuel usage or other applicable variables specified in Rule 2012, Appendix A, Table 3-A. The sharing of totalizing fuel meter may be allowed by the Executive Officer if the fuel meter serves large sources which have the same emission factor, concentration limit, or emission rate. The sharing of totalizing fuel meters shall not be allowed for large sources which are required to comply with an annual heat input limit. [2012]

2. Comply at all times with the specified NOx concentration limit in PPM measured over any continuous 60 minutes for that source or establish an equipment-specific emission rate that is reliable, accurate, representative of that sources emissions, and in accordance with the requirements specified in Rule 2012, Appendix A, Chapter 5. [2012]

C. The Operator of a NOx Process Unit, as defined in Rule 2012, shall, as applicable:

1. Install, maintain, and operate a totalizing fuel meter or any device approved by the Executive Officer to measure quarterly fuel usage or other applicable variables specified in Rule 2012, Table 2012-1, and Rule 2012, Appendix A, Table 4-A. The sharing of totalizing fuel meters may be allowed by the Executive Officer if the fuel meter serves process units which have the same emission factor or emission rate. The sharing of totalizing meter shall not be allowed for process units which are required to comply with an annual heat input limit. [2012]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

II. NOx Source Testing and Tune-up conditions

1. The operator shall conduct all required NOx source testing in compliance with an AQMD-approved source test protocol. [2012]

2. The operator shall, as applicable, conduct source tests for every large NOx source no later than December 31, 1996 and every 3 years thereafter. The source test shall include the determination of NOx concentration and a relative accuracy audit of the exhaust stack flow determination (e.g. in-stack flow monitor or fuel flow monitor based F-factor calculation). Such source test results shall be submitted per the schedule described by APEP. In lieu of submitting the first source test report, the facility permit holder may submit the results of a source test not more than 3 years old which meets the requirements when conducted. [2012]

3. All NOx large sources and NOx process units shall be tuned-up in accordance with the schedule specified in Rule 2012, Appendix A, Chapter 5, Table 5-B. [2012]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR RECLAIM SOURCES

The Facility shall comply with all applicable reporting and recordkeeping requirements in Regulation XX. These requirements may include but are not limited to the following:

I. Recordkeeping Requirements for all RECLAIM Sources

1. The operator shall maintain all monitoring data required to be measured or reported pursuant to Rule 2011 and Rule 2012, whichever is applicable. All records shall be made available to AQMD staff upon request and be maintained for at least:
    a. Three years after each APEP report is submitted to AQMD for a facility not subject to Title V, unless a different time period is required in Rule 2011 or Rule 2012 [2011 & 2012]; or
    b. Five years after each APEP report is submitted to AQMD for a facility subject to Title V. [3004(a)(4)(E)]
    c. Notwithstanding the above, all data gathered or computed for intervals of less than 15 minutes shall only be maintained a minimum of 48 hours. [2011 & 2012]
2. The operator shall store on site and make available to the Executive Officer upon request: records used to determine emissions, maintenance records, sources test reports, relative accuracy test audit reports, relative accuracy audit reports and fuel meter calibration records. [2011 & 2012]

II. Reporting Requirements for all RECLAIM Sources

1. The opearator shall submit a quarterly certification of emissions including the total facility NOx or SOx emissions, whichever is applicable, for the quarter within 30 days after the end of the first three quarters and 60 days after the end of the fourth quarter of a compliance year. [2004]

NOx Reporting Requirements

A. The Operator of a NOx Major Source, as defined in Rule 2012, shall, as applicable:

Not Applicable

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR RECLAIM SOURCES

B. The Operator of a NOx Large Source, as defined in Rule 2012, shall:

1. Install, maintain and operate a modem or any reporting device approved by the Executive Officer to report, to the AQMD, the total monthly NOx mass emissions from each large NOx source. The Operator shall comply with this requirement within 12 months of the date of entry to the RECLAIM Program. Such data shall be reported within 15 days after the end of each calendar month. [2012]

C. The Operator of a NOx Process Unit, as defined in Rule 2012, shall:

1. Electronically report the calculated quarterly NOx emissions for each NOx process unit. The Operator shall comply with this requirement within 12 months of the date of entry to the RECLAIM Program. [2012]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 261420, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 529048 Permit to Construct Issued: 04/27/12	D308		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV (5) [**RULE 407, 4-2-1982**]	B59.2, C1.29, C1.30, K67.25
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 261421, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 529050 Permit to Construct Issued: 04/27/12	D309		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5A) [**RULE 407, 4-2-1982**]; **NOX**: 19 LBS/1000 GAL DIESEL (1) [**RULE 2012, 5-6-2005**]; **NOX**: 102 LBS/1000 GAL GASOLINE (1) [**RULE 2012, 5-6-2005**]; **PM**: 0.1 GRAINS/SCF (5) [**RULE 409, 8-7-1981**]; **SOX**: 500 PPMV (5) [**RULE 407, 4-2-1982**]	B59.2, C1.29, C1.30, K67.25
Process 3: ORGANIC SOLVENT SURFACE COATING					

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 3: ORGANIC SOLVENT SURFACE COATING					
SPRAY COATING OPERATION, SPRAYLINE, MODEL NO. SL-SDG-184512,18 FT-0 IN W. X 45 FT-6 IN L. X 12 FT-0 IN H., AUTOMOTIVE TYPE, WITH 34 EXHUAST FILTERS, EACH 20" X 25", AND A 7.5 HP BLOWER, WITH SPRAY BOOTH WITH A/N: 535755 Permit to Construct Issued: 07/13/12	D339			**PM**: (9) [**RULE 404, 2-7-1986**]; **VOC**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	A63.4, B27.5, C6.1, D322.1, E175.1, H23.2, K67.2
HEATER, BANANZA, NATURAL GAS, WITH MODEL EP-LE MAXONBURNER, WITH LOW NOX BURNER, 1.944 MMBTU/HR	D342		NOX: PROCESS UNIT**	**CO**: 2000 PPMV (5) [**RULE 407, 4-2-1982**]; **NOX**: 30 PPMV NATURAL GAS (4) [**RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]; **NOX**: 130 LBS/MMSCF (3) [**RULE 2012, 5-6-2005**]; **PM**: (9) [**RULE 404, 2-7-1986**]; **PM**: 0.1 GRAINS/SCF NATURAL GAS (5) [**RULE 409, 8-7-1981**]	D29.1
SPRAY COATING OPERATION, SPRAYLINE, MODEL NO. SL-ISB-1088, 10 FT-0 IN W. X 10 FT-8 IN L. X 8 FT-2 IN H., FLOORTYPE, WITH 16 EXHUAST FILTERS, EACH 20" X 25" X 2", AND A 2 HP BLOWER, WITH SPRAY BOOTH A/N: 535757 Permit to Construct Issued: 07/13/12	D340			**PM**: (9) [**RULE 404, 2-7-1986**]; **VOC**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	A63.4, B27.5, C6.1, D322.1, E175.1, H23.2, K67.2

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 3: ORGANIC SOLVENT SURFACE COATING					
SPRAY COATING OPERATION, SPRAYLINE, MODEL NO. SL-ISB-1088, 8 FT-0 IN W. X 8 FT-2 IN H. X 2 FT- 8 IN D., BENCH TYPE TYPE, WITH ONE FILTER, 20" X 20" X 2", AND A 2 HP EXHAUST BLOWER, WITH SPRAY BOOTH A/N: 535758 Permit to Construct Issued: 07/13/12	D341			**PM**: (9) [**RULE 404, 2-7-1986**]; **VOC**: (9) [**RULE 1107, 11-9-2001;** *RULE 1107, 1-6-2006;* **RULE 1136, 6-14-1996; RULE 1171, 11-7-2003;** *RULE 1171, 5-1-2009*]	A63.4, B27.5, C6.1, D322.1, E175.1, H23.2, K67.2

* (1) (1A) (1B) Denotes RECLAIM emission factor
(2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit
(4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit
(6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: DEVICE ID INDEX

The following sub-section provides an index to the devices that make up the facility description sorted by device ID.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: DEVICE ID INDEX

Device Index For Section H			
Device ID	**Section H Page No.**	**Process**	**System**
D308	1	2	0
D309	1	2	0
D339	2	3	0
D340	2	3	0
D341	3	3	0
D342	2	3	0

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

F1.1 The operator shall limit the material processed to no more than 2000 lb(s) in any one year.

For the purpose of this condition, material processed shall be defined as 1,1,1 trichloroethane.

[H&S 44300, 7-1-1988]

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[**RULE 401, 3-2-1984;** RULE 401, 11-9-2001]

F14.2 The operator shall not purchase diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

[RULE 431.2, 9-15-2000]

F14.3 The operator shall not burn fuel oil containing sulfur compounds in excess of 0.05 percent by weight.

[**RULE 431.2, 5-4-1990;** RULE 431.2, 9-15-2000]

F48.1 The operator shall not operate at this facility non chain driven, uncontrolled charbroiler exceeding the opacity limits specified in Rule 401.

[**RULE 401, 3-2-1984;** RULE 401, 11-9-2001]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

DEVICE CONDITIONS

A. Emission Limits

A63.4 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT	Header 3	Header 4
VOC	Less than or equal to	14	LBS IN ANY ONE MONTH

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

For the purposes of this condition, the limit(s) shall be based on the total combined emissions from equipment under device numbers D339, D340, and D341.

To ensure compliance with the monthly Volatile Organic Compound (VOC) emission limit(s) of this condition, the operator shall comply with the following recordkeeping requirements:

(1) The operator shall comply with Rule 109 (Recordkeeping for Volatile Organic Compound Emissions).

(2) Within 14 calendar days after the end of each month, the operator shall total and record VOC emissions for the month from all equipment and operations covered by the monthly emission limit(s). The record shall include any procedures used to account for control device efficiencies and/or waste disposal. It shall be signed and certified for accuracy by the highest ranking individual responsible for compliance with District rules.

(3) The operator shall maintain a single list which includes only the name and address of each person from whom the facility acquired VOC-containing material regulated by the District that was used or stored at the facility during the preceding 12 months.

(4) The operator shall retain all purchase invoices for all VOC-containing material used or stored at the facility, and all waste manifests for all waste VOC-containing material removed from the facility, for five years.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D339, D340, D341]

B. Material/Fuel Type Limits

B27.5 The operator shall not use materials containing any compounds identified in the SCAQMD Rule 1401, as amended 09/10/2010.

[RULE 1401, 9-10-2010]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D339, D340, D341]

B59.2 The operator shall only use the following material(s) in this device :

diesel fuel or bio-diesel

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]

[Devices subject to this condition : D308, D309]

C. Throughput or Operating Parameter Limits

C1.29 The operator shall limit the operating time to no more than 10 hour(s) in any one day.

To comply with this condition, the operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the pressure washer.

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 2005, 5-6-2005; RULE 2005, 6-3-2011**]

[Devices subject to this condition : D308, D309]

C1.30 The operator shall limit the operating time to no more than 260 hour(s) in any one month.

[**RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005; **RULE 2012, 5-6-2005**]

[Devices subject to this condition : D308, D309]

C6.1 The operator shall use this equipment in such a manner that the differential pressure being monitored, as indicated below, does not exceed 0.25 inches water column.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

To comply with this condition, the operator shall install and maintain a(n) differential pressure gauge to accurately indicate the differential pressure across the filters.

The operator shall determine and record the parameter being monitored once every 7 days.

[**RULE 1303(a)(1)-BACT, 5-10-1996**]

[Devices subject to this condition : D339, D340, D341]

D. Monitoring/Testing Requirements

D29.1 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	Approved District method	District-approved averaging time	Outlet
CO emissions	Approved District method	District-approved averaging time	Outlet

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

The test shall be conducted no later than 180 days after the initial start-up of this equipment unless otherwise approved in writing by the district.

A source test protocol shall be submitted to the district no later than 60 days after the initial start-up of this equipment unless otherwise approved in writing by the district. The test protocol shall be approved in writing by the district before the test commences

The test protocol shall include the proposed operating conditions of the equipment during the test, the identity of the testing laboratory, a statement from the testing laboratory certifying that it meets the criteria in district rule 304(k), and a description of the sampling and analytical procedures to be used

The source tests shall consist of, but may not be limited to, testing of the burner NOx and CO emissions, referenced at 3 percent volume stack gas oxygen on a dry basis, during as-found operating conditions of the burner

NOx and CO emission determination shall be averaged over a period of at least 15 and no more than 60 consecutive minutes, and at least 15 minutes after unit start-up

A written notice of the source tests shall be submitted to the district at least 14 days prior to the source testing date so that an observer from the district may be present

Two complete copies of the source test report shall be submitted to the district within 45 days after source testing date unless otherwise approved in writing by the district. The source test report shall include, but may not be limited to, all testing data required by this condition

A testing laboratory certified by the California Air Resources Board in the required test methods for the criteria pollutants to be measured, and in compliance with district rule 304 (no conflict of interest) shall conduct the test

Sampling facilities shall comply with the district guidelines for construction of sampling and testing facilities, pursuant to rule 217.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

The operator shall also provide to the District a source test report containing, at a minimum, the following information:

Required Data	Reported As
Exhaust flow rate	Dry standard cubic feet per minute (DSCFM) and dry actual cubic feet per minute (DACFM)
Emissions data	Concentration (ppmv) corrected to 3 percent oxygen (dry basis), mass rate (lbs/hr), and lbs/MM Cubic Feet
Flue gas temperature	Under actual test condition
Fuel flow rate (CFH)	Under actual test condition
Moisture concentration	Under actual test condition
Oxygen levels in the exhaust	Under actual test condition

[**RULE 1303(a)(1)-BACT, 5-10-1996; RULE 2005, 5-6-2005; RULE 2005, 6-3-2011; RULE 2012, 5-6-2005**]

[Devices subject to this condition : D339]

D322.1 The operator shall perform a weekly inspection of the equipment and filter media for leaks, broken or torn filter media, and improperly installed filter media.

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D339, D340, D341]

E. Equipment Operation/Construction Requirements

E175.1 The operator shall not use this equipment unless all exhaust air passes through the following:

filter media at least 2 inches thick

[**RULE 1303(a)(1)-BACT, 5-10-1996**]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : D339, D340, D341]

H. Applicable Rules

H23.2 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	109
PM	District Rule	481

[**RULE 109, 5-2-2003; RULE 481, 1-11-2002**]

[Devices subject to this condition : D339, D340, D341]

K. Record Keeping/Reporting

K67.2 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the filter

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection

[**RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : D339, D340, D341]

K67.25 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

Operating time records as required per conditons C1.29 and C1.30

The records shall be kept for at least five years and made available to District personnel upon request

[**RULE 1303(a)(1)-BACT, 5-10-1996;** RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(2)-Offset, 5-10-1996;** RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]

[Devices subject to this condition : D308, D309]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION I: PLANS AND SCHEDULES

This section lists all plans approved by AQMD for the purposes of meeting the requirements of applicable AQMD rules.

NONE

NOTE: This section does not list compliance schedules pursuant to the requirements of Regulation XXX - Title V Permits; Rule 3004(a)(10)(C). For equipment subject to a variance, order for abatement, or alternative operating condition granted pursuant to Rule 518.2, equipment specific conditions are added to the equipment in Section D or H of the permit.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION J: AIR TOXICS
[40CFR 63 Subpart ZZZZ 01-18-2008]

NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS: STATIONARY RECIPROCATING INTERNAL COMBUSTION ENGINES

The owner/operator of stationary Reciprocating Internal Combustion Engines (RICE) located at major or area sources of hazardous air pollutant (HAP) emissions shall comply with the applicable requirements of 40 CFR 63 Subpart ZZZZ including but not limited to the following:

1. The owner/operator of existing, new or reconstructed stationary RICE shall comply with emission and operating limitation requirements as specified in §63.6600 and i§63.6601 at all times except during periods of startups, shutdowns, and malfunctions. The owner/operator shall also comply with requirements of the General Provisions (40 CFR 63 Subpart A) as specified in §63.6665.

2. The owner/operator shall operate and maintain a stationary RICE, including air pollution control and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times, including during startup, shutdown and malfunction pursuant to §63.6605.

3. The owner/operator shall demonstrate initial compliance as specified in §63.6610 and §63.6611, and subsequent performance tests and other procedures as specified in §63.6615 and §63.6620.

4. The owner/operator shall comply with monitoring, installation, operation, and maintenance requirements as specified in §63.6625 and §63.660.

5. The owner/operator shall monitor and collect data to demonstrate continuous compliance with emission and operating limitations as specified in §63.6635 and §63.6640.

6. The owner/operator shall sent notifications and reports as specified in §63.6645 and §63.6650. Also, the owner/operator shall keep records as specified in §63.6655.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

GENERAL PROVISIONS

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]

2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]

   (B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]

4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

Reopening for Cause

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:

   (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.

   (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.

   (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:

   (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or

   (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

   Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:

   (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;

   (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

   (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and

   (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]

10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]

11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]

12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]

13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]

15. Nothing in this permit or in any permit shield can alter or affect:

    (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;

    (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;

    (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;

    (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;

    (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and

    (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]

16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

EMERGENCY PROVISIONS

17. An emergency[1] constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:

    (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:

        (1) An emergency occurred and the operator can identify the cause(s) of the emergency;

        (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;

        (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,

        (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and

    (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]

18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

---

1 "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

RECORDKEEPING PROVISIONS

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:

    (A) The date, place as defined in the Title V permit, and time of sampling or measurements;

    (B) The date(s) analyses were performed;

    (C) The company or entity that performed the analyses;

    (D) The analytical techniques or methods used;

    (E) The results of such analyses; and

    (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]

20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]

21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

22. The operator shall comply with the following requirements for prompt reporting of deviations:

    (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

(B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.

(C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.

(D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]

23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]

24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:

(A) Identification of each permit term or condition that is the basis of the certification;

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

(B) The compliance status during the reporting period;

(C) Whether compliance was continuous or intermittent;

(D) The method(s) used to determine compliance over the reporting period and currently, and

(E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn: Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

PERIODIC MONITORING

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 109	5-2-2003	Federally enforceable
RULE 1106.1	2-12-1999	Federally enforceable
RULE 1107	1-6-2006	Non federally enforceable
RULE 1107	11-9-2001	Federally enforceable
RULE 1110.2	7-9-2010	Non federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	6-3-2011	Non federally enforceable
RULE 1122	10-1-2004	Federally enforceable
RULE 1122	5-1-2009	Non federally enforceable
RULE 1130	10-8-1999	Federally enforceable
RULE 1136	6-14-1996	Federally enforceable
RULE 1140	2-1-1980	Federally enforceable
RULE 1140	8-2-1985	Non federally enforceable
RULE 1145	12-4-2009	Non federally enforceable
RULE 1145	2-14-1997	Federally enforceable
RULE 1146	11-17-2000	Federally enforceable
RULE 1146	9-5-2008	Non federally enforceable
RULE 1151	12-11-1998	Federally enforceable
RULE 1151	12-2-2005	Non federally enforceable
RULE 1155	12-4-2009	Non federally enforceable
RULE 1162	11-17-2000	Federally enforceable
RULE 1162	7-8-2005	Non federally enforceable

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1168	1-7-2005	Non federally enforceable
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	5-1-2009	Non federally enforceable
RULE 118	12-7-1995	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(1)-Modeling	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and Offset Exemption	6-14-1996	Federally enforceable
RULE 1401	12-7-1990	Non federally enforceable
RULE 1401	3-4-2005	Non federally enforceable
RULE 1401	8-18-2000	Non federally enforceable
RULE 1401	9-10-2010	Non federally enforceable
RULE 1415	12-3-2010	Non federally enforceable
RULE 1415.1	12-3-2010	Non federally enforceable
RULE 1470	6-1-2007	Non federally enforceable
RULE 1472	3-7-2008	Non federally enforceable
RULE 2005	5-6-2005	Federally enforceable
RULE 2005	6-3-2011	Federally enforceable
RULE 2012	5-6-2005	Federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 217	1-5-1990	Federally enforceable
RULE 219	6-1-2007	Non federally enforceable
RULE 219	9-4-1981	Federally enforceable
RULE 2202	2-6-2004	Non federally enforceable
RULE 3002	11-14-1997	Federally enforceable
RULE 3002	11-5-2010	Non federally enforceable
RULE 3003	11-14-1997	Federally enforceable
RULE 3003	11-5-2010	Non federally enforceable
RULE 3004	12-12-1997	Federally enforceable

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

SECTION K: TITLE V Administration

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 3004(a)(4)-Periodic Monitoring	12-12-1997	Federally enforceable
RULE 3005	11-14-1997	Federally enforceable
RULE 3005	11-5-2010	Non federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 304	5-6-2011	Non federally enforceable
RULE 401	11-9-2001	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 405	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 442	12-15-2000	Federally enforceable
RULE 461	3-7-2008	Non federally enforceable
RULE 461	6-3-2005	Federally enforceable
RULE 462	5-14-1999	Federally enforceable
RULE 481	1-11-2002	Federally enforceable
RULE 701	6-13-1997	Federally enforceable
H&S 44300	7-1-1988	Non federally enforceable
40CFR 60 Subpart IIII	7-11-2006	Federally enforceable
40CFR 60 Subpart JJJJ	1-18-2008	Federally enforceable
40CFR 63 Subpart ZZZZ	1-18-2008	Federally enforceable
40CFR 82 Subpart F	5-14-1993	Federally enforceable

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN PERMIT PURSUANT TO RULE 219

1. STEAMERS, NATURAL GAS
2. LAUNDRY ROOM DRYER, NATURAL GAS
3. PYROTECHNICS, OTHER FUEL
4. CHARBROILERS, NATURAL GAS
5. WATER HEATERS, NATURAL GAS
6. SPACE HEATERS, NATURAL GAS
7. SPECIAL EFFECTS, NATURAL GAS
8. COOKING OVENS, NATURAL GAS
9. COOKING KETTLE, NATURAL GAS
10. COOKING FRYERS, NATURAL GAS
11. COOKING RANGES/STOVES, NATURAL GAS
12. COOKING GRIDDLES, NATURAL GAS
13. COOKING STEAMERS, NATURAL GAS
14. DISHWASHERS, NATURAL GAS
15. SALAMANDERS, NATURAL GAS
16. COFFEE BREWERS, NATURAL GAS
17. COOKING BROILERS, NATURAL GAS
18. SPACE HEATERS, KEROSENE

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN PERMIT PURSUANT TO RULE 219

19. INTERNAL COMBUSTION ENGINES, MOWERS, GASOLINE
20. INTERNAL COMBUSTION ENGINES, ROTOTILLERS, GASOLINE
21. INTERNAL COMBUSTION ENGINES, BLOWERS, GASOLINE/OIL
22. INTERNAL COMBUSTION ENGINES, ECHO GENERATOR, GASOLINE
23. INTERNAL COMBUSTION ENGINES, SAWS, GASOLINE/OIL
24. INTERNAL COMBUSTION ENGINES, TRIMMERS, GASOLINE/OIL
25. INTERNAL COMBUSTION ENGINES, COMPRESSORS, NATURAL GAS
26. INTERNAL COMBUSTION ENGINES, AUXILIARY, NATURAL GAS
27. TOWER LIGHTS, GASOLINE
28. SCRUBBERS, GASOLINE
29. VACUUMS, GASOLINE
30. PARTS WASHERS, NATURAL GAS

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1106.1 02-12-1999]

RULE 1106.1 **(Amended February 12, 1999)**

Pleasure Craft Coating Operations

Except as otherwise provided in Rule 1106.1

(1) Within the District, the operator shall not sell, offer for sale, solicit, apply, or require any other person to use in the District any pleasure craft coating with a VOC content in excess of the following limits, expressed as grams of VOC per liter of coating applied, less water and exempt solvents:

COATING	VOC LIMIT		
	On or After 7/1/94	On or After 2/12/99	On or After 1/1/2001
Topcoats			
Extreme High Gloss	490	650	490
High Gloss	420	420	420
Pretreatment Wash Primers	780	780	780
Finish Primer/Surfacer	420	600	420
High Build Primer Surfacer	340	340	340
Teak Primer	775	775	775
Antifoulant Coatings			
Aluminum Substrate	560	560	560
Other Substrates	150	400	330
Clear Wood Finishes			
Sealers	550	550	550
Varnishes	490	490	490
Others	420	420	420

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1106.1 02-12-1999]

In the case of any coating sold, offered for sale, or solicited for use, this prohibition shall only apply where it is designated anywhere on the container by any sticker or label affixed thereto, or where it is indicated in any sales or advertising literature, that the coating may be used as, or is suitable for use as, a pleasure craft coating.

(2) A person shall not apply pleasure craft coatings subject to the requirements of this rule with a coating containing carbon tetrachloride or any of the Group II exempt compounds as defined in paragraph (b)(4) of Rule 1106.1 except for: methylene chloride; perchloroethylene; cyclic, branched, or linear, completely methylated siloxanes (VMS); or parachlorobenzotrifluoride (PCBTF).

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 01-06-2006]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	**Air-Dried**				**Baked**			
	gm/l		**lb/gal**		**gm/l**		**lb/gal**	
	Current	**7/1/07**	**Current**	**7/1/07**	**Current**	**7/1/07**	**Current**	**7/1/07**
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 01-06-2006]

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates, cont.								
Coating	**Air-Dried**				**Baked**			
	gm/l		**lb/gal**		**gm/l**		**lb/gal**	
	Current	**7/1/07**	**Current**	**7/1/07**	**Current**	**7/1/07**	**Current**	**7/1/07**
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 01-06-2006]

(2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 11-09-2001]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	**Air-Dried**				**Baked**			
	gm/l		**lb/gal**		**gm/l**		**lb/gal**	
	Current	**7/1/07**	**Current**	**7/1/07**	**Current**	**7/1/07**	**Current**	**7/1/07**
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 11-09-2001]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates								
Coating	**Air-Dried**				**Baked**			
	gm/l		**lb/gal**		**gm/l**		**lb/gal**	
	Current	**7/1/07**	**Current**	**7/1/07**	**Current**	**7/1/07**	**Current**	**7/1/07**
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1107 11-09-2001]

VOC LIMITS Less Water and Less Exempt Compounds Effective Dates, cont.								
Coating	**Air-Dried**				**Baked**			
	gm/l		**lb/gal**		**gm/l**		**lb/gal**	
	Current	**7/1/07**	**Current**	**7/1/07**	**Current**	**7/1/07**	**Current**	**7/1/07**
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5

(2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 11-08-1996]

(1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.

(2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

TABLE OF STANDARDS

VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water And Less Exempt Compounds

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior Coatings	350	450		350			
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250				100		50
Graphic Arts (Sign) Coatings	500						

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 11-08-1996]

Industrial Maintenance Primers and Topcoats							
Alkyds	420						
Catalyzed Epoxy	420						
Bituminous Coatings	420						
Materials							
Inorganic Polymers	420						
Vinyl Chloride Polymers	420						
Chlorinated Rubber	420						
Acrylic Polymers	420						
Urethane Polymers	420						
Silicones	420						
Unique Vehicles	420						
Japans/Faux Finishing Coatings	350	700		350			
Magnesite Cement Coatings	600			450			
Mastic Coatings	300						
Metallic Pigmented Coatings	500						
Multi-Color Coatings	420		250				
Pigmented Lacquer	680		550			275	
Pre-Treatment Wash Primers	780						
Primers, Sealers, and Undercoaters	350						
Quick-Dry Enamels	400						
Roof Coatings	300						
Shellac							
Clear	730						
Pigmented	550						
Stains	350						
Swimming Pool Coatings							
Repair	650						
Other	340						
Traffic Coatings	250		150				
Waterproofing Sealers	400						
Wood Preservatives							
Below-Ground	350						
Other	350						

* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

TABLE OF STANDARDS (cont.)

VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 06-03-2011]

(1) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6) of Rule 1113, no person shall supply, sell, offer for sale, market, manufacture, blend, repackage, apply, store at a worksite, or solicit the application of any architectural coating within the District:

(A) That is listed in the Table of Standards 1 and contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified; or

(B) That is not listed in the Table of Standards 1, and contains VOC (excluding any colorant added to tint bases) in excess of 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, until January 1, 2014, at which time the limit drops to 50 grams of VOC per liter of coating, less water, less exempt compounds (0.42 pounds per gallon).

(2) No person within the District shall add colorant at the point of sale that is listed in the Table of Standards 2 and contains VOC in excess of the corresponding VOC limit specified in the Table of Standards 2, after the effective date specified.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 06-03-2011]

TABLE OF STANDARDS 1
VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water and Less Exempt Compounds

COATING CATEGORY	Ceiling Limit[1]	Current Limit[2]	Effective Date		
			7/1/08	1/1/12	1/1/14
Bond Breakers		350			
Clear Wood Finishes		275			
Varnish	350	275			
Sanding Sealers	350	275			
Lacquer		275			
Concrete-Curing Compounds		100			
Concrete-Curing Compounds For Roadways and Bridges[3]		350			
Concrete Surface Retarder		250			50
Driveway Sealer		100		50	
Dry-Fog Coatings		150			50
Faux Finishing Coatings					
Clear Topcoat		350		200	
Decorative Coatings		350			100
Glazes		350			
Japan		350			
Trowel Applied Coatings		350		150	50
Fire-Proofing Coatings		350			150
Flats	250	50	50		
Floor Coatings	100	50			
Form Release Compound		250			100
Graphic Arts (Sign) Coatings		500			150
Industrial Maintenance (IM) Coatings	420	100			
High Temperature IM Coatings		420			
Non-Sacrificial Anti-Graffiti Coatings		100			
Zinc-Rich IM Primers	340	100			
Magnesite Cement Coatings		450			
Mastic Coatings		300			100
Metallic Pigmented Coatings	500	500			150
Multi-Color Coatings		250			
Nonflat Coatings	150	50			
Pre-Treatment Wash Primers		420			
Primers, Sealers, and Undercoaters	200	100			
Reactive Penetrating Sealers		350			
Recycled Coatings		250			
Roof Coatings	250	50			
Roof Coatings, Aluminum		100			

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 06-03-2011]

Roof Primers, Bituminous	350	350			
Rust Preventative Coatings	400	100			
Stone Consolidant		450			
Sacrificial Anti-Graffiti Coatings		100		50	
Shellac					
Clear		730			
Pigmented		550			
Specialty Primers	350	100			
Stains		100			

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1113 06-03-2011]

COATING CATEGORY	Ceiling Limit[1]	Current Limit[2]	Effective Date		
			7/1/08	1/1/12	1/1/14
Stains, Interior	250	250			
Swimming Pool Coatings					
Repair		340			
Other		340			
Traffic Coatings		100			
Waterproofing Sealers	250	100			
Waterproofing Concrete/Masonry Sealers	400	100			
Wood Preservatives		350			

1. The specified ceiling limits are applicable to products sold under the Averaging Compliance Option.
2. The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.
3. Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

TABLE OF STANDARDS 1 (cont.)
VOC LIMITS

Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

TABLE OF STANDARDS 2
VOC LIMITS FOR COLORANTS

Grams of VOC Per Liter of Colorant
Less Water and Less Exempt Compounds

COLORANT	Limit[4]
Architectural Coatings, excluding IM Coatings	50
Solvent-Based IM	600
Waterborne IM	50

4. Effective January 1, 2014.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1130 10-08-1999]

(Amended October 8, 1999)

RULE 1130. GRAPHIC ARTS

Except as otherwise provided in Rule 1130

(1) VOC Content of Graphic Arts Materials

The operator shall not apply any graphic arts material, including any VOC-containing materials added to the original graphic arts materials, which contains a total VOC in excess of the limits specified below:

GRAPHIC ARTS MATERIAL	VOC LIMIT Grams per Liter of Coating (or Ink or Adhesive), Less Water and Less Exempt Compounds	
	(October 8, 1999)	Effective January 1, 2000
Lithographic Ink	300	300
Letterpress Ink	300	300
Gravure Ink	300	300
Flexographic Ink Non-Porous Substrate	300	300
Flexographic Ink Porous Substrate	300	225
Flexographic Fluorescent Ink	300	300
Coating	300	300
Adhesive	300	150

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1130 10-08-1999]

(2) VOC Content of Fountain Solution

Through December 31, 1999, the operator shall not apply in any graphic arts operation any fountain solution, including any VOC-containing materials added to the original fountain solution, which contains a total VOC in excess of 100 grams per liter of material. Effective January 1, 2000, the VOC content of fountain solution, including any VOC containing material added to the original fountain solution as applied, shall be:

(A) no greater than 80 grams per liter of material, or

(B) no greater than 100 grams per liter of material, if a refrigerated chiller is used.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1136 06-14-1996]

Except as otherwise provided in Rule 1136

(a) The operator shall not apply any coating to a wood product which has a VOC content, including any VOC-containing material added to the original coating supplied by the manufacturer, which exceeds the applicable limit specified below:

(1)

VOC LIMITS
Grams Per Liter (lb/gal) of Coating, [lbs VOC/lb of solids],
Less Water and Less Exempt Compounds

COATING	Current Limit I	Current Limit II	On and After 7/1/2005
Clear Sealers	550 (4.6) [1.39]	680 (5.7) [3.36]	275 (2.3) [0.36]
Clear Topcoat	550 (4.6) [1.37]	275 (2.3) [0.35]	275 (2.3) [0.35]
Pigmented Primers, Sealers & Undercoats	550 (4.6) [1.06]	600 (5.0) [1.08]	275 (2.3) [0.21]
Pigmented Topcoats	550 (4.6) [1.10]	275 (2.3) [0.25]	275 (2.3) [0.25]

The operator shall use coatings on a wood product that comply with either all VOC limits in column I or all VOC limits in column II. The operator that applies a primer, sealer or undercoat, but not a topcoat, to a wood product, shall be subject to column I for that wood product.

(2) Notwithstanding the requirements of clause (a)(1), an operator that applies a topcoat and a primer, sealer or undercoat to a shutter may, until July 1, 2005, choose to comply with the VOC limits specified below for that shutter:

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1136 06-14-1996]

VOC LIMITS

Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],
Less Water and Less Exempt Compounds

COATING	
Clear Sealers	275 (2.3) [0.36]
Clear Topcoat	680 (5.7) [2.99]
Pigmented Primers, Sealers & Undercoats	275 (2.3) [0.33]
Pigmented Topcoats	600 (5.0) [1.38]

(3)

VOC LIMITS

Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],
Less Water and Less Exempt Compounds

COATING	Current Limit	On and After 7/1/2005
Barrier Coat - Plastic Components	760 (6.3) [3.9]	275 (2.3) [0.28]
Composite Wood Edge Filler	550 (4.6) [1.15]	275 (2.3) [0.31]
Extreme Performance Coatings	420 (3.5) [0.51]	275 (2.3) [0.33]
Fillers	500 (4.2) [0.66]	275 (2.3) [0.18]
High-Solid Stains	550 (4.6) [1.23]	350 (2.9) [0.42]
Inks	500 (4.2) [0.96]	500 (4.2) [0.96]
Mold-Seal Coatings	750 (6.3) [4.2]	750 (6.3) [4.2]
Multi-Colored Coatings	685 (5.7) [2.6]	275 (2.3) [0.33]

VOC LIMITS

Grams Per Liter (lb/gal) of Material

COATING	Current Limit	On and After 7/1/2005
Low-Solids Barrier Coat - Plastic Components	760 (6.3)	120 (1.0)
Low-Solid Stains, Toners, and Washcoats	480 (4.0)	120 (1.0)

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1136 06-14-1996]

Any coating subject to this rule that meets any of the three VOC limit formats (grams per liter, lb/gal, or lbs VOC/lb of solids) is in compliance with this subparagraph.

(4) The VOC limit for japan coatings is 700 grams per liter of coatings, less water and exempt compounds, as applied.

(b) A person shall not use a stripper on wood products unless:

(1) it contains less than 350 grams of VOC per liter of material; or

(2) the VOC composite vapor pressure is 2 mm Hg (0.04 psia) or less at 20°C (68°F).

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1140 02-01-1980]

(1) The operator shall not, if he complies with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(A) As dark or darker in shade as that designated as No. 2 on the Ringelmann Chart, as published by the United States Bureau of Mines, or

(B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (1)(A).

(2) The operator shall not, if he is not complying with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(A) As dark or darker in shade as that designated as No. 1 on the Ringelmann Chart, as published by the United States Bureau of Mines, or

(B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (2)(A).

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1140 08-02-1985]

(1) The operator shall not, if he complies with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(A) As dark or darker in shade as that designated as No. 2 on the Ringelmann Chart, as published by the United States Bureau of Mines, or

(B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (1)(A).

(2) The operator shall not, if he is not complying with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(A) As dark or darker in shade as that designated as No. 1 on the Ringelmann Chart, as published by the United States Bureau of Mines, or

(B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (2)(A).

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1145 12-04-2009]

Except as otherwise provided in Rule 1145, no person shall apply on plastics, rubber, leather, or glass any coatings which are applied with a VOC content in excess of the limits listed in the Table of Standards.

TABLE OF STANDARDS

VOC LIMITS LESS WATER AND LESS EXEMPT COMPOUNDS		
COATING CATEGORIES	g/L	lbs/gal
Electrical dissipating and shock free coatings	360	3.0
Extreme performance two-component coatings	420	3.5
General one-component coatings	120	1.0
General two-component coatings	120	1.0
Leather antique coatings	156	1.3
Leather color coatings	60	0.5
Leather sealer coatings	60	0.5
Leather stain coatings	216	1.8
Leather top coatings	120	1.0
Metallic coatings	420	3.5
Military specification one-component coatings	340	2.8
Military specification two-component coatings	420	3.5
Mirror backing curtain coated coatings	500	4.2
Mirror backing rolled coated coatings	312	2.6
Mold seal coatings	750	6.3
Multi-color coatings	680	5.7
Refrigerated glass door coatings	480	4.0
Optical coatings	50	0.4
Vacuum metalizing coatings	800	6.7

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1145 02-14-1997]

Except as otherwise provided in Rule 1145, the operator shall not apply on plastics, glass, or rubber any coatings which are applied with a VOC content in excess of the limits specified below:

COATING	VOC LIMITS Less Water and Less Exempt Compounds			
	Current		On and After 1-1-98	
	g/L	lbs/gal	g/L	lbs/gal
General Coatings				
One-component	275	2.3	275	2.3
Two-component	420	3.5	420	3.5
Military Spec. Coating				
One-component	340	2.8	340	2.8
Two-component	420	3.5	420	3.5
Multi-Colored Coatings	685	5.7	685	5.7
Mold Seal Coatings	750	6.3	750	6.3
Vacuum Metalizing Coatings	800	6.7	800	6.7
Mirror Backing				
Curtain Coated	500	4.2	500	4.2
Roll Coated	430	3.6	430	3.6
Optical Coatings	800	6.7	800	6.7
Electric Dissipating Coatings and Shock-Free Coatings	800	6.7	360	3.0
Metallic Coatings	420	3.5	420	3.5

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1151 12-11-1998]

Except as otherwise provided in Rule 1151

(1) VOC Content of Coatings

A person shall not apply a coating to Group I vehicles and equipment, and Group II vehicles, or their parts and components, which has a VOC content which exceeds the limits contained in subparagraphs (1)(A) and (1)(B). Compliance with the VOC limits shall be based on VOC content, including any VOC material added to the original coating supplied by the manufacturer, less water and exempt compounds, as applied to the vehicle, mobile equipment, or parts and components.

(A) Group I Vehicles and Equipment

The operator who applies coatings to Group I vehicles and equipment, or their parts or components, shall not apply a coating which has a VOC content in excess of the limits in Table 1.

TABLE 1

VOC LIMITS
Grams Per Liter of Coating,
Less Water and Exempt Compounds

COATING	On and After December 12, 1998 g/L	lb/gal
Pretreatment	780	6.5
Primer/Primer Surfacer/ Primer Sealer	250	2.1
Topcoats		
General	340	2.8
Metallic/Iridescent	340*	2.8*
Multi-Colored	685	5.7
Multistage	340*	2.8*
Specialty Coating	840	7.0

*The VOC limits for Metallic/Irridescent and Multistage topcoats for spot repairs on Group I vehicles and mobil equipment will be 3.5 lb/gal (less water and exempt compounds).

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1151 12-11-1998]

(B) Group II Vehicles

The operator who applies coatings to Group II vehicles, or their parts or components, shall not apply a coating which has a VOC content in excess of the limits in Table 2.

TABLE 2

VOC Limits
Grams Per Liter of Coating,
Less Water and Exempt Compounds

COATING	On and After December 12, 1998		On and After July 1, 1999		On and After October 1, 1999	
	g/L	lb/gal	g/L	lb/gal	g/L	lb/gal
Pretreatment	780	6.5	780	6.5	780	6.5
Primer/Primer Surfacer	250	2.1	250	2.1	250	2.1
Primer Sealer	340	2.8	340	2.8	340	2.8
Topcoats						
General	420	3.5	420	3.5	420	3.5
Metallic/Iridescent	420	3.5	420	3.5	420	3.5
Multi-Colored	685	5.7	685	5.7	685	5.7
Multistage System						
≥ 2 gal/day[1]	540	4.5	420[1]	3.5	420	3.5
< 2 gal/day[2]	540	4.5	540[2]	4.5	420	3.5
Multi-Colored Multistage	420	3.5	420	3.5	420	3.5
Specialty Coating	840	7.0	840	7.0	840	7.0

[1] On and after July 1, 1999, any person who uses two gallons or more of combined basecoat and clearcoat, as applied, on any given day shall comply with the 420 g/L (3.5 lb/gal) limit.

[2] Any person who uses less than two gallons of combined basecoat and clearcoat, as applied, on each day up to September 30, 1999 shall comply with the 3.5 lb/gal limit on and after October 1, 1999.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1151 12-11-1998]

(2) Exempt Compounds

The operator shall not apply a coating which contains any Group II exempt compounds as defined in Rule 102 except for methylene chloride; carbon tetrachloride; perchloroethylene; or cyclic, branched, or linear, completely methylated siloxanes (VMS).

(3) Carcinogenic Materials

The operator shall not apply the coatings in which cadmium or hexavalent chromium was introduced as a pigment or as an agent to impart any property or characteristic to the coatings during manufacturing, distribution, or use of the applicable coatings.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1151 12-02-2005]

The following limits of this rule shall sunset on June 30, 2008, and the limits specified in Appendix A shall become effective on July 1, 2008.

Except as otherwise provided in Rule 1151

(1) VOC Content of Coatings

A person shall not apply a coating to Group I vehicles and equipment, and Group II vehicles, or their parts and components, which has a VOC content which exceeds the limits contained in subparagraphs (1)(A) and (1)(B). Compliance with the VOC limits shall be based on VOC content, including any VOC material added to the original coating supplied by the manufacturer, less water and exempt compounds, as applied to the vehicle, mobile equipment, or parts and components.

(A) Group I Vehicles and Equipment

A person who applies coatings to Group I vehicles and equipment, or their parts or components, shall not apply a coating which has a VOC content in excess of the limits in Table 1.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1151 12-02-2005]

TABLE 1

VOC LIMITS
Grams Per Liter of Coating, Less Water and Exempt Compounds

COATING	On and After December 12, 1998 g/L	lb/gal
Pretreatment	780	6.5
Primer/Primer Surfacer/ Primer Sealer	250	2.1
Topcoats		
General	340	2.8
Metallic/Iridescent	340*	2.8*
Multi-Colored	685	5.7
Multistage	340*	2.8*
Specialty Coating	840	7.0

*The VOC limits for Metallic/Iridescent and Multistage topcoats for spot repairs on Group I vehicles and mobile equipment will be 3.5 lb/gal (less water and exempt compounds).

(B) Group II Vehicles

A person who applies coatings to Group II vehicles, or their parts or components, shall not apply a coating which has a VOC content in excess of the limits in Table 2.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1151 12-02-2005]

TABLE 2

VOC Limits
Grams Per Liter of Coating,
Less Water and Exempt Compounds

COATING	On and After December 12, 1998		On and After July 1, 1999		On and After October 1, 1999	
	g/L	lb/gal	g/L	lb/gal	g/L	lb/gal
Pretreatment	780	6.5	780	6.5	780	6.5
Primer/Primer Surfacer	250	2.1	250	2.1	250	2.1
Primer Sealer	340	2.8	340	2.8	340	2.8
Topcoats						
General	420	3.5	420	3.5	420	3.5
Metallic/Iridescent	420	3.5	420	3.5	420	3.5
Multi-Colored	685	5.7	685	5.7	685	5.7
Multistage System						
≥ 2 gal/day[1]	540	4.5	420[1]	3.5	420	3.5
< 2 gal/day[2]	540	4.5	540[2]	4.5	420	3.5
Multi-Colored Multistage	420	3.5	420	3.5	420	3.5
Specialty Coating	840	7.0	840	7.0	840	7.0

[1] On and after July 1, 1999, any person who uses two gallons or more of combined basecoat and clearcoat, as applied, on any given day shall comply with the 420 g/L (3.5 lb/gal) limit.

[2] Any person who uses less than two gallons of combined basecoat and clearcoat, as applied, on each day up to September 30, 1999 shall comply with the 3.5 lb/gal limit on and after October 1, 1999.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1151 12-02-2005]

(2) Exempt Compounds

A person shall not apply a coating which contains any Group II exempt compounds as defined in Rule 102 except for methylene chloride; carbon tetrachloride; perchloroethylene; or cyclic, branched, or linear, completely methylated siloxanes (VMS).

(3) Carcinogenic Materials

A person shall not apply the coatings in which cadmium or hexavalent chromium was introduced as a pigment or as an agent to impart any property or characteristic to the coatings during manufacturing, distribution, or use of the applicable coatings.

Appendix A

Effective July 1, 2008, the emission limits specified in this appendix shall become effective and replace the limits specified above

Except as otherwise provided in Rule 1151

(1) A person shall not apply any coating to a vehicle, mobile equipment, or associated parts or components, that have a VOC content in excess of the limits contained in Table A of this paragraph. Compliance with the VOC limits shall be based on VOC content, including any VOC material added to the original coating supplied by the manufacturer, less water and exempt compounds, as applied to the vehicle, mobile equipment or parts and components.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1151 12-02-2005]
Table A – Coating Categories and VOC limits

Coating Categories	**VOC Limits** **Less Water and Less Exempt Compounds** **Effective Dates**					
	July 1, 2008		**January 1, 2009**		**January 1, 2010**	
	g/L	**lb/gal**	**g/L**	**lb/gal**	**g/L**	**lb/gal**
Adhesion Promoter					540	4.5
Clear Coating	250	2.1				
Color Coating	420	3.5				
Multi-Color Coating			680	5.7		
Pretreatment Coating			660	5.5		
Primer					250	2.1
Single-Stage Coating					340	2.8
Temporary Protective Coating			60	0.5		
Truck Bed Liner Coating			310	2.6		
Underbody Coating			430	3.6		
Uniform Finishing Coating			540	4.5		
Any other coating type			250	2.1		

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1151 12-02-2005]

(1) Most Restrictive VOC Limit

If any representation on information on the container of any automotive coating, or any label or sticker affixed to the container, or in any sales, advertising, or technical literature supplied by a person that indicates that the coating meets the definition of or is recommended for use for more than one of the coating categories listed in paragraph (1), then the lowest VOC content limit shall apply.

(2) VOC Limits Compliance Dates

The VOC limits in effect as of December 2, 2005 shall be applicable until superceded by the VOC limits and effectives dates in Table A of paragraph (1).

(3) Exempt Compounds

A person shall not manufacture, sell, offer for sale, distribute for use in the District, or apply any coating which contains any Group II Exempt Compounds as defined in Rule 102.

(4) Carcinogenic Materials

A person shall not manufacture the coatings in which cadmium or hexavalent chromium was introduced as a pigment or as an agent to impart any property or characteristic to the coatings during manufacturing, distribution, or use of the applicable coatings.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1162 11-17-2000]

The operator shall not use a polyester resin material in a polyester resin operation which has a monomer content in excess of the limits specified in the Table below.

Polyester Resin Materials	Monomer Content in Polyester Resin Materials as Applied (By Weight Percent)
General Purpose Polyester Resin	35
Corrosion-Resistant	48
Fire Retardant	42
High Strength	48
Clear Gel Coat	50
Pigmented Gel Coat	45

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1162 07-08-2005]

The operator shall not use polyester resin material in an open molding system, which has a monomer content in excess of the limits specified in the following Table.

Polyester Resin Materials	Monomer Percentage by Weight as Applied	
	Prior to 11-09-2001	Current Limits
Clear Gel Coat	50	-
For Marble Resins	-	40
For Other Resins	-	44
Pigmented Gel Coat	45	-
White and Off White	-	30
Non-White	-	37
Primer	-	28
Specialty Gel Coats	-	48
General Purpose Resin	35	-
Marble Resins	-	10 or (32 % as supplied, no fillers)
Solid Surface Resins	-	17
Tub/Shower Resins	-	24 or (35 % as supplied, no fillers)
Lamination Resins	-	31 or (35 % as supplied, no fillers)
Others	-	35
Fire Retardant Resin	42	38
Corrosion Resistant Resin	48	48
High Strength Resin	48	40

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1168 01-07-2005]

(1) Unless otherwise specified in paragraph (c)(2), a person shall not apply any adhesives, adhesive bonding primers, adhesive primers, or any other primer which have a VOC content in excess of 250 g/L less water and less exempt compounds.

(2) A person shall not apply adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers, or any other primer which have a VOC content in excess of the limits specified below:

VOC Limit*, Less Water and Less Exempt Compounds in Grams per Liter

Architectural Applications	Current VOC Limit*
Indoor Carpet Adhesives	50
Carpet Pad Adhesives	50
Outdoor Carpet Adhesives	150
Wood Flooring Adhesive	100
Rubber Floor Adhesives	60
Subfloor Adhesives	50
Ceramic Tile Adhesives	65
VCT and Asphalt Tile Adhesives	50
Dry Wall and Panel Adhesives	50
Cove Base Adhesives	50
Multipurpose Construction Adhesives	70
Structural Glazing Adhesives	100
Single Ply Roof Membrane Adhesives	250

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1168 01-07-2005]

Specialty Applications	VOC Limits and Effective Dates**			
	Current VOC Limit*	1-1-05	7-1-05	1-1-07
PVC Welding	510			
CPVC Welding	490			
ABS Welding	400		325	
Plastic Cement Welding	350	250		
Adhesive Primer for Plastic	650		550	
Computer Diskette Manufacturing	350			
Contact Adhesive	80			
Special Purpose Contact Adhesive	250			
Tire Retread	100			
Adhesive Primer for Traffic Marking Tape	150			
Structural Wood Member Adhesive	140			
Sheet Applied Rubber Lining Operations	850			
Top and Trim Adhesive	540			250

** The specified limits remain in effect unless revised limits are listed in subsequent columns.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1168 01-07-2005]

For adhesives, adhesive bonding primers, or any other primer not regulated by the above two tables and applied to the following substrates, the following limits shall apply:

Substrate Specific Applications	Current VOC Limit*
Metal to Metal	30
Plastic Foams	50
Porous Material (except wood)	50
Wood	30
Fiberglass	80

If an adhesive is used to bond dissimilar substrates together the adhesive with the highest VOC content shall be allowed.

Sealants	Current VOC Limit*
Architectural	250
Marine Deck	760
Nonmembrane Roof	300
Roadway	250
Single-Ply Roof Membrane	450
Other	420

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1168 01-07-2005]

Sealant Primers	**Current VOC Limit***
Architectural	
Non Porous	250
Porous	775
Modified Bituminous	500
Marine Deck	760
Other	750

* For low-solid adhesives or sealants the VOC limit is expressed in grams per liter of material as determined in paragraph (b)(32); for all other adhesives and sealants, VOC limits are expressed as grams of VOC per liter of adhesive or sealant less water and less exempt compounds as determined in paragraph (b)(31).

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-07-2003]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-07-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 11-07-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS VOC g/l (lb/gal)
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 05-01-2009]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	CURRENT LIMITS*	EFFECTIVE 1/1/2010
SOLVENT CLEANING ACTIVITY	**VOC g/l (lb/gal)**	**VOC g/l (lb/gal)**
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)	
(B) Repair and Maintenance Cleaning		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 05-01-2009]

	CURRENT LIMITS*	EFFECTIVE 1/1/2010
SOLVENT CLEANING ACTIVITY (cont.)	**VOC g/l (lb/gal)**	**VOC g/l (lb/gal)**
(iii) Medical Devices & Pharmaceuticals		
(A) Tools, Equipment, & Machinery	800 (6.7)	
(B) General Work Surfaces	600 (5.0)	
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)	
(D) Cleaning of Ink Application Equipment		
(i) General	25 (0.21)	
(ii) Flexographic Printing	25 (0.21)	
(iii) Gravure Printing		
(A) Publication	100 (0.83)	
(B) Packaging	25 (0.21)	
(iv) Lithographic (Offset) or Letter Press Printing		
(A) Roller Wash, Blanket Wash, & On-Press Components	100 (0.83)	

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 1171 05-01-2009]

	CURRENT LIMITS*	EFFECTIVE 1/1/2010
SOLVENT CLEANING ACTIVITY (cont.)	**VOC g/l (lb/gal)**	**VOC g/l (lb/gal)**
(B) Removable Press Components	25 (0.21)	
(v) Screen Printing	100 (0.83)	
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)	

* The specified limits remain in effect unless revised limits are listed in subsequent columns.

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 404 02-07-1986]

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a). Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 404(a)

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter"Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter"Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter"Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot	Cubic meters Per Minute	Cubic feet Per Minute	Milligrams per Cubic Meter	Grains per Cubic Foot
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 405 02-07-1986]

The operator shall not discharge into the atmosphere from this equipment, solid particulate matter including lead and lead compounds in excess of the rate shown in Table 405(a).

Where the process weight per hour is between figures listed in the table, the exact weight of permitted discharge shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

TABLE 405(a)

Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All Points of Process		Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All points of Process	
Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour
100 or less	220 or less	0.450	0.99	9000	19840	5.308	11.7
150	331	0.585	1.29	10000	22050	5.440	12.0
200	441	0.703	1.55	12500	27560	5.732	12.6
250	551	0.804	1.77	15000	33070	5.982	13.2
300	661	0.897	1.98	17500	38580	6.202	13.7
350	772	0.983	2.17	20000	44090	6.399	14.1
400	882	1.063	2.34	25000	55120	6.743	14.9
450	992	1.138	2.51	30000	66140	7.037	15.5
500	1102	1.209	2.67	35000	77160	7.296	16.1
600	1323	1.340	2.95	40000	88180	7.527	16.6

FACILITY PERMIT TO OPERATE
DISNEYLAND RESORT

APPENDIX B: RULE EMISSION LIMITS
[RULE 405 02-07-1986]

Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All Points of Process		Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All points of Process	
Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour	Kilograms Per Hour	Pounds Per Hour
700	1543	1.461	3.22	45000	99210	7.738	17.1
800	1764	1.573	3.47	50000	110200	7.931	17.5
900	1984	1.678	3.70	60000	132300	8.277	18.2
1000	2205	1.777	3.92	70000	154300	8.582	18.9
1250	2756	2.003	4.42	80000	176400	8.854	19.5
1500	3307	2.206	4.86	90000	198400	9.102	20.1
1750	3858	2.392	5.27	100000	220500	9.329	20.6
2000	4409	2.563	5.65	125000	275600	9.830	21.7
2250	4960	2.723	6.00	150000	330700	10.26	22.6
2500	5512	2.874	6.34	175000	385800	10.64	23.5
2750	6063	3.016	6.65	200000	440900	10.97	24.2
3000	6614	3.151	6.95	225000	496000	11.28	24.9
3250	7165	3.280	7.23	250000	551200	11.56	25.5
3600	7716	3.404	7.50	275000	606300	11.82	26.1
4000	8818	3.637	8.02	300000	661400	12.07	26.6
4500	9921	3.855	8.50	325000	716500	12.30	27.1
5000	11020	4.059	8.95	350000	771600	12.51	27.6
6000	13230	4.434	9.78	400000	881800	12.91	28.5
7000	15430	4.775	10.5	450000	992100	13.27	29.3
8000	17640	5.089	11.2	500000 or more	1102000 or more	13.60	30.0