



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

April 8, 2011
Via electronic submittal

Mr. Gerardo Rios
USEPA – Region IX
Mail Stop A-5-2
75 Hawthorne Blvd.
San Francisco, CA 94105

Dear Mr. Rios,

Proposed Minor Revision to Title V Permit for Eastern Municipal Water District (EMWD), San Jacinto Valley Regional Water Reclamation Facility (SJVRF) (ID# 019159)

Enclosed for your 45-day review is the proposed revision to the Title V Permit for EMWD, municipal waste water treatment plant located at 770 North Sanderson Avenue, San Jacinto, CA in Riverside County. This revision is considered to be a minor revision. We are enclosing the appropriate pages of the proposed Section H, which includes the permits as shown below, and the engineering evaluation.

SECTION H, PERMIT TO CONSTRUCT

Appl. No.	Equipment	Description
517632	ICE (50-500 HP) NON-EMERGENCY STATIONARY NAT GAS FIRED ONLY	Alteration of the natural gas fired ICE to replace the catalytic converter to be in compliance with Rule 1110.2 requirements.
517633	ICE (50-500 HP) NON-EMERGENCY STATIONARY NAT GAS FIRED ONLY	Alteration of the natural gas fired ICE to replace the catalytic converter to be in compliance with Rule 1110.2 requirements.

The initial Title V permit for this facility was issued on February 1, 2007.

This request is being made via electronic submittal in order to facilitate your review. If you have any questions or need additional information, please contact Ms. Angela Shibata at (909) 396-2737 or by email at ashibata@aqmd.gov.

Sincerely,

Jay Chen, P.E.
Senior AQ Engineering Manager
Refinery and Waste Management Permitting

JC: CDT: AIS
Enclosures

cc: Felipe Gregorio, EMWD, with proposed Title V permit Revision
A/N 517631 Title V Permit Revision (07)