

# PROPOSED

DATE

**CERTIFIED MAIL**  
**RETURN RECEIPT REQUESTED**  
(xxx)

08-xxxE CAB  
File No. 0424

Captain Donald D. Hodge  
Chief of Staff  
Commander Navy Region Hawaii  
850 Ticonderoga Street, Suite 110  
Pearl Harbor, Hawaii 96860-5101

Attn: Mr. Darren Chun

Dear Captain Hodge:

**Subject: Covered Source Permit (CSP) Renewal No. 0424-01-C**  
**Application for Renewal No. 0424-03**  
**U.S. Navy, Public Works Center (PWC) Pearl Harbor**  
**One (1) 2.0 MW Combustion Turbine**  
**Located at: Red Hill Water Pumping Station, Honolulu, Oahu**  
**UTM: Zone 4, 613,010 m east, 2,363,775 m north (Old Hawaiian Datum)**  
**Date of Expiration: [five years from DATE]**

The subject Covered Source Permit renewal is issued in accordance with Hawaii Administrative Rules, Title 11, Chapter 60.1. The issuance of this permit is based on your application dated September 6, 2007, and shall supersede CSP No. 0424-01-C, issued on October 17, 2003, in its entirety. A receipt for the renewal of a non-major CSP application fee of \$500.00 was previously mailed.

The Covered Source Permit is issued subject to the conditions/requirements set forth in the following Attachments:

Attachment I:	Standard Conditions
Attachment II:	Special Conditions
Attachment II-INSIG:	Special Conditions–Insignificant Activities
Attachment III:	Annual Fee Requirements
Attachment IV:	Annual Emissions Reporting Requirements

**PROPOSED**

Captain Donald D. Hodge  
Date  
Page 2

The forms for submission are as follows:

Compliance Certification  
Monitoring Report Form: Fuel Consumption and Certification  
Monitoring Report Form: Visible Emissions  
Annual Emissions Report Form: Fuel Consumption  
Ringelmann Chart

This permit: (a) shall not in any manner affect the title of the premises upon which the equipment is to be located; (b) does not release the permittee from any liability for any loss due to personal injury or property damage caused by, resulting from or arising out of the design, installation, maintenance, or operation of the equipment; and (c) in no manner implies or suggests that the Hawaii Department of Health, or its officers, agents, or employees, assumes any liability, directly or indirectly, for any loss due to personal injury or property damage caused by, resulting from or arising out of the design, installation, maintenance, or operation of the equipment.

Sincerely,

THOMAS E. ARIZUMI, P.E., CHIEF  
Environmental Management Division

KK:nn

Enclosures

c: CAB Enforcement Section

**ATTACHMENT I: STANDARD CONDITIONS  
COVERED SOURCE PERMIT NO. 0424-01-C**

**[Issuance Date:]**

**[Expiration Date:]**

This permit is granted in accordance with the Hawaii Administrative Rules (HAR), Title 11, Chapter 60.1, Air Pollution Control, and is subject to the following standard conditions:

1. Unless specifically identified, the terms and conditions contained in this permit are consistent with the applicable requirement, including form, on which each term or condition is based.  
  
(Auth.: HAR §11-60.1-90)
2. This permit, or a copy thereof, shall be maintained at or near the source and shall be made available for inspection upon request. The permit shall not be willfully defaced, altered, forged, counterfeited, or falsified.  
  
(Auth.: HAR §11-60.1-6; SIP §11-60-11)<sup>2</sup>
3. This permit is not transferable whether by operation of law or otherwise, from person to person, from place to place, or from one piece of equipment to another without the approval of the Department of Health, except as provided in HAR, Section 11-60.1-91.  
  
(Auth.: HAR §11-60.1-7; SIP §11-60-9)<sup>2</sup>
4. A request for transfer from person to person shall be made on forms furnished by the Department of Health.  
  
(Auth.: HAR §11-60.1-7)
5. In the event of any changes in control or ownership of the facilities to be constructed or modified, this permit shall be binding on all subsequent owners and operators. The permittee shall notify the succeeding owner and operator of the existence of this permit and its conditions by letter, copies of which will be forwarded to the Department of Health and the U.S. Environmental Protection Agency (EPA), Region 9.  
  
(Auth.: HAR §11-60.1-5, §11-60.1-7, §11-60.1-94)
6. The facility covered by this permit shall be constructed and operated in accordance with the application, and any information submitted as part of the application, for the Covered Source Permit. There shall be no deviation unless additional or revised plans are submitted to and approved by the Department of Health, and the permit is amended to allow such deviation.  
  
(Auth.: HAR §11-60.1-2, §11-60.1-4, §11-60.1-82, §11-60.1-84, §11-60.1-90)
7. This permit (a) does not release the permittee from compliance with other applicable statutes of the State of Hawaii, or with applicable local laws, regulations, or ordinances, and

(b) shall not constitute, nor be construed to be an approval of the design of the covered source.

(Auth.: HAR §11-60.1-5, §11-60.1-82)

8. The permittee shall comply with all the terms and conditions of this permit. Any permit noncompliance constitutes a violation of HAR, Chapter 11-60.1 and the Clean Air Act and is grounds for enforcement action; for permit termination, suspension, reopening, or amendment; or for denial of a permit renewal application.

(Auth.: HAR §11-60.1-3, §11-60.1-10, §11-60.1-19, §11-60.1-90)

9. If any term or condition of this permit becomes invalid as a result of a challenge to a portion of this permit, the other terms and conditions of this permit shall not be affected and shall remain valid.

(Auth.: HAR §11-60.1-90)

10. The permittee shall not use as a defense in an enforcement action that it would have been necessary to halt or reduce the permitted activity to maintain compliance with the terms and conditions of this permit.

(Auth.: HAR §11-60.1-90)

11. This permit may be terminated, suspended, reopened, or amended for cause pursuant to HAR, Sections, 11-60.1-10 and 11-60.1-98, and Hawaii Revised Statutes (HRS), Chapter 342B-27, after affording the permittee an opportunity for a hearing in accordance with HRS, Chapter 91.

(Auth.: HAR §11-60.1-3, §11-60.1-10, §11-60.1-90, §11-60.1-98)

12. The filing of a request by the permittee for the termination, suspension, reopening, or amendment of this permit, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

(Auth.: HAR §11-60.1-90)

13. This permit does not convey any property rights of any sort, or any exclusive privilege.

(Auth.: HAR §11-60.1-90)

14. The permittee shall notify the Department of Health and U.S. EPA Region 9 in writing of the following dates:

- a. The **anticipated date of initial start-up** for each emission unit of a new source or significant modification not more than sixty (60) days or less than thirty (30) days prior to such date;
- b. The **actual date of construction commencement** within fifteen (15) days after such date; and
- c. The **actual date of start-up** within fifteen (15) days after such date.

(Auth.: HAR §11-60.1-90)

15. The permittee shall furnish, in a timely manner, any information or records requested in writing by the Department of Health to determine whether cause exists for terminating, suspending, reopening, or amending this permit, or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Department of Health copies of records required to be kept by the permittee. For information claimed to be confidential, the Director of Health may require the permittee to furnish such records not only to the Department of Health but also directly to the U.S. EPA Region 9 along with a claim of confidentiality.

(Auth.: HAR §11-60.1-14, §11-60.1-90)

16. The permittee shall notify the Department of Health in writing, of the **intent to shut down air pollution control equipment for necessary scheduled maintenance** at least twenty-four (24) hours prior to the planned shutdown. The submittal of this notice shall not be a defense to an enforcement action. The notice shall include the following:
  - a. Identification of the specific equipment to be taken out of service, as well as its location and permit number;
  - b. The expected length of time that the air pollution control equipment will be out of service;
  - c. The nature and quantity of emissions of air pollutants likely to be emitted during the shutdown period;
  - d. Measures such as the use of off-shift labor and equipment that will be taken to minimize the length of the shutdown period; and
  - e. The reasons why it would be impossible or impractical to shut down the source operation during the maintenance period.

(Auth.: HAR §11-60.1-15; SIP §11-60-16)<sup>2</sup>

17. **Except for emergencies which result in noncompliance with any technology-based emission limitation in accordance with HAR, Section 11-60.1-16.5, in the event any emission unit, air pollution control equipment, or related equipment malfunctions or breaks down in such a manner as to cause the emission of air pollutants in violation of HAR, Chapter 11-60.1 or this permit, the permittee shall immediately notify the Department of Health of the malfunction or breakdown, unless the protection of personnel or public health or safety demands immediate attention to the malfunction or breakdown and makes such notification infeasible. In the latter case, the notice shall be provided as**

soon as practicable. Within five (5) working days of this initial notification, the permittee shall also submit, in writing, the following information:

- a. Identification of each affected emission point and each emission limit exceeded;
- b. Magnitude of each excess emission;
- c. Time and duration of each excess emission;
- d. Identity of the process or control equipment causing the excess emission;
- e. Cause and nature of each excess emission;
- f. Description of the steps taken to remedy the situation, prevent a recurrence, limit the excessive emissions, and assure that the malfunction or breakdown does not interfere with the attainment and maintenance of the National Ambient Air Quality Standards and state ambient air quality standards;
- g. Documentation that the equipment or process was at all times maintained and operated in a manner consistent with good practice for minimizing emissions; and
- h. A statement that the excess emissions are not part of a recurring pattern indicative of inadequate design, operation, or maintenance.

The submittal of these notices shall not be a defense to an enforcement action.

(Auth.: HAR §11-60.1-16; SIP §11-60-16)<sup>2</sup>

18. The permittee may request confidential treatment of any records in accordance with HAR, Section 11-60.1-14.

(Auth.: HAR §11-60.1-14, §11-60.1-90)

19. This permit shall become invalid with respect to the authorized construction if construction is not commenced as follows:

- a. Within eighteen (18) months after the permit takes effect, is discontinued for a period of eighteen (18) months or more, or is not completed within a reasonable time.
- b. For phased construction projects, each phase shall commence construction within eighteen (18) months of the projected and approved commencement dates in the permit. This provision shall be applicable only if the projected and approved commencement dates of each construction phase are defined in Attachment II, Special Conditions, of this permit.

(Auth.: HAR §11-60.1-9, §11-60.1-90)

20. The Department of Health may extend the time periods specified in Standard Condition No. 19 upon a satisfactory showing that an extension is justified. Requests for an extension shall be submitted in writing to the Department of Health.

(Auth.: HAR §11-60.1-9, §11-60.1-90)

21. The permittee shall submit fees in accordance with HAR, Chapter 11-60.1, Subchapter 6.

(Auth.: HAR §11-60.1-90)

22. All certifications shall be in accordance with HAR, section 11-60.1-4.

(Auth.: HAR §11-60.1-4, HAR §11-60.1-90)

23. The permittee shall allow the Director of Health, the Regional Administrator for the U.S. EPA and/or an authorized representative, upon presentation of credentials or other documents required by law:

- a. To enter the premises where a source is located or emission-related activity is conducted, or where records must be kept under the conditions of this permit and inspect at reasonable times all facilities, equipment, including monitoring and air pollution control equipment, practices, operations, or records covered under the terms and conditions of this permit and request copies of records or copy records required by this permit; and
- b. To sample or monitor at reasonable times substances or parameters to ensure compliance with this permit or applicable requirements of HAR, Chapter 11-60.1.

(Auth.: HAR §11-60.1-11, §11-60.1-90)

24. Within thirty (30) days of **permanent discontinuance of the construction, modification, relocation, or operation of the facility covered by this permit**, the discontinuance shall be reported in writing to the Department of Health by a responsible official of the source.

(Auth.: HAR §11-60.1-8; SIP §11-60-10)<sup>2</sup>

25. Each permit renewal application shall be submitted to the Department of Health and the U.S. EPA Region 9 no less than twelve months and no more than eighteen months prior to the permit expiration date. The director may allow a permit renewal application to be submitted no less than six months prior to the permit expiration date, if the director determines that there is reasonable justification.

(Auth.: HAR §11-60.1-101, 40 CFR §70.5(a)(1)(iii))<sup>1</sup>

26. The terms and conditions included in this permit, including any provision designed to limit a source's potential to emit, are federally enforceable unless such terms, conditions, or requirements are specifically designated as not federally enforceable.

(Auth.: HAR §11-60.1-93)

27. The compliance plan and compliance certification submittal requirements shall be in accordance with HAR, Sections 11-60.1-85 and 11-60.1-86. As specified in HAR, Section 11-60.1-86, the compliance certification shall be submitted to the Department of

Health and the U.S. EPA Region 9 once per year, or more frequently as set by any applicable requirement.

(Auth.: HAR §11-60.1-90)

28. **Any document (including reports) required to be submitted by this permit shall be certified as being true, accurate, and complete by a responsible official in accordance with HAR, Sections 11-60.1-1 and 11-60.1-4, and shall be mailed to the following address:**

**Clean Air Branch  
Environmental Management Division  
Hawaii Department of Health  
P.O. Box 3378  
Honolulu, HI 96801-3378**

**Upon request and as required by this permit, all correspondence to the State of Hawaii Department of Health associated with this Covered Source Permit shall have duplicate copies forwarded to:**

**Chief  
Permits Office, (Attention: Air-3)  
Air Division  
U.S. Environmental Protection Agency  
Region 9  
75 Hawthorne Street  
San Francisco, CA 94105**

(Auth.: HAR §11-60.1-4, §11-60.1-90)

29. To determine compliance with submittal deadlines for time-sensitive documents, the postmark date of the document shall be used. If the document was hand-delivered, the date received ("stamped") at the Clean Air Branch shall be used to determine the submittal date.

(Auth.: HAR §11-60.1-5, §11-60.1-90)

---

<sup>1</sup>The citations to the Code of Federal Regulations (CFR) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the CFR. Due to the integration of the preconstruction and operating permit requirements, permit conditions may incorporate more stringent requirements than those set forth in the CFR.

<sup>2</sup>The citations to the State Implementation Plan (SIP) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the SIP.

**ATTACHMENT II: SPECIAL CONDITIONS  
COVERED SOURCE PERMIT NO. 0424-01-C**

**Issuance Date:**

**Expiration Date:**

In addition to the standard conditions of the Covered Source Permit, the following special conditions shall apply to the permitted facility:

**Section A. Equipment Description**

1. This permit encompasses one (1) 2.0 MW Allison Gas Combustion Turbine (CT) Generator, model no. 501-KA, JP-5 fuel-fired, I.D. No. TG-897.

(Auth.: HAR §11-60.1-3)

2. The permittee shall permanently attach an identification tag or name plate on the CT, which identifies the model no., serial no., and manufacturer. The identification tag or name plate shall be permanently attached to the equipment in a conspicuous location.

(Auth.: HAR §11-60.1-5)

**Section B. Applicable Federal Regulations**

1. The CT is subject to the provisions of the following federal regulations:
  - a. 40 CFR Part 60, Standards of Performance for New Stationary Sources, Subpart A-General Provisions; and
  - b. 40 CFR Part 60, Standards of Performance for New Stationary Sources, Subpart GG-Standards of Performance for Stationary Gas Turbines.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161, 40 CFR 60)<sup>1</sup>

2. The permittee shall comply with all applicable provisions of these standards, including all emission limits, notification, testing, monitoring, and reporting requirements. The major requirements of these standards are detailed in the special conditions of this permit.

(Auth.: HAR §11-60.1-3, §11-60.1-90, §11-60.1-161, 40 CFR 60)<sup>1</sup>

**Section C. Operational and Emission Limitations**

1. "Start-up" and "Shut-down"
  - a. A "Start-up" sequence shall be from the time the combustion turbine (CT) is initially brought up to between 25% and 35% load.

- b. A "Shut-down" sequence shall be considered from the time when the CT is below 25% load, until fuel use at the CT ceases.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-90)

## 2. Fuel Specifications and Usage

- a. The CT shall be fired only on JP-5 jet propulsion (aviation) fuel with a maximum sulfur content not to exceed 0.2 percent by weight.
- b. The total fuel consumption for the CT shall not exceed 329,000 gallons in any rolling twelve-month (12-month) period.

(Auth.: HAR §11-60.1-3, §11-60.1-90)

## 3. Opacity Limits

The CT shall not exhibit visible emissions of twenty (20) percent opacity or greater, for any six (6) minute averaging period, except as follows: during "Start-up," "Shut-down," or equipment breakdown, the CT may exhibit visible emissions greater than twenty (20) percent opacity but not exceeding sixty (60) percent opacity for a period aggregating not more than six (6) minutes in any sixty (60) minute period.

(Auth.: HAR §11-60.1-3, HAR §11-60.1-5, §11-60.1-32, §11-60.1-90, SIP §11-60-24)<sup>1,2</sup>

- 4. The CT is categorized and has been evaluated as an emergency/standby unit and shall be operated only in the event of a power outage and during periods of testing and maintenance.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-90, and 40 CFR 60 Subpart GG)

## 5. Alternate Operating Scenarios

- a. Terms and conditions for reasonably anticipated operating scenarios identified by the permittee in the covered source permit application and approved by the Department of Health are as follows:

- i. The permittee may replace the CT with a temporary replacement unit if any repair work reasonably warrants the removal (i.e., equipment failure, engine overhaul, or any major equipment problems requiring maintenance for efficient operation) of the CT from its site and the following provisions are adhered to:

- A) Written notification identifying the reasons for the replacement from the site of operation is submitted to and approved by the Department of Health *prior* to the exchange;
- B) The CT is replaced with another unit with equal or less emissions;

- C) The temporary replacement unit complies with all applicable conditions including all air pollution control equipment requirements, operating restrictions and emission limits; and
  - D) The CT shall be repaired and returned to service at the same location in a timely manner; and *Prior* to the installation of the replacement CT, the permittee shall submit to the Department of Health written documentation on the removal and return dates; and on the make, size, model and serial numbers for both the temporary replacement unit and installed unit.
- ii. The permittee shall contemporaneously with making a change from one operating scenario to another, record in a log at the permitted facility the scenario under which it is operating and, if required by any applicable requirement or the Department of Health, submit written notification to the Department of Health.
  - iii. The terms and conditions under each alternative operating scenario shall meet all applicable requirements including conditions of this permit.

(Auth.: HAR §11-60.1-3, §11-60.1-90)

**Section D. Monitoring and Recordkeeping Requirements**

1. Fuel Monitoring

The permittee shall at its own expense operate and maintain a non-resetting fuel meter on the combustion turbine (CT) for the permanent recording of the total fuel usage. The following information shall be recorded for the total fuel consumption by the CT:

- a. Date of the meter readings;
- b. Beginning and ending meter readings for each month;
- c. Total fuel consumption for each month; and
- d. Total fuel consumption on a rolling twelve (12) month basis.

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90)

2. Total Fuel Usage and Specification

- a. Fuel delivery receipts shall be maintained, showing the supplier, fuel type, sulfur content (percent by weight), date of delivery, and amount (in gallons) of fuel delivered to the facility for subsequent transfer to the CT covered under this permit. Fuel sulfur content may be demonstrated by providing the supplier's fuel specification sheet, if derived by ASTM D 2880 for the type of fuel purchased and received; and

- b. Any daily period(s) during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.2% by weight, shall be recorded.

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90)

### 3. Visible Emissions (V.E.)

- a. Except in those months where V.E. observations are conducted by a certified reader for the annual observation of the combustion turbine (CT), the permittee shall conduct **monthly** (*calendar month*) V.E. observations for the CT in accordance with 40 CFR Part 60, Appendix A, Method 9 or by use of a Ringelmann Chart as provided. For each monthly observation, the permittee shall record two (2) consecutive observations, each six (6) minutes in duration with readings taken at fifteen (15) second intervals. Records shall be completed and maintained in accordance with the *Visible Emissions Form Requirements*.
- b. The permittee shall conduct **annual** (*calendar year*) V.E. observations for the CT by a certified reader in accordance with 40 CFR Part 60, Appendix A, Method 9. For the annual observation, the permittee shall record two (2) consecutive observations, each six (6) minutes in duration with readings taken at fifteen (15) second intervals.
- c. Upon written request and justification by the permittee, the Department of Health may waive the requirement for a specific annual V.E. observation. The waiver request is to be submitted prior to the required annual V.E. observation and must include documentation justifying such action. Documentation should include, but is not limited to, the results of the prior V.E. observations indicating compliance by a wide margin, documentation of continuing compliance, and further that operations of the source have not changed since the previous annual V.E. observation.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-90)

### 4. Inspection, Maintenance, and Repair Log

The permittee shall maintain records on inspections, maintenance, and any repair work conducted on the CT. At a minimum, these records shall include: the date of the inspection; name and title of the inspector; a short description of the action and/or any such repair work; and a description of the part(s) inspected or repaired.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-90)

### 5. Records

All records, including support information, shall be true, accurate, maintained for **at least five (5) years** following the date of the monitoring sample, measurement, test, report, or application. Support information includes all maintenance, inspection, and repair records,

and copies of all reports required by this permit. These records shall be in a permanent form suitable for inspection and made available to the Department of Health or their representative upon request.

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90)

6. Possible Continuous Emission Monitors or Additional Stack Testing

The Department of Health may at any time require the permittee to install, operate, and maintain continuous emission monitors, or conduct additional stack/fuel testing, or ambient air monitoring.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-90)

**Section E. Notification and Reporting Requirements**

1. Notification and reporting pertaining to the following events shall be done in accordance with Attachment I, Standard Condition Nos. 17 and 25, respectively:

- a. *Emissions of air pollutants in violation of HAR, Chapter 11-60.1 or this permit (excluding technology-based emission exceedances due to emergencies); and*
- b. *Permanent discontinuance of construction, modification, relocation, or operation of the facility covered by this permit.*

(Auth.: HAR §11-60.1-8, §11-60.1-15, §11-60.1-16, §11-60.1-90; 40 CFR §60.48c(a); SIP §11-60-10, §11-60-16)<sup>1,2</sup>

2. Deviations

The permittee shall report (in writing) **within five (5) working days** any deviations from the permit requirements, including those attributable to upset conditions, the probable cause of such deviations and any corrective actions or preventive measures taken. Corrective actions may include a requirement for additional stack testing, or more frequent monitoring, or the implementation of a corrective action plan.

(Auth.: HAR §11-60.1-3, §11-60.1-15, §11-60.1-16, §11-60.1-90)

3. Monitoring Reports

The permittee shall submit, **semi-annually**, the attached *Monitoring Report Form: "Fuel Consumption and Certification,"* and *Monitoring Report Form: "Visible Emissions"* to the Department of Health. These reports shall be submitted **within sixty (60) days after the**

end of each semi-annual calendar period (January 1 to June 30 and July 1 to December 31), and shall be signed and dated by a responsible official.

(Auth.: HAR §11-60.1-3, §11-60.1-90)

#### 4. Compliance Certification

- a. During the permit term, the permittee shall submit at least **annually** to the Department of Health and U.S. EPA Region 9, the Compliance Certification form pursuant to HAR, Subsection 11-60.1-86. The permittee shall indicate whether or not compliance is being met with each term or condition of this permit. The compliance certification shall include, at a minimum, the following information:
  - i. The identification of each term or condition of the permit that is the basis of the certification;
  - ii. The compliance status;
  - iii. Whether compliance was continuous or intermittent;
  - iv. The methods used for determining the compliance status of the source currently and over the reporting period;
  - v. Any additional information indicating the source's compliance status with any applicable enhanced monitoring and compliance certification including the requirements of Section 114(a)(3) of the Clean Air Act or any applicable monitoring and analysis provisions of Section 504(b) of the Clean Air Act; and
  - vi. Any additional information as required by the Department of Health including information to determine compliance.
- b. The compliance certification shall be submitted **within ninety (90) days after** the end of each calendar year, and shall be signed and dated by a responsible official.
- c. Upon written request of the permittee, the deadline for submitting the compliance certification may be extended, if the Department of Health determines that reasonable justification exists for the extension.

(Auth.: HAR §11-60.1-4, §11-60.1-86, §11-60.1-90)

#### 5. Annual Emissions

- a. As required by *Attachment IV: Annual Emissions Reporting Requirements* and in conjunction with the requirements of *Attachment III: Annual Fee Requirements*, the permittee shall report **annually** the total tons/yr emitted of each regulated air pollutant, including hazardous air pollutants. The reporting of annual emissions is due **within sixty (60) days following the end of each calendar year**. The completion and submittal of *Annual Emissions Report Form: "Fuel Consumption,"* shall satisfy the annual emissions reporting requirement for fuel usage.

- b. Upon the written request of the permittee, the deadline for reporting of annual emissions may be extended, if the Department of Health determines that reasonable justification exists for the extension.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-11, §11-60.1-90)

**Section F. Agency Notification**

1. Any document (including reports) required to be submitted by this permit shall be done in accordance with Attachment I, Standard Condition 29.

(Auth.: HAR §11-60.1-4, §11-60.1-90)

---

<sup>1</sup> The citation to the Code of Federal Regulations (CFR) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the CFR. Due to the integration of the preconstruction and operating permit requirements, permit conditions may incorporate more stringent requirements than those set forth in the CFR.

<sup>2</sup> The citation to the State Implementation Plan (SIP) identified under a particular condition, indicate that the permit condition complies with the specified provision(s) of the SIP.

**ATTACHMENT II - INSIG  
SPECIAL CONDITIONS - INSIGNIFICANT ACTIVITIES  
COVERED SOURCE PERMIT NO. 0424-01-C**

**[Issuance Date]**

**[Expiration Date]**

In addition to the Standard Conditions of the Covered Source Permit, the following Special Conditions shall apply to the permitted facility:

**Section A. Equipment Description**

This attachment encompasses insignificant activities listed in HAR, §11-60.1-82(f) and (g) for which provisions of this permit and HAR, Subchapter 2, General Prohibitions, apply.

(Auth.: HAR §11-60.1-3)

**Section B. Operational Limitations**

1. The permittee shall take measures to operate applicable insignificant activities in accordance with the provisions of HAR, Subchapter 2 for visible emissions, fugitive dust, incineration, process industries, sulfur oxides from fuel combustion, storage of volatile organic compounds, volatile organic compound water separation, pump and compressor requirements, and waste gas disposal.

(Auth.: HAR §11-60.1-3, §11-60.1-82, §11-60.1-90)

2. The Department of Health may at any time require the permittee to further abate emissions if an inspection indicates poor or insufficient controls.

(Auth.: HAR §11-60.1-3, §11-60.1-5, §11-60.1-82, §11-60.1-90)

**Section C. Monitoring and Recordkeeping Requirements**

1. The Department of Health reserves the right to require monitoring, recordkeeping, or testing of any insignificant activity to determine compliance with the applicable requirements.

(Auth.: HAR §11-60.1-3, §11-60.1-90)

2. All records shall be maintained for at least five (5) years from the date of any required monitoring, recordkeeping, testing, or reporting. These records shall be true, accurate, and maintained in a permanent form suitable for inspection and made available to the Department of Health or its authorized representative upon request.

(Auth.: HAR §11-60.1-3, §11-60.1-11, §11-60.1-90)

**Section D. Notification and Reporting**

Compliance Certification

During the permit term, the permittee shall submit at least **annually** to the Department of Health and U.S. EPA Region 9, the attached *Compliance Certification Form* pursuant to HAR, Subsection 11-60.1-86. The permittee shall indicate whether or not compliance is being met with each term or condition of this permit. The compliance certification shall include, at a minimum, the following information:

1. The identification of each term or condition of the permit that is the basis of the certification;
2. The compliance status;
3. Whether compliance was continuous or intermittent;
4. The methods used for determining the compliance status of the source currently and over the reporting period;
5. Any additional information indicating the source's compliance status with any applicable enhanced monitoring and compliance certification including the requirements of Section 114(a)(3) of the Clean Air Act or any applicable monitoring and analysis provisions of Section 504(b) of the Clean Air Act; and
6. Any additional information as required by the Department of Health including information to determine compliance.

The compliance certification shall be submitted **within ninety (90) days** after the end of each calendar year, and shall be signed and dated by a responsible official.

Upon written request of the permittee, the deadline for submitting the compliance certification may be extended, if the Department of Health determines that reasonable justification exists for the extension.

In lieu of addressing each emission unit as specified in *Compliance Certification Form*, the permittee may address insignificant activities as a single unit provided compliance is met with all applicable requirements. If compliance is not totally attained, the permittee shall identify the specific insignificant activity and provide the details associated with the noncompliance.

(Auth.: HAR §11-60.1-4, §11-60.1-86, §11-60.1-90)

CSP No. 0424-01-C  
Attachment II - INSIG  
Page 3 of 3  
Issuance Date:  
Expiration Date:

**PROPOSED**

**Section E. Agency Notification**

Any document (including reports) required to be submitted by this Covered Source Permit shall be done in accordance with Attachment I, Standard Condition No. 28.

(Auth.: HAR §11-60.1-4, §11-60.1-90)

## PROPOSED

### ATTACHMENT III: ANNUAL FEE REQUIREMENTS COVERED SOURCE PERMIT NO. 0424-01-C

**Issuance Date:**

**Expiration Date:**

The following requirements for the submittal of annual fees are established pursuant to Hawaii Administrative Rules (HAR), Title 11, Chapter 60.1, Air Pollution Control. Should HAR, Chapter 60.1 be revised such that the following requirements are in conflict with the provisions of HAR, Chapter 60.1, the permittee shall comply with the provisions of HAR, Chapter 60.1.

1. Annual fees shall be paid in full:
  - a. **Within sixty (60) days** after the end of each calendar year; and
  - b. **Within thirty (30) days** after the permanent discontinuance of the covered source.
2. The annual fees shall be determined and submitted in accordance with Hawaii Administrative Rules, Chapter 11-60.1, Subchapter 6.
3. The annual emissions data for which the annual fees are based shall accompany the submittal of any annual fees and submitted on forms furnished by the Department of Health.
4. The annual fees and the emission data shall be mailed to:

**Clean Air Branch  
Environmental Management Division  
State of Hawaii Department of Health  
P.O. Box 3378  
Honolulu, HI 96801-3378**

**PROPOSED**

**ATTACHMENT IV: ANNUAL EMISSIONS REPORTING REQUIREMENTS  
COVERED SOURCE PERMIT NO. 0424-01-C**

**Issuance Date:**

**Expiration Date:**

In accordance with the Hawaii Administrative Rules, Title 11, Chapter 60.1, Air Pollution Control, the permittee shall report to the Department of Health the nature and amounts of emissions.

1. Complete the attached form ***Annual Emissions Report Form: Fuel Consumption***.
2. The reporting period shall be from January 1 to December 31 of each year. All reports shall be submitted to the Department of Health within **sixty (60) days** after the end of each calendar year and shall be mailed to the following address:

**Clean Air Branch  
Environmental Management Division  
State of Hawaii Department of Health  
P.O. Box 3378  
Honolulu, HI 96801-3378**

3. The permittee shall retain the information submitted, including all emission calculations. These records shall be in a permanent form suitable for inspection, retained for a minimum of five (5) years, and made available to the Department of Health upon request.
4. Any information submitted to the Department of Health without a request for confidentiality shall be considered public record.
5. In accordance with HAR, Section 11-60.1-14, the permittee may request confidential treatment of specific information by submitting a written request to the Department of Health and clearly identifying the specific information that is to be accorded confidential treatment

**PROPOSED**

**COMPLIANCE CERTIFICATION FORM  
COVERED SOURCE PERMIT NO. 0424-01-C  
PAGE 1 OF \_\_\_\_**

**Issuance Date:** \_\_\_\_\_

**Expiration Date:** \_\_\_\_\_

In accordance with the Hawaii Administrative Rules, Title 11, Chapter 60.1, Air Pollution Control, the permittee shall report to the Department of Health the following certification at least annually, or more frequently as requested by the Department.

(Make Copies of the Compliance Certification Form for Future Use)

For Period: \_\_\_\_\_ Date: \_\_\_\_\_

Company/Facility Name: \_\_\_\_\_

Responsible Official (Print): \_\_\_\_\_

Title: \_\_\_\_\_

Responsible Official (Signature): \_\_\_\_\_

I certify that I have knowledge of the facts herein set forth, that the same are true, accurate and complete to the best of my knowledge and belief, and that all information not identified by me as confidential in nature shall be treated by Department of Health as public record. I further state that I will assume responsibility for the construction, modification, or operation of the source in accordance with the Hawaii Administrative Rules, Title 11, Chapter 60.1, Air Pollution Control, and any permit issued thereof.

**PROPOSED**

**COMPLIANCE CERTIFICATION FORM  
COVERED SOURCE PERMIT NO. 0424-01-C  
(CONTINUED, PAGE 2 OF \_\_\_)**

**Issuance Date:**

**Expiration Date:**

The purpose of this form is to evaluate whether or not the facility was in compliance with the permit terms and conditions during the covered period. If there were any deviations to the permit terms and conditions during the covered period, the deviation(s) shall be certified as *intermittent compliance* for the particular permit term(s) or condition(s). Deviations include failure to monitor, record, report, or collect the minimum data required by the permit to show compliance. In the absence of any deviation, the particular permit term(s) or condition(s) may be certified as *continuous compliance*.

**Instructions:**

Please certify Sections A, B, and C below for continuous or intermittent compliance. Sections A and B are to be certified as a group of permit conditions. Section C shall be certified individually for each operational and emissions limit condition as listed in the Special Conditions section of the permit (list all applicable equipment for each condition). Any deviations shall also be listed individually and described in Section D. The facility may substitute its own generated form in verbatim for Sections C and D.

**A. Attachment I, Standard Conditions**

<u>Permit term/condition</u> All standard conditions	<u>Equipment(s)</u> All Equipment(s) listed in the permit	<u>Compliance</u> Continuous Intermittent
---	--	---

**B. Special Conditions - Monitoring, Recordkeeping, Reporting, Testing, and INSIG**

<u>Permit term/condition</u> All monitoring conditions	<u>Equipment(s)</u> All Equipment(s) listed in the permit	<u>Compliance</u> Continuous Intermittent
<u>Permit term/condition</u> All recordkeeping conditions	<u>Equipment(s)</u> All Equipment(s) listed in the permit	<u>Compliance</u> Continuous Intermittent
<u>Permit term/condition</u> All reporting conditions	<u>Equipment(s)</u> All Equipment(s) listed in the permit	<u>Compliance</u> Continuous Intermittent
<u>Permit term/condition</u> All testing conditions	<u>Equipment(s)</u> All Equipment(s) listed in the permit	<u>Compliance</u> Continuous Intermittent
<u>Permit term/condition</u> All INSIG conditions	<u>Equipment(s)</u> All Equipment(s) listed in the permit	<u>Compliance</u> Continuous Intermittent

**PROPOSED**

**COMPLIANCE CERTIFICATION FORM  
COVERED SOURCE PERMIT NO. 0424-01-C  
(CONTINUED, PAGE \_\_\_\_ OF \_\_\_\_)**

**Issuance Date:**

**Expiration Date:**

**C. Special Conditions - Operational and Emissions Limitations**

Each permit term/condition shall be identified in chronological order using attachment and section numbers (e.g., Attachment II, B.1, Attachment IIA, Special Condition No. B.1.f, etc.). Each equipment shall be identified using the description stated in Section A of the Special Conditions (e.g., unit no., model no., serial no., etc.). Check all methods (as required by permit) used to determine the compliance status of the respective permit term/condition.

<u>Permit term/condition</u>	<u>Equipment(s)</u>	<u>Method</u>	<u>Compliance</u>
		monitoring recordkeeping reporting testing none of the above	Continuous Intermittent
		monitoring recordkeeping reporting testing none of the above	Continuous Intermittent
		monitoring recordkeeping reporting testing none of the above	Continuous Intermittent
		monitoring recordkeeping reporting testing none of the above	Continuous Intermittent
		monitoring recordkeeping reporting testing none of the above	Continuous Intermittent
		monitoring recordkeeping reporting testing none of the above	Continuous Intermittent

**(Make Additional Copies if Needed)**

**COMPLIANCE CERTIFICATION FORM  
COVERED SOURCE PERMIT NO. 0424-01-C  
(CONTINUED, PAGE \_\_\_ OF \_\_\_)**

**Issuance Date:**

**Expiration Date:**

**D. Deviations**

<u>Permit Term/ Condition</u>	<u>Equipment(s) / Brief Summary of Deviation</u>	<u>Deviation Period time (am/pm) &amp; date (mo/day/yr)</u>	<u>Date of Written Deviation Report to DOH (mo/day/yr)</u>
		Beginning:  Ending:	

**(Make Additional Copies if Needed)**

**MONITORING REPORT FORM  
FUEL CONSUMPTION AND CERTIFICATION  
COVERED SOURCE PERMIT NO. 0424-01-C**

**Issuance Date:** \_\_\_\_\_

**Expiration Date:** \_\_\_\_\_

In accordance with the Hawaii Administrative Rules, Title 11, Chapter 60.1, Air Pollution Control, the permittee shall report to the Department of Health the following information, semi-annually:

(Make Copies for Future Use)

For Period: \_\_\_\_\_ Date: \_\_\_\_\_

Facility Name: \_\_\_\_\_

Equipment Location: \_\_\_\_\_

Equipment Description: \_\_\_\_\_

Equipment Capacity/Rating (specify units): \_\_\_\_\_  
(Units such as Horsepower, kilowatt, tons/hour, etc.)

Serial/ID No.: \_\_\_\_\_

Type of Fuel: \_\_\_\_\_ Maximum %Sulfur Content by Weight: \_\_\_\_\_

**I certify that I have knowledge of the facts herein set forth, that the same are true, accurate and complete to the best of my knowledge and belief, and that all information not identified by me as confidential in nature shall be treated by Department of Health as public record.**

Responsible Official (PRINT): \_\_\_\_\_

TITLE: \_\_\_\_\_

Responsible Official (Signature): \_\_\_\_\_

**1. Fuel Consumption**

MONTH	FUEL CONSUMPTION		NOTES
	MONTHLY CONSUMPTION	ROLLING 12-MONTH TOTAL	
January			
February			
March			
April			
May			
June			
July			
August			
September			
October			
November			
December			

**2. Fuel Certification**

Equipment Description	Type of Fuel Fired	Maximum % Sulfur Content by Weight

- If not already on file at the Department of Health, provide the supplier's fuel specification sheet for the type of fuel indicated in the above table. The fuel specification sheet shall indicate the % sulfur content by weight.



**VISIBLE EMISSIONS FORM REQUIREMENTS  
STATE OF HAWAII  
COVERED SOURCE PERMIT NO. 0424-01-C**

**Issuance Date:**

**Expiration Date:**

The following Visible Emissions (V.E.) Form shall be completed **monthly** (*each calendar month*) for each equipment subject to opacity limits in accordance with Method 9 or by use of a Ringelmann Chart as provided. At least **annually** (*calendar year*), V.E. observations shall be conducted for each equipment subject to opacity limits by a certified reader in accordance with Method 9. The V.E. Form shall be completed as follows:

1. Visible emissions observations shall take place during the day only and shall be compared to the Ringelmann Chart provided. The opacity shall be noted in 5 percent increments (i.e., 25%).
2. Orient the sun within a 140 degree sector to your back. Provide a source layout sketch on the V.E. Form using the symbols as shown.
3. Stand at least three (3) stack heights, but not more than a quarter mile from the stack.
4. Two (2) consecutive six (6) minute observations shall be taken at fifteen (15) second intervals for each stack/emission point.
5. The six (6) minute average opacity reading shall be calculated for each observation.
6. If possible, the observations shall be performed as follows:
  - a. Read from where the line of sight is at right angles to the wind direction.
  - b. The line of sight shall not include more than one (1) plume at a time.
  - c. Read at the point in the plume with the greatest opacity (without condensed water vapor), ideally while the plume is no wider than the stack diameter.
  - d. Read the plume at fifteen (15) second intervals only. Do not read continuously.
  - e. The equipment shall be operating at maximum permitted capacity.
7. If the equipment was shut-down for that period, briefly explain the reason for shut-down in the comment column.

The permittee shall retain the completed V.E. Forms for recordkeeping. These records shall be in a permanent form suitable for inspection, retained for a minimum of five (5) years, and be made available to the Department of Health, or their representative upon request.

Any required initial and annual performance test performed in accordance with Method 9 by a certified reader shall satisfy the respective V.E. monitoring requirement for the month the performance test is performed.

**VISIBLE EMISSIONS FORM  
STATE OF HAWAII  
COVERED SOURCE PERMIT NO. 0424-01-C**

**Issuance Date:** \_\_\_\_\_


**Expiration Date:** \_\_\_\_\_

(Make Copies for Future Use For Each Equipment)


Permit No.: 0424-01-C

Company Name: \_\_\_\_\_

Equipment and Fuel: \_\_\_\_\_



Draw North Arrow



**Site Conditions:**

Stack height above ground (ft): \_\_\_\_\_

Stack distance from observer (ft): \_\_\_\_\_

Emission color (black or white): \_\_\_\_\_

Sky conditions (% cloud cover): \_\_\_\_\_

Wind speed (mph): \_\_\_\_\_

Temperature (°F): \_\_\_\_\_

Observer Name: \_\_\_\_\_

Certified? (Yes/No): \_\_\_\_\_

Observation Date and Start Time: \_\_\_\_\_

SECONDS MINUTES	0	15	30	45	COMMENTS
1					
2					
3					
4					
5					
6					
Six (6) Minute Average Opacity Reading (%):					

Observation Date and Start Time: \_\_\_\_\_

SECONDS MINUTES	0	15	30	45	COMMENTS
1					
2					
3					
4					
5					
6					
Six (6) Minute Average Opacity Reading (%):					

**ANNUAL EMISSIONS REPORT FORM  
FUEL CONSUMPTION  
COVERED SOURCE PERMIT NO. 0424-01-C**

**Issuance Date:** \_\_\_\_\_

**Expiration Date:** \_\_\_\_\_

In accordance with the Hawaii Administrative Rules, Title 11, Chapter 60.1, Air Pollution Control, the permittee shall report to the Department of Health the following information, annually:

(Make Copies for Future Use)

For Period: \_\_\_\_\_ Date: \_\_\_\_\_

Facility Name: \_\_\_\_\_

Equipment Location: \_\_\_\_\_

Equipment Description: \_\_\_\_\_

Equipment Capacity/Rating (specify units): \_\_\_\_\_  
(Units such as Horsepower, kilowatt, tons/hour, etc.)

Serial/ID No.: \_\_\_\_\_

Type of Fuel: \_\_\_\_\_ Maximum %Sulfur Content by Weight: \_\_\_\_\_

**I certify that I have knowledge of the facts herein set forth, that the same are true, accurate and complete to the best of my knowledge and belief, and that all information not identified by me as confidential in nature shall be treated by Department of Health as public record.**

Responsible Official (PRINT): \_\_\_\_\_

TITLE: \_\_\_\_\_

Responsible Official (Signature): \_\_\_\_\_

**1. Fuel Consumption**

Calendar Year	Total Fuel Consumption