

February 7, 2011

Ms. Deborah Jordan
Director, Air Management Division
United States Environmental Protection Agency
75 Hawthorne Street
San Francisco, CA 94105

Re: Revision of Synthetic Minor Permit for Facility A3245,
GWF Power Systems Site 3

Dear Ms. Jordan:

The purpose of this letter is to issue a revision of the synthetic minor operating permit for the above facility.

In response to the facility's request, the permit has been modified for increasing the heat input of the Fluidized Bed Combustor (S-1) from 223 MMBtu/hr to 245 MMBtu/hr, for accommodating composition changes in petroleum coke, and for reflecting administrative and operational changes. Permitted emission limits will not change.

The revision is effective as of the date of this letter. The synthetic minor permit evaluation and conditions are attached.

The District will also notify the California Air Resources Board and the facility in writing of these permit actions.

If you have any questions regarding this matter, please call Jim Karas, Air Quality Engineering Manager, at (415) 749-4742.

Very truly yours,

Jack P. Broadbent
Executive Officer/APCO

Signed by Brian F. Bateman
by Engineering Division

ALAMEDA COUNTY

Tom Bates
(Vice-Chair)
Scott Haggerty
Jennifer Hosterman
Nate Miley

CONTRA COSTA COUNTY

John Gioia
(Secretary)
David Hudson
Mark Ross
Gayle B. Uilkema

MARIN COUNTY

Harold Brown, Jr.

NAPA COUNTY

Brad Wagenknecht
(Chair)

SAN FRANCISCO COUNTY

Chris Daly
Eric Mar
Gavin Newsom

SAN MATEO COUNTY

Carol Klatt
Carole Groom

SANTA CLARA COUNTY

Susan Garner
Ash Kalra
Liz Kniss
Ken Yeager

SOLANO COUNTY

Jim Spering

SONOMA COUNTY

Shirlee Zane
Pamela Torliatt

Jack P. Broadbent
EXECUTIVE OFFICER/APCO

Enclosure

H:\engineering\titlev\synmin\letters\A3245revision-15603

