

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

PERMIT TO OPERATE

Permit No.
A/N 556617

Equipment Description:

BULK GASOLINE LOADING RACK NO. 1 CONSISTING OF THE FOLLOWING:

1. FOUR 4" BOTTOM LOADING ARMS WITH BREAKAWAY COUPLERS AND DRY BREAK CONNECTIONS.
2. TWO 4" VAPOR RETURN CONNECTIONS.
3. TEN TOTALIZING FLOW METERS.
4. ELEVEN GASOLINE PUMPS, EACH INLINE WITH MECHANICAL SEAL AND 100 HP MOTOR (COMMON TO LOADING RACKS 1 THROUGH 6).
5. SUMP TANK T-903, UNDERGROUND, 4,000 GALLON CAPACITY, 8' DIA. X 31' L. (COMMON TO LOADING RACKS 1 THROUGH 8).
6. TANK TK-120, UNDERGROUND, 7'-9" DIA. X 14'-8" L., 5,000 GALLON CAPACITY (COMMON TO LOADING RACKS 1 THROUGH 8).
7. THREE ETHANOL TRANSFER PUMPS, EACH WITH 25 HP MOTOR AND TANDEM MECHANICAL SEALS VENTED TO VAPOR RECOVERY SYSTEM OR TO STANDBY AIR POLLUTION CONTROL SYSTEM (COMMON TO LOADING RACKS 1 THROUGH 6).
8. SIX ADDITIVE PUMPS, 2 HP MAGNETIC DRIVE GEAR PUMPS (COMMON TO LOADING RACKS 1 THROUGH 6).

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 5,843,411 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[H & S Code §41954]

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

- 4) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 7,000,000 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[RULE 462, RULE 1303(b)(2) - OFFSETS]

- 5) DISPLACED VAPORS FROM THE TRUCK LOADING OPERATION SHALL BE VENTED TO A VAPOR RECOVERY SYSTEM (VRU NO. 1, VRU NO. 2, AND/OR STANDBY FLARE). THE VAPOR RECOVERY SYSTEM SHALL BE CALIFORNIA AIR RESOURCES BOARD (CARB) CERTIFIED. IF THE VAPOR RECOVERY SYSTEM DOES NOT REQUIRE CARB CERTIFICATION PER CALIFORNIA HEALTH AND SAFETY CODE 41954, IT SHALL BE APPROVED BY AQMD. THE VAPOR RECOVERY SYSTEM SHALL BE CERTIFIED TO REDUCE VOC EMISSIONS FROM LOADING OPERATIONS TO 0.08 POUNDS OR LESS PER 1000 GALLONS LOADED.
[RULE 462, 40CFR 63 SUBPART R]

- 6) THIS EQUIPMENT SHALL NOT BE USED TO LOAD OR UNLOAD ORGANIC LIQUIDS INTO ANY TRANSPORT VESSEL UNLESS THE VESSEL HAS A VALID CERTIFICATION OF VAPOR INTEGRITY AS DEFINED BY THE APPLICABLE AIR RESOURCES BOARD CERTIFICATION AND TEST PROCEDURES, PURSUANT TO CALIFORNIA HEALTH AND SAFETY CODE SECTION 41962(g).
[RULE 462, 40CFR 63 SUBPART R]

- 7) THE OPERATOR SHALL PERFORM AN INSPECTION OF THE VAPOR COLLECTION SYSTEM, THE VAPOR CONTROL SYSTEM, AND THE COMPONENTS AND FITTINGS OF THIS EQUIPMENT FOR VAPOR AND/OR LIQUID LEAKS. THE OPERATOR SHALL USE THE MEASURES FOR INSPECTION, REPORTING, MAINTENANCE, AND LEAK CRITERIA EQUIVALENT TO THOSE SPECIFIED IN AQMD RULE 1173 PER SETTLEMENT AGREEMENT BETWEEN AQMD AND ARCO PRODUCTS COMPANY AND ITS SUCCESSORS, DATED MARCH 15, 1991.
[RULE 462, 40CFR 63 SUBPART R, SETTLEMENT AGREEMENT]

- 8) THE OPERATOR SHALL RECORD ALL LEAKS, REPAIRS, AND REINSPECTIONS AS REQUIRED BY THE CONDITIONS OF THIS PERMIT, AND SUBMIT THOSE AS QUARTERLY OR ANNUAL INSPECTION REPORTS TO THE EXECUTIVE OFFICER, NO LATER THAN 30 DAYS AFTER THE END OF EACH QUARTER, OR 60 DAYS AFTER THE END OF EACH CALENDAR YEAR, RESPECTIVELY.
[RULE 462]

- 9) THE RECORDS REQUIRED BY CONDITIONS OF THIS PERMIT INCLUDING CARGO TANK INTEGRITY TESTS, PERIODIC LEAK INSPECTIONS, COMPONENT IDENTIFICATION, TYPE, SERVICE, LOCATION, LEAK RATE, DATE AND TIME OF INSPECTION AND REPAIR, REINSPECTIONS, AND MAINTENANCE, SHALL BE RETAINED AT THE FACILITY AND SHALL BE MADE AVAILABLE TO ANY DISTRICT REPRESENTATIVE UPON REQUEST.
[RULE 462, 40CFR 63 SUBPART R]

Periodic Monitoring: NONE

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

Emissions and Requirements:

- 10) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

HAP/TOC: 10 MG/LITER OF GASOLINE LOADED, 40CFR 63 SUBPART R
VOC: 0.08 LB/1000 GALLONS OF ORGANIC LIQUID LOADED, RULE 462
VOC: RULE 1173 (PER SETTLEMENT AGREEMENT 3/15/1991)

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

PERMIT TO OPERATE

Permit No.
A/N 556618

Equipment Description:

BULK GASOLINE LOADING RACK NO. 2 CONSISTING OF THE FOLLOWING:

1. FOUR 4" BOTTOM LOADING ARMS WITH BREAKAWAY COUPLERS AND DRY BREAK CONNECTIONS.
2. TWO 4" VAPOR RETURN CONNECTIONS.
3. TEN TOTALIZING FLOW METERS.
4. ELEVEN GASOLINE PUMPS, EACH INLINE WITH MECHANICAL SEAL AND 100 HP MOTOR (COMMON TO LOADING RACKS 1 THROUGH 6).
5. SUMP TANK T-903, UNDERGROUND, 4,000 GALLON CAPACITY, 8' DIA. X 31' L. (COMMON TO LOADING RACKS 1 THROUGH 8).
6. TANK TK-120, UNDERGROUND, 7'-9" DIA. X 14'-8" L., 5,000 GALLON CAPACITY (COMMON TO LOADING RACKS 1 THROUGH 8).
7. THREE ETHANOL TRANSFER PUMPS, EACH WITH 25 HP MOTOR AND TANDEM MECHANICAL SEALS VENTED TO VAPOR RECOVERY SYSTEM OR TO STANDBY AIR POLLUTION CONTROL SYSTEM (COMMON TO LOADING RACKS 1 THROUGH 6).
8. SIX ADDITIVE PUMPS, 2 HP MAGNETIC DRIVE GEAR PUMPS (COMMON TO LOADING RACKS 1 THROUGH 6).

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 5,843,411 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[H & S Code §41954]

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

- 4) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 7,000,000 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[RULE 462, RULE 1303(b)(2) - OFFSETS]
- 5) DISPLACED VAPORS FROM THE TRUCK LOADING OPERATION SHALL BE VENTED TO A VAPOR RECOVERY SYSTEM (VRU NO. 1, VRU NO. 2, AND/OR STANDBY FLARE). THE VAPOR RECOVERY SYSTEM SHALL BE CALIFORNIA AIR RESOURCES BOARD (CARB) CERTIFIED. IF THE VAPOR RECOVERY SYSTEM DOES NOT REQUIRE CARB CERTIFICATION PER CALIFORNIA HEALTH AND SAFETY CODE 41954, IT SHALL BE APPROVED BY AQMD. THE VAPOR RECOVERY SYSTEM SHALL BE CERTIFIED TO REDUCE VOC EMISSIONS FROM LOADING OPERATIONS TO 0.08 POUNDS OR LESS PER 1000 GALLONS LOADED.
[RULE 462, 40CFR 63 SUBPART R]
- 6) THIS EQUIPMENT SHALL NOT BE USED TO LOAD OR UNLOAD ORGANIC LIQUIDS INTO ANY TRANSPORT VESSEL UNLESS THE VESSEL HAS A VALID CERTIFICATION OF VAPOR INTEGRITY AS DEFINED BY THE APPLICABLE AIR RESOURCES BOARD CERTIFICATION AND TEST PROCEDURES, PURSUANT TO CALIFORNIA HEALTH AND SAFETY CODE SECTION 41962(g).
[RULE 462, 40CFR 63 SUBPART R]
- 7) THE OPERATOR SHALL PERFORM AN INSPECTION OF THE VAPOR COLLECTION SYSTEM, THE VAPOR CONTROL SYSTEM, AND THE COMPONENTS AND FITTINGS OF THIS EQUIPMENT FOR VAPOR AND/OR LIQUID LEAKS. THE OPERATOR SHALL USE THE MEASURES FOR INSPECTION, REPORTING, MAINTENANCE, AND LEAK CRITERIA EQUIVALENT TO THOSE SPECIFIED IN AQMD RULE 1173 PER SETTLEMENT AGREEMENT BETWEEN AQMD AND ARCO PRODUCTS COMPANY AND ITS SUCCESSORS, DATED MARCH 15, 1991.
[RULE 462, 40CFR 63 SUBPART R, SETTLEMENT AGREEMENT]
- 8) THE OPERATOR SHALL RECORD ALL LEAKS, REPAIRS, AND REINSPECTIONS AS REQUIRED BY THE CONDITIONS OF THIS PERMIT, AND SUBMIT THOSE AS QUARTERLY OR ANNUAL INSPECTION REPORTS TO THE EXECUTIVE OFFICER, NO LATER THAN 30 DAYS AFTER THE END OF EACH QUARTER, OR 60 DAYS AFTER THE END OF EACH CALENDAR YEAR, RESPECTIVELY.
[RULE 462]
- 9) THE RECORDS REQUIRED BY CONDITIONS OF THIS PERMIT INCLUDING CARGO TANK INTEGRITY TESTS, PERIODIC LEAK INSPECTIONS, COMPONENT IDENTIFICATION, TYPE, SERVICE, LOCATION, LEAK RATE, DATE AND TIME OF INSPECTION AND REPAIR, REINSPECTIONS, AND MAINTENANCE, SHALL BE RETAINED AT THE FACILITY AND SHALL BE MADE AVAILABLE TO ANY DISTRICT REPRESENTATIVE UPON REQUEST.
[RULE 462, 40CFR 63 SUBPART R]

Periodic Monitoring: NONE

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

Emissions and Requirements:

- 10) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

HAP/TOC: 10 MG/LITER OF GASOLINE LOADED, 40CFR 63 SUBPART R
VOC: 0.08 LB/1000 GALLONS OF ORGANIC LIQUID LOADED, RULE 462
VOC: RULE 1173 (PER SETTLEMENT AGREEMENT 3/15/1991)

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

PERMIT TO OPERATE

Permit No.
A/N 556619

Equipment Description:

BULK GASOLINE LOADING RACK NO. 3 CONSISTING OF THE FOLLOWING:

1. FOUR 4" BOTTOM LOADING ARMS WITH BREAKAWAY COUPLERS AND DRY BREAK CONNECTIONS.
2. TWO 4" VAPOR RETURN CONNECTIONS.
3. TEN TOTALIZING FLOW METERS.
4. ELEVEN GASOLINE PUMPS, EACH INLINE WITH MECHANICAL SEAL AND 100 HP MOTOR (COMMON TO LOADING RACKS 1 THROUGH 6).
5. SUMP TANK T-903, UNDERGROUND, 4,000 GALLON CAPACITY, 8' DIA. X 31' L. (COMMON TO LOADING RACKS 1 THROUGH 8).
6. TANK TK-120, UNDERGROUND, 7'-9" DIA. X 14'-8" L., 5,000 GALLON CAPACITY (COMMON TO LOADING RACKS 1 THROUGH 8).
7. THREE ETHANOL TRANSFER PUMPS, EACH WITH 25 HP MOTOR AND TANDEM MECHANICAL SEALS VENTED TO VAPOR RECOVERY SYSTEM OR TO STANDBY AIR POLLUTION CONTROL SYSTEM (COMMON TO LOADING RACKS 1 THROUGH 6).
8. SIX ADDITIVE PUMPS, 2 HP MAGNETIC DRIVE GEAR PUMPS (COMMON TO LOADING RACKS 1 THROUGH 6).

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 5,843,411 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[H & S Code §41954]

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

- 4) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 7,000,000 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[RULE 462, RULE 1303(b)(2) - OFFSETS]
- 5) DISPLACED VAPORS FROM THE TRUCK LOADING OPERATION SHALL BE VENTED TO A VAPOR RECOVERY SYSTEM (VRU NO. 1, VRU NO. 2, AND/OR STANDBY FLARE). THE VAPOR RECOVERY SYSTEM SHALL BE CALIFORNIA AIR RESOURCES BOARD (CARB) CERTIFIED. IF THE VAPOR RECOVERY SYSTEM DOES NOT REQUIRE CARB CERTIFICATION PER CALIFORNIA HEALTH AND SAFETY CODE 41954, IT SHALL BE APPROVED BY AQMD. THE VAPOR RECOVERY SYSTEM SHALL BE CERTIFIED TO REDUCE VOC EMISSIONS FROM LOADING OPERATIONS TO 0.08 POUNDS OR LESS PER 1000 GALLONS LOADED.
[RULE 462, 40CFR 63 SUBPART R]
- 6) THIS EQUIPMENT SHALL NOT BE USED TO LOAD OR UNLOAD ORGANIC LIQUIDS INTO ANY TRANSPORT VESSEL UNLESS THE VESSEL HAS A VALID CERTIFICATION OF VAPOR INTEGRITY AS DEFINED BY THE APPLICABLE AIR RESOURCES BOARD CERTIFICATION AND TEST PROCEDURES, PURSUANT TO CALIFORNIA HEALTH AND SAFETY CODE SECTION 41962(g).
[RULE 462, 40CFR 63 SUBPART R]
- 7) THE OPERATOR SHALL PERFORM AN INSPECTION OF THE VAPOR COLLECTION SYSTEM, THE VAPOR CONTROL SYSTEM, AND THE COMPONENTS AND FITTINGS OF THIS EQUIPMENT FOR VAPOR AND/OR LIQUID LEAKS. THE OPERATOR SHALL USE THE MEASURES FOR INSPECTION, REPORTING, MAINTENANCE, AND LEAK CRITERIA EQUIVALENT TO THOSE SPECIFIED IN AQMD RULE 1173 PER SETTLEMENT AGREEMENT BETWEEN AQMD AND ARCO PRODUCTS COMPANY AND ITS SUCCESSORS, DATED MARCH 15, 1991.
[RULE 462, 40CFR 63 SUBPART R, SETTLEMENT AGREEMENT]
- 8) THE OPERATOR SHALL RECORD ALL LEAKS, REPAIRS ,AND REINSPECTIONS AS REQUIRED BY THE CONDITIONS OF THIS PERMIT, AND SUBMIT THOSE AS QUARTERLY OR ANNUAL INSPECTION REPORTS TO THE EXECUTIVE OFFICER, NO LATER THAN 30 DAYS AFTER THE END OF EACH QUARTER, OR 60 DAYS AFTER THE END OF EACH CALENDAR YEAR, RESPECTIVELY.
[RULE 462]
- 9) THE RECORDS REQUIRED BY CONDITIONS OF THIS PERMIT INCLUDING CARGO TANK INTEGRITY TESTS, PERIODIC LEAK INSPECTIONS, COMPONENT IDENTIFICATION, TYPE, SERVICE, LOCATION, LEAK RATE, DATE AND TIME OF INSPECTION AND REPAIR, REINSPECTIONS, AND MAINTENANCE, SHALL BE RETAINED AT THE FACILITY AND SHALL BE MADE AVAILABLE TO ANY DISTRICT REPRESENTATIVE UPON REQUEST.
[RULE 462, 40CFR 63 SUBPART R]

Periodic Monitoring: NONE

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

Emissions and Requirements:

- 10) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

HAP/TOC: 10 MG/LITER OF GASOLINE LOADED, 40CFR 63 SUBPART R
VOC: 0.08 LB/1000 GALLONS OF ORGANIC LIQUID LOADED, RULE 462
VOC: RULE 1173 (PER SETTLEMENT AGREEMENT 3/15/1991)

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

PERMIT TO OPERATE

Permit No.
A/N 556620

Equipment Description:

BULK GASOLINE LOADING RACK NO. 4 CONSISTING OF THE FOLLOWING:

1. FOUR 4" BOTTOM LOADING ARMS WITH BREAKAWAY COUPLERS AND DRY BREAK CONNECTIONS.
2. TWO 4" VAPOR RETURN CONNECTIONS.
3. TEN TOTALIZING FLOW METERS.
4. ELEVEN GASOLINE PUMPS, EACH INLINE WITH MECHANICAL SEAL AND 100 HP MOTOR (COMMON TO LOADING RACKS 1 THROUGH 6).
5. SUMP TANK T-903, UNDERGROUND, 4,000 GALLON CAPACITY, 8' DIA. X 31' L. (COMMON TO LOADING RACKS 1 THROUGH 8).
6. TANK TK-120, UNDERGROUND, 7'-9" DIA. X 14'-8" L., 5,000 GALLON CAPACITY (COMMON TO LOADING RACKS 1 THROUGH 8).
7. THREE ETHANOL TRANSFER PUMPS, EACH WITH 25 HP MOTOR AND TANDEM MECHANICAL SEALS VENTED TO VAPOR RECOVERY SYSTEM OR TO STANDBY AIR POLLUTION CONTROL SYSTEM (COMMON TO LOADING RACKS 1 THROUGH 6).
8. SIX ADDITIVE PUMPS, 2 HP MAGNETIC DRIVE GEAR PUMPS (COMMON TO LOADING RACKS 1 THROUGH 6).

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 5,843,411 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[H & S Code §41954]

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

- 4) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 7,000,000 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[RULE 462, RULE 1303(b)(2) - OFFSETS]
- 5) DISPLACED VAPORS FROM THE TRUCK LOADING OPERATION SHALL BE VENTED TO A VAPOR RECOVERY SYSTEM (VRU NO. 1, VRU NO. 2, AND/OR STANDBY FLARE). THE VAPOR RECOVERY SYSTEM SHALL BE CALIFORNIA AIR RESOURCES BOARD (CARB) CERTIFIED. IF THE VAPOR RECOVERY SYSTEM DOES NOT REQUIRE CARB CERTIFICATION PER CALIFORNIA HEALTH AND SAFETY CODE 41954, IT SHALL BE APPROVED BY AQMD. THE VAPOR RECOVERY SYSTEM SHALL BE CERTIFIED TO REDUCE VOC EMISSIONS FROM LOADING OPERATIONS TO 0.08 POUNDS OR LESS PER 1000 GALLONS LOADED.
[RULE 462, 40CFR 63 SUBPART R]
- 6) THIS EQUIPMENT SHALL NOT BE USED TO LOAD OR UNLOAD ORGANIC LIQUIDS INTO ANY TRANSPORT VESSEL UNLESS THE VESSEL HAS A VALID CERTIFICATION OF VAPOR INTEGRITY AS DEFINED BY THE APPLICABLE AIR RESOURCES BOARD CERTIFICATION AND TEST PROCEDURES, PURSUANT TO CALIFORNIA HEALTH AND SAFETY CODE SECTION 41962(g).
[RULE 462, 40CFR 63 SUBPART R]
- 7) THE OPERATOR SHALL PERFORM AN INSPECTION OF THE VAPOR COLLECTION SYSTEM, THE VAPOR CONTROL SYSTEM, AND THE COMPONENTS AND FITTINGS OF THIS EQUIPMENT FOR VAPOR AND/OR LIQUID LEAKS. THE OPERATOR SHALL USE THE MEASURES FOR INSPECTION, REPORTING, MAINTENANCE, AND LEAK CRITERIA EQUIVALENT TO THOSE SPECIFIED IN AQMD RULE 1173 PER SETTLEMENT AGREEMENT BETWEEN AQMD AND ARCO PRODUCTS COMPANY AND ITS SUCCESSORS, DATED MARCH 15, 1991.
[RULE 462, 40CFR 63 SUBPART R, SETTLEMENT AGREEMENT]
- 8) THE OPERATOR SHALL RECORD ALL LEAKS, REPAIRS, AND REINSPECTIONS AS REQUIRED BY THE CONDITIONS OF THIS PERMIT, AND SUBMIT THOSE AS QUARTERLY OR ANNUAL INSPECTION REPORTS TO THE EXECUTIVE OFFICER, NO LATER THAN 30 DAYS AFTER THE END OF EACH QUARTER, OR 60 DAYS AFTER THE END OF EACH CALENDAR YEAR, RESPECTIVELY.
[RULE 462]
- 9) THE RECORDS REQUIRED BY CONDITIONS OF THIS PERMIT INCLUDING CARGO TANK INTEGRITY TESTS, PERIODIC LEAK INSPECTIONS, COMPONENT IDENTIFICATION, TYPE, SERVICE, LOCATION, LEAK RATE, DATE AND TIME OF INSPECTION AND REPAIR, REINSPECTIONS, AND MAINTENANCE, SHALL BE RETAINED AT THE FACILITY AND SHALL BE MADE AVAILABLE TO ANY DISTRICT REPRESENTATIVE UPON REQUEST.
[RULE 462, 40CFR 63 SUBPART R]

Periodic Monitoring: NONE

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

Emissions and Requirements:

- 10) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

HAP/TOC: 10 MG/LITER OF GASOLINE LOADED, 40CFR 63 SUBPART R
VOC: 0.08 LB/1000 GALLONS OF ORGANIC LIQUID LOADED, RULE 462
VOC: RULE 1173 (PER SETTLEMENT AGREEMENT 3/15/1991)

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

PERMIT TO OPERATE

Permit No.
A/N 556621

Equipment Description:

BULK GASOLINE LOADING RACK NO. 5 CONSISTING OF THE FOLLOWING:

1. FOUR 4" BOTTOM LOADING ARMS WITH BREAKAWAY COUPLERS AND DRY BREAK CONNECTIONS.
2. TWO 4" VAPOR RETURN CONNECTIONS.
3. TEN TOTALIZING FLOW METERS.
4. ELEVEN GASOLINE PUMPS, EACH INLINE WITH MECHANICAL SEAL AND 100 HP MOTOR (COMMON TO LOADING RACKS 1 THROUGH 6).
5. SUMP TANK T-903, UNDERGROUND, 4,000 GALLON CAPACITY, 8' DIA. X 31' L. (COMMON TO LOADING RACKS 1 THROUGH 8).
6. TANK TK-120, UNDERGROUND, 7'-9" DIA. X 14'-8" L., 5,000 GALLON CAPACITY (COMMON TO LOADING RACKS 1 THROUGH 8).
7. THREE ETHANOL TRANSFER PUMPS, EACH WITH 25 HP MOTOR AND TANDEM MECHANICAL SEALS VENTED TO VAPOR RECOVERY SYSTEM OR TO STANDBY AIR POLLUTION CONTROL SYSTEM (COMMON TO LOADING RACKS 1 THROUGH 6).
8. SIX ADDITIVE PUMPS, 2 HP MAGNETIC DRIVE GEAR PUMPS (COMMON TO LOADING RACKS 1 THROUGH 6).

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 5,843,411 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[H & S Code §41954]

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

- 4) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 7,000,000 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[RULE 462, RULE 1303(b)(2) - OFFSETS]
- 5) DISPLACED VAPORS FROM THE TRUCK LOADING OPERATION SHALL BE VENTED TO A VAPOR RECOVERY SYSTEM (VRU NO. 1, VRU NO. 2, AND/OR STANDBY FLARE). THE VAPOR RECOVERY SYSTEM SHALL BE CALIFORNIA AIR RESOURCES BOARD (CARB) CERTIFIED. IF THE VAPOR RECOVERY SYSTEM DOES NOT REQUIRE CARB CERTIFICATION PER CALIFORNIA HEALTH AND SAFETY CODE 41954, IT SHALL BE APPROVED BY AQMD. THE VAPOR RECOVERY SYSTEM SHALL BE CERTIFIED TO REDUCE VOC EMISSIONS FROM LOADING OPERATIONS TO 0.08 POUNDS OR LESS PER 1000 GALLONS LOADED.
[RULE 462, 40CFR 63 SUBPART R]
- 6) THIS EQUIPMENT SHALL NOT BE USED TO LOAD OR UNLOAD ORGANIC LIQUIDS INTO ANY TRANSPORT VESSEL UNLESS THE VESSEL HAS A VALID CERTIFICATION OF VAPOR INTEGRITY AS DEFINED BY THE APPLICABLE AIR RESOURCES BOARD CERTIFICATION AND TEST PROCEDURES, PURSUANT TO CALIFORNIA HEALTH AND SAFETY CODE SECTION 41962(g).
[RULE 462, 40CFR 63 SUBPART R]
- 7) THE OPERATOR SHALL PERFORM AN INSPECTION OF THE VAPOR COLLECTION SYSTEM, THE VAPOR CONTROL SYSTEM, AND THE COMPONENTS AND FITTINGS OF THIS EQUIPMENT FOR VAPOR AND/OR LIQUID LEAKS. THE OPERATOR SHALL USE THE MEASURES FOR INSPECTION, REPORTING, MAINTENANCE, AND LEAK CRITERIA EQUIVALENT TO THOSE SPECIFIED IN AQMD RULE 1173 PER SETTLEMENT AGREEMENT BETWEEN AQMD AND ARCO PRODUCTS COMPANY AND ITS SUCCESSORS, DATED MARCH 15, 1991.
[RULE 462, 40CFR 63 SUBPART R, SETTLEMENT AGREEMENT]
- 8) THE OPERATOR SHALL RECORD ALL LEAKS, REPAIRS, AND REINSPECTIONS AS REQUIRED BY THE CONDITIONS OF THIS PERMIT, AND SUBMIT THOSE AS QUARTERLY OR ANNUAL INSPECTION REPORTS TO THE EXECUTIVE OFFICER, NO LATER THAN 30 DAYS AFTER THE END OF EACH QUARTER, OR 60 DAYS AFTER THE END OF EACH CALENDAR YEAR, RESPECTIVELY.
[RULE 462]
- 9) THE RECORDS REQUIRED BY CONDITIONS OF THIS PERMIT INCLUDING CARGO TANK INTEGRITY TESTS, PERIODIC LEAK INSPECTIONS, COMPONENT IDENTIFICATION, TYPE, SERVICE, LOCATION, LEAK RATE, DATE AND TIME OF INSPECTION AND REPAIR, REINSPECTIONS, AND MAINTENANCE, SHALL BE RETAINED AT THE FACILITY AND SHALL BE MADE AVAILABLE TO ANY DISTRICT REPRESENTATIVE UPON REQUEST.
[RULE 462, 40CFR 63 SUBPART R]

Periodic Monitoring: NONE

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

Emissions and Requirements:

- 10) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

HAP/TOC: 10 MG/LITER OF GASOLINE LOADED, 40CFR 63 SUBPART R
VOC: 0.08 LB/1000 GALLONS OF ORGANIC LIQUID LOADED, RULE 462
VOC: RULE 1173 (PER SETTLEMENT AGREEMENT 3/15/1991)

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

PERMIT TO OPERATE

Permit No.
A/N 556622

Equipment Description:

BULK GASOLINE AND DIESEL LOADING RACK NO. 6 CONSISTING OF THE FOLLOWING:

1. FOUR 4" GASOLINE BOTTOM LOADING ARMS WITH BREAKAWAY COUPLERS AND DRY BREAK CONNECTIONS.
2. TWO 3" VAPOR RETURN CONNECTIONS.
3. TEN TOTALIZING GASOLINE FLOW METERS.
4. ELEVEN GASOLINE PUMPS, EACH INLINE WITH MECHANICAL SEAL AND 100 HP MOTOR (COMMON TO LOADING RACKS 1 THROUGH 6).
5. TWO DIESEL PUMPS, EACH INLINE WITH MECHANICAL SEAL AND 100 HP MOTOR (COMMON TO LOADING RACKS 6 THROUGH 8).
6. SUMP TANK T-903, UNDERGROUND, 4,000 GALLON CAPACITY, 8' DIA. X 31' L. (COMMON TO LOADING RACKS 1 THROUGH 8).
7. TANK TK-120, UNDERGROUND, 7'-9" DIA. X 14'-8" L., 5,000 GALLON CAPACITY (COMMON TO LOADING RACKS 1 THROUGH 8).
8. TWO 4" DIESEL BOTTOM LOADING ARMS WITH BREAKAWAY COUPLERS AND DRY BREAK CONNECTIONS.
9. TWO TOTALIZING DIESEL FLOW METERS.
10. THREE ETHANOL TRANSFER PUMPS, EACH WITH 25 HP MOTOR AND TANDEM MECHANICAL SEALS VENTED TO VAPOR RECOVERY SYSTEM OR TO STANDBY AIR POLLUTION CONTROL SYSTEM (COMMON TO LOADING RACKS 1 THROUGH 6).
11. SIX ADDITIVE PUMPS, 2 HP MAGNETIC DRIVE GEAR PUMPS (COMMON TO LOADING RACKS 1 THROUGH 6).

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 5,843,411 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[H & S Code §41954]
- 4) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 7,000,000 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[RULE 462, RULE 1303(b)(2) - OFFSETS]
- 5) DISPLACED VAPORS FROM THE TRUCK LOADING OPERATION SHALL BE VENTED TO A VAPOR RECOVERY SYSTEM (VRU NO. 1, VRU NO. 2, AND/OR STANDBY FLARE). THE VAPOR RECOVERY SYSTEM SHALL BE CALIFORNIA AIR RESOURCES BOARD (CARB) CERTIFIED. IF THE VAPOR RECOVERY SYSTEM DOES NOT REQUIRE CARB CERTIFICATION PER CALIFORNIA HEALTH AND SAFETY CODE 41954, IT SHALL BE APPROVED BY AQMD. THE VAPOR RECOVERY SYSTEM SHALL BE CERTIFIED TO REDUCE VOC EMISSIONS FROM LOADING OPERATIONS TO 0.08 POUNDS OR LESS PER 1000 GALLONS LOADED.
[RULE 462, 40CFR 63 SUBPART R]
- 6) THIS EQUIPMENT SHALL NOT BE USED TO LOAD OR UNLOAD ORGANIC LIQUIDS INTO ANY TRANSPORT VESSEL UNLESS THE VESSEL HAS A VALID CERTIFICATION OF VAPOR INTEGRITY AS DEFINED BY THE APPLICABLE AIR RESOURCES BOARD CERTIFICATION AND TEST PROCEDURES, PURSUANT TO CALIFORNIA HEALTH AND SAFETY CODE SECTION 41962(g).
[RULE 462, 40CFR 63 SUBPART R]
- 7) THE OPERATOR SHALL PERFORM AN INSPECTION OF THE VAPOR COLLECTION SYSTEM, THE VAPOR CONTROL SYSTEM, AND THE COMPONENTS AND FITTINGS OF THIS EQUIPMENT FOR VAPOR AND/OR LIQUID LEAKS. THE OPERATOR SHALL USE THE MEASURES FOR INSPECTION, REPORTING, MAINTENANCE, AND LEAK CRITERIA EQUIVALENT TO THOSE SPECIFIED IN AQMD RULE 1173 PER SETTLEMENT AGREEMENT BETWEEN AQMD AND ARCO PRODUCTS COMPANY AND ITS SUCCESSORS, DATED MARCH 15, 1991.
[RULE 462, 40CFR 63 SUBPART R, SETTLEMENT AGREEMENT]
- 8) THE OPERATOR SHALL RECORD ALL LEAKS, REPAIRS, AND REINSPECTIONS AS REQUIRED BY THE CONDITIONS OF THIS PERMIT, AND SUBMIT THOSE AS QUARTERLY OR ANNUAL INSPECTION REPORTS TO THE EXECUTIVE OFFICER, NO LATER THAN 30 DAYS AFTER THE END OF EACH QUARTER, OR 60 DAYS AFTER THE END OF EACH CALENDAR YEAR, RESPECTIVELY.
[RULE 462]

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

- 9) THE RECORDS REQUIRED BY CONDITIONS OF THIS PERMIT INCLUDING CARGO TANK INTEGRITY TESTS, PERIODIC LEAK INSPECTIONS, COMPONENT IDENTIFICATION, TYPE, SERVICE, LOCATION, LEAK RATE, DATE AND TIME OF INSPECTION AND REPAIR, REINSPECTIONS, AND MAINTENANCE, SHALL BE RETAINED AT THE FACILITY AND SHALL BE MADE AVAILABLE TO ANY DISTRICT REPRESENTATIVE UPON REQUEST.
[RULE 462, 40CFR 63 SUBPART R]

Periodic Monitoring: NONE

Emissions and Requirements:

- 10) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

HAP/TOC: 10 MG/LITER OF GASOLINE LOADED, 40CFR 63 SUBPART R
VOC: 0.08 LB/1000 GALLONS OF ORGANIC LIQUID LOADED, RULE 462
VOC: RULE 1173 (PER SETTLEMENT AGREEMENT 3/15/1991)

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

PERMIT TO OPERATE

Permit No.
A/N 556623

Equipment Description:

BULK DIESEL LOADING RACK NO. 7 CONSISTING OF THE FOLLOWING:

1. TWO 4" BOTTOM LOADING ARMS WITH BREAKAWAY COUPLERS AND DRY BREAK CONNECTIONS.
2. TWO 3" VAPOR RETURN CONNECTIONS.
3. TWO TOTALIZING FLOW METERS.
4. TWO DIESEL PUMPS, EACH INLINE WITH MECHANICAL SEAL AND 100 HP MOTOR (COMMON TO LOADING RACKS 6 THROUGH 8).
5. SUMP TANK T-903, UNDERGROUND, 4,000 GALLON CAPACITY, 8' DIA. X 31' L. (COMMON TO LOADING RACKS 1 THROUGH 8).
6. TANK TK-120, UNDERGROUND, 7'-9" DIA. X 14'-8" L., 5,000 GALLON CAPACITY (COMMON TO LOADING RACKS 1 THROUGH 8).

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 5,843,411 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[H & S Code §41954]
- 4) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 7,000,000 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[RULE 462, RULE 1303(b)(2) - OFFSETS]

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

- 5) THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED TO AN AIR POLLUTION CONTROL DEVICE WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1) - BACT]

Periodic Monitoring: NONE

Emissions and Requirements:

- 6) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

VOC: RULE 1173 (PER SETTLEMENT AGREEMENT 3/15/1991)

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

PERMIT TO OPERATE

Permit No.
A/N 556624

Equipment Description:

BULK DIESEL LOADING RACK NO. 8 CONSISTING OF THE FOLLOWING:

1. TWO 4" BOTTOM LOADING ARMS WITH BREAKAWAY COUPLERS AND DRY BREAK CONNECTIONS.
2. TWO 3" VAPOR RETURN CONNECTIONS.
3. TWO TOTALIZING FLOW METERS.
4. TWO DIESEL PUMPS, EACH INLINE WITH MECHANICAL SEAL AND 100 HP MOTOR (COMMON TO LOADING RACKS 6 THROUGH 8).
5. SUMP TANK T-903, UNDERGROUND, 4,000 GALLON CAPACITY, 8' DIA. X 31' L. (COMMON TO LOADING RACKS 1 THROUGH 8).
6. TANK TK-120, UNDERGROUND, 7'-9" DIA. X 14'-8" L., 5,000 GALLON CAPACITY (COMMON TO LOADING RACKS 1 THROUGH 8).

Conditions:

- 1) OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
- 2) THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
- 3) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 5,843,411 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[H & S Code §41954]
- 4) THE LOADING RATE FOR ALL COMMODITIES AT THIS FACILITY SHALL NOT EXCEED 7,000,000 GALLONS PER DAY. THROUGHPUT SHALL BE MONITORED AND RECORDED BY AN AUTOMATED SYSTEM DESIGNED TO SHUT DOWN THE LOADING OPERATION WHEN THE LOADING RATE LIMIT IS REACHED.
[RULE 462, RULE 1303(b)(2) - OFFSETS]

FACILITY PERMIT TO OPERATE TESORO LOGISTICS, VINVALE TERMINAL

- 5) THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED TO AN AIR POLLUTION CONTROL DEVICE WHICH IS IN FULL USE AND WHICH HAS BEEN ISSUED A PERMIT TO OPERATE BY THE EXECUTIVE OFFICER.
[RULE 1303(a)(1) - BACT]

Periodic Monitoring: NONE

Emissions and Requirements:

- 6) THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- VOC: RULE 1173 (PER SETTLEMENT AGREEMENT 3/15/1991)