



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

January 14, 2011
Via electronic submittal

Mr. Gerardo Rios
USEPA – Region IX
Mail Stop A-5-2
75 Hawthorne Blvd.
San Francisco, CA 94105

Dear Mr. Rios,

Proposed De Minimis Significant Revision to Title V Permit for Eastern Municipal Water District (EMWD), San Jacinto Regional Water Reclamation Plant (ID# 019159)

Enclosed for your 45-day review is the proposed revision to the Title V Permit for EMWD, municipal waste water treatment plant located at 770 North Sanderson Avenue, San Jacinto, CA in Riverside County. This revision is considered to be a de minimis significant. We are enclosing the appropriate pages of the proposed Section H, which includes the permits as shown below, and the engineering evaluation.

SECTION D, PERMIT TO OPERATE

Appl. No.	Equipment	Description
511886	STORAGE TANK - UREA	Installation of a urea tank to be used for the NOx control system under A/N 504398.

SECTION H, PERMIT TO CONSTRUCT

Appl. No.	Equipment	Description
504395	ICE (50-500 HP) NON-EMERGENCY STATIONARY NAT GAS & DIGESTER GAS FIRED	Alteration of the digester gas fired ICE to allow the ICE to be vented to the NOx control system under A/N 504398.
504396	ICE (50-500 HP) NON-EMERGENCY STATIONARY NAT GAS FIRED ONLY	Alteration of the natural gas fired ICE to allow the ICE to be vented to the NOx control system under A/N 504398.
504398	AIR POLLUTION CONTROL SYSTEM, NOX CONTROL	Installation of a NOx control system which will vent three engines under A/Ns 504395, 504396, and 504502.
504502	ICE (50-500 HP) NON-EMERGENCY STATIONARY NAT GAS FIRED ONLY	Alteration of the natural gas fired ICE to allow the ICE to be vented to the NOx control system under A/N 504398.

The initial Title V permit for this facility was issued on February 1, 2007.

This request is being made via electronic submittal in order to facilitate your review. If you have any questions or need additional information, please contact Ms. Angela Shibata at (909) 396-2737 or by email at ashibata@aqmd.gov.

Sincerely,



Jay Chen, P.E.

Senior AQ Engineering Manager

Refinery and Waste Management Permitting

JC: CDT: AIS

Enclosures

cc: Felipe Gregorio, EMWD, with proposed permit
A/N 504394, Title V Permit Revision (No. 05)