

PROPOSED

DATE

Mr. Hans R. Tobler
General Manager
Kalaeloa Partners, L.P.
91-111 Kalaeloa Boulevard
Kapolei, Hawaii 96707

09-XXXE CAB
File No. 0214

Dear Mr. Tobler:

**Subject: Amendment to Covered Source Permit (CSP) No. 0214-01-C
Minor Modification Application No. 214-08
Kalaeloa Partners, L.P.
Kalaeloa Cogeneration Plant
Located at: 91-111 Kalaeloa Boulevard, Kapolei, Oahu
Expiration Date: May 15, 2013**

In accordance with Hawaii Administrative Rules, Chapter 11-60.1, and pursuant to your May 6, 2009, minor modification application, the Department of Health hereby amends Covered Source Permit (CSP) No. 0214-01-C, issued to Kalaeloa Partners, L.P. on May 16, 2008. The amendment increases the annual specification used oil consumption limit from 2,000 gallons to 10,000 gallons, as calculated on a rolling 12-month basis.

Attachment II, Special Condition C.1.c.iii has been modified to the following:

- iii. The total amount of specification used oil fired in the combustion turbine shall not exceed 10,000 gallons as calculated on a rolling 12-month basis.

All other permit conditions of CSP No. 0214-01-C, issued on May 16, 2008, shall not be affected and shall remain valid.

A receipt for the minor modification application filing fee of \$200.00 is enclosed.

If you have any questions regarding this matter, please contact Mr. Kevin Kihara my staff at (808) 586-4200.

Sincerely,

THOMAS E. ARIZUMI, P.E., CHIEF
Environmental Management Division

KK:ta
Enclosure

c: CAB Monitoring Section