

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
<b>System 1: EMERGENCY</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 133DN, WITH TURBOCHARGER, 210 HP A/N: 478422	D1		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.1, C1.11, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 64DT, WITH TURBOCHARGER, 137 HP A/N: 478423	D2		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.1, C1.11, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 133DT, WITH TURBOCHARGER, 290 HP A/N: 478424	D4		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.1, C1.11, D12.1, E71.4, E71.7, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 64DT, WITH TURBOCHARGER, 137 HP A/N: 478425	D7		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.1, C1.11, C177.1, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 64DTA, WITH AFTERCOOLER, TURBOCHARGER, 163 HP A/N: 478426	D8		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.1, C1.11, C177.1, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16

- \* (1) (1A) (1B) Denotes RECLAIM emission factor
- (3) Denotes RECLAIM concentration limit
- (5) (5A) (5B) Denotes command and control emission limit
- (7) Denotes NSR applicability limit
- (9) See App B for Emission Limits
- (2) (2A) (2B) Denotes RECLAIM emission rate
- (4) Denotes BACT emission limit
- (6) Denotes air toxic control rule limit
- (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
- (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 133DTA, WITH AFTERCOOLER, TURBOCHARGER, 368 HP A/N: 195818	D10		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.2, C177.1, D12.1, E71.7, H23.6
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 6.4DTA, WITH AFTERCOOLER, TURBOCHARGER, 160 HP A/N: 478430	D12		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.1, C1.11, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL 3208TA, WITH AFTERCOOLER, TURBOCHARGER, 299 HP A/N: 478431	D15		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.1, C1.20, C177.1, D12.1, E71.6, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, DETROIT DIESEL, MODEL 40-8.7LT, WITH TURBOCHARGER, 205 BHP A/N: 478432	D95		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.1, C1.11, C177.1, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL 3508 DITA, WITH AFTERCOOLER, TURBOCHARGER, 1337 BHP A/N: 303611	D98		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.3, C177.1, D12.1, E71.6, H23.6

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, JOHN DEERE, MODEL 6059T, WITH A TURBOCHARGER, 166 BHP A/N: 478433	D99		NOX: PROCESS UNIT**	<b>NOX:</b> 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]	C1.1, C1.20, C177.1, D12.1, E71.6, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, GENERAC 7.4GN, MODEL CG070, WITH CATALYTIC REDUCTION, 116 HP A/N: 334912	D101		NOX: PROCESS UNIT**	<b>NOX:</b> 37.9 LBS/MMSCF NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; <b>NOX:</b> 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]	C1.1, D12.1, H23.12
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP A/N: 344925	D115		NOX: PROCESS UNIT**	<b>CO:</b> 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; <b>NOX:</b> 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; <b>NOX:</b> 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements  
 \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP A/N: 344926	D116		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]	C1.1, D12.1, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP A/N: 344927	D117		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP A/N: 344928	D118		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3408SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 460 BHP A/N: 344929	D119		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]	C1.1, D12.1, H23.12, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3306SITA, NATURAL GAS, RICH BURN, WITH TURBOCHARGER AND AFTERCOOLER, WITH CATALYTIC REDUCTION, 194 BHP A/N: 344913	D120		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3304SINA, NATURAL GAS, WITH CATALYTIC REDUCTION, 95 BHP A/N: 344914	D121		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3516SITA, NATURAL GAS, LEAN BURN, WITH TURBOCHARGER AND AFTERCOOLER, 1482 BHP A/N: 344899	D122		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344933	D123		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344934	D124		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344935	D125		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements  
 \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344936	D126		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344937	D127		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 405, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344938	D128		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CATERPILLAR, MODEL G3406SITA, NATURAL GAS, WITH CATALYTIC REDUCTION, 367 BHP A/N: 344939	D129		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, H23.12, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, GASOLINE, FORD, MODEL LSG-875R-6003-C, WITH CATALYTIC REDUCTION, 193 HP A/N: 359091	D131		NOX: PROCESS UNIT**	CO: 0.6 GRAM/BHP-HR GASOLINE (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 0.15 GRAM/BHP-HR GASOLINE (4) [RULE 2005, 5-6-2005]; NOX: 102 LBS/1000 GAL GASOLINE (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 0.15 GRAM/BHP-HR GASOLINE (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, GENERAC, MODEL 7.5 DTA, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 184 BHP A/N: 362182	D133		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 2005, 5-6-2005]; NOX: 264 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; ROG: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, E71.6, E202.2, H23.6, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements  
 \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, CUMMINS, MODEL 800 GTA 500 G3, NATURAL GAS, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 1334 BHP A/N: 360419	D134		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, E202.3, H23.12, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL 3303 ATACC, WITH AFTERCOOLER, TURBOCHARGER, 377 BHP A/N: 378803	D149		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; NOX: 302 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; ROG: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, C1.11, D12.1, E71.1, E71.4, H23.6, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements  
 \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, PARADISE PIER HOTEL, DIESEL FUEL, CUMMINS, MODEL N-855-F, 6 CYLINDERS, FOUR CYCLE, NATURALLY ASPIRATED, SERIAL NO. 1815303, 240 HP A/N: 311603	D152		NOX: PROCESS UNIT**	<b>NOX:</b> 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]	C1.1, C1.22, D12.1, H23.6
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, PARADISE PIER HOTEL, DIESEL FUEL, CATERPILLAR, MODEL 3508DI, 8 CYLINDERS, INTERCOOLED, SERIAL NO. 28Z00641, WITH TURBOCHARGER, 712 HP A/N: 478427	D153		NOX: PROCESS UNIT**	<b>NOX:</b> 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]	C1.1, C1.20, C177.1, D12.1, E71.6, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, CUMMINS, MODEL 4BT3.9-G4, 4 CYLINDERS, SERIAL NO. 45901859, WITH TURBOCHARGER, 102 HP A/N: 363159	D159		NOX: PROCESS UNIT**	<b>CO:</b> 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; <b>NOX:</b> 6.9 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; <b>NOX:</b> 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>PM10:</b> 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; <b>ROG:</b> 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.8, D12.1, E71.6, H23.6, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements  
 \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, CUMMINS, MODEL 6CT8.3G, 6 CYLINDERS, FOUR CYCLE, WITH TURBOCHARGER, 207 HP A/N: 478428	D160		NOX: PROCESS UNIT**	<b>NOX:</b> 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]	C1.1, C1.11, C177.1, D12.1, E71.4, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, CUMMINS, MODEL 6CT8.3G, 6 CYLINDERS, FOUR CYCLE, WITH TURBOCHARGER, 207 HP A/N: 241137	D162		NOX: PROCESS UNIT**	<b>NOX:</b> 2.9 LBS/HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; <b>NOX:</b> 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> 0.11 LBS/HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C177.1, D12.1, E71.6, H23.6, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, CUMMINS, MODEL 6CT8.3G, 6 CYLINDERS, FOUR CYCLE, WITH TURBOCHARGER, 207 HP A/N: 241138	D163		NOX: PROCESS UNIT**	<b>NOX:</b> 2.9 LBS/HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; <b>NOX:</b> 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> 0.11 LBS/HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C177.1, D12.1, E71.6, H23.6, K67.4
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DISNEYLAND HOTEL, DIESEL FUEL, CLARKE GM DIESEL INC, MODEL MD-4-1226, 4 CYLINDERS, SERIAL NO. 47463, 73 HP A/N: 241139	D164		NOX: PROCESS UNIT**	<b>NOX:</b> 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]	C1.8, C1.22, D12.1, H23.6, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DISNEYLAND HOTEL, DIESEL FUEL, ALLIS-CHALMERS, MODEL 649, 6 CYLINDERS, FOUR CYCLE, SERIAL NO. K820640605, 73 HP A/N: 478429	D168		NOX: PROCESS UNIT**	NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]	C1.1, C1.20, D12.1, E71.6, E116.1, H23.6, H23.11, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, JOHN DEERE, MODEL 6081A, WITH AFTERCOOLER, TURBOCHARGER, 250 BHP A/N: 397419	D169		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 2005, 5-6-2005]; NOX: 304 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; ROG: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, C1.11, D12.1, E71.1, E71.4, H23.6, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY FIRE, DIESEL FUEL, CUMMINS, MODEL 6BTA5.9F1, PARADISE PIER HOTEL, WITH AFTERCOOLER, TURBOCHARGER, 182 BHP A/N: 408907	D172		NOX: PROCESS UNIT**	CO: 8.5 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 6.9 GRAM/BHP-HR DIESEL (4) [RULE 2005, 5-6-2005]; NOX: 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; PM10: 0.38 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; ROG: 1 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; SOX: 15 PPM DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, C1.22, D12.1, H23.6, K67.4, K67.12
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, CATERPILLAR, MODEL G3412STIA/450KW, SERIAL NO. 7DM, JOHNSON MATTHEY-MODEL QXC-30-08-NSCR, MODEL EPC-100-CONTROLLER, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 622 BHP A/N: 412302	D173		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, C1.11, D12.1, E71.1, E202.3, K67.4

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements  
 \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, CUMMINS, MODEL GTA14 GS/GC 280 KW, WITH NSCR-MIRATECH, MODEL MCS-22Y1515-08-C2, CONTROLLER-MODEL MEC-2001-1LP, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 431 BHP A/N: 419597	D174		NOX: PROCESS UNIT**	<b>CO:</b> 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; <b>NOX:</b> 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; <b>NOX:</b> 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, C1.11, D12.1, E71.3, E202.3, K67.13
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, PERKINS, MODEL 1004-40T, WITH TURBOCHARGER, 95.2 BHP A/N: 425385	D175		NOX: PROCESS UNIT**	<b>CO:</b> 3.7 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; <b>NOX:</b> 469 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>NOX + ROG:</b> 5.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>PM:</b> 0.3 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, C1.11, D12.1, E71.4, H23.6, K67.14

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements  
 \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, CATERPILLAR, MODEL G3406SITA (250 KW), WITH NSCR,JOHNSON MATTHEY, QXC20, A/F, WOODWARD, MODEL GECO, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 367 BHP A/N: 431660	D176		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT, 5-10-1996]; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)-BACT, 5-10-1996]	C1.1, C1.11, D12.1, E71.5, E202.3, H23.12, K67.14
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, FORD, MODEL WSG-1068, WITH NSCR,MINE-X, MODEL DC47, NEUTRONIC, MARK V, A/F CONTROLLER, WITH CATALYTIC REDUCTION, TURBOCHARGER, 176 BHP A/N: 436095	D178		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 2192.45 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996]	C1.1, D12.1, E202.3, H23.12, K67.14

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL G3456 DITA AA, WITH AFTERCOOLER, TURBOCHARGER, 685 BHP A/N: 445773	D179		NOX: PROCESS UNIT**	CO: 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; NOX: 221 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; NOX + ROG: 4.8 GRAM/BHP-HR DIESEL (4) [RULE 2005, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; PM: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470, 6-1-2007]; PM10: 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, D12.1, E71.4, E116.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL G3456 DITA AA, WITH AFTERCOOLER, TURBOCHARGER, 685 BHP A/N: 445774	D180		NOX: PROCESS UNIT**	CO: 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; NOX: 221 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX + ROG: 4.8 GRAM/BHP-HR DIESEL (4) [RULE 2005, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; PM: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470, 6-1-2007]; PM10: 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, D12.1, E71.4, E116.1, H23.6, K67.16

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements  
 \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL G3456 DITA AA, WITH AFTERCOOLER, TURBOCHARGER, 685 BHP A/N: 445775	D181		NOX: PROCESS UNIT**	<b>CO:</b> 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; <b>NOX:</b> 221 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>NOX + ROG:</b> 4.8 GRAM/BHP-HR DIESEL (4) [RULE 2005, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>PM:</b> 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470, 6-1-2007]; <b>PM10:</b> 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, D12.1, E71.4, E116.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, FORD, MODEL ESG-642, WITH NSCR, MODEL L102, WITH AIR FUEL RATIO CONTROLLER, WITH CATALYTIC REDUCTION, 67 BHP A/N: 444735	D182		NOX: PROCESS UNIT**	<b>CO:</b> 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; <b>NOX:</b> 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; <b>NOX:</b> 437 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, D12.1, E71.4, E71.5, H23.12, K67.14

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements  
 \*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL 3306ATAACC, WITH AFTERCOOLER, TURBOCHARGER, 377 BHP A/N: 445546	D183		NOX: PROCESS UNIT**	CO: 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; NOX: 209 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX + ROG: 4.8 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; PM: 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470, 6-1-2007]; PM10: 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, D12.1, E71.4, E116.1, H23.6, K67.16

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL C-9 DITA, LOCATED AT NEMO SITE, WITH AFTERCOOLER, TURBOCHARGER, 398 BHP A/N: 459428	D223		NOX: PROCESS UNIT**	<b>CO:</b> 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; <b>NOX:</b> 136 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>NOX + ROG:</b> 3 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>PM:</b> 0.15 GRAM/BHP-HR DIESEL (5) [RULE 1470, 6-1-2007]; <b>PM10:</b> 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, C1.11, D12.1, E71.4, E116.1, H23.6, K67.16
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, CATERPILLAR, MODEL G3046 SITA, WITH NSCR,JOHNSON MATTHEY, MODEL QXE 10-8, A/F, GILL MODEL 120, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 367 BHP A/N: 478405	D259		NOX: PROCESS UNIT**	<b>CO:</b> 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; <b>NOX:</b> 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; <b>NOX:</b> 413 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, C1.11, D12.1, E71.5, E116.1, E202.3, H23.12, K67.14

- |   |   |
|---|---|
| <p>* (1) (1A) (1B) Denotes RECLAIM emission factor<br/>         (3) Denotes RECLAIM concentration limit<br/>         (5) (5A) (5B) Denotes command and control emission limit<br/>         (7) Denotes NSR applicability limit<br/>         (9) See App B for Emission Limits</p> | <p>(2) (2A) (2B) Denotes RECLAIM emission rate<br/>         (4) Denotes BACT emission limit<br/>         (6) Denotes air toxic control rule limit<br/>         (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)<br/>         (10) See section J for NESHAP/MACT requirements</p> |
|---|---|

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, NATURAL GAS, GENERAL MOTORS, MODEL VORTEC 8.1 L POWERTRAIN, WITH NSCR, CLEAN AIR, MODEL CQD0950BCCN40 WITH AIR/FUEL RATIO CONTROLLER, WITH CATALYTIC REDUCTION, TURBOCHARGER, 195 BHP A/N: 499582	D276		NOX: PROCESS UNIT**	CO: 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; NOX: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 390 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; ROG: 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, C1.11, D12.1, E71.5, E202.3, K67.14
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, DIESEL FUEL, CATERPILLAR, MODEL C9 ATAAC, SIX CYLINDERS, WITH AFTERCOOLER, TURBOCHARGER, 480 BHP A/N: 513584	D289		NOX: PROCESS UNIT**	CO: 2.6 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; NOX: 132 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX + ROG: 3 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; PM10: 0.15 GRAM/BHP-HR DIESEL (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470, 6-1-2007]	C1.1, C1.11, D12.1, E71.4, E116.1, H23.6, K67.16

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (3) Denotes RECLAIM concentration limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (7) Denotes NSR applicability limit  
 (9) See App B for Emission Limits  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (4) Denotes BACT emission limit  
 (6) Denotes air toxic control rule limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 1: INTERNAL COMBUSTION, INDUSTRIAL</b>					
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, LOCATED AT CARSLAND NORTH, NATURAL GAS, G248, RICH BURN, DOOSAN, MODEL D183TIC, WITH TWO NSCR, NGE WITH AIR/FUEL RATIO CONTROLLER, WITH CATALYTIC REDUCTION, TURBOCHARGER, 530 BHP WITH  A/N: 515138          GENERATOR, 395 KW	D290		NOX: PROCESS UNIT**	<b>CO:</b> 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1703 - PSD Analysis, 10-7-1988]; <b>NOX:</b> 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1703(a)(2) - PSD-BACT, 10-7-1988; <b>RULE 2005, 5-6-2005</b> ]; <b>NOX:</b> 575 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, C1.11, D12.1, E71.5, E175.3, E202.3, H23.12, I296.1, K67.25, K67.26
INTERNAL COMBUSTION ENGINE, EMERGENCY POWER, LOCATED AT CARSLAND NORTH, NATURAL GAS, G244, RICH BURN, DOOSAN, MODEL D146L, WITH TWO NSCR, NGE WITH AIR/FUEL RATIO CONTROLLER, WITH CATALYTIC REDUCTION, AFTERCOOLER, TURBOCHARGER, 402 BHP WITH  A/N: 515140          GENERATOR, 300 KW	D291		NOX: PROCESS UNIT**	<b>CO:</b> 2 GRAM/BHP-HR NATURAL GAS (4) [RULE 1703 - PSD Analysis, 10-7-1988]; <b>NOX:</b> 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1703(a)(2) - PSD-BACT, 10-7-1988; <b>RULE 2005, 5-6-2005</b> ]; <b>NOX:</b> 477 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; <b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> 1.5 GRAM/BHP-HR NATURAL GAS (4) [RULE 1303(a)(1) -BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	C1.1, C1.11, D12.1, E71.5, E175.3, E202.3, H23.12, I296.2, K67.25, K67.26

- |   |   |
|---|---|
| <p>* (1) (1A) (1B) Denotes RECLAIM emission factor<br/>         (3) Denotes RECLAIM concentration limit<br/>         (5) (5A) (5B) Denotes command and control emission limit<br/>         (7) Denotes NSR applicability limit<br/>         (9) See App B for Emission Limits</p> | <p>(2) (2A) (2B) Denotes RECLAIM emission rate<br/>         (4) Denotes BACT emission limit<br/>         (6) Denotes air toxic control rule limit<br/>         (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)<br/>         (10) See section J for NESHAP/MACT requirements</p> |
|---|---|

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, EAST UNIT # 2, NATURAL GAS, SUPERIOR, MODEL LND145P, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 12.57 MMBTU/HR WITH A/N: 370698  BURNER, INDUSTRIAL COMBUSTION, MODEL LNDG105, WITH LOW NOX BURNER	D16		NOX: LARGE SOURCE**	CO: 400 PPMV (5) [RULE 1146, 11-17-2000; RULE 1146, 9-5-2008]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 30 PPMV NATURAL GAS (3) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	D12.3, D12.4, H23.4, H23.12
BOILER, WEST UNIT # 2, NATURAL GAS, SUPERIOR, MODEL LND145S, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 9.95 MMBTU/HR WITH A/N: 405301  BURNER, INDUSTRIAL COMBUSTION, MODEL LNDG105, WITH LOW NOX BURNER	D17		NOX: PROCESS UNIT**	CO: 400 PPMV (5) [RULE 1146, 11-17-2000; RULE 1146, 9-5-2008]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 47.75 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	D12.4, H23.4, H23.12

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, EAST UNIT # 1, NATURAL GAS, SUPERIOR, MODEL LND145P, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 12.57 MMBTU/HR WITH A/N: 370699  BURNER, INDUSTRIAL COMBUSTION, MODEL LNDG105, WITH LOW NOX BURNER	D18		NOX: LARGE SOURCE**	CO: 400 PPMV (5) [RULE 1146, 11-17-2000; RULE 1146, 9-5-2008]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 30 PPMV NATURAL GAS (3) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	D12.3, D12.4, H23.4
BOILER, WEST UNIT # 1, NATURAL GAS, SUPERIOR, MODEL LND145S, WITH FLUE GAS RECIRCULATION, OXYGEN CONTENT CONTROL, 9.95 MMBTU/HR WITH A/N: 405302  BURNER, INDUSTRIAL COMBUSTION, MODEL LNDG105, WITH LOW NOX BURNER	D19		NOX: PROCESS UNIT**	CO: 400 PPMV (5) [RULE 1146, 11-17-2000; RULE 1146, 9-5-2008]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 47.75 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	D12.4, H23.4, H23.12

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.









## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, PARADISE PIER HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 1, 5 MMBTU/HR WITH A/N: 459430  BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D206		NOX: PROCESS UNIT**	CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 400 PPMV NATURAL GAS (5) [RULE 1146, 11-17-2000; RULE 1146, 9-5-2008]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012, 5-6-2005]; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	D12.4, H23.4, H23.12

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.





## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, PARADISE PIER HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 4, 5 MMBTU/HR WITH A/N: 459433          BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D211		NOX: PROCESS UNIT**	CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1) -BACT, 12-6-2002]; CO: 400 PPMV NATURAL GAS (5) [RULE 1146, 11-17-2000; RULE 1146, 9-5-2008]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012, 5-6-2005]; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	D12.4, H23.4, H23.12

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.









## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, DISNEYLAND HOTEL, NATURAL GAS, CAMUS HYDRONICS LIMITED, MODEL 5001-DFX, NO. 5, 5 MMBTU/HR WITH A/N: 473762  BURNER, BEKAERT COMBUSTION TECHNOLOGY, MODEL DF-5000	D221		NOX: PROCESS UNIT**	CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 400 PPMV NATURAL GAS (5) [RULE 1146, 11-17-2000; RULE 1146, 9-5-2008]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 12 PPMV NATURAL GAS (3) [RULE 2012, 5-6-2005]; NOX: 12 PPMV NATURAL GAS (4) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	C1.13, D12.4, H23.4, H23.12
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, STEAM X, MODEL DELCO, S/N VH0103, 0.28 MMBTU/HR A/N: 471807	D225		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, STEAM X, MODEL VANGUARD, S/N 10062708, 0.28 MMBTU/HR A/N: 471808	D226		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 407, 4-2-1982]	B59.2, C1.14, D12.8, K67.24

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, A&M EQUIPMENT SERVICE, MODEL AMHGD-2003, NO. 2,, S/N 15016495, 0.21 MMBTU/HR A/N: 471810	D228		NOX: PROCESS UNIT**	<b>CO:</b> 2000 PPMV (5A) [RULE 407, 4-2-1982]; <b>NOX:</b> 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 1, S/N 239325, 0.3 MMBTU/HR A/N: 471811	D229		NOX: PROCESS UNIT**	<b>CO:</b> 2000 PPMV (5A) [RULE 407, 4-2-1982]; <b>NOX:</b> 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 2, S/N 239326, 0.3 MMBTU/HR A/N: 471812	D230		NOX: PROCESS UNIT**	<b>CO:</b> 2000 PPMV (5A) [RULE 407, 4-2-1982]; <b>NOX:</b> 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 1, S/N 228121, 0.3 MMBTU/HR A/N: 471813	D231		NOX: PROCESS UNIT**	<b>CO:</b> 2000 PPMV (5A) [RULE 407, 4-2-1982]; <b>NOX:</b> 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 2, S/N 234517, 0.3 MMBTU/HR A/N: 471814	D232		NOX: PROCESS UNIT**	<b>CO:</b> 2000 PPMV (5A) [RULE 407, 4-2-1982]; <b>NOX:</b> 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; <b>PM:</b> 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 3, S/N 206382, 0.3 MMBTU/HR A/N: 471816	D233		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 4, S/N 266334, 0.3 MMBTU/HR A/N: 471817	D234		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 5, S/N 205669, 0.3 MMBTU/HR A/N: 471818	D235		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 6, S/N 206383, 0.3 MMBTU/HR A/N: 471820	D236		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 7, S/N 206385, 0.3 MMBTU/HR A/N: 471821	D237		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24

- |  |  |
|--|--|
| <ul style="list-style-type: none"> <li>* (1) (1A) (1B) Denotes RECLAIM emission factor</li> <li>(3) Denotes RECLAIM concentration limit</li> <li>(5) (5A) (5B) Denotes command and control emission limit</li> <li>(7) Denotes NSR applicability limit</li> <li>(9) See App B for Emission Limits</li> </ul> | <ul style="list-style-type: none"> <li>(2) (2A) (2B) Denotes RECLAIM emission rate</li> <li>(4) Denotes BACT emission limit</li> <li>(6) Denotes air toxic control rule limit</li> <li>(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)</li> <li>(10) See section J for NESHAP/MACT requirements</li> </ul> |
|--|--|

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 8, S/N 227965, 0.3 MMBTU/HR A/N: 471822	D238		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 9, S/N 228794, 0.3 MMBTU/HR A/N: 471823	D239		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 10 S/N 243798, 0.3 MMBTU/HR A/N: 471824	D240		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 281, NO. 4, S/N 20925, 0.56 MMBTU/HR A/N: 471829	D244		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.17, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, WALTERS, MODEL 247, NO. 4, S/N 20928, 0.56 MMBTU/HR A/N: 471840	D253		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, D12.8, K67.24

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 11, S/N 245187, 0.3 MMBTU/HR A/N: 478418	D255		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.18, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 12, S/N 247032, 0.3 MMBTU/HR A/N: 478419	D256		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.18, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO. 13, S/N 244141, 0.3 MMBTU/HR A/N: 478420	D257		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.18, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216, NO.14, S/N 244142, 0.3 MMBTU/HR A/N: 478421	D258		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.18, D12.8, K67.24

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
HEATER, CPI, NO. 1, NATURAL GAS, FULTON, MODEL FT0400-C, WITH LOW NOX BURNER, 5.128 MMBTU/HR A/N: 478416	D260		NOX: PROCESS UNIT**	CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 400 PPMV (5) [RULE 1146, 11-17-2000; RULE 1146, 9-5-2008]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 20 PPMV NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 24.57 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	C1.19, C1.21, D12.4, D29.1, E202.4, H23.9, H23.12
HEATER, CPI, NO. 2, NATURAL GAS, FULTON, MODEL FT0400-C, WITH LOW NOX BURNER, 5.128 MMBTU/HR A/N: 478417	D261		NOX: PROCESS UNIT**	CO: 50 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 400 PPMV (5) [RULE 1146, 11-17-2000; RULE 1146, 9-5-2008]; CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 20 PPMV NATURAL GAS (4) [RULE 2005, 5-6-2005]; NOX: 24.57 LBS/MMSCF NATURAL GAS (1) [RULE 2012, 5-6-2005]; PM: (9) [RULE 404, 2-7-1986]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	C1.19, C1.21, D12.4, D29.1, E202.4, H23.9

- |  |  |
|--|--|
| <ul style="list-style-type: none"> <li>* (1) (1A) (1B) Denotes RECLAIM emission factor</li> <li>(3) Denotes RECLAIM concentration limit</li> <li>(5) (5A) (5B) Denotes command and control emission limit</li> <li>(7) Denotes NSR applicability limit</li> <li>(9) See App B for Emission Limits</li> </ul> | <ul style="list-style-type: none"> <li>(2) (2A) (2B) Denotes RECLAIM emission rate</li> <li>(4) Denotes BACT emission limit</li> <li>(6) Denotes air toxic control rule limit</li> <li>(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)</li> <li>(10) See section J for NESHAP/MACT requirements</li> </ul> |
|--|--|

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 3, S/N 250379, 0.3 MMBTU/HR A/N: 487371	D262		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 4, S/N 250376, 0.3 MMBTU/HR A/N: 487373	D263		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 5, S/N 250375, 0.3 MMBTU/HR A/N: 487374	D264		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, NO. 6, S/N 250377, 0.3 MMBTU/HR A/N: 487375	D265		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.14, C1.16, D12.8, K67.24
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO.1, 0.16 MMBTU/HR A/N: 498054	D266		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.23, D12.8, K67.22

- |  |  |
|--|--|
| <ul style="list-style-type: none"> <li>* (1) (1A) (1B) Denotes RECLAIM emission factor</li> <li>(3) Denotes RECLAIM concentration limit</li> <li>(5) (5A) (5B) Denotes command and control emission limit</li> <li>(7) Denotes NSR applicability limit</li> <li>(9) See App B for Emission Limits</li> </ul> | <ul style="list-style-type: none"> <li>(2) (2A) (2B) Denotes RECLAIM emission rate</li> <li>(4) Denotes BACT emission limit</li> <li>(6) Denotes air toxic control rule limit</li> <li>(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)</li> <li>(10) See section J for NESHAP/MACT requirements</li> </ul> |
|--|--|

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO. 2, 0.16 MMBTU/HR A/N: 498055	D267		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO.3, 0.16 MMBTU/HR A/N: 498056	D268		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3E209, NO. 4, 0.16 MMBTU/HR A/N: 498057	D269		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE51, NO. 1, 0.175 MMBTU/HR A/N: 498058	D270		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 409, 8-7-1981]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE51, NO. 2, 0.175 MMBTU/HR A/N: 498059	D271		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.23, D12.8, K67.22

- |   |   |
|---|---|
| <p>* (1) (1A) (1B) Denotes RECLAIM emission factor<br/>         (3) Denotes RECLAIM concentration limit<br/>         (5) (5A) (5B) Denotes command and control emission limit<br/>         (7) Denotes NSR applicability limit<br/>         (9) See App B for Emission Limits</p> | <p>(2) (2A) (2B) Denotes RECLAIM emission rate<br/>         (4) Denotes BACT emission limit<br/>         (6) Denotes air toxic control rule limit<br/>         (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)<br/>         (10) See section J for NESHAP/MACT requirements</p> |
|---|---|

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE52, NO. 1, 0.219 MMBTU/HR A/N: 498060	D272		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE52, NO. 2, 0.219 MMBTU/HR A/N: 498061	D273		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.23, D12.8, K67.22
HEATER, SPACE HEATER TYPE, PORTABLE, DIESEL FUEL, DAYTON, MODEL 3VE52, NO. 2, 0.219 MMBTU/HR A/N: 498061	D274		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 409, 8-7-1981]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.23, D12.8, K67.22
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL HOT2-1100, NO. 1, S/N 250378, 0.16 MMBTU/HR A/N: 499580	D275		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2005, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 407, 4-2-1982]	B59.2, C1.24, D12.8, K67.22
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216X4, NO. 1, S/N 254070, 0.3 MMBTU/HR A/N: 504518	D284		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, K67.23

- |   |   |
|---|---|
| <p>* (1) (1A) (1B) Denotes RECLAIM emission factor<br/>         (3) Denotes RECLAIM concentration limit<br/>         (5) (5A) (5B) Denotes command and control emission limit<br/>         (7) Denotes NSR applicability limit<br/>         (9) See App B for Emission Limits</p> | <p>(2) (2A) (2B) Denotes RECLAIM emission rate<br/>         (4) Denotes BACT emission limit<br/>         (6) Denotes air toxic control rule limit<br/>         (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)<br/>         (10) See section J for NESHAP/MACT requirements</p> |
|---|---|

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216X4, NO. 2, S/N 254071, 0.3 MMBTU/HR A/N: 504519	D285		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216X4, NO. 3, S/N 254072, 0.3 MMBTU/HR A/N: 504520	D286		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 216X4, NO. 4, S/N 254073, 0.3 MMBTU/HR A/N: 504521	D287		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, AM CLEANING EQUIPMENT, MODEL AM-HGD-2403, S/N 15040755, 0.21 MMBTU/HR A/N: 504522	D288		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257084, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515325	D297		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX: 102 LBS/1000 GAL GASOLINE (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, I296.4, K67.23

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257411, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515326	D298		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX: 102 LBS/1000 GAL GASOLINE (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, I296.4, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257086, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515327	D299		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX: 102 LBS/1000 GAL GASOLINE (1); PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, I296.4, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257439, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515329	D300		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX: 102 LBS/1000 GAL GASOLINE (1); PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, I296.4, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257440, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515330	D301		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX: 102 LBS/1000 GAL GASOLINE (1); PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, I296.4, K67.23

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 2: EXTERNAL COMBUSTION, BOILERS, INDUSTRIAL</b>					
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257085, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515331	D302		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX: 102 LBS/1000 GAL GASOLINE (1) ; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, I296.4, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257126, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515332	D303		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX: 102 LBS/1000 GAL GASOLINE (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, I296.4, K67.23
BOILER, PRESSURE WASHER TYPE, PORTABLE, DIESEL FUEL, ALKOTA, MODEL 7205, S/N 257438, WITH 20 HP GASOLINE ICE DRIVING A PUMP, 0.353 MMBTU/HR A/N: 515333	D304		NOX: PROCESS UNIT**	CO: 2000 PPMV (5A) [RULE 407, 4-2-1982]; NOX: 19 LBS/1000 GAL DIESEL (1) [RULE 2012, 5-6-2005]; NOX: 102 LBS/1000 GAL GASOLINE (1) [RULE 2012, 5-6-2005]; PM: 0.1 GRAINS/SCF (5) [RULE 409, 8-7-1981]	B59.2, C1.16, C1.26, D12.8, I296.4, K67.23
<b>Process 3: ORGANIC SOLVENT SURFACE COATING</b>					
SPRAY COATING OPERATION, WATER WASH TYPE, WITH SPRAY BOOTH A/N: 12162X	D20			PM: (9) [RULE 404, 2-7-1986]; ROG: (9) [RULE 1107, 11-9-2001; RULE 1107, 1-6-2006; RULE 1136, 6-14-1996; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]	D322.2, H23.2, K67.3
SPRAY COATING OPERATION, FLOOR TYPE, WITH 24 EXHAUST FILTERS, EACH 20" X 25" X 2", WITH SPRAY BOOTH A/N: 214087	D21			PM: (9) [RULE 404, 2-7-1986]; ROG: (9) [RULE 1107, 11-9-2001; RULE 1107, 1-6-2006; RULE 1136, 6-14-1996; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]	A63.1, B27.4, C6.1, D322.1, E175.1, H23.2, K67.2

\* (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 3: ORGANIC SOLVENT SURFACE COATING</b>					
SPRAY COATING OPERATION, FLOOR TYPE, WITH 21 EXHUAST FILTERS, EACH 20" X 25" X 2", WITH SPRAY BOOTH A/N: 214086	D22			<b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> (9) [RULE 1107, 11-9-2001]; <i>RULE 1107, 1-6-2006; RULE 1136, 6-14-1996; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]</i>	A63.1, B27.4, C6.1, D322.1, E175.1, H23.2, K67.2
SPRAY COATING OPERATION, AUTOMOTIVE TYPE, WITH 22 EXHAUST FILTERS, EACH 20" X 25" X 2", WITH SPRAY BOOTH A/N: 19482X	D24			<b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> (9) [RULE 1107, 11-9-2001]; <i>RULE 1107, 1-6-2006; RULE 1136, 6-14-1996; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]</i>	C6.1, D322.1, E175.1, H23.2, K67.2
SPRAY COATING OPERATION, SPRAY BOOTH (PORTABLE INTRA-FACILITY), SHOP PRO, MODEL NO. 5410, FLOOR TYPE, WITH 2 EXHUAST FILTERS, EACH 20" X 20" X 1", AND A 1.5 HP BLOWER, WITH SPRAY BOOTH A/N:	D305			<b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> (9) [RULE 1107, 11-9-2001]; <i>RULE 1107, 1-6-2006; RULE 1136, 6-14-1996; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]</i>	A63.2, B27.5, C6.1, D322.1, E175.1, H23.2, K67.2
SPRAY COATING OPERATION, SPRAY SYSTEMS, MODEL NO. BB-96., FLOOR TYPE, WITH 20 EXHUAST FILTERS, EACH 20" X 25", AND A 0.75 HP BLOWER, WITH SPRAY BOOTH A/N:	D306			<b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> (9) [RULE 1107, 11-9-2001]; <i>RULE 1107, 1-6-2006; RULE 1136, 6-14-1996; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]</i>	A63.2, B27.5, C6.1, D322.1, E175.1, H23.2, K67.2
SPRAY COATING OPERATION, SPRAY SYSTEMS, INC., MODEL NO. I-1487, FLOOR TYPE, WITH 24 EXHUAST FILTERS, EACH 20" X 25", AND A 2 HP BLOWER, WITH SPRAY BOOTH A/N:	D307			<b>PM:</b> (9) [RULE 404, 2-7-1986]; <b>ROG:</b> (9) [RULE 1107, 11-9-2001]; <i>RULE 1107, 1-6-2006; RULE 1136, 6-14-1996; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]</i>	A63.2, B27.5, C6.1, D322.1, E175.1, H23.2, K67.2

- |   |   |
|---|---|
| <p>* (1) (1A) (1B) Denotes RECLAIM emission factor<br/>         (3) Denotes RECLAIM concentration limit<br/>         (5) (5A) (5B) Denotes command and control emission limit<br/>         (7) Denotes NSR applicability limit<br/>         (9) See App B for Emission Limits</p> | <p>(2) (2A) (2B) Denotes RECLAIM emission rate<br/>         (4) Denotes BACT emission limit<br/>         (6) Denotes air toxic control rule limit<br/>         (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)<br/>         (10) See section J for NESHAP/MACT requirements</p> |
|---|---|

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 3: ORGANIC SOLVENT SURFACE COATING</b>					
SPRAY COATING OPERATION, SOLVENT, DISNEYLAND HOTEL, AUTOMOTIVE TYPE, WITH 44 EXHAUST FILTERS, EACH 20" X 25" X 1.5", WITH SPRAY BOOTH A/N: 241140	D165			PM: (9) [RULE 404, 2-7-1986]; ROG: (9) [RULE 1107, 11-9-2001]; RULE 1107, 1-6-2006; RULE 1136, 6-14-1996; RULE 1145, 2-14-1997; RULE 1145, 12-4-2009; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]	B27.4, C1.9, C1.10, C6.1, D322.1, E175.2, H23.2, K67.2, K67.8
<b>Process 4: PETROLEUM MARKETING, CONSUMER FLEET FUELING</b>					
<b>System 1: FUEL STORAGE AND DISPENSING SYSTEMS</b>					
STORAGE TANK, UNDERGROUND, GASOLINE, NOT METHANOL COMPATIBLE, WITH OPW (VR-102-E), 10000 GALS A/N:	D36				D330.1, E193.1, J373.1, K67.20
STORAGE TANK, UNDERGROUND, GASOLINE, NOT METHANOL COMPATIBLE, WITH OPW (VR-102-E), 10000 GALS A/N:	D40				D330.1, E193.1, J373.1, K67.20
FUEL DISPENSING NOZZLE, BALANCE TYPE PHASE II CONTROL, GASOLINE, WITH BALANCE RETRACTOR (G-70-52-AM), WITH PHASE II VAPOR RECOVERY SYSTEM A/N:	D88				D330.1, E193.2, J110.1, J373.1, K67.20
FUEL DISPENSING NOZZLE, BALANCE TYPE PHASE II CONTROL, GASOLINE, WITH BALANCE RETRACTOR (G-70-52-AM), WITH PHASE II VAPOR RECOVERY SYSTEM A/N:	D89				D330.1, E193.1, E193.2, J110.1, J373.1

- |   |   |
|---|---|
| <p>* (1) (1A) (1B) Denotes RECLAIM emission factor<br/>         (3) Denotes RECLAIM concentration limit<br/>         (5) (5A) (5B) Denotes command and control emission limit<br/>         (7) Denotes NSR applicability limit<br/>         (9) See App B for Emission Limits</p> | <p>(2) (2A) (2B) Denotes RECLAIM emission rate<br/>         (4) Denotes BACT emission limit<br/>         (6) Denotes air toxic control rule limit<br/>         (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)<br/>         (10) See section J for NESHAP/MACT requirements</p> |
|---|---|

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 4: PETROLEUM MARKETING, CONSUMER FLEET FUELING</b>					
FUEL DISPENSING NOZZLE, VACUUM ASSIST PHASE II CONTROL, GASOLINE, WITH HEALY PHASE II EVR NOT INCLUDING ISD (VR0201-G), WITH PHASE II VAPOR RECOVERY SYSTEM A/N:	D90				D330.1, E193.1, E193.2, J110.1, J373.1, K67.19
DISPENSE MOBILE FUELER, GASOLINE, FRANZEN-HILL (G-70-193), WITH TWO HEALY 100 JET PUMPS, 400 GALS; WIDTH: 3 FT 8 IN; HEIGHT: 3 FT 10 IN; LENGTH: 7 FT 1 IN A/N: 367066	D147				C1.6, C1.7, E71.2, J110.1, J397.1, K67.6
FUEL DISPENSING NOZZLE, GASOLINE, EQUIPPED WITH PHASE II VAPOR RECOVERY, HEALY, MODEL 400 ORVR A/N: 367066	D148				
<b>Process 5: FABRICATED METALS</b>					
<b>System 1:</b>					
ABRASIVE BLASTING, OPEN, SAND WITH A/N: 193050  ABRASIVE BLASTING NOZZLE, DIAMETER: .38 IN	D44			<b>PM: (9) [RULE 1140, 2-1-1980; RULE 1140, 8-2-1985; RULE 405, 2-7-1986]</b>	D323.1, K67.5

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 5: FABRICATED METALS</b>					
ABRASIVE BLASTING, ROOM, SAND, BAGHOUSE SERVICES, WITH 3000 LB POT, WIDTH: 15 FT 8 IN; HEIGHT: 15 FT 11 IN; LENGTH: 28 FT WITH  A/N: 385807  ABRASIVE BLASTING NOZZLE, 2, MAXIMUM WORKING PRESSURE OF 120 PSI, DIAMETER: .63 IN	D156	C158		PM: (9) [RULE 404, 2-7-1986]	B27.2, K67.11
BAGHOUSE, UNITED AIR SPECIALIST, MODEL SBD24-3, PULSE JET CLEANING, SERIAL NO. 60042645, 7440 SQ.FT.; 24 CARTRIDGE  A/N: 385808	C158	D156		PM: (9) [RULE 404, 2-7-1986]	C6.2, D322.3, D381.1, E102.1, K67.10
ABRASIVE BLASTING, CARBON DIOXIDE (DRY ICE), COLDJET, MODEL 2000, WITH 40 POUND CAPACITY HOPPER WITH  A/N: 404957  ABRASIVE BLASTING NOZZLE, 1, WITH A MAX. THROAT AREA OF 0.068 IN2, 140 PSIA	D170			PM: (9) [RULE 1140, 2-1-1980; RULE 1140, 8-2-1985; RULE 405, 2-7-1986]	B59.1, D381.1, H23.5, K67.11
<b>Process 7: FABRICATED METALS, MACHINING OPERATIONS</b>					
<b>System 1:</b>					
PLASMA ARC CUTTER, DUAL CARRIAGE TYPE, WITH A FOUR TORCH CAPACITY  A/N: 243063	D48	C49		PM: (9) [RULE 405, 2-7-1986]	D323.1

- |   |   |
|---|---|
| <p>* (1) (1A) (1B) Denotes RECLAIM emission factor<br/>         (3) Denotes RECLAIM concentration limit<br/>         (5) (5A) (5B) Denotes command and control emission limit<br/>         (7) Denotes NSR applicability limit<br/>         (9) See App B for Emission Limits</p> | <p>(2) (2A) (2B) Denotes RECLAIM emission rate<br/>         (4) Denotes BACT emission limit<br/>         (6) Denotes air toxic control rule limit<br/>         (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)<br/>         (10) See section J for NESHAP/MACT requirements</p> |
|---|---|

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 7: FABRICATED METALS, MACHINING OPERATIONS</b>					
ELECTROSTATIC PRECIPITATOR, TEPCO TRION, MODEL T5200, WITH A 3 H.P. BLOWER A/N: 249015	C49	D48		PM: (9) [RULE 404, 2-7-1986]	D323.1, E202.1
<b>Process 8: SMOKE EFFECTS</b>					
<b>System 1:</b>					
FILTER, HEPA, FARR A/N: 288923	C96			PM: (9) [RULE 404, 2-7-1986]	D322.1, D323.1, K67.2
<b>Process 9: R-219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECIFIC RULES</b>					
<b>System 1:</b>					
RULE 219 EXEMPT EQUIPMENT, AIR CONDITIONING UNITS, COMFORT A/C	E102				H23.3
RULE 219 EXEMPT EQUIPMENT, PRINTING EQUIPMENT, WITH RELATED COATING, LAMINATING AND DRYING EQUIPMENT	E104			ROG: (9) [RULE 1130.1, 12-13-1996; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]	
RULE 219 EXEMPT EQUIPMENT, CLEANING EQUIPMENT, SMALL, UNHEATED, NON-CONVEYORIZED	E105			ROG: (9) [RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]	H23.1
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS	E107			ROG: (9) [RULE 1113, 11-8-1996; RULE 1113, 7-13-2007; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]	K67.1
RULE 219 EXEMPT EQUIPMENT, HAND LAY, BRUSH AND ROLL UP RESIN OPERATIONS	E108			ROG: (9) [RULE 1162, 11-17-2000; RULE 1162, 7-8-2005; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]	
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, LOW USE OR EMISSIONS	E111			ROG: (9) [RULE 1106.1, 2-12-1999; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]	

- \* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
<b>Process 9: R-219 EXEMPT EQUIPMENT SUBJECT TO SOURCE SPECIFIC RULES</b>					
RULE 219 EXEMPT EQUIPMENT, LAMINATING EQUIPMENT, LOW USE OR EMISSIONS	E112			<b>ROG: (9) [RULE 1168, 1-7-2005; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]</b>	
RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, LOW USE OR EMISSIONS	E113			<b>ROG: (5) [RULE 1128, 3-8-1996; RULE 1171, 11-7-2003; RULE 1171, 5-1-2009]</b>	

\* (1) (1A) (1B) Denotes RECLAIM emission factor  
 (2) (2A) (2B) Denotes RECLAIM emission rate  
 (3) Denotes RECLAIM concentration limit  
 (4) Denotes BACT emission limit  
 (5) (5A) (5B) Denotes command and control emission limit  
 (6) Denotes air toxic control rule limit  
 (7) Denotes NSR applicability limit  
 (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)  
 (9) See App B for Emission Limits  
 (10) See section J for NESHAP/MACT requirements

\*\* Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

# **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

## **SECTION D: DEVICE ID INDEX**

**The following sub-section provides an index  
to the devices that make up the facility  
description sorted by device ID.**

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D1	1	1	1
D2	1	1	1
D4	1	1	1
D7	1	1	1
D8	1	1	1
D10	2	1	1
D12	2	1	1
D15	2	1	1
D16	26	2	0
D17	26	2	0
D18	27	2	0
D19	27	2	0
D20	51	3	0
D21	51	3	0
D22	52	3	0
D24	52	3	0
D36	53	4	1
D40	53	4	1
D44	54	5	1
D48	55	7	1
C49	56	7	1
D88	53	4	1
D89	53	4	1
D90	54	4	1
D95	2	1	1
C96	56	8	1
D98	2	1	1
D99	3	1	1
D101	3	1	1
E102	56	9	1
E104	56	9	1
E105	56	9	1
E107	56	9	1
E108	56	9	1
E111	56	9	1

**FACILITY PERMIT TO OPERATE  
 DISNEYLAND RESORT**

**SECTION D: DEVICE ID INDEX**

<b>Device Index For Section D</b>			
<b>Device ID</b>	<b>Section D Page No.</b>	<b>Process</b>	<b>System</b>
E112	57	9	1
E113	57	9	1
D115	3	1	1
D116	4	1	1
D117	4	1	1
D118	5	1	1
D119	5	1	1
D120	6	1	1
D121	6	1	1
D122	7	1	1
D123	7	1	1
D124	8	1	1
D125	8	1	1
D126	9	1	1
D127	9	1	1
D128	10	1	1
D129	10	1	1
D131	11	1	1
D133	11	1	1
D134	12	1	1
D135	28	2	0
D137	29	2	0
D138	30	2	0
D139	31	2	0
D147	54	4	1
D148	54	4	1
D149	12	1	1
D152	13	1	1
D153	13	1	1
D156	55	5	1
C158	55	5	1
D159	13	1	1
D160	14	1	1
D162	14	1	1
D163	14	1	1

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: DEVICE ID INDEX

Device Index For Section D			
Device ID	Section D Page No.	Process	System
D164	14	1	1
D165	53	3	0
D168	15	1	1
D169	15	1	1
D170	55	5	1
D172	16	1	1
D173	16	1	1
D174	17	1	1
D175	17	1	1
D176	18	1	1
D177	25	1	2
D178	18	1	1
D179	19	1	1
D180	19	1	1
D181	20	1	1
D182	20	1	1
D183	21	1	1
D206	32	2	0
D207	33	2	0
D209	34	2	0
D211	35	2	0
D214	36	2	0
D215	37	2	0
D217	38	2	0
D219	39	2	0
D221	40	2	0
D223	22	1	1
D225	40	2	0
D226	40	2	0
D228	41	2	0
D229	41	2	0
D230	41	2	0
D231	41	2	0
D232	41	2	0
D233	42	2	0

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: DEVICE ID INDEX

<b>Device Index For Section D</b>			
<b>Device ID</b>	<b>Section D Page No.</b>	<b>Process</b>	<b>System</b>
D234	42	2	0
D235	42	2	0
D236	42	2	0
D237	42	2	0
D238	43	2	0
D239	43	2	0
D240	43	2	0
D244	43	2	0
D253	43	2	0
D255	44	2	0
D256	44	2	0
D257	44	2	0
D258	44	2	0
D259	22	1	1
D260	45	2	0
D261	45	2	0
D262	46	2	0
D263	46	2	0
D264	46	2	0
D265	46	2	0
D266	46	2	0
D267	47	2	0
D268	47	2	0
D269	47	2	0
D270	47	2	0
D271	47	2	0
D272	48	2	0
D273	48	2	0
D274	48	2	0
D275	48	2	0
D276	23	1	1
D284	48	2	0
D285	49	2	0
D286	49	2	0
D287	49	2	0

**FACILITY PERMIT TO OPERATE  
 DISNEYLAND RESORT  
 SECTION D: DEVICE ID INDEX**

<b>Device Index For Section D</b>			
<b>Device ID</b>	<b>Section D Page No.</b>	<b>Process</b>	<b>System</b>
D288	49	2	0
D289	23	1	1
D290	24	1	1
D291	24	1	1
D292	25	1	1
D297	49	2	0
D298	50	2	0
D299	50	2	0
D300	50	2	0
D301	50	2	0
D302	51	2	0
D303	51	2	0
D304	51	2	0
D305	52	3	0
D306	52	3	0
D307	52	3	0

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

#### **FACILITY CONDITIONS**

F1.1 The operator shall limit the material processed to no more than 2000 lb(s) in any one year.

For the purpose of this condition, material processed shall be defined as 1,1,1 trichloroethane.

[H&S 44300, 7-1-1988]

F9.1 Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:

(a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or

(b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[**RULE 401, 3-2-1984**; RULE 401, 11-9-2001]

F14.2 The operator shall not purchase diesel fuel containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

[RULE 431.2, 9-15-2000]

F14.3 The operator shall not burn fuel oil containing sulfur compounds in excess of 0.05 percent by weight.

[**RULE 431.2, 5-4-1990**; RULE 431.2, 9-15-2000]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

F48.1 The operator shall not operate at this facility non chain driven, uncontrolled charbroiler exceeding the opacity limits specified in Rule 401.

[RULE 401, 3-2-1984; RULE 401, 11-9-2001]

#### DEVICE CONDITIONS

##### A. Emission Limits

A63.1 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
VOC	Less than or equal to 10 LBS IN ANY ONE DAY

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D21, D22]

A63.2 The operator shall limit emissions from this equipment as follows:

CONTAMINANT	EMISSIONS LIMIT
VOC	Less than or equal to 14 LBS IN ANY ONE MONTH

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

#### **The operator shall comply with the terms and conditions set forth below:**

For the purposes of this condition, the limit(s) shall be based on the total combined emissions from equipment under device numbers D305, D306, and D307.

To ensure compliance with the monthly Volatile Organic Compound (VOC) emission limit(s) of this condition, the operator shall comply with the following recordkeeping requirements:

- (1) The operator shall comply with Rule 109 (Recordkeeping for Volatile Organic Compound Emissions).
- (2) Within 14 calendar days after the end of each month, the operator shall total and record VOC emissions for the month from all equipment and operations covered by the monthly emission limit(s). The record shall include any procedures used to account for control device efficiencies and/or waste disposal. It shall be signed and certified for accuracy by the highest ranking individual responsible for compliance with District rules.
- (3) The operator shall maintain a single list which includes only the name and address of each person from whom the facility acquired VOC-containing material regulated by the District that was used or stored at the facility during the preceding 12 months.
- (4) The operator shall retain all purchase invoices for all VOC-containing material used or stored at the facility, and all waste manifests for all waste VOC-containing material removed from the facility, for five years.

[**RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D305, D306, D307]

#### **B. Material/Fuel Type Limits**

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

B27.2 The operator shall not use abrasive material (except for abrasive containing nickel ) containing any carcinogenic compounds identified in the SCAQMD Rule 1401, as amended 18-aug-2000.

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D156]

B27.4 The operator shall not use materials containing any compounds identified in the SCAQMD Rule 1401, as amended 12/07/1990.

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D21, D22, D165]

B27.5 The operator shall not use materials containing any compounds identified in the SCAQMD Rule 1401 (except for those compounds listed below), as amended 09/10/2010.

COMPOUND	CAS NO.
Zinc and Zinc Compounds	7440-66-6

[RULE 1401, 9-10-2010]

[Devices subject to this condition : D305, D306, D307]

B59.1 The operator shall only use the following material(s) in this device :

Diesel fuel

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[RULE 1140, 8-2-1985]

[Devices subject to this condition : D170]

B59.2 The operator shall only use the following material(s) in this device :

diesel fuel or bio-diesel

[**RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]

[Devices subject to this condition : D225, D226, D228, D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D244, D253, D255, D256, D257, D258, D262, D263, D264, D265, D266, D267, D268, D269, D270, D271, D272, D273, D274, D275, D284, D285, D286, D287, D288, D297, D298, D299, D300, D301, D302, D303, D304]

#### **C. Throughput or Operating Parameter Limits**

C1.1 The operator shall limit the operating time to no more than 200 hour(s) in any one year.

[RULE 1110.2, 7-9-2010; **RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 2005, 5-6-2005**]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D15, D95, D99, D101, D115, D116, D117, D118, D119, D120, D121, D122, D123, D124, D125, D126, D127, D128, D129, D131, D133, D134, D149, D152, D153, D160, D168, D169, D172, D173, D174, D175, D176, D178, D179, D180, D181, D182, D183, D223, D259, D276, D289, D290, D291, D292]

C1.2 The operator shall limit the operating time to no more than 125 hour(s) in any one year.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996]**

[Devices subject to this condition : D10]

C1.3 The operator shall limit the operating time to no more than 100 hour(s) in any one year.

**[RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996]**

[Devices subject to this condition : D98]

C1.6 The operator shall limit the gasoline dispensed to no more than 240000 gallon(s) per year.

[RULE 1401, 8-18-2000]

[Devices subject to this condition : D147]

C1.7 The operator shall limit the gasoline dispensed to no more than 20000 gallon(s) in any one calendar month.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[**RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D147]

C1.8 The operator shall limit the operating time to no more than 199 hour(s) in any one year.

[RULE 1110.2, 7-9-2010; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996**]

[Devices subject to this condition : D159, D164]

C1.9 The operator shall limit the coating and solvent usage to no more than 4 gallon(s) per day.

[**RULE 1303(b)(2)-Offset, 5-10-1996**]

[Devices subject to this condition : D165]

C1.10 The operator shall limit the coating and solvent usage to no more than 88 gallon(s) per month.

[**RULE 1303(b)(2)-Offset, 5-10-1996**]

[Devices subject to this condition : D165]

C1.11 The operator shall limit the maintenance testing to no more than 50 hour(s) in any one year.

[RULE 1303, 10-20-2000; **RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1470, 6-1-2007; RULE 1703(a)(2) - PSD-BACT, 10-7-1988]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D95, D149, D160, D169, D173, D174, D175, D176, D223, D259, D276, D289, D290, D291, D292]

C1.12 The operator shall limit the operating time to no more than 1092 in any one calendar year.

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D177]

C1.13 The operator shall limit the natural gas fuel usage to no more than 15.569 MM cubic feet in any one calendar month.

The fuel usage limit of 15.569 mmcf/month is the total fuel to be used in the five boilers.

[**RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D214, D215, D217, D219, D221]

C1.14 The operator shall limit the operating time to no more than 300 hour(s) in any one month.

[**RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005; **RULE 2012, 5-6-2005**]

[Devices subject to this condition : D225, D226, D228, D229, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D244, D253, D262, D263, D264, D265]

C1.16 The operator shall limit the operating time to no more than 22 hour(s) in any one day.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]**

[Devices subject to this condition : D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D255, D256, D257, D258, D262, D263, D264, D265, D284, D285, D286, D287, D288, D297, D298, D299, D300, D301, D302, D303, D304]

C1.17 The operator shall limit the operating time to no more than 12 hour(s) in any one day.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]**

[Devices subject to this condition : D244]

C1.18 The operator shall limit the operating time to no more than 330 hour(s) in any one month.

**[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]**

[Devices subject to this condition : D255, D256, D257, D258]

C1.19 The operator shall limit the fuel usage to no more than 6.156 MM cubic feet in any one calendar month.

This limit shall be based on the total combined limit for equipment D260 and D261.

This equipment shall only use natural gas as a fuel.

The operator shall identify the primary and secondary heater fuel usage..

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[**RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D260, D261]

- C1.20 The operator shall limit the maintenance testing to no more than 30 hour(s) in any one year.

[RULE 1303(a)(1)-BACT, 12-6-2002; **RULE 1303(b)(1)-Modeling, 5-10-1996**; RULE 1470, 6-1-2007]

[Devices subject to this condition : D15, D99, D153, D168]

- C1.21 The operator shall limit the fuel usage to no more than 2.637 MM cubic feet in any one calendar month.

This equipment shall only use natural gas as a fuel.

The operator shall identify the primary and secondary heater.

This condition only applies to the secondary heater.

[**RULE 1303(b)(2)-Offset, 5-10-1996**; RULE 1303(b)(2)-Offset, 12-6-2002]

[Devices subject to this condition : D260, D261]

- C1.22 The operator shall limit the maintenance testing to no more than 34 hour(s) in any one year.

[RULE 1470, 6-1-2007]

[Devices subject to this condition : D152, D164, D172]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

C1.23 The operator shall limit the operating time to no more than 200 hour(s) in any one calendar month.

**[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D266, D267, D268, D269, D270, D271, D272, D273, D274]

C1.24 The operator shall limit the operating time to no more than 160 hour(s) in any one calendar month.

**[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D275]

C1.26 The operator shall limit the operating time to no more than 572 hour(s) in any one month.

**[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005; RULE 2012, 5-6-2005]**

[Devices subject to this condition : D284, D285, D286, D287, D288, D297, D298, D299, D300, D301, D302, D303, D304]

C6.1 The operator shall use this equipment in such a manner that the differential pressure being monitored, as indicated below, does not exceed 0.25 inches water column.

To comply with this condition, the operator shall install and maintain a(n) differential pressure gauge to accurately indicate the differential pressure across the filters.

The operator shall determine and record the parameter being monitored once every 7 days.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 1303(a)(1)-BACT, 5-10-1996]**

[Devices subject to this condition : D21, D22, D24, D165, D305, D306, D307]

C6.2 The operator shall use this equipment in such a manner that the differential pressure being monitored, as indicated below, does not exceed 5 inches water column.

To comply with this condition, the operator shall install and maintain a(n) differential pressure gauge to accurately indicate the differential pressure across the filters.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : C158]

C177.1 The operator shall set and maintain the fuel injection timing of the engine at 4 degrees retarded relative to standard timing.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : D7, D8, D10, D15, D95, D98, D99, D153, D160, D162, D163]

#### **D. Monitoring/Testing Requirements**

D12.1 The operator shall install and maintain a(n) timer to accurately indicate the elapsed operating time of the engine.

**[RULE 1110.2, 7-9-2010; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;  
RULE 1703(a)(2) - PSD-BACT, 10-7-1988; RULE 2005, 5-6-2005; RULE 2012,  
5-6-2005]**

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D1, D2, D4, D7, D8, D10, D12, D15, D95, D98, D99, D101, D115, D116, D117, D118, D119, D120, D121, D122, D123, D124, D125, D126, D127, D128, D129, D131, D133, D134, D149, D152, D153, D159, D160, D162, D163, D164, D168, D169, D172, D173, D174, D175, D176, D177, D178, D179, D180, D181, D182, D183, D223, D259, D276, D289, D290, D291, D292]

- D12.3 The operator shall install and maintain a(n) flow meter to accurately indicate the flue gas flow in the flue gas recirculation system.

For the purpose of this condition a flue gas flow regulator that indicates the percent open setting in the FGR system may be used instead of a flow meter.

**[RULE 1303(a)(1)-BACT, 5-10-1996]**

[Devices subject to this condition : D16, D18]

- D12.4 The operator shall install and maintain a(n) non-resettable totalizing fuel flow meter to accurately indicate the fuel usage of the equipment.

**[RULE 2012, 5-6-2005]**

[Devices subject to this condition : D16, D17, D18, D19, D206, D207, D209, D211, D214, D215, D217, D219, D221, D260, D261]

- D12.8 The operator shall install and maintain a(n) timer to accurately indicate the elapsed operating time from the pressure washer.

**[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005; RULE 2012, 5-6-2005]**

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D225, D226, D228, D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D244, D253, D255, D256, D257, D258, D262, D263, D264, D265, D266, D267, D268, D269, D270, D271, D272, D273, D274, D275, D284, D285, D286, D287, D288, D297, D298, D299, D300, D301, D302, D303, D304]

D29.1 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NOX emissions	District method 100.1	District-approved averaging time	Outlet
CO emissions	District method 100.1	District-approved averaging time	Outlet

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

A. SOURCE TESTING SHALL BE CONDUCTED WITHIN 30 DAYS AFTER ACHIEVING MAXIMUM PRODUCTION RATE AT WHICH THE EQUIPMENT WILL BE OPERATED, BUT NO LATER THAN 90 DAYS AFTER INITIAL START-UP

B. THE SOURCE TEST SHALL BE DONE TO VERIFY EMISSIONS LIMITS FOR NOX AND CO CO, 20 PPMV AND 50 PPMV RESPECTIVELY

C. THE TEST SHALL BE CONDUCTED FOR 15 MINUTES EACH WHILE OPERATING AT NORMAL LOAD, HIGH, LOW AND AVERAGE FIRING RATES

D. TWO COMPLETE COPIES OF SOURCE TEST REPORTS (INCLUDE THE APPLICATION NUMBER AND A COPY OF THE PERMIT IN THE REPORT) SHALL BE SUBMITTED TO THE DISTRICT (ADDRESSED TO SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT, ATTN: ROY OLIVARES, P.O. BOX 4941, DIAMOND BAR, CA 91765). THE RESULTS IN WRITING SHALL BE SUBMITTED WITHIN 45 DAYS AFTER THE SOURCE TEST IS COMPLETED. IT SHALL INCLUDE, BUT NOT LIMITED TO EMISSIONS RATE IN POUNDS PER HOUR AND CONCENTRATION IN PPMV AT THE OUTLET OF THE HEATER

E. TESTING LABORATORY CERTIFIED BY THE CALIFORNIA AIR RESOURCES BOARD IN THE REQUIRED TEST METHODS FOR CRITERIA POLLUTANT TO BE MEASURED, AND IN COMPLIANCE WITH DISTRICT RULE 304 (NO CONFLICT OF INTEREST) SHALL CONDUCT THE TEST

F. SAMPLING FACILITIES SHALL COMPLY WITH THE ATTACHED AQMD "GUIDELINES FOR CONSTRUCTION OF SAMPLING AND TESTING FACILITIES", PURSUANT TO RULE 217.

**[RULE 1146, 11-17-2000; RULE 1146, 9-5-2008; RULE 1303(a)(1)-BACT, 5-10-1996;  
RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005, 5-6-2005]**

[Devices subject to this condition : D260, D261]

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

D322.1 The operator shall perform a weekly inspection of the equipment and filter media for leaks, broken or torn filter media, and improperly installed filter media.

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : D21, D22, D24, C96, D165, D305, D306, D307]

D322.2 The operator shall perform a weekly inspection to check for the water wash integrity.

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : D20]

D322.3 The operator shall perform annual inspection of the equipment and filter media for leaks, broken or torn filter media, and improperly installed filter media.

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : C158]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

D323.1 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on a semi-annual basis, at least, unless the equipment did not operate during the entire semi-annual period. The routine semi-annual inspection shall be conducted while the equipment is in operation and during daylight hours.

If any visible emissions (not including condensed water vapor) are detected that last more than three minutes in any one hour, the operator shall verify and certify within 24 hours that the equipment causing the emission and any associated air pollution control equipment are operating normally according to their design and standard procedures and under the same conditions under which compliance was achieved in the past, and either:

- 1). Take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit; or
- 2). Have a CARB-certified smoke reader determine compliance with the opacity standard, using EPA Method 9 or the procedures in the CARB manual "Visible Emission Evaluation", within three business days and report any deviations to AQMD.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

- 1). Stack or emission point identification;
- 2). Description of any corrective actions taken to abate visible emissions;
- 3). Date and time visible emission was abated; and
- 4). All visible emission observation records by operator or a certified smoke reader.

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : D44, D48, C49, C96, D177]

D330.1 The operator shall have a person that has been trained in accordance with Rule 461 conduct a semi-annual inspection of the gasoline transfer and dispensing equipment. The first inspection shall be in accordance with Rule 461, Attachment B, the second inspection shall be in accordance with Rule 461, Attachment C, and the subsequent inspections shall alternate protocols. The operator shall keep records of the inspection and the repairs in accordance to Rule 461 and Section K of this Permit.

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : D36, D40, D88, D89, D90]

D381.1 The operator shall conduct an inspection for visible emissions from all stacks and other emission points of this equipment whenever there is a public complaint of visible emissions, whenever visible emissions are observed, and on an annual basis, at least, unless the equipment did not operate during the entire annual period. The routine annual inspection shall be conducted while the equipment is in operation and during daylight hours. If any visible emissions (not including condensed water vapor) are detected, the operator shall take corrective action(s) that eliminates the visible emissions within 24 hours and report the visible emissions as a potential deviation in accordance with the reporting requirements in Section K of this permit.

The operator shall keep the records in accordance with the recordkeeping requirements in Section K of this permit and the following records:

- 1). Stack or emission point identification;
- 2). Description of any corrective actions taken to abate visible emissions; and
- 3). Date and time visible emission was abated.

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : C158, D170]

#### **E. Equipment Operation/Construction Requirements**

E71.1 The operator shall only operate this equipment during emergencies resulting in an interruption of service of the primary power supply or during stage II or III electrical emergency declared by the California Independent system operator (in addition to maintenance and testing of this engine)..

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : D149, D169, D173]

E71.2 The operator shall only operate this equipment using the manufacturers recommendation for the installation, operation and maintenance of the phase one and phase two vapor recovery equipment. The manufacturers manuals shall be readily accessible on site and made available to District representatives upon request.

**[RULE 461, 6-3-2005; RULE 461, 3-7-2008]**

[Devices subject to this condition : D147]

E71.3 The operator shall only operate this equipment during operation beyond 50 hours per year for maintenance and testing is allowed only in the event of loss of grid power or up to 30 minutes prior to a rotating outage provided that: 1) the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time; and 2) the engine is located in a utility service block that is subject to the rotating outage.

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : D174]

- E71.4 The operator shall only operate this equipment during operation beyond 50 hours per year for maintenance and testing is allowed only in the event of loss of grid power or up to 30 minutes prior to a rotating outage provided that: 1) the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time; and 2) the engine is located in a utility service block that is subject to the rotating outage.

Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470,  
6-1-2007]**

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D95, D149, D160, D169,  
D175, D179, D180, D181, D182, D183, D223, D289]

- E71.5 The operator shall only operate this equipment during operation beyond 50 hours per year, this engine shall only operate during emergencies resulting in an interruption of service of the primary power supply or during stage II or III electrical emergency declared by the electrical grid operator. Operators may use this engine as part of interruptible electrical service program.

An interruptible electric service program is a program in which the facility receives payment or reduced rate in return for a requirement to reduce its electric load on the grid when requested to do so by the utility, the grid operator, or other organization.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1703(a)(2) - PSD-BACT, 10-7-1988]**

[Devices subject to this condition : D176, D182, D259, D276, D290, D291, D292]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

#### The operator shall comply with the terms and conditions set forth below:

E71.6 The operator shall only operate this equipment during operation beyond 30 hours per year for maintenance and testing is allowed only in the event of loss of grid power or up to 30 minutes prior to a rotating outage provided that: 1) the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time; and 2) the engine is located in a utility service block that is subject to the rotating outage.

Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470, 6-1-2007]

[Devices subject to this condition : D15, D98, D99, D133, D153, D159, D162, D163, D168]

E71.7 The operator shall only operate this equipment during operation beyond 20 hours per year for maintenance and testing is allowed only in the event of loss of grid power or up to 30 minutes prior to a rotating outage provided that: 1) the electrical grid operator or electric utility has ordered rotating outages in the control area where the engine is located or has indicated that it expects to issue such an order at a certain time; and 2) the engine is located in a utility service block that is subject to the rotating outage.

Engine operation shall be terminated immediately after the utility distribution company advises that a rotating outage is no longer imminent or in effect.

[**RULE 1303(a)(1)-BACT, 5-10-1996**; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470, 6-1-2007]

[Devices subject to this condition : D4, D10]

E102.1 The operator shall discharge dust collected in this equipment only into closed containers.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]**

[Devices subject to this condition : C158]

E116.1 This engine shall not be used as part of a demand response program using interruptible service contract in which a facility receives a payment or reduced rates in return for reducing its electric load on the grid when requested to do so by the utility or the grid operator.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1470, 6-1-2007]**

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D15, D95, D99, D153, D160, D168, D179, D180, D181, D183, D223, D259, D289]

E175.1 The operator shall not use this equipment unless all exhaust air passes through the following:

filter media at least 2 inches thick

**[RULE 1303(a)(1)-BACT, 5-10-1996]**

[Devices subject to this condition : D21, D22, D24, D305, D306, D307]

E175.2 The operator shall not use this equipment unless all exhaust air passes through the following:

filter media at least 1.5 inches thick

**[RULE 1303(a)(1)-BACT, 5-10-1996]**

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D165]

E175.3 The operator shall not use this equipment unless all exhaust air passes through the following:

This engine shall not be operated unless its exhaust is vented to the non-selective catalytic reduction unit which is in full operation and which is in good operating condition at all times.

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1703 - PSD Analysis, 10-7-1988; RULE 2005, 5-6-2005]**

[Devices subject to this condition : D290, D291, D292]

E193.1 The operator shall operate and maintain this equipment as follows:

ALL PERMIT CONDITIONS APPLICABLE TO THE EQUIPMENT DESCRIBED IN THE PREVIOUS PERMIT TO OPERATE N15788 SHALL REMAIN IN EFFECT UNTIL THE NEW OR MODIFIED EQUIPMENT IS CONSTRUCTED AND OPERATED AS DESCRIBED IN THIS NEW PERMIT. THIS PERMIT TO CONSTRUCT/OPERATE SHALL BECOME INVALID IF THE MODIFICATION AS DESCRIBED IN THE EQUIPMENT DESCRIPTION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE. IF THE MODIFICATION HAS NOT BEEN COMPLETED WITHIN ONE YEAR FROM THE ISSUE DATE OF THE PERMIT

A WRITTEN REQUEST SHALL BE SUBMITTED TO THE AQMD (ATTENTION: RANDY MATSUYAMA) TO REINSTATE THE PREVIOUSLY INACTIVATED PERMIT TO OPERATE. A NEW APPLICATION SHALL BE FILED IF THERE ARE PLANS TO CONTINUE WITH THE MODIFICATION. FURTHERMORE, THIS CONDITION DOES NOT ALLOW ANY TIME EXTENSIONS TO ANY MODIFICATIONS REQUIRED BY THE CALIFORNIA AIR RESOURCES BOARD OR AQMD

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[**RULE 461, 9-8-1995**; RULE 461, 3-7-2008]

[Devices subject to this condition : D36, D40, D89, D90]

E193.2 The operator shall operate and maintain this equipment as follows:

ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS  
FACILITY SHALL BE INSTALLED, OPERATED AND MAINTAINED TO MEET  
ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS

[**RULE 461, 6-3-2005**; RULE 461, 3-7-2008]

[Devices subject to this condition : D88, D89, D90]

E202.1 The operator shall clean and maintain this equipment according to the following specifications:

Thoroughly clean the ionizers and collector cells quarterly

[**RULE 1303(a)(1)-BACT, 5-10-1996**; **RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997**]

[Devices subject to this condition : C49]

E202.2 The operator shall clean and maintain this equipment according to the following specifications:

the diesel catalyst shall be inspected once every calendar year and cleaned, if necessary. If cleaning is necessary, all loose soot deposits shall be removed and the catalyst shall be washed according to manufacturers specifications

[**RULE 1303(a)(1)-BACT, 5-10-1996**]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D133]

E202.3 The operator shall clean and maintain this equipment according to the following specifications:

the engine shall not be operated without the use of an automatic air to fuel ratio controller which shall be maintained and kept in proper operating conditions at all times as specified by the manufacturer

the catalytic converter temperature and exhaust oxygen concentration shall be maintained within the effective operating range of the catalytic converter as specified by the manufacturer

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1703(a)(2) - PSD-BACT, 10-7-1988;  
RULE 2005, 5-6-2005]**

[Devices subject to this condition : D134, D173, D174, D176, D178, D259, D276, D290, D291, D292]

E202.4 The operator shall clean and maintain this equipment according to the following specifications:

Records shall be maintained of inspections and maintenance of the burners

The operator shall follow the procedures specified by the manufacturer to tune-up and maintain the combustion system (including but not limited to the burner and air/fuel control device) of this heater

Manufacturers maintenance procedures shall be kept by the operator and made available at the request of AQMD

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 2005,  
5-6-2005]**

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D135, D137, D138, D139, D260, D261]

#### **H. Applicable Rules**

H23.1 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	1122

[**RULE 1122, 10-1-2004; RULE 1122, 5-1-2009**]

[Devices subject to this condition : E105]

H23.2 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
VOC	District Rule	109
PM	District Rule	481

[**RULE 109, 5-2-2003; RULE 481, 1-11-2002**]

[Devices subject to this condition : D20, D21, D22, D24, D165, D305, D306, D307]

H23.3 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
Refrigerants	District Rule	1415

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

Refrigerants | 40CFR82, SUBPART | F

[RULE 1415, 10-14-1994; **40CFR 82 Subpart F, 5-14-1993**]

[Devices subject to this condition : E102]

H23.4 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
CO	District Rule	1146

This CO emissions (concentration) shall be tested at least once per year per Rule 1146 (d)(6).

[**RULE 1146, 11-17-2000**; RULE 1146, 9-5-2008]

[Devices subject to this condition : D16, D17, D18, D19, D135, D137, D138, D139, D206, D207, D209, D211, D214, D215, D217, D219, D221]

H23.5 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM	District Rule	1140

[**RULE 1140, 2-1-1980**; RULE 1140, 8-2-1985]

[Devices subject to this condition : D170]

H23.6 This equipment is subject to the applicable requirements of the following rules or regulations:

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

Contaminant	Rule	Rule/Subpart
PM	District Rule	1470

[RULE 1470, 6-1-2007]

[Devices subject to this condition : D1, D2, D4, D7, D8, D10, D12, D15, D95, D98, D99, D133, D149, D152, D153, D159, D160, D162, D163, D164, D168, D169, D172, D175, D179, D180, D181, D183, D223, D289]

H23.9 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
CO	District Rule	1146

7. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH SOURCE TESTING REQUIREMENTS IN SUBDIVISION (d)(6)--COMPLIANCE DETERMINATION OF RULE 1146.

8. THE OPERATOR OF THIS EQUIPMENT SHALL COMPLY WITH PERIODIC MONITORING REQUIREMENTS OF RULE 1146 (c)(8).

[**RULE 1146, 11-17-2000**; RULE 1146, 9-5-2008]

[Devices subject to this condition : D260, D261]

H23.11 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
PM	District Rule	1472

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[RULE 1472, 3-7-2008]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D15, D95, D99, D153, D160, D168]

H23.12 This equipment is subject to the applicable requirements of the following rules or regulations:

Contaminant	Rule	Rule/Subpart
SOX	District Rule	431.1

[RULE 431.1, 6-12-1998]

[Devices subject to this condition : D16, D17, D19, D101, D115, D116, D117, D118, D119, D120, D121, D122, D123, D124, D125, D126, D127, D128, D129, D134, D135, D137, D138, D139, D176, D178, D182, D206, D207, D209, D211, D214, D215, D217, D219, D221, D259, D260, D290, D291, D292]

#### **I. Administrative**

I296.1 This equipment shall not be operated unless the operator demonstrates to the Executive Officer that the facility holds sufficient RTCs to offset the annual emissions increase for the first 12 months of operation. In addition, this equipment shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the start of operation, the facility holds sufficient RTCs in an amount equal to the annual emissions increase.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

#### The operator shall comply with the terms and conditions set forth below:

To comply with this condition, the operator shall , prior to each compliance year hold a minimum NOx RTCs of 350 lbs.

In accordance with Rule 2005 (f), unused RTCs may be sold only during the reconciliation period for the fourth quarter of the applicable compliance year inclusive of the 1st compliance year.

#### [RULE 2012, 5-6-2005]

[Devices subject to this condition : D290]

- I296.2 This equipment shall not be operated unless the operator demonstrates to the Executive Officer that the facility holds sufficient RTCs to offset the annual emissions increase for the first 12 months of operation. In addition, this equipment shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the start of operation, the facility holds sufficient RTCs in an amount equal to the annual emissions increase.

To comply with this condition, the operator shall , prior to each compliance year hold a minimum NOx RTCs of 266 lbs.

In accordance with Rule 2005 (f), unused RTCs may be sold only during the reconciliation period for the fourth quarter of the applicable compliance year inclusive of the 1st compliance year.

#### [RULE 2012, 5-6-2005]

[Devices subject to this condition : D291]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

#### The operator shall comply with the terms and conditions set forth below:

I296.3 This equipment shall not be operated unless the operator demonstrates to the Executive Officer that the facility holds sufficient RTCs to offset the annual emissions increase for the first 12 months of operation. In addition, this equipment shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the start of operation, the facility holds sufficient RTCs in an amount equal to the annual emissions increase.

To comply with this condition, the operator shall , prior to each compliance year hold a minimum NOx RTCs of 266 lbs.

In accordance with Rule 2005 (f), unused RTCs may be sold only during the reconciliation period for the fourth quarter o fthe applicable compliance year inclusive of the 1st compliance year.

[RULE 2012, 5-6-2005]

[Devices subject to this condition : D292]

I296.4 This equipment shall not be operated unless the operator demonstrates to the Executive Officer that the facility holds sufficient RTCs to offset the annual emissions increase for the first 12 months of operation. In addition, this equipment shall not be operated unless the operator demonstrates to the Executive Officer that, at the commencement of each compliance year after the start of operation, the facility holds sufficient RTCs in an amount equal to the annual emissions increase.

To comply with this condition, the operator shall , prior to each compliance year hold a minimum NOx RTCs of 341 lbs.

In accordance with Rule 2005 (f), unused RTCs may be sold only during the reconciliation period for the fourth quarter o fthe applicable compliance year inclusive of the 1st compliance year.

[RULE 2012, 5-6-2005]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D297, D298, D299, D300, D301, D302, D303, D304]

#### **J. Rule 461**

J110.1 The operator shall use, except for diesel transfer, the phase II vapor recovery system in full operation whenever gasoline from this equipment is dispensed to motor vehicles as defined in Rule 461. This system shall be installed, operated and maintained to meet all CARB certification requirements.

[RULE 461, 6-3-2005; RULE 461, 3-7-2008]

[Devices subject to this condition : D88, D89, D90, D147]

J373.1 The operator shall comply with the following gasoline transfer and dispensing requirements:

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

a). At least seventy-two (72) hours prior to back-filling any underground storage tank or piping, the SCAQMD shall be notified by e-mail at [r461backfill@aqmd.gov](mailto:r461backfill@aqmd.gov) or by facsimile at telephone number (909) 396-3606. Such notification shall include the name of the owner or operator; the name of the contractors; the location of the facility; and the scheduled start and completion dates of the back-filling procedure. The backfilling procedure shall not commence until inspected by a District representative.

b). As required by AQMD Rule 461 or CARB Executive Order, a static pressure leak decay test shall be conducted to demonstrate that the storage tanks, the remote and/or nozzle vapor recovery check valves, associated vapor return piping and fittings are free from vapor leaks. The test shall be conducted in accordance with CARB Test Procedure Method TP-201.3. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of the test.

The AQMD shall be notified by e-mail at [R461testing@aqmd.gov](mailto:R461testing@aqmd.gov) or by facsimile at telephone number (909) 396-3606 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractors; the location of the facility; and the scheduled start and completion dates of the static pressure leak decay test.

c). Depending on the system configuration, a pressure integrity test of the drop tube/drain valve assembly shall be conducted to quantify the pressure integrity of both the drop tube and drain valve seal or a pressure integrity test of the drop tube overflow prevention device and spill container drain and the pressure integrity of the spill container drain valve. Either test shall be conducted as a reverification test and the test shall be conducted in accordance with test procedure method TP-201.1C or TP-201.1D, respectively. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of the test.

The AQMD shall be notified by e-mail at [r461testing@aqmd.gov](mailto:r461testing@aqmd.gov) or by facsimile at (909) 396-2606 at least 72 hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractor; the location of the facility; and the scheduled start and completion dates of the of the pressure integrity test of drop tube/drain valve assembly or pressure integrity test of the drop tube

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

overflow prevention device and spill container drain valve.

d). A leak rate and cracking pressure test of pressure/vacuum relief vent valves shall be conducted within thirty (30) days after the start of operation of the (add type) Phase I EVR equipment and at least once every three (3) years thereafter to determine the pressure and vacuum at which the pressure/vacuum vent valve actuates, and to determine the volumetric leak rate at a given pressure. The test shall be conducted in accordance with the test procedure method TP-201.1E. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of test. This test result shall be kept on site for three (3) years and made available to district representatives upon request.

The AQMD shall be notified by e-mail at [r461testing@aqmd.gov](mailto:r461testing@aqmd.gov) or by facsimile at (909) 396-2606 at least 72 hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractor; the location of the facility; and the scheduled start and completion dates of the leak rate and cracking pressure of pressure/vacuum relief vent valves test.

e). A static torque test of rotatable Phase I adaptors shall be conducted as a reverification test to quantify the amount of static torque required to start the rotation of the rotatable Phase I adaptors. The test shall be conducted in accordance with the test procedure method outlined in TP-201-1B.. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of the test.

The AQMD shall be notified by e-mail at [r461testing@aqmd.gov](mailto:r461testing@aqmd.gov) or by facsimile at (909) 396-2606 at least 72 hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractor; the location of the facility; and the scheduled start and completion dates of the static torque test of rotatable Phase I adaptors.

f). The Phase II vapor recovery systems shall be installed, operated, and maintained such that the maximum allowable pressure through the system including nozzle, vapor hose, swivels, and underground piping does not exceed the dynamic back pressures described by the California Air Resources Board (CARB) Executive Order by which

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

the system was certified:

Nitrogen Flowrates (CFH)    Dynamic Back Pressure (Inches of Water)

60                                    0.35

80                                    0.62

As required by AQMD Rule 461 or CARB Executive Order, dynamic back pressure tests shall be conducted to determine the Phase II system vapor recovery back pressures. The tests shall be conducted in accordance with CARB Test Procedure Method TP-201.4. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of the test.

The AQMD shall be notified by e-mail at [R461testing@aqmd.gov](mailto:R461testing@aqmd.gov) or by facsimile at telephone number (909) 396-3606 at least seventy two (72) hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractors; the location of the facility; and the scheduled start and completion dates of the dynamic back pressure test.

The test shall be conducted as frequently as that required by the most recent amendment to Rule 461 or CARB Executive Order requirements, whichever is more stringent.

g). If the CARB Executive Order requires the installation of a liquid removal device, a liquid removal rate test shall be conducted to demonstrate the removal of gasoline from the vapor passage of the coaxial hose. The test shall be conducted within thirty days of initial installation and in accordance with CARB test procedure Method TP-201.6. Results shall be submitted to the AQMD, Engineering and Compliance, within seventy-two (72) hours of the test.

The AQMD shall be notified by e-mail at [r461testing@aqmd.gov](mailto:r461testing@aqmd.gov) or by facsimile at telephone number (909) 396-3606 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator; the name of the contractors; the location of the facility; and the scheduled start and completion dates of the liquid removal rate test.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

The testing frequency for the above mentioned tests shall be conducted in accordance with the most recent AQMD Rule 461 amendment or CARB Executive Order requirements, whichever is more stringent.

All records and test results that are required to be maintained by Rule 461 shall be kept on site and made available to AQMD representatives upon request.

**[RULE 461, 6-3-2005; RULE 461, 3-7-2008]**

[Devices subject to this condition : D36, D40, D88, D89, D90]

J397.1 The operator shall comply with the following CARB Executive Order G-70-193:

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

#### The operator shall comply with the terms and conditions set forth below:

1. The owner or operator of this equipment shall conduct a physical inspection of the equipment and manually monitor the system gauge levels during gasoline dispensing on a daily operating basis per site. The equipment shall operate within the following gauge levels:

- |                              |                    |
|------------------------------|--------------------|
| a) Vapor return line vacuum: | 35" to 65" wc      |
| b) Gasoline supply pressure: | 27 psig to 35 psig |
| c) Cargo tank pressure:      | less than 18" wc   |

All physical inspections and gauge observations shall be recorded in a systems log and be kept on board the mobile fueler at all times.

2. If a violation of the gauge ranges specified in conditions 1a, 1b, or 1c occurs, the owner or operator of this equipment shall:

- Record the date, time period, and fuel totalizing meter reading when the system first began to fail to operate within the specified range.
- Record the date and time that contact was made with an authorized representative to have the system inspected and repaired.
- Record the date and time that the authorized representative inspected the system, provide a written description of the repairs performed, and record the fuel totalizing meter reading.

3. This equipment shall cease all gasoline dispensing operations when any one of the following conditions occur:

- One of the jet pumps is disabled;
- Failing to achieve the minimum operating vacuum of 35" wc within five seconds after the system has been activated for three consecutive dispensing episodes;
- A vacuum level below 15" wc for more than three seconds after the system has reached 35" wc;

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

- d) A vacuum level above 85" wc during a dispensing episode to non-ORVR vehicles;
- e) Except during testing operations, a closed valve at the vapor return line connection to each jet pump;
- f) A pressure in the cargo tank headspace exceeding 18" wc for more than five minutes (accumulated) during any sixty minute gasoline dispensing period;
- g) Except during repair operations, an open drain valve in the liquid drop out pot;
- h) Except during testing operations, a closed drain valve at the liquid drop out pot in the liquid removal line;
- i) Any observation of breaks, cracks, or holes in the tank insulation, which affects the insulating properties or durability of the insulation;
- j) The accumulated length of all tears of the nozzle boot (including rips, slits, cracks, etc.) exceeds 0.5" in length; or
- k) The faceplate and fill pipe interface cannot achieve a seal of at least 25 percent of the accumulated circumference of the faceplate.

4. Within thirty (30) days of initial operation and at least once every twelve months from the previous test, a vapor return line vacuum integrity test shall be conducted and pass in accordance with Exhibit 3 of CARB Executive Order G-70-193. Results shall be submitted to the AQMD, Office of Engineering and Compliance, within forty-eight (48) hours of test.

The AQMD shall be notified at telephone number (909) 396-3886 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator of this equipment; the name of the testing contractor; the location of the mobile fueler; and the scheduled start and completion dates of the vapor return line vacuum integrity test.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

5. Within thirty (30) days of initial operation and at least once every twelve months from the previous test, a fill pipe pressure regulation fueling test shall be conducted and pass in accordance with Exhibit 4 of CARB Executive Order G-70-193. Results shall be submitted to the AQMD, Office of Engineering and Compliance, within forty-eight (48) hours of test.

The AQMD shall be notified at telephone number (909) 396-3886 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator of this equipment; the name of the testing contractor; the location of the mobile fueler; and the scheduled start and completion dates of the fill pipe pressure regulation fueling test.

6. Within thirty (30) days of initial operation and at least once every twelve months from the previous test, a ten gallon per minute flowrate limitation test shall be conducted and pass in accordance with Exhibit 5 of CARB Executive Order G-70-193. Results shall be submitted to the AQMD, Office of Engineering and Compliance, within forty-eight (48) hours of test.

The AQMD shall be notified at telephone number (909) 396-3886 at least seventy-two (72) hours prior to testing. Such notification shall include the name of the owner or operator of this equipment; the name of the testing contractor; the location of the mobile fueler; and the scheduled start and completion dates of the ten gallon per minute limitation test.

7. The individual and company performing any maintenance on any part of the vapor recovery system shall provide at a minimum for the owner or operator of the mobile fueler, a chronological record consisting of the following information for the mobile fueler's maintenance log. The date of service, name of maintenance technician, a contact phone number, a description of and location of any equipment replaced including appropriate test results, and a description of the system problems repaired.

9. Except for necessary inspections due to equipment failures, and for scheduled maintenance and repairs; the mobile fueler dome hatch shall remain closed and latched at all times. Furthermore, the mobile fueler dome hatch shall remain closed

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS**

**The operator shall comply with the terms and conditions set forth below:**

and latched until the head space pressure is less than 2" wc.

8. A current CARB certification decal shall be displayed on the mobile fueler in a manner approved by the executive officer.

10. All physical inspection and gauge observation records; all test results; and all maintenance records as required by this CARB Executive Order shall be prepared, shall be retained for two years, and shall be kept within the mobile fueler and made available to district representatives upon request.

**[RULE 461, 6-3-2005; RULE 461, 3-7-2008]**

[Devices subject to this condition : D147]

#### **K. Record Keeping/Reporting**

K67.1 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

For architectural applications where no thinners, reducers, or other VOC containing materials are added, maintain semi-annual records for all coating consisting of (a) coating type, (b) VOC content as supplied in grams per liter (g/l) of materials for low-solids coatings, (c) VOC content as supplied in g/l of coating, less water and exempt solvent, for other coatings.

For architectural applications where thinners, reducers, or other VOC containing materials are added, maintain daily records for each coating consisting of (a) coating type, (b) VOC content as applied in grams per liter (g/l) of materials used for low-solids coatings, (c) VOC content as applied in g/l of coating, less water and exempt solvent, for other coatings.

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : E107]

K67.2 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the filter

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : D21, D22, D24, C96, D165, D305, D306, D307]

K67.3 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the water wash

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : D20]

K67.4 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

date of operation, elapsed time in hours, and reason for operation

[RULE 1110.2, 7-9-2010; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;**  
**RULE 2005, 5-6-2005]**

[Devices subject to this condition : D115, D116, D119, D124, D125, D126, D127,  
D128, D129, D131, D133, D134, D149, D159, D162, D163, D164, D169, D172,  
D173]

K67.5 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Purchase records of abrasive used or daily records of abrasives used and evidence of ARB certification

If abrasives are re-used, records to demonstrate that such abrasives are tested with CARB Method 371-A

Daily records of the description of items blasted to demonstrate compliance

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : D44]

K67.6 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

All maintenance, monthly and annual gasoline dispensed records, shall be prepared, shall be retained for five years, and shall be kept within the mobile fueler and made available to District representatives upon request.

All daily inspection records shall be completed immediately after the daily inspection.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

**[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 461, 6-3-2005; RULE 461, 3-7-2008]**

[Devices subject to this condition : D147]

K67.8 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

The operator shall keep records in accordance with the requirements of rule 109 (record keeping for volatile organic compound emissions). Such records shall be retained for a period of three years and shall be made available to any district representative upon request.

Within 14 calendar days after the end of each month, the operator shall total and record VOC emissions for the month from all permitted equipment covered by the monthly limit. The record shall include any procedures used to account for control device efficiencies and/or waste disposal. It shall be signed and certified for accuracy by the highest ranking individual responsible for operation of equipment subject to the permit.

The operator shall maintain a single list which includes only the name and address of each person from whom the facility acquired VOC-containing material regulated by the district that was used or stored at the facility during the preceding 12 months.

The operator shall retain all purchase invoices for all VOC-containing material used or stored at the facility, and all waste manifest for all waste VOC containing material removed from the facility, for 36 months.

**[RULE 109, 5-2-2003; RULE 1303(b)(2)-Offset, 5-10-1996]**

[Devices subject to this condition : D165]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

K67.10 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

the name of the person performing the inspection and/or maintenance of the baghouse

the date, time and results of the inspection

the date, time and description of any maintenance or repairs resulting from the inspection

**[RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]**

[Devices subject to this condition : C158]

K67.11 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

copy of MSDS shall be kept for the abrasive material used in this equipment

[RULE 1401, 12-7-1990]

[Devices subject to this condition : D156, D170]

K67.12 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

MSDS for the diesel fuel used in this equipment

**[RULE 1303(a)(1)-BACT, 5-10-1996]**

[Devices subject to this condition : D172]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

#### The operator shall comply with the terms and conditions set forth below:

K67.13 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

The log shall list the date of operation, the timer reading in hours at the beginning and end of operation, and the reason for operation. The total hours of operation (include hours for manual and automatic operation) shall be recorded sometime during the first 15 days of January of each year.

[RULE 1110.2, 7-9-2010; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;**  
**RULE 2005, 5-6-2005]**

[Devices subject to this condition : D174]

K67.14 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

An engine operating log shall be kept and maintained on file to record when this engine is started manually. The log shall list the date of operation, the timer reading in hours at the beginning and end of operation, and the reason for operation for a minimum of five calendar years prior to the current year and made available to District personnel upon request. The total hours of operation (include hours for manual and automatic operation) shall be recorded sometime during the first 15 days of January

[RULE 1110.2, 7-9-2010; **RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996;**  
**RULE 2005, 5-6-2005]**

[Devices subject to this condition : D175, D176, D178, D182, D259, D276]

K67.15 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

The hours of operation per year.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[**RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1401, 12-7-1990**]

[Devices subject to this condition : D177]

K67.16 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

An engine operating log shall be maintained which on a monthly basis shall include manual and automatic operation and shall list all engine operations in each of the following areas:

EMERGENCY USE HOURS OF OPERATION.

MAINTENANCE AND TESTING HOURS.

OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION).

In addition, each time the engine is started manually, the log shall include the date of operation and the timer reading in hours at the beginning and end of operation. The log shall be kept for a minimum of three calendar years prior to the current year and made available to District personnel upon request. The total hours of operation for the previous calendar year shall be recorded sometime during the first 15 days of January of each year.

[**RULE 1110.2, 7-9-2010; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 1470, 6-1-2007; RULE 2005, 5-6-2005**]

[Devices subject to this condition : D1, D2, D4, D7, D8, D12, D15, D95, D99, D153, D160, D168, D179, D180, D181, D183, D223, D289]

K67.19 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

IN ACCORDANCE WITH RULE 461(j), THE OWNER/OPERATOR SHALL ADHERE TO THE FOLLOWING TASK COMPLETEION DATES AS SUBMITTED ON FORM 461-CP:

COMPLETE PERMIT APPLICATION PACKAGES TO ALL APPLICABLE GOVERNMENT AGENCIES NO LATER THAN 8/15/08

PURCHASE ORDER FOR CARB CERTIFIED PHASE II EVR SYSTEM NO LATER THAN 8/30/08

SIGN CONTRACT FOR INSTALLATION OF CARB CERTIFIED PHASE II EVER SYSTEM NO LATER THAN 8/11/2008

SIGN CONTRACT FOR TESTING OF CARB CERTIFIED PHASE II EVR SYSTEM NO LATER THAN 8/11/2008

START DATE OF EQUIPMENT INSTALLATION NO LATER THAN 11/15/2008

START DATE OF TESTING PHASE II EVR SYSTEM NO LATER THAN 12/30/2008

**[RULE 461, 6-3-2005; RULE 461, 3-7-2008]**

[Devices subject to this condition : D90]

K67.20 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE FOR FIVE YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST.

**[RULE 461, 6-3-2005; RULE 461, 3-7-2008]**

[Devices subject to this condition : D36, D40, D88]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

K67.22 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Operating time records as required per conditons C1.23 and C1.24.

The records shall be kept for at least five years and made available to District personnel upon request

**[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]**

[Devices subject to this condition : D266, D267, D268, D269, D270, D271, D272, D273, D274, D275]

K67.23 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Operating time records as required per conditons C1.16 and C1.26

The records shall be kept for at least five years and made available to District personnel upon request

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]**

[Devices subject to this condition : D284, D285, D286, D287, D288, D297, D298, D299, D300, D301, D302, D303, D304]

K67.24 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

#### The operator shall comply with the terms and conditions set forth below:

Operating time records as required per conditons C1.14, C1.16 and C1.18

The records shall be kept for at least five years and made available to District personnel upon request

**[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 3-4-2005]**

[Devices subject to this condition : D225, D226, D228, D229, D230, D231, D232, D233, D234, D235, D236, D237, D238, D239, D240, D244, D253, D255, D256, D257, D258, D262, D263, D264, D265]

K67.25 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

An engine operating log shall be kept and maintained, documenting the total time the engine is operated each month and specific reason for operation as:

- A. Emergency use.
- B. Maintenance and testing.
- C. Other (describe the reason for operating).

In addition, each time the engine is manually started, the log shall include the date of operation, the specific reason for operation, and the totalizing hour meter reading (in hours and tenths of hours) at the beginning and end of operation.

**[RULE 1110.2, 7-9-2010; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1304(a)-Modeling and Offset Exemption, 6-14-1996; RULE 2005, 5-6-2005]**

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

**The operator shall comply with the terms and conditions set forth below:**

[Devices subject to this condition : D290, D291, D292]

K67.26 The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

On or before January 15th of each year, the operator shall record in the engine operating log, the following:

A. The total hours of operation for the previous calendar year, and

B. The total hours of engine operation for maintenance and testing for the previous calendar year.

The engine operating log shall be retained on site for a minimum of five calendar years and shall be made available to the Executive Officer or representative upon request.,

[**RULE 1110.2, 6-3-2005; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1304(a)  
-Modeling and Offset Exemption, 6-14-1996; RULE 2005, 10-15-1993**]

[Devices subject to this condition : D290, D291, D292]

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **SECTION K: TITLE V Administration**

#### **GENERAL PROVISIONS**

1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

#### **Permit Renewal and Expiration**

3. (A) Except for solid waste incineration facilities subject to standards under section 129(e) of the Clean Air Act, this permit shall expire five years from the date that this Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2), 3004(f)]  
  
(B) A Title V permit for a solid waste incineration facility combusting municipal waste subject to standards under Section 129(e) of the Clean Air Act shall expire 12 years from the date of issuance unless such permit has been renewed pursuant to this regulation. These permits shall be reviewed by the Executive Officer at least every five years from the date of issuance. [3004(f)(2)]
4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

#### **Duty to Provide Information**

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

#### **Payment of Fees**

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **SECTION K: TITLE V Administration**

#### **Reopening for Cause**

7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
- (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) of Rule 3004.
  - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
  - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable requirements. [3005(g)(1)]

#### **COMPLIANCE PROVISIONS**

8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
- (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
  - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION K: TITLE V Administration

9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
  - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
  - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
  - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
  - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]
  
10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]
  
11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]
  
12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay any permit condition. [3004(a)(7)(D)]
  
13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION K: TITLE V Administration

14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 41700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
  
15. Nothing in this permit or in any permit shield can alter or affect:
  - (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
  - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
  - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
  - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
  - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
  - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
  
16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION K: TITLE V Administration EMERGENCY PROVISIONS

17. An emergency<sup>1</sup> constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limit only if:
- (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
    - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
    - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
    - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
    - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
  - (B) The operator complies with the breakdown provisions of Rule 430 – Breakdown Provisions, or subdivision (i) of Rule 2004 – Requirements, whichever is applicable. [3002(g), 430, 2004(i)]
18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 - Emergencies. [118]

---

<sup>1</sup> "Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **SECTION K: TITLE V Administration RECORDKEEPING PROVISIONS**

19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
- (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
  - (B) The date(s) analyses were performed;
  - (C) The company or entity that performed the analyses;
  - (D) The analytical techniques or methods used;
  - (E) The results of such analyses; and
  - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(t)]
21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

### **REPORTING PROVISIONS**

22. The operator shall comply with the following requirements for prompt reporting of deviations:
- (A) Breakdowns shall be reported as required by Rule 430 – Breakdown Provisions or subdivision (i) of Rule 2004 - Requirements, whichever is applicable.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION K: TITLE V Administration

- (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.
- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
- (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
- (A) Identification of each permit term or condition that is the basis of the certification;

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **SECTION K: TITLE V Administration**

- (B) The compliance status during the reporting period;
- (C) Whether compliance was continuous or intermittent;
- (D) The method(s) used to determine compliance over the reporting period and currently, and
- (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn:  
Air-3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

### **PERIODIC MONITORING**

26. All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the TitleV application file. [3004(a)(4)]

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION K: TITLE V Administration

#### *FACILITY RULES*

*This facility is subject to the following rules and regulations*

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

<b>RULE SOURCE</b>	<b>Adopted/Amended Date</b>	<b>FEDERAL Enforceability</b>
RULE 109	5-2-2003	Federally enforceable
RULE 1106.1	2-12-1999	Federally enforceable
RULE 1107	1-6-2006	Non federally enforceable
RULE 1107	11-9-2001	Federally enforceable
RULE 1110.2	6-3-2005	Non federally enforceable
RULE 1110.2	7-9-2010	Non federally enforceable
RULE 1113	11-8-1996	Federally enforceable
RULE 1113	7-13-2007	Non federally enforceable
RULE 1122	10-1-2004	Federally enforceable
RULE 1122	5-1-2009	Non federally enforceable
RULE 1128	3-8-1996	Federally enforceable
RULE 1130.1	12-13-1996	Federally enforceable
RULE 1136	6-14-1996	Federally enforceable
RULE 1140	2-1-1980	Federally enforceable
RULE 1140	8-2-1985	Non federally enforceable
RULE 1145	12-4-2009	Non federally enforceable
RULE 1145	2-14-1997	Federally enforceable
RULE 1146	11-17-2000	Federally enforceable
RULE 1146	9-5-2008	Non federally enforceable
RULE 1162	11-17-2000	Federally enforceable
RULE 1162	7-8-2005	Non federally enforceable
RULE 1168	1-7-2005	Federally enforceable

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION K: TITLE V Administration

<b>RULE SOURCE</b>	<b>Adopted/Amended Date</b>	<b>FEDERAL Enforceability</b>
RULE 1171	11-7-2003	Federally enforceable
RULE 1171	5-1-2009	Non federally enforceable
RULE 118	12-7-1995	Non federally enforceable
RULE 1303(a)(1)-BACT	12-6-2002	Non federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(a)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(1)-Modeling	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	12-6-2002	Non federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 1304(a)-Modeling and Offset Exemption	6-14-1996	Federally enforceable
RULE 1401	12-7-1990	Non federally enforceable
RULE 1401	3-4-2005	Non federally enforceable
RULE 1401	8-18-2000	Non federally enforceable
RULE 1401	9-10-2010	Non federally enforceable
RULE 1415	10-14-1994	Non federally enforceable
RULE 1470	6-1-2007	Non federally enforceable
RULE 1472	3-7-2008	Non federally enforceable
RULE 1703 - PSD Analysis	10-7-1988	Federally enforceable
RULE 1703(a)(2) - PSD-BACT	10-7-1988	Non federally enforceable
RULE 2005	10-15-1993	Federally enforceable
RULE 2005	5-6-2005	Federally enforceable
RULE 2012	1-7-2005	Federally enforceable
RULE 2012	12-5-2003	Federally enforceable
RULE 2012	5-6-2005	Federally enforceable
RULE 204	10-8-1993	Federally enforceable
RULE 217	1-5-1990	Federally enforceable
RULE 219	6-1-2007	Non federally enforceable
RULE 219	9-4-1981	Federally enforceable
RULE 2202	11-8-1996	Non federally enforceable
RULE 3002	11-14-1997	Federally enforceable
RULE 3003	11-14-1997	Federally enforceable

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### SECTION K: TITLE V Administration

<b>RULE SOURCE</b>	<b>Adopted/Amended Date</b>	<b>FEDERAL Enforceability</b>
RULE 3004(a)(4)-Periodic Monitoring	12-12-1997	Federally enforceable
RULE 3005	11-14-1997	Federally enforceable
RULE 3007	10-8-1993	Federally enforceable
RULE 304	1-14-1982	Non federally enforceable
RULE 401	11-9-2001	Non federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 402	5-7-1976	Non federally enforceable
RULE 404	2-7-1986	Federally enforceable
RULE 405	2-7-1986	Federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 408	5-7-1976	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 430	7-12-1996	Non federally enforceable
RULE 431.1	6-12-1998	Federally enforceable
RULE 431.2	5-4-1990	Federally enforceable
RULE 431.2	9-15-2000	Non federally enforceable
RULE 461	3-7-2008	Non federally enforceable
RULE 461	6-3-2005	Federally enforceable
RULE 462	5-14-1999	Federally enforceable
RULE 481	1-11-2002	Federally enforceable
RULE 701	6-13-1997	Federally enforceable
H&S 44300	7-1-1988	Non federally enforceable
40CFR 82 Subpart F	5-14-1993	Federally enforceable

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1106.1 02-12-1999]

**RULE 1106.1**

**(Amended February 12, 1999)**

Pleasure Craft Coating Operations

Except as otherwise provided in Rule 1106.1

- (1) Within the District, the operator shall not sell, offer for sale, solicit, apply, or require any other person to use in the District any pleasure craft coating with a VOC content in excess of the following limits, expressed as grams of VOC per liter of coating applied, less water and exempt solvents:

<u>COATING</u>	<u>VOC LIMIT</u>		
	On or After 7/1/94	On or After 2/12/99	On or After 1/1/2001
Topcoats			
Extreme High Gloss	490	650	490
High Gloss	420	420	420
Pretreatment Wash Primers	780	780	780
Finish Primer/Surfacer	420	600	420
High Build Primer Surfacer	340	340	340
Teak Primer	775	775	775
Antifoulant Coatings			
Aluminum Substrate	560	560	560
Other Substrates	150	400	330
Clear Wood Finishes			
Sealers	550	550	550
Varnishes	490	490	490
Others	420	420	420

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **APPENDIX B: RULE EMISSION LIMITS [RULE 1106.1 02-12-1999]**

In the case of any coating sold, offered for sale, or solicited for use, this prohibition shall only apply where it is designated anywhere on the container by any sticker or label affixed thereto, or where it is indicated in any sales or advertising literature, that the coating may be used as, or is suitable for use as, a pleasure craft coating.

- (2) A person shall not apply pleasure craft coatings subject to the requirements of this rule with a coating containing carbon tetrachloride or any of the Group II exempt compounds as defined in paragraph (b)(4) of Rule 1106.1 except for: methylene chloride; perchloroethylene; cyclic, branched, or linear, completely methylated siloxanes (VMS); or parachlorobenzotrifluoride (PCBTF).

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1107 01-06-2006]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

<b>VOC LIMITS</b>								
<b>Less Water and Less Exempt Compounds</b>								
<b>Effective Dates</b>								
<b>Coating</b>	<b>Air-Dried</b>				<b>Baked</b>			
	<b>gm/l</b>		<b>lb/gal</b>		<b>gm/l</b>		<b>lb/gal</b>	
	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1107 01-06-2006]

<b>VOC LIMITS</b>								
<b>Less Water and Less Exempt Compounds</b>								
<b>Effective Dates, cont.</b>								
<b>Coating</b>	<b>Air-Dried</b>				<b>Baked</b>			
	<b>gm/l</b>		<b>lb/gal</b>		<b>gm/l</b>		<b>lb/gal</b>	
	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **APPENDIX B: RULE EMISSION LIMITS [RULE 1107 01-06-2006]**

- (2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1107 11-09-2001]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

<b>VOC LIMITS</b>								
<b>Less Water and Less Exempt Compounds</b>								
<b>Effective Dates</b>								
<b>Coating</b>	<b>Air-Dried</b>				<b>Baked</b>			
	<b>gm/l</b>		<b>lb/gal</b>		<b>gm/l</b>		<b>lb/gal</b>	
	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1107 11-09-2001]

Except as otherwise provided in Rule 1107

(1) VOC Content of Coatings

A person shall not apply to metal parts and products subject to the provisions of this rule any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below:

<b>VOC LIMITS</b>								
<b>Less Water and Less Exempt Compounds</b>								
<b>Effective Dates</b>								
<b>Coating</b>	<b>Air-Dried</b>				<b>Baked</b>			
	<b>gm/l</b>		<b>lb/gal</b>		<b>gm/l</b>		<b>lb/gal</b>	
	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>
General One-Component	275	275	2.3	2.3	275	275	2.3	2.3
General Multi-Component	340	340	2.8	2.8	275	275	2.3	2.3
Military Specification	340	340	2.8	2.8	275	275	2.3	2.3
Etching Filler	420	420	3.5	3.5	420	420	3.5	3.5
Solar-Absorbent	420	420	3.5	3.5	360	360	3.0	3.0
Heat-Resistant	420	420	3.5	3.5	360	360	3.0	3.0
Extreme High-Gloss	420	340	3.5	2.8	360	360	3.0	3.0
Metallic	420	420	3.5	3.5	420	420	3.5	3.5

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1107 11-09-2001]

<b>VOC LIMITS</b>								
<b>Less Water and Less Exempt Compounds</b>								
<b>Effective Dates, cont.</b>								
<b>Coating</b>	<b>Air-Dried</b>				<b>Baked</b>			
	<b>gm/l</b>		<b>lb/gal</b>		<b>gm/l</b>		<b>lb/gal</b>	
	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>	<b>Current</b>	<b>7/1/07</b>
Extreme Performance	420	420	3.5	3.5	360	360	3.0	3.0
Prefabricated Architectural One-Component	420	275	3.5	2.3	275	275	2.3	2.3
Prefabricated Architectural Multi-Component	420	340	3.5	2.8	275	275	2.3	2.3
Touch Up	420	420	3.5	3.5	360	360	3.0	3.0
Repair	420	420	3.5	3.5	360	360	3.0	3.0
Silicone Release	420	420	3.5	3.5	420	420	3.5	3.5
High-Performance Architectural	420	420	3.5	3.5	420	420	3.5	3.5
Camouflage	420	420	3.5	3.5	420	420	3.5	3.5
Vacuum-Metalizing	420	420	3.5	3.5	420	420	3.5	3.5
Mold-Seal	420	420	3.5	3.5	420	420	3.5	3.5
High-Temperature	420	420	3.5	3.5	420	420	3.5	3.5
Electric-Insulating Varnish	420	420	3.5	3.5	420	420	3.5	3.5
Pan Backing	420	420	3.5	3.5	420	420	3.5	3.5
Pretreatment Coatings	420	420	3.5	3.5	420	420	3.5	3.5

- (2) A person shall not use VOC-containing materials which have a VOC content of more than 200 grams per liter of material for stripping any coating governed by this rule.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-08-1996]

- (1) Except as provided in paragraphs (c)(2), (c)(3), and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, or solicit the application of, any architectural coating which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, or manufacture, blend, or repackage such a coating for use within the District.
- (2) Except as provided in paragraphs (c)(3) and (c)(4) of Rule 1113, the operator shall not supply, sell, offer for sale, apply, solicit the application of, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified.

### TABLE OF STANDARDS

#### VOC LIMITS

#### Grams of VOC Per Liter of Coating, Less Water And Less Exempt Compounds

COATING	Limit*	Effective Date of Adoption	Effective 1/1/1998	Effective 1/1/1999	Effective 7/1/2001	Effective 1/1/2005	Effective 7/1/2008
Bond Breakers	350						
Clear Wood Finishes							
Varnish	350						
Sanding Sealers	350						
Lacquer	680		550			275	
Concrete-Curing Compounds	350						
Dry-Fog Coatings	400						
Fire-proofing Exterior Coatings	350	450		350			
Fire-Retardant Coatings							
Clear	650						
Pigmented	350						
Flats	250				100		50
Graphic Arts (Sign) Coatings	500						

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1113 11-08-1996]

Industrial Maintenance						
Primers and Topcoats						
Alkyds	420					
Catalyzed Epoxy	420					
Bituminous Coatings	420					
Materials						
Inorganic Polymers	420					
Vinyl Chloride Polymers	420					
Chlorinated Rubber	420					
Acrylic Polymers	420					
Urethane Polymers	420					
Silicones	420					
Unique Vehicles	420					
Japans/Faux Finishing	350	700		350		
Coatings						
Magnesite Cement Coatings	600			450		
Mastic Coatings	300					
Metallic Pigmented Coatings	500					
Multi-Color Coatings	420		250			
Pigmented Lacquer	680		550		275	
Pre-Treatment Wash Primers	780					
Primers, Sealers, and Undercoaters	350					
Quick-Dry Enamels	400					
Roof Coatings	300					
Shellac						
Clear	730					
Pigmented	550					
Stains	350					
Swimming Pool Coatings						
Repair	650					
Other	340					
Traffic Coatings	250		150			
Waterproofing Sealers	400					
Wood Preservatives						
Below-Ground	350					
Other	350					

\* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

### TABLE OF STANDARDS (cont.)

#### VOC LIMITS

#### Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007]**

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6), no person shall supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings, except anti-graffiti coatings, for residential use or for use in areas such as office space and meeting rooms of industrial, commercial or institutional facilities not exposed to such extreme environmental conditions described in the definition of industrial maintenance coatings; or of any rust-preventative coating for industrial use, unless such a rust preventative coating complies with the Industrial Maintenance Coating VOC limit specified in the Table of Standards.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007] TABLE OF STANDARDS VOC LIMITS

**Grams of VOC Per Liter of Coating,  
Less Water and Less Exempt Compounds**

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Bond Breakers	350							
Clear Wood Finishes	350					275		
Varnish	350					275		
Sanding Sealers	350					275		
Lacquer	680	550			275			
Clear Brushing Lacquer	680				275			
Concrete-Curing Compounds	350						100	
Concrete-Curing Compounds For Roadways and Bridges**	350							
Dry-Fog Coatings	400						150	
Fire-Proofing Exterior Coatings	450	350						
Fire-Retardant Coatings***								
Clear	650							
Pigmented	350							
Flats	250	100						50
Floor Coatings	420		100			50		
Graphic Arts (Sign) Coatings	500							
Industrial Maintenance (IM) Coatings	420			250		100		
High Temperature IM Coatings			420					
Zinc-Rich IM Primers	420		340			100		
Japans/Faux Finishing Coatings	700	350						
Magnesite Cement Coatings	600	450						
Mastic Coatings	300							
Metallic Pigmented Coatings	500							
Multi-Color Coatings	420	250						
Nonflat Coatings	250		150			50		

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007]

COATING CATEGORY	Ceiling Limit*	Current Limit	Effective Date					
			1/1/03	1/1/04	1/1/05	7/1/06	7/1/07	7/1/08
Nonflat High Gloss	250		150				50	
Pigmented Lacquer	680	550			275			
Pre-Treatment Wash Primers	780		420					
Primers, Sealers, and Undercoaters	350		200			100		
Quick-Dry Enamels	400		250			150	50	
Quick-Dry Primers, Sealers, and Undercoaters	350		200			100		
Recycled Coatings			250					
Roof Coatings	300		250		50			
Roof Coatings, Aluminum	500				100			
Roof Primers, Bituminous	350		350					
Rust Preventative Coatings	420		400			100		
Shellac								
Clear	730							
Pigmented	550							
Specialty Primers	350					250	100	
Stains	350		250				100	
Stains, Interior	250							
Swimming Pool Coatings								
Repair	650		340					
Other	340							
Traffic Coatings	250	150					100	
Waterproofing Sealers	400		250			100		
Waterproofing	400					100		
Concrete/Masonry Sealers								
Wood Preservatives								
Below-Ground	350							
Other	350							

\* The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards.

\*\* Does not include compounds used for curbs and gutters, sidewalks, islands, driveways and other miscellaneous concrete areas.

\*\*\* The Fire-Retardant Coating category will be eliminated on January 1, 2007 and subsumed by the coating category for which they are formulated.

# FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

## APPENDIX B: RULE EMISSION LIMITS [RULE 1113 07-13-2007]

### TABLE OF STANDARDS (cont.) VOC LIMITS

#### Grams of VOC Per Liter of Material

COATING	Limit
Low-Solids Coating	120

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **APPENDIX B: RULE EMISSION LIMITS [RULE 1130.1 12-13-1996]**

Except as otherwise provided in Rule 1130.1

(1) VOC Content of Screen Printing Materials

The operator shall not apply to any substrate any screen printing material, excluding extreme performance screen printing materials, which contains, as applied, a total amount of VOC in excess of the limits specified in subparagraphs (1)(A), (1)(B), or (1)(C). The applicable VOC limit for a screen printing operation shall be determined by first looking for the product in subparagraph (1)(A). If the product is not listed in subparagraph (1)(A), look for the product's substrate in subparagraph (1)(B). If the substrate is not listed in subparagraph (1)(B), look for the applicable limit in subparagraph (1)(C).

In lieu of meeting the requirements in subparagraph (1)(C), the operator may comply with the requirements in paragraph (2) if the screen printing material qualifies for an extreme performance classification under subdivision (e) of Rule 1130.1.

(A) For screen printing coatings and inks used in the production of the following products:

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1130.1 12-13-1996]

#### VOC LIMIT

grams per Liter of  
Coating

**PRODUCT** (or Ink), Less water and  
Less Exempt  
Compounds

On and After  
December 13, 1996

	<u>g/L-</u>	<u>lbs/gal-</u>
Chlorine Indicator	500	4.2
Containers	800	6.7
Electronic Circuit	850	7.1
Mechanically- Formed Products	800	6.7
Overlays	800	6.7
Polyethylene Products	800	6.7
Stained Glass Overlay	800	6.7
Sterilization Indicator	600	5.0
Sub-Printed Products	800	6.7
Water Slide Decals:		
Opaque Inks	800	6.7
Clear Inks	800	6.7
Ceramic Decal Inks	800	6.7

- (B) For screen printing coatings and inks not regulated by subparagraph (1)(A) and which are applied to the following specified substrates:

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1130.1 12-13-1996]

#### VOC LIMIT

grams per Liter of Coating  
(or Ink), Less water  
and Less Exempt  
Compounds

**SUBSTRATE**

On and After  
December 13, 1996

	<u>g/L</u>	<u>lbs/gal</u>
Ceramic	800	6.7
Fiberglass	600	5.0
Glass or Metal	600	5.0
Man-Made Textile	800	6.7
Unsealed Aluminum	800	6.7

If a substrate is regulated under more than one substrate category listed in subparagraph (1)(B), the category with the highest VOC limit shall apply.

- (C) For screen printing materials not regulated by the provisions in subparagraph (1)(A) or (1)(B), which have the following material classifications:

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1130.1 12-13-1996]

<u>SCREEN PRINTING MATERIAL</u>	<b>VOC LIMIT</b> grams per Liter of Coating (or Ink or Adhesive), Less water and <u>Less Exempt</u> <u>Compounds</u>	
	<u>On and After</u> <u>December 13, 1996</u>	
	<u>g/L</u>	<u>lbs/gal</u>
Adhesive	400	3.3
Coating	400	3.3
Fine Detail Loose-leaf Binder Ink	745	6.2
Fluorescent Ink	540	4.5
High-VOC Serigraph Ink	800	6.7
Loose-leaf Binder Metallic Ink	745	6.2
Metallic Ink	400	3.3
Printing Ink	400	3.3
Resists	600	5.0
Scratch-Off Ink	800	6.7
Water-Slide Decal Adhesive	800	6.7

If a screen printing material is regulated under more than one screen printing material category listed in subparagraph (1)(C), the category with the highest VOC limit shall apply.

(2) **VOC Content of Extreme Performance Screen Printing Materials**

The operator shall not apply any extreme performance screen printing material in excess of the limits specified below:

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1130.1 12-13-1996]

#### VOC LIMIT Grams of VOC per Liter of ExtremePerformance Screen Printing Material, Less Water and Less Exempt Compounds

	<u>g/L</u>	<u>lbs/gal</u>
On and after July 9, 1993	800	6.7
On and after January 1, 2003	400	3.3

(3) Usage of High-VOC Serigraph Inks

The total usage of high-VOC serigraph inks, as defined in paragraph (b)(23) of Rule 1130.1, shall not exceed 10 percent, (by volume), of the total usage of screen printing materials applied on all serigraphs at a facility, on a monthly basis, unless an approved emission control system is used to reduce emissions from high-VOC serigraph inks by an equivalent or greater level to that which would have been achieved by the use of an ink containing 3.3 pounds per gallon VOC (less water and exempt compounds). The required overall control efficiency of the emission control system shall be determined by the equation in paragraph (d)(1) of Rule 1130.1.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1136 06-14-1996]

Except as otherwise provided in Rule 1136

- (a) The operator shall not apply any coating to a wood product which has a VOC content, including any VOC-containing material added to the original coating supplied by the manufacturer, which exceeds the applicable limit specified below:

(1)

<u>COATING</u>	<b>VOC LIMITS</b>		
	Grams Per Liter (lb/gal) of Coating, [lbs VOC/lb of solids], Less Water and Less Exempt Compounds		
	<u>Current Limit</u>		<u>On and After</u> <u>7/1/2005</u>
	<u>I</u>	<u>or</u>	<u>II</u>
Clear Sealers	550 (4.6) [1.39]	680 (5.7) [3.36]	275 (2.3) [0.36]
Clear Topcoat	550 (4.6) [1.37]	275 (2.3) [0.35]	275 (2.3) [0.35]
Pigmented Primers, Sealers & Undercoats	550 (4.6) [1.06]	600 (5.0) [1.08]	275 (2.3) [0.21]
Pigmented Topcoats	550 (4.6) [1.10]	275 (2.3) [0.25]	275 (2.3) [0.25]

The operator shall use coatings on a wood product that comply with either all VOC limits in column I or all VOC limits in column II. The operator that applies a primer, sealer or undercoat, but not a topcoat, to a wood product, shall be subject to column I for that wood product.

- (2) Notwithstanding the requirements of clause (a)(1), an operator that applies a topcoat and a primer, sealer or undercoat to a shutter may, until July 1, 2005, choose to comply with the VOC limits specified below for that shutter:

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1136 06-14-1996]

#### VOC LIMITS

Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],  
Less Water and Less Exempt Compounds

#### COATING

Clear Sealers	275 (2.3) [0.36]
Clear Topcoat	680 (5.7) [2.99]
Pigmented Primers, Sealers & Undercoats	275 (2.3) [0.33]
Pigmented Topcoats	600 (5.0) [1.38]

(3)

#### VOC LIMITS

Grams Per Liter, (lb/gal) of Coating, [lbs VOC/lb of solids],  
Less Water and Less Exempt Compounds

<u>COATING</u>	<u>Current Limit</u>	<u>On and After 7/1/2005</u>
Barrier Coat - Plastic Components	760 (6.3) [3.9]	275 (2.3) [0.28]
Composite Wood Edge Filler	550 (4.6) [1.15]	275 (2.3) [0.31]
Extreme Performance Coatings	420 (3.5) [0.51]	275 (2.3) [0.33]
Fillers	500 (4.2) [0.66]	275 (2.3) [0.18]
High-Solid Stains	550 (4.6) [1.23]	350 (2.9) [0.42]
Inks	500 (4.2) [0.96]	500 (4.2) [0.96]
Mold-Seal Coatings	750 (6.3) [4.2]	750 (6.3) [4.2]
Multi-Colored Coatings	685 (5.7) [2.6]	275 (2.3) [0.33]

#### VOC LIMITS

Grams Per Liter (lb/gal) of Material

<u>COATING</u>	<u>Current Limit</u>	<u>On and After 7/1/2005</u>
Low-Solids Barrier Coat - Plastic Components	760 (6.3)	120 (1.0)
Low-Solid Stains, Toners, and Washcoats	480 (4.0)	120 (1.0)

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **APPENDIX B: RULE EMISSION LIMITS [RULE 1136 06-14-1996]**

Any coating subject to this rule that meets any of the three VOC limit formats (grams per liter, lb/gal, or lbs VOC/lb of solids) is in compliance with this subparagraph.

- (4) The VOC limit for japan coatings is 700 grams per liter of coatings, less water and exempt compounds, as applied.
- (b) A person shall not use a stripper on wood products unless:
- (1) it contains less than 350 grams of VOC per liter of material; or
  - (2) the VOC composite vapor pressure is 2 mm Hg (0.04 psia) or less at 20°C (68°F).

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **APPENDIX B: RULE EMISSION LIMITS [RULE 1140 02-01-1980]**

- (1) The operator shall not, if he complies with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
  - (A) As dark or darker in shade as that designated as No. 2 on the Ringelmann Chart, as published by the United States Bureau of Mines, or
  - (B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (1)(A).
- (2) The operator shall not, if he is not complying with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
  - (A) As dark or darker in shade as that designated as No. 1 on the Ringelmann Chart, as published by the United States Bureau of Mines, or
  - (B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (2)(A).

## **FACILITY PERMIT TO OPERATE DISNEYLAND RESORT**

### **APPENDIX B: RULE EMISSION LIMITS [RULE 1140 08-02-1985]**

- (1) The operator shall not, if he complies with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
  - (A) As dark or darker in shade as that designated as No. 2 on the Ringelmann Chart, as published by the United States Bureau of Mines, or
  - (B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (1)(A).
  
- (2) The operator shall not, if he is not complying with an applicable performance standard in section (b)(4) of Rule 1140, discharge into the atmosphere from any abrasive blasting any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
  - (A) As dark or darker in shade as that designated as No. 1 on the Ringelmann Chart, as published by the United States Bureau of Mines, or
  - (B) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in (2)(A).

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1145 12-04-2009]

Except as otherwise provided in Rule 1145, no person shall apply on plastics, rubber, leather, or glass any coatings which are applied with a VOC content in excess of the limits listed in the Table of Standards.

### TABLE OF STANDARDS

<b>VOC LIMITS</b>		
<b>LESS WATER AND LESS EXEMPT COMPOUNDS</b>		
COATING CATEGORIES	g/L	lbs/gal
Electrical dissipating and shock free coatings	360	3.0
Extreme performance two-component coatings	420	3.5
General one-component coatings	120	1.0
General two-component coatings	120	1.0
Leather antique coatings	156	1.3
Leather color coatings	60	0.5
Leather sealer coatings	60	0.5
Leather stain coatings	216	1.8
Leather top coatings	120	1.0
Metallic coatings	420	3.5
Military specification one-component coatings	340	2.8
Military specification two-component coatings	420	3.5
Mirror backing curtain coated coatings	500	4.2
Mirror backing rolled coated coatings	312	2.6
Mold seal coatings	750	6.3
Multi-color coatings	680	5.7
Refrigerated glass door coatings	480	4.0
Optical coatings	50	0.4
Vacuum metalizing coatings	800	6.7

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1145 02-14-1997]

Except as otherwise provided in Rule 1145, the operator shall not apply on plastics, glass, or rubber any coatings which are applied with a VOC content in excess of the limits specified below:

#### COATING

	<b>VOC LIMITS</b>			
	<b><u>Less Water and Less Exempt</u></b>			
	<b><u>Compounds</u></b>			
	<u>Current</u>		<u>On and After 1-1-98</u>	
	<u>g/L</u>	<u>lbs/gal</u>	<u>g/L</u>	<u>lbs/gal</u>
General Coatings				
One-component	275	2.3	275	2.3
Two-component	420	3.5	420	3.5
Military Spec. Coating				
One-component	340	2.8	340	2.8
Two-component	420	3.5	420	3.5
Multi-Colored Coatings	685	5.7	685	5.7
Mold Seal Coatings	750	6.3	750	6.3
Vacuum Metalizing Coatings	800	6.7	800	6.7
Mirror Backing				
Curtain Coated	500	4.2	500	4.2
Roll Coated	430	3.6	430	3.6
Optical Coatings	800	6.7	800	6.7
Electric Dissipating Coatings and Shock-				
Free Coatings	800	6.7	360	3.0
Metallic Coatings	420	3.5	420	3.5

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1162 11-17-2000]

The operator shall not use a polyester resin material in a polyester resin operation which has a monomer content in excess of the limits specified in the Table below.

Polyester Resin Materials	Monomer Content in Polyester Resin Materials as Applied (By Weight Percent)
General Purpose Polyester Resin	35
Corrosion-Resistant	48
Fire Retardant	42
High Strength	48
Clear Gel Coat	50
Pigmented Gel Coat	45

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1162 07-08-2005]

The operator shall not use polyester resin material in an open molding system, which has a monomer content in excess of the limits specified in the following Table.

Polyester Resin Materials	Monomer Percentage by Weight as Applied	
	Prior to 11-09-2001	Current Limits
Clear Gel Coat	50	-
For Marble Resins	-	40
For Other Resins	-	44
Pigmented Gel Coat	45	-
White and Off White	-	30
Non-White	-	37
Primer	-	28
Specialty Gel Coats	-	48
General Purpose Resin	35	-
Marble Resins	-	10 or (32 % as supplied, no fillers) 17
Solid Surface Resins	-	24 or
Tub/Shower Resins	-	(35 % as supplied, no fillers)
Lamination Resins	-	31 or (35 % as supplied, no fillers) 35
Others	-	
Fire Retardant Resin	42	38
Corrosion Resistant Resin	48	48
High Strength Resin	48	40

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

- (1) Unless otherwise specified in paragraph (c)(2), a person shall not apply any adhesives, adhesive bonding primers, adhesive primers, or any other primer which have a VOC content in excess of 250 g/L less water and less exempt compounds.
- (2) A person shall not apply adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers, or any other primer which have a VOC content in excess of the limits specified below:

#### **VOC Limit\*, Less Water and Less Exempt Compounds in Grams per Liter**

Architectural Applications	Current VOC Limit*
Indoor Carpet Adhesives	50
Carpet Pad Adhesives	50
Outdoor Carpet Adhesives	150
Wood Flooring Adhesive	100
Rubber Floor Adhesives	60
Subfloor Adhesives	50
Ceramic Tile Adhesives	65
VCT and Asphalt Tile Adhesives	50
Dry Wall and Panel Adhesives	50
Cove Base Adhesives	50
Multipurpose Construction Adhesives	70
Structural Glazing Adhesives	100
Single Ply Roof Membrane Adhesives	250

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

Specialty Applications	VOC Limits and Effective Dates**			
	Current VOC Limit*	1-1-05	7-1-05	1-1-07
PVC Welding	510			
CPVC Welding	490			
ABS Welding	400		325	
Plastic Cement Welding	350	250		
Adhesive Primer for Plastic	650		550	
Computer Diskette Manufacturing	350			
Contact Adhesive	80			
Special Purpose Contact Adhesive	250			
Tire Retread	100			
Adhesive Primer for Traffic Marking Tape	150			
Structural Wood Member Adhesive	140			
Sheet Applied Rubber Lining Operations	850			
Top and Trim Adhesive	540			250

\*\* The specified limits remain in effect unless revised limits are listed in subsequent columns.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

For adhesives, adhesive bonding primers, or any other primer not regulated by the above two tables and applied to the following substrates, the following limits shall apply:

Substrate Specific Applications	Current VOC Limit*
Metal to Metal	30
Plastic Foams	50
Porous Material (except wood)	50
Wood	30
Fiberglass	80

If an adhesive is used to bond dissimilar substrates together the adhesive with the highest VOC content shall be allowed.

Sealants	Current VOC Limit*
Architectural	250
Marine Deck	760
Nonmembrane Roof	300
Roadway	250
Single-Ply Roof Membrane	450
Other	420

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1168 01-07-2005]

Sealant Primers	Current VOC Limit*
Architectural	
Non Porous	250
Porous	775
Modified Bituminous	500
Marine Deck	760
Other	750

\* For low-solid adhesives or sealants the VOC limit is expressed in grams per liter of material as determined in paragraph (b)(32); for all other adhesives and sealants, VOC limits are expressed as grams of VOC per liter of adhesive or sealant less water and less exempt compounds as determined in paragraph (b)(31).

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-07-2003]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	500 (4.2)
(iii) Medical Devices & Pharmaceuticals	800 (6.7)
(B) Repair and Maintenance Cleaning	
(i) General	25 (0.21)
(ii) Electrical Apparatus Components & Electronic Components	900 (7.5)

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-07-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(iii) Medical Devices & Pharmaceuticals	
(A) Tools, Equipment, & Machinery	800 (6.7)
(B) General Work Surfaces	600 (5.0)
(C) Cleaning of Coatings or Adhesives Application Equipment	550 (4.6)
(D) Cleaning of Ink Application Equipment	
(i) General	25 (0.21)
(ii) Flexographic Printing	25 (0.21)
(iii) Gravure Printing	
(A) Publication	750 (6.3)
(B) Packaging	25 (0.21)
(iv) Lithographic or Letter Press Printing	

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1171 11-07-2003]

SOLVENT CLEANING ACTIVITY	CURRENT LIMITS
	VOC g/l (lb/gal)
(A) Roller Wash – Step 1	600 (5.0)
(B) Roller Wash-Step 2, Blanket Wash, & On-Press Components	800 (6.7)
(C) Removable Press Components	25 (0.21)
(v) Screen Printing	750 (6.3)
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	800 (6.7)
(vii) Specialty Flexographic Printing	600 (5.0)
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1171 05-01-2009]

(1) Solvent Requirements

A person shall not use a solvent to perform solvent cleaning operations unless the solvent complies with the applicable requirements set forth below:

	<b>CURRENT LIMITS*</b>	<b>EFFECTIVE 1/1/2010</b>
<b>SOLVENT CLEANING ACTIVITY</b>	<b>VOC g/l (lb/gal)</b>	<b>VOC g/l (lb/gal)</b>
(A) Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	
(iii) Medical Devices & Pharmaceuticals	800 (6.7)	
(B) Repair and Maintenance Cleaning		
(i) General	25 (0.21)	
(ii) Electrical Apparatus Components & Electronic Components	100 (0.83)	

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1171 05-01-2009]

	<b>CURRENT LIMITS*</b>	<b>EFFECTIVE 1/1/2010</b>
<b>SOLVENT CLEANING ACTIVITY (cont.)</b>	<b>VOC g/l (lb/gal)</b>	<b>VOC g/l (lb/gal)</b>
(iii) Medical Devices & Pharmaceuticals		
(A) Tools, Equipment, & Machinery	800 (6.7)	
(B) General Work Surfaces	600 (5.0)	
(C) Cleaning of Coatings or Adhesives Application Equipment	25 (0.21)	
(D) Cleaning of Ink Application Equipment		
(i) General	25 (0.21)	
(ii) Flexographic Printing	25 (0.21)	
(iii) Gravure Printing		
(A) Publication	100 (0.83)	
(B) Packaging	25 (0.21)	
(iv) Lithographic (Offset) or Letter Press Printing		
(A) Roller Wash, Blanket Wash, & On-Press Components	100 (0.83)	

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 1171 05-01-2009]

	<b>CURRENT LIMITS*</b>	<b>EFFECTIVE 1/1/2010</b>
<b>SOLVENT CLEANING ACTIVITY (cont.)</b>	<b>VOC g/l (lb/gal)</b>	<b>VOC g/l (lb/gal)</b>
(B) Removable Press Components	25 (0.21)	
(v) Screen Printing	100 (0.83)	
(vi) Ultraviolet Ink/ Electron Beam Ink Application Equipment (except screen printing)	650 (5.4)	100 (0.83)
(vii) Specialty Flexographic Printing	100 (0.83)	
(E) Cleaning of Polyester Resin Application Equipment	25 (0.21)	

\* The specified limits remain in effect unless revised limits are listed in subsequent columns.

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

The operator shall not discharge into the atmosphere from this equipment, particulate matter in excess of the concentration at standard conditions, shown in Table 404(a). Where the volume discharged is between figures listed in the Table, the exact concentration permitted to be discharged shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

**TABLE 404(a)**

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
25 or less	883 or less	450	0.196	900	31780	118	0.0515
30	1059	420	.183	1000	35310	113	.0493
35	1236	397	.173	1100	38850	109	.0476
40	1413	377	.165	1200	42380	106	.0463
45	1589	361	.158	1300	45910	102	.0445

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
50	1766	347	.152	1400	49440	100	.0437
60	2119	324	.141	1500	52970	97	.0424
70	2472	306	.134	1750	61800	92	.0402
80	2825	291	.127	2000	70630	87	.0380
90	3178	279	.122	2250	79460	83	.0362
100	3531	267	.117	2500	88290	80	.0349
125	4414	246	.107	3000	105900	75	.0327
150	5297	230	.100	4000	141300	67	.0293
175	6180	217	.0947	5000	176600	62	.0271
200	7063	206	.0900	6000	211900	58	.0253
250	8829	190	.0830	8000	282500	52	.0227
300	10590	177	.0773	10000	353100	48	.0210
350	12360	167	.0730	15000	529700	41	.0179
400	14130	159	.0694	20000	706300	37	.0162
450	15890	152	.0664	25000	882900	34	.0148

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 404 02-07-1986]

Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter” Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions		Volume Discharged Calculated as Dry Gas At Standard Conditions		Maximum Concentration of Particulate Matter Allowed in Discharged Gas Calculated as Dry Gas at Standard Conditions	
		Milligrams per Cubic Meter	Grains per Cubic Foot			Milligrams per Cubic Meter	Grains per Cubic Foot
Cubic meters Per Minute	Cubic feet Per Minute			Cubic meters Per Minute	Cubic feet Per Minute		
500	17660	146	.0637	30000	1059000	32	.0140
600	21190	137	.0598	40000	1413000	28	.0122
700	24720	129	.0563	50000	1766000	26	.0114
800	28250	123	.0537	70000 or more	2472000 or more	23	.0100

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 405 02-07-1986]

The operator shall not discharge into the atmosphere from this equipment, solid particulate matter including lead and lead compounds in excess of the rate shown in Table 405(a).

Where the process weight per hour is between figures listed in the table, the exact weight of permitted discharge shall be determined by linear interpolation.

For the purposes of this rule, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

**TABLE 405(a)**

Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All Points of Process		Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All points of Process	
		Kilograms Per Hour	Pounds Per Hour			Kilograms Per Hour	Pounds Per Hour
100 or less	220 or less	0.450	0.99	9000	19840	5.308	11.7
150	331	0.585	1.29	10000	22050	5.440	12.0
200	441	0.703	1.55	12500	27560	5.732	12.6
250	551	0.804	1.77	15000	33070	5.982	13.2
300	661	0.897	1.98	17500	38580	6.202	13.7
350	772	0.983	2.17	20000	44090	6.399	14.1
400	882	1.063	2.34	25000	55120	6.743	14.9
450	992	1.138	2.51	30000	66140	7.037	15.5
500	1102	1.209	2.67	35000	77160	7.296	16.1
600	1323	1.340	2.95	40000	88180	7.527	16.6

## FACILITY PERMIT TO OPERATE DISNEYLAND RESORT

### APPENDIX B: RULE EMISSION LIMITS [RULE 405 02-07-1986]

Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All Points of Process		Process Weight Per Hour		Maximum Discharge Rate Allowed for Solid Particulate Matter (Aggregate Discharged From All points of Process	
		Kilograms Per Hour	Pounds Per Hour			Kilograms Per Hour	Pounds Per Hour
700	1543	1.461	3.22	45000	99210	7.738	17.1
800	1764	1.573	3.47	50000	110200	7.931	17.5
900	1984	1.678	3.70	60000	132300	8.277	18.2
1000	2205	1.777	3.92	70000	154300	8.582	18.9
1250	2756	2.003	4.42	80000	176400	8.854	19.5
1500	3307	2.206	4.86	90000	198400	9.102	20.1
1750	3858	2.392	5.27	100000	220500	9.329	20.6
2000	4409	2.563	5.65	125000	275600	9.830	21.7
2250	4960	2.723	6.00	150000	330700	10.26	22.6
2500	5512	2.874	6.34	175000	385800	10.64	23.5
2750	6063	3.016	6.65	200000	440900	10.97	24.2
3000	6614	3.151	6.95	225000	496000	11.28	24.9
3250	7165	3.280	7.23	250000	551200	11.56	25.5
3600	7716	3.404	7.50	275000	606300	11.82	26.1
4000	8818	3.637	8.02	300000	661400	12.07	26.6
4500	9921	3.855	8.50	325000	716500	12.30	27.1
5000	11020	4.059	8.95	350000	771600	12.51	27.6
6000	13230	4.434	9.78	400000	881800	12.91	28.5
7000	15430	4.775	10.5	450000	992100	13.27	29.3
8000	17640	5.089	11.2	500000 or more	1102000 or more	13.60	30.0